

Republic of Angola
Ministry of Energy and
Water Affairs

The Project for
Power Development Master Plan
in the Republic of Angola

Final Report

December 2018

Japan International Cooperation Agency (JICA)

Tokyo Electric Power Services Co., Ltd.(TEPSCO)

International Institute of Electric Power, Ltd.(IIEP)

| |
|--------|
| IL |
| JR |
| 18-081 |

【Table of Contents】

| | |
|---|------|
| Chapter 1 Outline of the Survey..... | 1-1 |
| 1.1 Background of Survey..... | 1-1 |
| 1.2 Purpose of the Survey..... | 1-1 |
| 1.2.1 Purpose..... | 1-1 |
| 1.2.2 Implementing Organizations of the Partner Country..... | 1-2 |
| 1.3 Activities | 1-2 |
| Chapter 2 Review of the Current Situation in the Power Sector..... | 2-1 |
| 2.1 Location of Angola..... | 2-1 |
| 2.2 Country overview | 2-2 |
| 2.2.1 Social situation | 2-2 |
| 2.2.2 Economic condition..... | 2-2 |
| 2.3 Review of the current status of the power sector structure..... | 2-4 |
| 2.3.1 Electricity Sector Transformation Program (PTSE)..... | 2-4 |
| 2.3.2 Power sector organization after sector reform..... | 2-4 |
| 2.4 Review of the current power demand and supply | 2-10 |
| 2.4.1 Demand status | 2-10 |
| 2.4.2 Power supply status | 2-11 |
| 2.5 Review of cooperation by donors and activities by the private sector | 2-12 |
| 2.5.1 Cooperation by donors | 2-12 |
| 2.5.2 Activity by the private sector | 2-12 |
| 2.6 Review of the Intended Nationally Determined Contributions (INDCs) relating to the power sector in Angola..... | 2-13 |
| 2.7 Some issues faced by the Angola power sector..... | 2-15 |
| 2.7.1 Issues in term of the organization..... | 2-15 |
| 2.7.2 Issues related to electric power system..... | 2-15 |
| 2.7.3 Issues in terms of power policy | 2-16 |
| Chapter 3 Primary Energy Analysis for Power Development | 3-1 |
| 3.1 General energy condition in Angola..... | 3-1 |
| 3.1.1 Primary energy flow analysis | 3-1 |
| 3.2 The potential of primary energy | 3-5 |
| 3.2.1 Large hydropower | 3-5 |
| 3.2.2 Oil..... | 3-8 |
| 3.2.3 Natural gas..... | 3-10 |
| 3.2.4 Renewable energy | 3-10 |
| 3.2.5 Coal | 3-15 |

| | | |
|---|--|------------|
| 3.3 | Condition of energy supply facilities | 3-16 |
| 3.3.1 | Liquefied natural gas (LNG) plant | 3-16 |
| 3.3.2 | Oil refinery plant | 3-16 |
| 3.4 | Price trends for each form of primary energy | 3-17 |
| 3.4.1 | Crude oil | 3-18 |
| 3.4.2 | Natural gas..... | 3-18 |
| 3.4.3 | Selected fuel price for formulating the “Optimal Generation Mix” | 3-19 |
| 3.5 | Items to Prepare to Promote Power Development | 3-20 |
| 3.5.1 | Options for Power Supply | 3-20 |
| 3.5.2 | Options for Fuel, and Fuel Characteristics | 3-20 |
| 3.5.3 | Setting of Thermal Power Generation Planning Scenarios and Selection of Fuel | 3-21 |
| 3.5.4 | Facilities to Prepare for Power Development Promotion | 3-24 |
| Chapter 4 Procedure for Formulating a Power Master Plan based on the Optimal Generation Mix (“The Best Mix”) | | 4-1 |
| 4.1 | Basic policy for an optimal generation mix | 4-1 |
| 4.2 | Items to examine | 4-1 |
| 4.2.1 | Economic matters | 4-1 |
| 4.2.2 | Supply reliability | 4-4 |
| 4.2.3 | Energy security | 4-6 |
| 4.2.4 | Environmental and social considerations | 4-7 |
| 4.3 | Flow for formulating a power development master plan | 4-8 |
| Chapter 5 Power Demand Forecast..... | | 5-1 |
| 5.1 | Power demand forecast in current plan and related data | 5-1 |
| 5.1.1 | Current power demand forecast..... | 5-1 |
| 5.1.2 | Forecast of GDP and population growth | 5-2 |
| 5.1.3 | Relevance and problems of the current power demand forecast | 5-5 |
| 5.2 | Power Demand Results and Regional Characteristics..... | 5-6 |
| 5.2.1 | Power Demand Results..... | 5-6 |
| 5.2.2 | Regional characteristics of power demand | 5-9 |
| 5.3 | Power demand forecast up to 2040 | 5-10 |
| 5.3.1 | Power demand forecasting methodology | 5-10 |
| 5.3.2 | Annual maximum power demand forecast | 5-10 |
| 5.3.3 | Daily load curve forecast..... | 5-13 |
| 5.3.4 | Annual generated energy demand forecast..... | 5-18 |
| 5.3.5 | Macro-evaluation of power demand forecast | 5-19 |
| Chapter 6 Optimization of the Generation Development Plan..... | | 6-1 |

| | | |
|---|---|------------|
| 6.1 | Current situation of power generation facilities | 6-1 |
| 6.1.1 | Existing power plants | 6-1 |
| 6.1.2 | Performance of large hydropower stations | 6-7 |
| 6.1.3 | Power stations under construction..... | 6-8 |
| 6.2 | Current power development plan | 6-11 |
| 6.3 | Preparation for a long-term power development plan by 2040 | 6-14 |
| 6.3.1 | Setting conditions for an economic evaluations study using PDPAT | 6-14 |
| 6.3.2 | Selection of the generation type for use in development planning..... | 6-16 |
| 6.3.3 | Basic conditions for optimization of development plan | 6-18 |
| 6.4 | The most economical power supply configuration in 2040 | 6-19 |
| 6.4.1 | Hydropower development plan | 6-19 |
| 6.4.2 | Relationship between LOLE and Reserve Capacity..... | 6-20 |
| 6.4.3 | Most economical power supply composition ratio by using PDPAT..... | 6-21 |
| 6.5 | Formulation of the power development plan..... | 6-22 |
| 6.5.1 | Power development plan (Draft) by 2040 | 6-22 |
| 6.5.2 | Impact of introducing renewable energy | 6-24 |
| 6.5.3 | Power development plan with renewable energy (base plan)..... | 6-25 |
| 6.5.4 | Greenhouse gas emission in the base case..... | 6-29 |
| 6.6 | Scenario case studies | 6-30 |
| 6.6.1 | Setting the scenario | 6-30 |
| 6.6.2 | Delays in the development of the power stations | 6-31 |
| 6.6.3 | Development location of CCGT..... | 6-33 |
| 6.6.4 | Additional development of renewable energy..... | 6-37 |
| 6.7 | Recommended project list | 6-40 |
| Chapter 7 Study on optimization of the transmission system development plan..... | | 7-1 |
| 7.1 | Current power system in Angola..... | 7-1 |
| 7.2 | Transmission system of the capital city Luanda..... | 7-3 |
| 7.3 | Power system enhancement plan by RNT..... | 7-3 |
| 7.4 | Characteristics of the main power system in Angola | 7-5 |
| 7.4.1 | Voltage reference | 7-5 |
| 7.5 | Information gathering and analysis of the existing transmission facilities in Angola..... | 7-6 |
| 7.5.1 | Outline | 7-6 |
| 7.5.2 | The existing transmission lines | 7-6 |
| 7.5.3 | The existing substations | 7-11 |
| 7.6 | Information gathering and analysis of the latest transmission development plan | 7-13 |
| 7.6.1 | Existing development strategies and plans..... | 7-13 |
| 7.6.2 | Analysis of the technical data and the latest cost in existing facilities | 7-19 |

| | |
|--|------------|
| 7.6.3 Analysis based on international interconnection with neighboring countries (Democratic Republic of Congo, Namibia, Zambia) | 7-22 |
| 7.7 Transmission network development plan | 7-25 |
| 7.7.1 Policy | 7-25 |
| 7.7.2 Regional supply substation plan based on demand forecasts | 7-26 |
| 7.7.3 220 kV power transmission line plan based on the regional supply substation plan | 7-29 |
| 7.7.4 Transmission Development plan based on the Generation Development Plan | 7-31 |
| 7.7.5 400 kV main Transmission Line and Substation Plan based on electric power system analysis | 7-36 |
| 7.7.6 The future vision of the main power system | 7-38 |
| 7.7.7 Demand assumptions for the substations | 7-38 |
| 7.7.8 The transmission development plan for 2040 | 7-39 |
| 7.7.9 The evaluation for the power system analysis | 7-45 |
| 7.7.10 Validity of distributed installation of CCGT | 7-45 |
| 7.7.11 Consideration for measures to reduce power transmission loss | 7-46 |
| 7.7.12 Annual plan for transmission development system | 7-47 |
| 7.7.13 Required volume of reactive power compensators | 7-52 |
| 7.7.14 Fault Current | 7-53 |
| 7.7.15 Summary of the power transmission system development plan up to 2040 | 7-54 |
| Chapter 8 Review on Private Investment Environment | 8-1 |
| 8.1 Report on private Investment | 8-1 |
| 8.2 Review of the Private Investment Environment Report | 8-2 |
| 8.2.1 Private investment environment in Angola | 8-3 |
| 8.2.2 Legal system in Angola | 8-3 |
| 8.3 Interviews with Japanese companies | 8-4 |
| 8.3.1 Interviews with Japanese Companies in Angola | 8-4 |
| 8.4 New Private Investment Law | 8-5 |
| 8.4.1 New Private Investment Law (2015) | 8-5 |
| 8.4.2 Private power project in accordance with the New Private Investment Law | 8-5 |
| 8.5 Summary and Bottlenecks | 8-6 |
| Chapter 9 Long-term Investment Plan | 9-1 |
| 9.1 Premise for fundraising | 9-1 |
| 9.2 Fundraising for investment | 9-1 |
| 9.2.1 ODA loan | 9-1 |
| 9.2.2 Typical Loan Conditions | 9-4 |
| 9.3 Long-term Investment Plan | 9-4 |
| 9.3.1 Summary of the Long-term Investment Plan | 9-4 |

| | |
|---|-------------|
| 9.3.2 Long-Run Marginal Cost (LRMC)..... | 9-10 |
| 9.3.3 Recommendations on the Optimal Financial Strategy | 9-15 |
| Chapter 10 Economic and Financial Analysis..... | 10-1 |
| 10.1 Financial Analysis of RNT • PRODEL • ENDE..... | 10-1 |
| 10.1.1 RNT | 10-1 |
| 10.1.2 PRODEL..... | 10-4 |
| 10.1.3 ENDE..... | 10-6 |
| 10.2 Analysis of Financial Soundness and Sustainability | 10-9 |
| 10.2.1 Analysis of a unit revenue price per kWh..... | 10-9 |
| 10.2.2 Bill Collection..... | 10-9 |
| 10.2.3 Financial Soundness..... | 10-10 |
| 10.3 Review of the Financial Condition of PRODEL, RNT and ENDE..... | 10-11 |
| 10.3.1 Tariff..... | 10-11 |
| 10.3.2 Cost Structure | 10-11 |
| 10.3.3 Borrowing | 10-11 |
| 10.3.4 Regulation on the fiscal budget and the tariff | 10-11 |
| 10.3.5 Some Financial Issues to be considered..... | 10-12 |
| 10.3.6 Other issues..... | 10-12 |
| Chapter 11 Environmental and Social Considerations | 11-1 |
| 11.1 Outline of the Strategic Environmental Assessment (SEA) Approach for the Power Development Master Plan | 11-1 |
| 11.2 Overview of the present state of the proposed project area..... | 11-3 |
| 11.3 Structure and regime for environmental and social considerations in Angola..... | 11-7 |
| 11.3.1 Legal and regulatory frameworks for environmental and social considerations..... | 11-7 |
| 11.3.2 Differences between the JICA guidelines and Angolan regulations | 11-9 |
| 11.3.3 Organizations and their roles for Environmental and Social considerations | 11-10 |
| 11.4 Comparison of Alternatives (including Zero Options)..... | 11-13 |
| 11.5 Scoping..... | 11-14 |
| 11.6 Results of SEA | 11-15 |
| 11.7 Environmental Evaluation..... | 11-62 |
| 11.8 Scenario analysis from environmental and social viewpoints..... | 11-63 |
| 11.9 Expected mitigation measures..... | 11-65 |
| 11.10 Implementation of the monitoring plan..... | 11-66 |
| 11.11 Stakeholder Meeting..... | 11-67 |
| 11.12 SEA concerning transmission expansion plans..... | 11-77 |
| Chapter 12 Drafting the Master Plan | 12-1 |

| | | |
|---|--|-------------|
| 12.1 | To Draft Comprehensive Power Master Plans toward the Year 2040..... | 12-1 |
| 12.1.1 | Generation Development Project List Formulation Policy | 12-1 |
| 12.1.2 | Policy for Formulating the Transmission Development Project List..... | 12-2 |
| 12.1.3 | Project Lists | 12-4 |
| 12.2 | Projects to which Japan can contribute from a technical standpoint | 12-19 |
| 12.2.1 | South Transmission System Enhancement Project | 12-19 |
| 12.2.2 | New CCGT Project | 12-21 |
| 12.2.3 | New GT Construction as a Peak Demand Power Supply & Introduction of SCADA for GT Control | 12-22 |
| 12.2.4 | Project to Repower Old Hydropower Plants | 12-23 |
| 12.3 | Advice to MINEA, RNT, PRODEL, ENDE and IRSEA's Action Plan on the Power Development Master Plan | 12-24 |
| 12.3.1 | Action Plan for the Power Development Master Plan | 12-24 |
| 12.3.2 | Establishment of an Organization to Formulate and Continuously Revise the PDMP | 12-25 |
| 12.3.3 | Improvement Activities to Establish a Method for Accurate Power Demand Forecasts .. | 12-25 |
| 12.3.4 | Ongoing study on the occupancy hydropower potential | 12-26 |
| 12.3.5 | Management and Improvement of Fund Procurement..... | 12-26 |
| 12.3.6 | Deploying the PDMP and reflecting it in the medium-term plan of each entity | 12-28 |
| 12.3.7 | Improvement of Power Operation System / Introduction of SCADA | 12-30 |
| 12.3.8 | Improvement of Operation System to Make Use of Power Generation Characteristics ... | 12-31 |
| 12.3.9 | Establishment of standards for transmission and substation facilities | 12-33 |
| Chapter 13 Technology Transfer & Capacity Building | | 13-1 |
| 13.1 | Workshop | 13-1 |
| 13.2 | Training in Japan | 13-3 |
| 13.2.1 | Participants..... | 13-3 |
| 13.2.2 | Activity Records | 13-3 |
| 13.3 | Additional Training in Japan | 13-11 |
| 13.3.1 | Participants..... | 13-11 |
| 13.3.2 | Activity Results..... | 13-12 |

【List of Figures】

| | | |
|-------------|---|------|
| Figure 2-1 | GDP of Angola | 2-3 |
| Figure 2-2 | GDP growth rate of Angola..... | 2-3 |
| Figure 2-3 | GDP of Angola by sector..... | 2-3 |
| Figure 2-4 | Restructuring of the Electric Sector..... | 2-4 |
| Figure 2-5 | MINEA's Organization Chart..... | 2-5 |
| Figure 2-6 | RNT organization chart | 2-6 |
| Figure 2-7 | RNT grid map (as of July 2017)..... | 2-7 |
| Figure 2-8 | PRODEL organization chart..... | 2-8 |
| Figure 2-9 | ENDE organization chart..... | 2-9 |
| Figure 2-10 | Consumption energy | 2-10 |
| Figure 2-11 | Consumption energy by sector and system..... | 2-10 |
| Figure 2-12 | Power demand in Angola..... | 2-11 |
| Figure 2-13 | Baseline structure (2005) of GHG emissions in Angola by sector and emissions in the energy sector | 2-13 |
| Figure 2-14 | Baseline scenario and projections of unconditional and conditional mitigation scenarios in Angola..... | 2-14 |
| Figure 3-1 | Primary energy flow in Angola | 3-1 |
| Figure 3-2 | Consumption of oil products in Angola (consumption includes international bunker)... | 3-2 |
| Figure 3-3 | Oil production in Angola..... | 3-2 |
| Figure 3-4 | Exported oil production from Angola..... | 3-3 |
| Figure 3-5 | Imported oil production into Angola..... | 3-3 |
| Figure 3-6 | Refined oil production in Angola | 3-4 |
| Figure 3-7 | Converted oil products for power production in Angola..... | 3-4 |
| Figure 3-8 | Hydropower potential throughout Angola..... | 3-5 |
| Figure 3-9 | Locations of existing/planned hydroelectric power plants | 3-7 |
| Figure 3-10 | Crude oil production results in Angola (2012~2016) | 3-8 |
| Figure 3-11 | Oil development in Angola..... | 3-9 |
| Figure 3-12 | Amounts of natural gas produced in Angola | 3-10 |
| Figure 3-13 | The total capacity of projects considered for each RE | 3-11 |
| Figure 3-14 | the medium-small hydropower potential diagram in Angola | 3-12 |
| Figure 3-15 | Solar energy potential in Angola | 3-13 |
| Figure 3-16 | Wind Energy potential in Angola..... | 3-14 |
| Figure 3-17 | Biomass generation potential in Angola..... | 3-15 |
| Figure 3-18 | Actual production of LNG from 2012 to 2016..... | 3-16 |
| Figure 3-19 | Changes in crude oil prices in the international market..... | 3-18 |
| Figure 3-20 | Forecasted fluctuation of natural gas prices (2000 - 2040) | 3-19 |

| | | |
|-------------|---|------|
| Figure 5-1 | Current Power Demand Forecast (annual maximum demand)..... | 5-1 |
| Figure 5-2 | Actual records of power demand..... | 5-2 |
| Figure 5-3 | Past records and forecast of real GDP | 5-2 |
| Figure 5-4 | Population Density Map (2014)..... | 5-3 |
| Figure 5-5 | Population Density Distribution by Region (2014) | 5-3 |
| Figure 5-6 | Population Forecast in Angola..... | 5-4 |
| Figure 5-7 | Relationship between GDP Growth Rate and Generated Energy Growth Rate | 5-4 |
| Figure 5-8 | Monthly Maximum Demand and Load-shedding Results..... | 5-6 |
| Figure 5-9 | Comparison of Monthly Maximum Demand Results in North System..... | 5-7 |
| Figure 5-10 | Actual Daily Load Curves (North System: 2016) | 5-7 |
| Figure 5-11 | Actual Daily Load Curves (North System: 2016) | 5-8 |
| Figure 5-12 | Location of Lauca Hydropower Plant..... | 5-8 |
| Figure 5-13 | Power Demand Forecasting Flow in Angola..... | 5-10 |
| Figure 5-14 | Electrification Plan | 5-11 |
| Figure 5-15 | Annual Maximum Power Demand Forecast..... | 5-12 |
| Figure 5-16 | Daily Load Curves as of 2016 (North System)..... | 5-14 |
| Figure 5-17 | Daily Load Curve Forecast up to 2040 (North System; Highest 3 days) | 5-15 |
| Figure 5-18 | Daily Load Curves of Isolated Subsystem in North System (2016)..... | 5-15 |
| Figure 5-19 | Daily Load Curves as of 2016 (Center+South+East System)..... | 5-16 |
| Figure 5-20 | Daily Load Curve Forecast (Center+South+East System; Highest 3 days) | 5-17 |
| Figure 5-21 | Daily Load Curve Forecast (Whole County; Highest 3 days)..... | 5-17 |
| Figure 5-22 | Generated Energy Demand Forecast | 5-18 |
| Figure 5-23 | Relationship between GDP and Electricity Consumption per Capita | 5-19 |
| Figure 6-1 | Composition of installed capacity | 6-1 |
| Figure 6-2 | Composition of available generation capacity..... | 6-2 |
| Figure 6-3 | Inflow record of Capanda Hydropower Station..... | 6-7 |
| Figure 6-4 | Generation record of Capanda Hydropower Station..... | 6-8 |
| Figure 6-5 | Location of Soyo 1 CCGT | 6-9 |
| Figure 6-6 | Bird's-eye View of Soyo 1 CCGT..... | 6-9 |
| Figure 6-7 | Actual records of the forced outage rates of power stations..... | 6-15 |
| Figure 6-8 | Annual expenditure by generation type (2018) | 6-18 |
| Figure 6-9 | Annual expenditure by generation type (2040) | 6-18 |
| Figure 6-10 | Character of peak facilities (2040) | 6-18 |
| Figure 6-11 | Character of middle facilities (2040)..... | 6-18 |
| Figure 6-12 | Development pattern for large hydropower by 2040..... | 6-20 |
| Figure 6-13 | Relationship between LOLE and reserve margin rate | 6-20 |
| Figure 6-14 | Necessary reserve margin rate equivalent to LOLE of 24 hrs | 6-20 |

| | | |
|-------------|---|------|
| Figure 6-15 | Configuration ratio of GT and total annual cost (year 2040)..... | 6-21 |
| Figure 6-16 | Cost minimum configuration of power supply in the year 2040 (November balance) | 6-22 |
| Figure 6-17 | Power development plan (Draft) | 6-23 |
| Figure 6-18 | Impact of introducing wind power (year 2040) | 6-24 |
| Figure 6-19 | Impact of introducing solar power (year 2040) | 6-24 |
| Figure 6-20 | kW balance of each month in 2040 | 6-26 |
| Figure 6-21 | kWh balance of each month in 2040 | 6-26 |
| Figure 6-22 | Example of load dispatch for one day <dry season, November 2040> | 6-26 |
| Figure 6-23 | Example of load dispatch for one day <flood season, May 2040>..... | 6-26 |
| Figure 6-24 | Example of weekly load dispatch <dry season, November 2040>..... | 6-26 |
| Figure 6-25 | Example of weekly load dispatch <flood season, May 2040> | 6-26 |
| Figure 6-26 | Power development plan (base case)..... | 6-27 |
| Figure 6-27 | Supply–demand balance (base case, peak balance in November)..... | 6-28 |
| Figure 6-28 | Supply–demand balance (base case, installed capacity-annual peak balance) | 6-28 |
| Figure 6-29 | Annual generation cost (base case)..... | 6-29 |
| Figure 6-30 | Unit cost of generation (base case)..... | 6-29 |
| Figure 6-31 | Greenhouse gas emission (base case)..... | 6-29 |
| Figure 6-32 | Angolan reduction plan (DRAFT INDC) and base case emission | 6-30 |
| Figure 6-33 | Influence of delays in hydropower development..... | 6-31 |
| Figure 6-34 | Influence of demand rise (=delay in the development of all power station types) | 6-32 |
| Figure 6-35 | Cost increase for introducing emergency power supply..... | 6-33 |
| Figure 6-36 | Increase of CO ₂ emission by introducing emergency power supply | 6-33 |
| Figure 6-37 | Cost increase when using LPG/LNG as fuel for CCGT | 6-35 |
| Figure 6-38 | CO ₂ reduction effect of large-scale introduction of wind/solar power | 6-38 |
| Figure 6-39 | Increase of generation cost by introducing wind/solar power | 6-39 |
| Figure 6-40 | Increase of unit cost by introducing wind/solar power..... | 6-39 |
| Figure 7-1 | Transmission system map of Angola (July 2017) | 7-2 |
| Figure 7-2 | Transmission system map of the center of the capital city Luanda | 7-3 |
| Figure 7-3 | Transmission system map of Angola (2025) | 7-4 |
| Figure 7-4 | Transmission system map of Angola (2027) | 7-5 |
| Figure 7-5 | 66 kV concrete pole | 7-7 |
| Figure 7-6 | 66 kV one circuit angle tower..... | 7-7 |
| Figure 7-7 | 60 kV underground cable branch tower..... | 7-7 |
| Figure 7-8 | 60 kV steel pipe tower | 7-7 |
| Figure 7-9 | 220 kV steel pipe tower (tension)..... | 7-8 |
| Figure 7-10 | 220 kV steel pipe tower (suspension)..... | 7-8 |

| | | |
|-------------|---|------|
| Figure 7-11 | 220 kV Transmission line along the road | 7-8 |
| Figure 7-12 | 220 kV steel angle tower | 7-8 |
| Figure 7-13 | 400 kV one circuit transmission lines (distant view)..... | 7-9 |
| Figure 7-14 | 66 kV/15 kV transformer made in China | 7-11 |
| Figure 7-15 | Control screen for variable compensation reactor | 7-11 |
| Figure 7-16 | 220 kV vertical type gas-insulated circuit breaker | 7-11 |
| Figure 7-17 | Indoor type gas-insulated switchgear | 7-11 |
| Figure 7-18 | Example of a multiple bus configuration (220 kV Futungo substation)..... | 7-12 |
| Figure 7-19 | Existing plan for the northern system as of 2022 by RNT | 7-17 |
| Figure 7-20 | Existing plan for the northern system as of 2027 by RNT | 7-17 |
| Figure 7-21 | Existing plan for the central, southern and western systems as of 2022 by RNT..... | 7-18 |
| Figure 7-22 | Existing plan for the central, southern and western systems as of 2027 by RNT..... | 7-18 |
| Figure 7-23 | Estimated 400 kV substation cost..... | 7-20 |
| Figure 7-24 | Estimated 220 kV substation cost..... | 7-21 |
| Figure 7-25 | Outline of international interconnections with Angol | 7-22 |
| Figure 7-26 | Outline of the international interconnection plan concept with SAPP | 7-24 |
| Figure 7-27 | Flowchart of the Transmission Network Development Plan..... | 7-25 |
| Figure 7-28 | System connection status of Soyo thermal power station..... | 7-32 |
| Figure 7-29 | Status of connection of Luachimo hydroelectric power station..... | 7-32 |
| Figure 7-30 | Connection status of thermal power stations in the Luanda area..... | 7-33 |
| Figure 7-31 | Connection status of hydropower stations in the Cuanza River area..... | 7-33 |
| Figure 7-32 | Connection status of hydropower stations in the Quive River area..... | 7-34 |
| Figure 7-33 | System connection status around the Lobito thermal power plant | 7-34 |
| Figure 7-34 | System connection status of the Namibe thermal powerplant and Baynes hydropower plant | 7-35 |
| Figure 7-35 | Main power system of the center of Luanda in 2017 (400 kV, 220 kV) | 7-40 |
| Figure 7-36 | Main power system of the center of Luanda in 2040 (RNT's draft) | 7-40 |
| Figure 7-37 | Main power system of the center of Luanda in 2040 (JICA's draft) | 7-41 |
| Figure 7-38 | Eastern bulk power system calculation result in 2040 (Capanda=Xa-Mutenba T/L : N-1) | 7-42 |
| Figure 7-39 | Eastern bulk power system calculation result in 2040 (Mutenba = Saurimo T/L : N-1) | 7-43 |
| Figure 7-40 | Main power system in 2040 (400 kV, 220 kV) | 7-44 |
| Figure 7-41 | RNT's power system plan in 2040 (400 kV, 220 kV) | 7-46 |
| Figure 7-42 | Main power system in 2025 (400 kV, 220 kV) | 7-48 |
| Figure 7-43 | Main power system in 2030 (400 kV, 220 kV) | 7-49 |
| Figure 7-44 | Main power system in 2035 (400 kV, 220 kV) | 7-50 |

| | | |
|--------------|--|-------|
| Figure 7-45 | Main power system in 2040 (400 kV, 220 kV) | 7-51 |
| Figure 8-1 | Ranking of Angola and other comparator countries | 8-1 |
| Figure 8-2 | Ranks and scores for each topic | 8-2 |
| Figure 9-1 | Annual Investment up to 2040 (in terms of the Construction Schedule) | 9-6 |
| Figure 9-2 | Borrowings up to 2040 and Financial Expenses | 9-9 |
| Figure 9-3 | Total Annual Cost and Unit Cost for Generation | 9-11 |
| Figure 9-4 | Total Annual Cost and Unit Cost for Transmission and Sub-station | 9-11 |
| Figure 9-5 | Annual Unit Incremental Cost for Generation | 9-12 |
| Figure 9-6 | Annual Unit Incremental Cost for Transmission and Sub-station | 9-13 |
| Figure 11-1 | Workflow for the SEA | 11-1 |
| Figure 11-2 | Status of Vegetation | 11-3 |
| Figure 11-3 | Welwitschia mirabilis | 11-4 |
| Figure 11-4 | Distribution of Protected Areas | 11-5 |
| Figure 11-5 | Screening and Appraisal for Environmental Permit Issuance | 11-12 |
| Figure 11-6 | Locations of the Generation Power Site | 11-17 |
| Figure 11-7 | Site for CAMBAMBE Hydropower Plant | 11-18 |
| Figure 11-8 | Site for CIMANGOLA Thermal Power Plant | 11-22 |
| Figure 11-9 | Site for BENJAMIN Wind Power Plant | 11-24 |
| Figure 11-10 | Site for CALENGA Wind Power Plant | 11-28 |
| Figure 11-11 | Site for GASTAO Wind Power Plant | 11-30 |
| Figure 11-12 | Site for KIWABANZOJI I Wind Power Plant | 11-32 |
| Figure 11-13 | Site for MUSSENDE I Wind Power Plant | 11-34 |
| Figure 11-14 | Site for NHAREA Wind Power Plant | 11-36 |
| Figure 11-15 | Site for TOMBWA Wind Power Plant | 11-38 |
| Figure 11-16 | Site for BENGUELA Solar Power Plant | 11-40 |
| Figure 11-17 | Site for CARACULO Solar Power Plant | 11-42 |
| Figure 11-18 | Site for CAMBOUNGUE Solar Power Plant | 11-44 |
| Figure 11-19 | Site for GANDA/ALTOCATUMBELA Solar Power Plant | 11-46 |
| Figure 11-20 | Site for Solar LOBITO/CATUMBELA Power Plant | 11-48 |
| Figure 11-21 | Site for LUBANGO Solar Power Plant | 11-50 |
| Figure 11-22 | Site for MATALA Solar Power Plant | 11-52 |
| Figure 11-23 | Site for QUIPUNGO Solar Power Plant | 11-54 |
| Figure 11-24 | Site for NAMACUNDE Solar Power Plant | 11-56 |
| Figure 11-25 | Site for TECHAMUTETE Solar Power Plant | 11-58 |
| Figure 11-26 | Environmental Impact Analysis Diagram of Power Generation Type (Overall) | 11-62 |
| Figure 11-27 | Transmission Lines to be evaluated by SEA (5+1 Routes) | 11-77 |
| Figure 12-1 | Summary of Generation Development Plan & Transmission Development Plan | 12-11 |

| | | |
|--------------|---|-------|
| Figure 12-2 | Project Map toward 2040..... | 12-12 |
| Figure 12-3 | Project Map toward 2040 (nearby Luanda) | 12-13 |
| Figure 12-4 | Project Map toward 2040 (Northern Region from Luanda) | 12-14 |
| Figure 12-5 | Project Map toward 2040 (Western Region from Luanda) | 12-15 |
| Figure 12-6 | Project Map toward 2040 (Central Region)..... | 12-16 |
| Figure 12-7 | Project Map toward 2040 (South Region) | 12-17 |
| Figure 12-8 | Current Project under Construction | 12-18 |
| Figure 12-9 | South Transmission System Enhancement Project Map | 12-19 |
| Figure 12-10 | Biópio HPP's Current Status | 12-23 |
| Figure 12-11 | Example of Organization to Formulate PDPM..... | 12-25 |
| Figure 12-12 | Action Plan and Structure for Power Demand Forecast | 12-26 |
| Figure 12-13 | Example of SCADA | 12-30 |
| Figure 12-14 | TEPCO's Load Dispatching Offices | 12-31 |
| Figure 12-15 | Staffing of Load Dispatching Office | 12-32 |

【List of Tables】

| | | |
|-----------|---|------|
| Table2-1 | Installed capacity of power plants in Angola (as of the end of June 2017) | 2-8 |
| Table2-2 | ENDE company profile..... | 2-9 |
| Table2-3 | Power plants commissioned in 2016 & 2017..... | 2-11 |
| Table 3-1 | List of new large hydropower plants..... | 3-6 |
| Table 3-2 | Information on existing/planned refinery facilities..... | 3-17 |
| Table 3-3 | Fuel Characteristics..... | 3-20 |
| Table 5-1 | Transition of Electrification Rate..... | 5-5 |
| Table 5-2 | Electrification Rate and Maximum Power Demand by Province (2016)..... | 5-9 |
| Table 5-3 | Incremental Power Demand Forecast for Commercial and Industrial Sectors | 5-11 |
| Table 5-4 | Annual Maximum Power Demand Forecast | 5-12 |
| Table 5-5 | Monthly Maximum Demand Fluctuation Normalized..... | 5-13 |
| Table 5-6 | Monthly Maximum Demand Fluctuation Normalized..... | 5-16 |
| Table 5-7 | Annual Generated Energy Demand Forecast by System | 5-18 |
| Table 6-1 | Major power generation plants by region by type (MW) | 6-1 |
| Table 6-2 | Available capacity of thermal power (MW) | 6-2 |
| Table 6-3 | Available capacity by type by region (MW)..... | 6-2 |
| Table 6-4 | Ownership of power plants (MW) | 6-2 |
| Table 6-5 | List of existing hydropower stations as of October 2017 | 6-4 |
| Table 6-6 | List of existing thermal power stations as of October 2017..... | 6-5 |

| | | |
|------------|---|------|
| Table 6-7 | Candidate hydropower projects | 6-12 |
| Table 6-8 | Candidate wind power generation projects | 6-13 |
| Table 6-9 | Candidate solar power projects | 6-13 |
| Table 6-10 | Construction unit cost for each type of power | 6-14 |
| Table 6-11 | Fuel types and efficiencies of thermal power plants | 6-14 |
| Table 6-12 | Conditions for financial evaluation..... | 6-15 |
| Table 6-13 | Calorific values and greenhouse gas emissions per unit for different fuels..... | 6-16 |
| Table 6-14 | Fuel price for development planning | 6-16 |
| Table 6-15 | Expected emission from power generation (base case) and DRAFT INDC..... | 6-30 |
| Table 6-16 | Pros and cons of the locations set for thermal power..... | 6-34 |
| Table 6-17 | Cost characteristics of candidate sites for CCGT | 6-36 |
| Table 6-18 | Narrowing down and selection of CCGT location..... | 6-37 |
| Table 6-19 | Long-term power development plan | 6-40 |
| Table 7-1 | Voltage criteria..... | 7-6 |
| Table 7-2 | List of 400 kV transmission lines (as of October 2017) | 7-10 |
| Table 7-3 | List of 220 kV transmission lines (as of October 2017) | 7-10 |
| Table 7-4 | List of 400 kV substations (as of October 2017) | 7-12 |
| Table 7-5 | List of 220 kV substations (as of October 2017) | 7-13 |
| Table 7-6 | Existing 400 kV main power transmission plans by RNT (~ 2027) | 7-14 |
| Table 7-7 | Existing 400 kV main substation plans by RNT (~ 2027) | 7-14 |
| Table 7-8 | Existing 220 kV main power transmission line plans by RNT (~ 2027) | 7-15 |
| Table 7-9 | Existing 220 kV main substation plans by RNT (~ 2027) | 7-16 |
| Table 7-10 | Estimated transmission line cost per km..... | 7-19 |
| Table 7-11 | Cost per substation based on the total transformer capacity | 7-21 |
| Table 7-12 | 220 kV Substation plan based on demand forecast of northern region..... | 7-26 |
| Table 7-13 | 220 kV Substation plan based on the demand forecast for the central region | 7-27 |
| Table 7-14 | 220 kV Substation plan based on the demand forecast for the southern region | 7-28 |
| Table 7-15 | 220 kV Substation plan based on the demand forecast for the western region..... | 7-28 |
| Table 7-16 | Review of the Transmission Line plan accompanying the regional supply substation plan | 7-30 |
| Table 7-17 | Result of Transmission Line connection based on the power generation plan | 7-31 |
| Table 7-18 | 400 kV main Substation plan based on electric power system analysis | 7-36 |
| Table 7-19 | 400 kV main Transmission Line plan based on electric power system analysis | 7-37 |
| Table 7-20 | Substation load data | 7-38 |
| Table 7-21 | Sensitivity of 400kV Saurimo Bus..... | 7-41 |
| Table 7-22 | Cost Comparison..... | 7-43 |
| Table 7-23 | Transmission losses of each CCGT installed site in 2040 | 7-45 |

| | | |
|-------------|---|------|
| Table 7-24 | Transmission losses in 2040 | 7-47 |
| Table 7-25 | Required Volume of Reactive Power Compensators in each Substation..... | 7-52 |
| Table 7-26 | Three-Phase Short Circuit Fault Currents | 7-53 |
| Table 7-27 | List of 400 kV Substation Projects | 7-54 |
| Table 7-28 | List of 220 kV Substation Projects (1)..... | 7-55 |
| Table 7-29 | List of 220 kV Substation Projects (2)..... | 7-56 |
| Table 7-30 | List of 400 kV Transmission Line Projects..... | 7-57 |
| Table 7-31 | 220 kV List of Transmission Line Projects | 7-58 |
| Table 7-32 | List of Power Supply Transmission Line Projects..... | 7-59 |
| Table 8-1 | Problems in Angola's investment environment..... | 8-3 |
| Table 8-2 | Names of laws related to the private investment environment | 8-4 |
| Table 9-1 | Typical Loan Conditions | 9-4 |
| Table 9-2 | Unit Prices for Construction | 9-5 |
| Table 9-3 | Long-term Investment Plan up to 2040 (commissioning Year)..... | 9-5 |
| Table 9-4 | Long-term Investment and 2016 Sales and Net Profit levels of PRODEL and RNT | 9-6 |
| Table 9-5 | Standardized Annual Construction Schedule during the Construction Period..... | 9-7 |
| Table 9-6 | Long-term Investment Amount up to 2040 (in terms of the Construction Schedule)..... | 9-7 |
| Table 9-7 | Loan Conditions for Candidate Loans | 9-9 |
| Table 9-8 | Borrowings up to 2040 and Financial Expenses | 9-9 |
| Table 9-9 | Details on Depreciation and IDC | 9-10 |
| Table 9-10 | Annual Unit Incremental Cost for Generation (hydro and thermal) | 9-12 |
| Table 9-11 | Annual Unit Incremental Cost for Transmission and Sub-station | 9-12 |
| Table 9-12 | Unit Revenue Price/kWh and Unit Cost Price/kWh | 9-13 |
| Table 9-13 | Unit Prices and Unit Incremental Costs | 9-14 |
| Table 9-14 | Summary of Power Tariffs as of December 2015..... | 9-14 |
| Table 9-15 | Equity Ratios with Long-term Investment..... | 9-16 |
| Table 10-1 | Profit and Loss Statement (P/L)..... | 10-1 |
| Table 10-2 | Balance Sheet (B/S) | 10-2 |
| Table 10-3 | Cash Flow Statement (C/F)..... | 10-3 |
| Table 10-4 | Major financial ratios | 10-4 |
| Table 10-5 | Profit and Loss Statement (P/L)..... | 10-4 |
| Table 10-6 | Balance Sheet (B/S) | 10-5 |
| Table 10-7 | Cash Flow Statement (C/F)..... | 10-6 |
| Table 10-8 | Major financial ratios | 10-6 |
| Table 10-9 | Profit and Loss Statement (P/L)..... | 10-7 |
| Table 10-10 | Balance Sheet (B/S) | 10-7 |
| Table 10-11 | Cash Flow Statement (CF)..... | 10-8 |

| | | |
|-------------|---|-------|
| Table 10-12 | Major financial ratios | 10-9 |
| Table 10-13 | Unit Revenue Prices and Unit Cost Prices | 10-9 |
| Table 10-14 | Collection (days) for Bills (days)..... | 10-10 |
| Table 10-15 | Current Ratio..... | 10-10 |
| Table 10-16 | Debt Equity Ratio | 10-10 |
| Table 10-17 | The Unit Incremental Cost Derived from the Long-term Investment..... | 10-11 |
| Table 10-18 | GDP and General Government Gross Debt of Angola..... | 10-13 |
| Table 11-1 | Number of Endangered Species in Angola | 11-5 |
| Table 11-2 | List of Protected Area | 11-5 |
| Table 11-3 | General Land Balance Sheet..... | 11-6 |
| Table 11-4 | Legal and Regulatory Frameworks for Environmental and Social Considerations | 11-7 |
| Table 11-5 | International Treaties/Conventions Concerning SEA..... | 11-8 |
| Table 11-6 | Reduction of CO ₂ emissions by project proposed by M/P..... | 11-9 |
| Table 11-7 | Differences between JICA Guidelines and Angolan regulations on SEA | 11-9 |
| Table 11-8 | Scoping Item Selection for SEA | 11-14 |
| Table 11-9 | Selected scoping items and impact evaluation indicators | 11-15 |
| Table 11-10 | Impact Evaluation Criteria..... | 11-15 |
| Table 11-11 | Power Development Candidate Sites for SEA..... | 11-16 |
| Table 11-12 | Evaluation Results on the CAMBAMBE HPP | 11-19 |
| Table 11-13 | Evaluation Results on the MATALA HPP | 11-21 |
| Table 11-14 | Evaluation Results on the CIMANGOLA Thermal Power Plant | 11-23 |
| Table 11-15 | Evaluation Results on the BENJAMIN Wind Power Plant | 11-25 |
| Table 11-16 | Evaluation Results on the CACULA Wind Power Plant..... | 11-27 |
| Table 11-17 | Evaluation Results on the CALENGA Wind Power Plant | 11-29 |
| Table 11-18 | Evaluation Results on the GASTAO Wind Power Plant | 11-31 |
| Table 11-19 | Evaluation Results on the KIWABANZOJI I Wind Power Plant..... | 11-33 |
| Table 11-20 | Evaluation Results on the MUSSENDE I Wind Power Plant..... | 11-35 |
| Table 11-21 | Evaluation Results on the NHAREA Wind Power Plant..... | 11-37 |
| Table 11-22 | Evaluation Results on the TOMBWA Wind Power Plant | 11-39 |
| Table 11-23 | Evaluation Results on the BENGUELA Solar Power Plant | 11-41 |
| Table 11-24 | Evaluation Results on the CARACULO Solar Power Plant..... | 11-43 |
| Table 11-25 | Evaluation Results on the CAMBOUNGUE Solar Power Plant | 11-45 |
| Table 11-26 | Evaluation Results on the GANDA/ALTOCATUMBELA Solar Power Plant..... | 11-47 |
| Table 11-27 | Evaluation Results on the LOBITO/CATUMBELA Solar Power Plant | 11-49 |
| Table 11-28 | Evaluation Results on the LUBANGO Solar Power Plant | 11-51 |
| Table 11-29 | Evaluation Results on the MATALA Solar Power Plant..... | 11-53 |
| Table 11-30 | Evaluation Results on the QUIPUNGO Solar Power Plant | 11-55 |

| | | |
|-------------|--|-------|
| Table 11-31 | Evaluation Results on the NAMACUNDE Solar Power Plant | 11-57 |
| Table 11-32 | Evaluation Results on the TECHAMUTETE Solar Power Plant | 11-59 |
| Table 11-33 | Evaluation Results on the Huila Biomass Power Plant Power Plant | 11-61 |
| Table 11-34 | Environmental indicator on each power generation plant..... | 11-62 |
| Table 11-35 | Evaluation Points on the Global Environment for Each Power Source | 11-63 |
| Table 11-36 | Evaluation Points on the Regional Environment for Each Power Source | 11-63 |
| Table 11-37 | Expected Mitigation Measures for Each Power Source..... | 11-65 |
| Table 11-38 | Common Monitoring Items for Power Development Project..... | 11-66 |
| Table 11-39 | List of T/Ls to be evaluated by SEA..... | 11-77 |
| Table 11-40 | Items to watch when implementing or selecting the T/L routes and weighing the impacts of each route..... | 11-78 |
| Table 11-41 | Scoping for Capanda PS – Saurimo Transmission Line | 11-79 |
| Table 11-42 | Scoping for Cambambe PS – Lubango Transmission Line | 11-80 |
| Table 11-43 | Scoping for Belem do Dango – Lubango SS Transmission Line | 11-81 |
| Table 11-44 | Scoping for Lubango SS – Cahama SS – Baynes SS Transmission Line..... | 11-83 |
| Table 11-45 | Scoping for Belem do Dango – Ondjiva SS Transmission Line..... | 11-84 |
| Table 11-46 | Scoping for Cahama SS – Ruacana PS Transmission Line | 11-85 |
| Table 11-47 | Survey Items and Methods..... | 11-86 |
| Table 11-48 | Environmental Items to be considered for Determination of the T/L Route | 11-88 |
| Table 11-49 | Expected Mitigation Measures for Transmission Lines..... | 11-89 |
| Table 11-50 | Common Monitoring Items for Transmission Line Expansion Projects..... | 11-89 |
| Table 12-1 | List of Generation Development Plan Projects..... | 12-4 |
| Table 12-2 | List of 400 kV Substation Projects | 12-5 |
| Table 12-3 | List of 220 kV Substation Projects (1) | 12-6 |
| Table 12-4 | List of 220 kV Substation Projects (2)..... | 12-7 |
| Table 12-5 | List of 400 kV Transmission Line Projects..... | 12-8 |
| Table 12-6 | List of 220 kV Transmission Line Projects | 12-9 |
| Table 12-7 | List of Transmission Line Projects for Newly Developed Power Sources | 12-10 |
| Table 12-8 | List of South Transmission System Enhancement Projects | 12-20 |
| Table 12-9 | CCGT Project (example) | 12-21 |
| Table 12-10 | Construction of Peak Demand Power Supply & Introduction of SCADA | 12-22 |
| Table 12-11 | Current Status of the HPP | 12-23 |
| Table 12-12 | Action Plans for the Power Development Master Plan..... | 12-24 |
| Table 12-13 | Flow of Implementation of ODA Loan..... | 12-28 |
| Table 12-14 | Medium-Term Planning Cycle..... | 12-29 |
| Table 12-15 | The standard for Substation facilities..... | 12-33 |
| Table 12-16 | The standard for Transmission line facilities | 12-33 |

| | |
|--|-------|
| Table 12-17 Compare of AAAC and LL-ACSR..... | 12-34 |
| Table 12-18 Schedule for Action Plan on PDMP | 12-35 |
| Table 13-1 Workshop Curriculum | 13-1 |
| Table 13-2 Participants List | 13-3 |
| Table 13-3 Activity Record of Training in Japan..... | 13-4 |

【Abbreviations】

| Abbreviation | Word |
|-----------------|---|
| ACCC | All Aluminium Alloy Conductor |
| AC | Alternating Current |
| ACSR | Aluminum Conductors Steel Reinforced |
| AGC | Automatic Generation Control |
| AOA | Angolan Kwanza |
| ARAP | Abbreviated Resettlement Action Plan |
| ATP | Alternative Transient Program |
| AfDB | African Development Bank |
| BAU | Business as Usual |
| bbl | Barrel |
| BOD | Biochemical Oxygen Demand |
| BOT | Build-Operate-Transfer |
| BP | British Petroleum |
| bp | Base Point |
| bpd | barrel per day |
| B/S | Balance Sheet |
| C/C | Combined Cycle |
| C/P | Counterpart |
| CCGT | Combined Cycle Gas Turbine |
| CCPP | Combined Cycle Power Plant |
| CIRR | Commercial Interest Reference Rates |
| CMEC | China Machinery Engineering Corporation |
| CO ₂ | Carbon Dioxide |
| COP | Conference of the Parties |
| CR | Critically Endangered |
| CRF | Capital Recovery Factor |
| DAC | Development Assistance Committee |
| DC | Direct Current |
| DES | Debt Equity Swap |
| DFR | Draft Final Report |
| DG | Diesel Generator |
| DNA | National Directorate of Water |
| DNEE | National Directorate of Electric Energy |
| DNER | National Directorate of Renewable Energies |
| DNERL | National Directorate of Rural and Local Electrification |
| DNPAIA | National Directorate for Prevention and Environmental Impact Assessment |
| DR Congo | Democratic Republic of the Congo |
| ECA | Export Credit Agency |
| EDEL | Empresa de Electricidade de Luanda |
| EFL | Environmental Framework Law |
| EIA | Environmental Impact Assessment |
| EIRR | Economic Internal Rate of Return |
| EMMP | Environmental Monitoring Plan |
| EMP | Environmental Management Plan |
| EMTP | Electromagnetic Transient Program |
| EN | Endangered |
| ENDE | National Electricity Distribution Company |
| ENE | Empresa Nacional de Electricidade |

| Abbreviation | Word |
|----------------------|--|
| EPA | Environmental Protection Agency |
| EPC | Engineering, Procurement and Construction |
| EU | European Union |
| EUR | Euro |
| F/S | Feasibility Study |
| FIRR | Financial Internal Rate of Return |
| FR | Final Report |
| GABHIC | Gabinete Para a Administração da Bacia Hidroelétrica do Cunene |
| GAMEK | Gabinete de Abinete de Aproveitamento do Médio Kwanza |
| GDP | Gross Domestic Product |
| GE | General Electric Company |
| GHG | Green House Gas |
| GIB | Gas Insulated Busbars |
| GIS | Gas Insulated Switchgear |
| GIS | Geographic Information System |
| GIT | Gas Insulated Transformer |
| GT | Gas Turbine |
| GW | Gigawatt |
| GWh | Gigawatt hour |
| HFO | Heavy Fuel Oil |
| HPP | Hydropower Plant |
| HPS | Hydropower Station |
| HQ | Headquarters |
| HRSG | Heat Recovery Steam Generator |
| HV | High Voltage |
| IDC | Interest during Construction |
| IEA | International Energy Agency |
| IMF | International Monetary Fund |
| INDC | Intended Nationally Determined Contribution |
| INE | Instituto Nacional de Estatística |
| I/P | Implementation Report |
| IPP | Independent Power Producer |
| IRR | Internal Rate of Return |
| IRSEA | Instituto Regulador dos Servicos de Electricidade e Agua |
| IUCN | International Union for Conservation of Nature |
| Ic/R | Inception Report |
| It/R | Interim Report |
| JBIC | Japan Bank for International Corporation |
| JCC | Joint Coordination Committee |
| JICA | Japan International Cooperation Agency |
| JOGMEC | Japan Oil, Gas and Metals National Corporation |
| JPY | Japanese Yen |
| JV | Joint Venture |
| km | Kilometer |
| kV | Kilovolt |
| kW | Kilowatt |
| kWh | Kilowatt Hour |
| kt-CO ₂ e | Kiloton of Carbon Dioxide Equivalent |
| L/A | Loan Agreement |
| LFO | Light Fuel Oil |
| LIBOR | London Interbank Offered Rate |
| LNG | Liquefied Natural Gas |
| LOLE | loss of load expectation |

| Abbreviation | Word |
|--------------|--|
| LOLP | Loss of Load Probability |
| LPG | liquefied petroleum gas |
| LRMC | Long-run Marginal Cost |
| LV | Low Voltage |
| Mcal | Mega calorie |
| MINEA | Ministry of Energy and Water Resources |
| MMBTU | Million British Thermal Unit |
| MOEF | Ministry of Environment and Forestry |
| MOU | Memorandum of Understanding |
| MScfpd | Million Standard cubic feet per day |
| MUS\$ | Million U.S. dollar |
| MVA | Mega volt ampere |
| MW | Megawatt |
| NDP | National Development Plan |
| NESSP | National Power Security Strategy and Policy |
| NEXI | Nippon Export and Investment |
| NG | Natural Gas |
| NGO | Non-Governmental Organization |
| NLDC | National Load Dispatch Center |
| O&M | Operation and Maintenance |
| ODA | Official Development Assistance |
| OECD | Organisation for Economic Co-operation and Development |
| OJT | On-the-Job Training |
| OPGW | Optical Fiber Ground Wire |
| OVPS | Overvoltage Protectors |
| PAP | Project Affected People |
| PDMP | Power Development Master Plan |
| PDPAT | Power Development Planning Assist Tool |
| PIL | Private Investment Law |
| P/L | Profit and Loss Statement |
| PPP | Public Private Partnership |
| PRODEL | Public Electricity Production Company |
| PSRSP | Power Sector Reform Support Program |
| PSS/E | Power System Simulator for Engineering |
| PTSE | Electricity Sector Transformation Program |
| p.u. | per unit |
| PV | Photovoltaic Power Generation |
| RETICS | Reliability Evaluation Tool for Inter-connected System |
| RNT | National Electricity Transportation Company |
| ROA | Return on Assets |
| ROW | Right of Way |
| SAPP | Southern African Power Pool |
| SAF | Special Assistance Facility |
| SAPI | Special Assistance for Project Implementation |
| SAPROF | Special Assistance for Project Formation |
| SAPS | Special Assistance for Project Sustainability |
| SCADA | Supervisory Control and Data Acquisition |
| SEA | Strategic Environmental Assessment |
| SGL | Sovereign Guarantee Loan |
| SHM | Stakeholder Meeting |
| SS | Substation |
| ST | Steam Turbine |
| T/L | Transmission Line |

| Abbreviation | Word |
|--------------|---|
| TEPCO | Tokyo Electric Power Company |
| TEPSCO | Tokyo Electric Power Service Company |
| TOR | Terms of Reference |
| TPP | Thermal Power Plant |
| TWh | Terawatt Hour |
| UNDP | United Nation Development Programme |
| UNFCC | United Nations Framework Convention on Climate Change |
| USD | U.S. Dollar |
| UXO | Unexploded Ordnance |
| VU | Vulnerable |
| WB | World Bank |

Summary

1. Purpose of the Survey

The purpose of this Survey is to produce a master plan for the generation and transmission development of the whole of Angola up to the year 2040, and thereby contribute to the smooth implementation of power development to enable a stable power supply for the country. In the course of the survey, the Survey Team will seek to:

- Formulate a comprehensive power development master plan (2018-2040) encompassing nationwide generation development plans and transmission development plans.
- Promote a sufficient understanding of the master plan by related organizations (MINEA, RNT, PRODEL, ENDE) and build up the capacity of personnel in related organizations to formulate and revise power development master plans.

2. Activities

- Preparations at home and Discussion and Consultation on the Inception Report
- Review of the current situation in the power sector
- Power demand forecast
- Analysis on primary energy sources for generation development
- Formulation of a generation development plan based on an optimal power generation mix
- Study on optimization of the transmission system development plan
- Review of the framework and implementation of private investment
- Formulation of a long-term investment plan
- Economic and financial analysis
- Environmental and social considerations
- Drafting of the Master Plan
- Capacity building

3. Review of the Current Situation in the Power Sector


3.1 Social & Economic Situation

| Item | Number |
|---------------|---------------------------------------|
| Occupied Area | 1,246,700km ² |
| Population | 25,900,000 (year 2014, source: MINEA) |
| GDP | 103 Billion USD (WB : year 2015) |

3.2 Current Status of the Power Sector

The Angola Electricity Sector is undergoing organizational reforms under the Electricity Sector Transformation Program (PTSE).

MINEA has reorganized GAMEK, ENE and EDEL into three new public companies, i.e., the power generation company PRODEL, the power transmission company RNT, and the electricity distribution company ENDE.




(Sources: The Transformation Program for the Electricity Sector-PTSE)

A PTSE roadmap on sector reform recommends the following based on a study the PTSE performed on an optimum model for the electricity market: a restructuring of the market into a classic single-buyer model, an unbundling of the power utilities into Generation, Transmission, and Distribution core activities, the establishment of commercial contracts among market participants, and amendments to the laws to improve the regulations and attract PPP. The study further proposed four (4) reform phases, each with specific deliverables:

- (i) Preparation Phase (2010-2013) for the design of a new market structure;
- (ii) Phase I (2014- 2017), a stabilization phase following the sector restructuring and unbundling of the power utilities;
- (iii) Phase II (2018-2021), transition to efficient operation with limited use of IPPs, mainly in RE using RE Feed-In tariffs;
- (iv) Phase III (2021-2025), partial liberalization of the power market with the introduction of the PPP and IPPs and limited concessions for the distribution system.

3.3 Record of Power Demand & Supply



(Source: Prepared by the JICA Survey Team based on Data from RNT (NLDC))

Figure Monthly Maximum Demand and Load-shedding Results (North System)


3.4 Existing power plants

Table Major power generation plants by region and type (MW)

| Region | Total | Hydropower (except small) | Thermal Power | | Renewable | | |
|----------------------|--------------|---------------------------------|---------------|------------|-----------|----------|-------------|
| | | | GT | Diesel | Biomass | Wind | Solar PV |
| Whole Country | 4,339 | 2,365 | 1,181 | 743 | 50 | 0 | 0 |
| North Region | 3,527 | 2,172 | 899 | 407 | 50 | 0 | 0 |
| Central Region | 492 | 125 | 254 | 113 | 0 | 0 | 0 |
| South Region | 221 | 41 | 28 | 152 | 0 | 0 | 0 |
| East Region | 99 | 28 | 0 | 71 | 0 | 0 | 0 |

(Source: Prepared by the JICA Survey Team based on Data from PRODEL, MINEA)

3.5 Current power system in Angola




(Source: RNT)

Figure Transmission system map of Angola (July 2017)

3.6 Angolan Policy on Climate Change Measures (INDC etc.)

The country is committed to stabilizing its emissions by reducing GHG emissions by up to 50% below the BAU emission levels by 2030 through unconditional and conditional actions.

Projection of GHG emissions in 2030



| | 2005 | 2020 | 2030 |
|--|--------|---------|-------------------|
| Emissions-BAU scenario (ktCO ₂ e) | | | 193,250 |
| Emissions-Unconditional scenario (ktCO ₂ e) | 66,812 | 125,778 | 125,612 (-35%) |
| Emissions-Conditional scenario (ktCO ₂ e) | | | 96,625 (-50%) |

(source : DRAFT INDC of the Republic of Angola)

Figure Baseline scenario and projections of unconditional and conditional mitigation scenarios in Angola

4. Primary Energy Analysis for Power Development

4.1 The potential of primary energy

| Primary energy | Potential |
|----------------|---|
| Crude oil | Confirmed crude oil reserves: 12.7 billion barrels (BP statistics at the end of 2014) |
| Natural gas | Confirmed natural gas reserves in Angola: total 9.7 trillion cubic feet (2014, Cedigaz) |
| Hydropower | Hydropower Potential: 18GW (Atras and National Strategy for the new Renewable Energies) |
| Solar energy | 17.3GW (Atras and National Strategy for the new Renewable Energies) |
| Wind energy | 3.9GW (Angola Energia 2025) |
| Biomass | 4GW (Angola Energia 2025) |

4.2 Status of energy supply facilities

(1) LNG Production Facilities

The Angola LNG plant located in Soyo of Zair State is the only LNG production facility in Angola. Petroleum-associated gas obtained as a result of oil extraction is sent to this facility in a pipeline and processed within the facility to LNG. The Angola LNG production facility has a capacity to produce 34 MSm³/d.

(2) Oil Refinery

The only oil refinery currently established in Angola is the Luanda Refinery in the capital city Luanda. Angola's oil refining capacity is therefore insufficient relative to the national consumption of petroleum products. Currently, more than 80% of the consumption is covered by imported products.

Sonangol has formulated a plan to build new refineries in Lobito in central Angola, in Soyo and Cabinda in northern Angola, and in Namibe in southern Angola. The refinery plan at Lobito was scheduled to commence in 2018, but construction was halted in August 2016 due to a lack of funds. The Soyo refinery plan was launched but never reached the construction phase. Construction for the Namibe refinery was commenced in July 2017 and is currently proceeding.

In February 2018, Sonangol announced new oil refinery development plans in Lobito and Cabinda and expansion plans for the existing Luanda Refinery. Under the Lobito plan, a facility with a 200,000 bpd/day capacity (unchanged from the previous plan) will be completed by 2022. Under the Cabinda plan, a smaller refinery than that in Lobito will be completed by 2020. The expansion plan for the existing Luanda Refinery aims to expand production from the current 57,000 bpd/day to 65,000 bpd/day by 2020.

4.3 Fuel Price

Studies for long-term power development planning require that future fuel prices be set for thermal power. For this purpose, we adopt future fuel prices based on the current international price and IEA's long-term forecast under the New Policy Scenario (see the Table below).

Table Fuel prices for development planning

unit: UScents/Mcal

| Year | CrudeOil | LFO | HFO | LPG | NG | LNG |
|------|----------|-------|-------|-------|-------|-------|
| 2015 | 3.281 | 3.948 | 3.919 | 4.041 | 1.036 | 4.087 |
| 2020 | 5.082 | 6.116 | 6.071 | 6.259 | 1.633 | 3.810 |
| 2025 | 6.111 | 7.354 | 7.300 | 7.527 | 1.892 | 4.266 |
| 2030 | 7.140 | 8.593 | 8.529 | 8.795 | 2.151 | 4.722 |
| 2035 | 7.558 | 9.096 | 9.029 | 9.310 | 2.450 | 4.822 |
| 2040 | 7.977 | 9.599 | 9.528 | 9.825 | 2.749 | 4.921 |

(Source: JICA Study Team, based on the international price in 2015 and IEA data)

5. Procedure for Formulating a Power Master Plan based on the Optimal Generation Mix (“The Best Mix”)




Figure Flow for Formulating a Power Development Master Plan

6. Power Demand Forecast

6.1 Power demand forecasting methodology





Figure Power Demand Forecasting Flow in Angola

6.2 Annual maximum power demand forecast

Annual maximum demand in the residential consumer sector was calculated based on the electrification rate, population, mean population per customer, maximum power demand per contract. The annual maximum power demand up to 2040 was then assumed by adding the annual maximum power demand forecast for commercial and industrial customers. The results are shown in the table and figure below. As a result of the calculations, the maximum power demand forecast for 2040 was 11,226 MW.



| | 2016 | 2020 | 2025 | 2030 | 2035 | 2040 |
|---------|-------|-------|-------|-------|-------|--------|
| North | 1,546 | 2,584 | 3,570 | 4,753 | 5,864 | 6,839 |
| Central | 266 | 574 | 877 | 1,275 | 1,765 | 2,313 |
| South | 135 | 267 | 499 | 758 | 1,060 | 1,409 |
| East | 42 | 91 | 249 | 346 | 490 | 665 |
| Total | 1,989 | 3,516 | 5,195 | 7,132 | 9,180 | 11,226 |

(Source: JICA Survey Team)

Figure Annual Maximum Power Demand Forecast

6.3 Annual generated energy demand forecast

Generation energy demand is calculated by the following formula.


Generation energy demand (kWh) = annual maximum power demand (kW) × 8,760 hours × annual load factor

Table Annual Generated Energy Demand Forecast by System

(Unit: GWh)

| | North | Center | South | East | Whole |
|------|--------|--------|-------|-------|--------|
| 2016 | 9,522 | 1,325 | 673 | 208 | 11,728 |
| 2020 | 15,977 | 2,860 | 1,329 | 453 | 20,619 |
| 2025 | 22,183 | 4,366 | 2,485 | 1,241 | 30,275 |
| 2030 | 29,685 | 6,347 | 3,774 | 1,723 | 41,529 |
| 2035 | 36,805 | 8,790 | 5,279 | 2,442 | 53,316 |
| 2040 | 43,136 | 11,518 | 7,015 | 3,309 | 64,979 |

(Source: JICA Survey Team)




(Source: JICA Survey Team)

Figure Generated Energy Demand Forecast

7. Optimization of the Generation Development Plan

7.1 Relationship between LOLE and Reserve Capacity

The reserve margin ratio corresponding to 24 hours of LOLE was formulated by PDPAT and RETICS. The examination results are shown in the figures below. The required reserve margin gradually decreases over time, reaching about 11% after 2030. This level, 11%, is therefore set as the target value.

**Figure Relationship between LOLE and reserve margin rate****Figure Necessary reserve margin rate equivalent to LOLE of 24hrs**

7.2 The Most economical power supply composition ratio by using PDPAT

Here we consider the power supply composition that minimizes the total cost in the year 2040, the final year of the power master plan. We examine the most economical configuration in 2040 among large hydropower, combined cycle (CCGT), and gas turbine (GT).

The following assumptions are adopted for the calculation using PDPAT:

- The target year is 2040.
- The reserve margin rate is set at 11%, is the value selected in 6.4.2. GT shares the capacity for the reserve margin, as it has a lower fixed cost.
- The supply configuration ratio is calculated in the month with the lowest reserve margin for the year and is defined as the ratio of the available supply (excluding the capacity corresponding to the reserve margin) of each power source to the peak demand of the month.

The figure below shows the relation between the total cost per year and the configuration ratio of GT, calculated using PDPAT. The annual cost is lowest when the configuration ratio of GT is 12%.




Figure Configuration ratio of GT and total annual cost (year 2040)

Peak demand in the year 2040 appears in December. Meanwhile, the most severe month of the year in terms of the supply-demand balance is November, since supply capacity of hydropower declines during the drought period. The figure below shows the power configuration ratio when the ratio of GT is set to 12% in the November 2040 section. This configuration ratio corresponds to the future target value. The final power development plan formulated for each year up to 2040 needs to approach this power configuration ratio.




Figure Cost minimum power supply configuration in the year 2040 (November balance)

7.3 List of Generation Development Plan Projects

The table below shows recommended power development projects.


Table Long-term power development plan

| Year | Long-term Power Development Plan | | | | |
|-------|--|-----------------|---|--------------------------------|------------------|
| | Hydropower | CCGT | GT | Wind power | Solar power |
| 2017 | | Soyo1-1 (250) | | | |
| 2018 | Lauca (2070) Lomaun ext.(65) | Soyo1-2 (500) | | | |
| 2019 | | | | | |
| 2020 | Luachimo ext.(34) | | | | |
| 2021 | | Soyo2-1 (375) | | | |
| 2022 | | Soyo2-2 (375) | Cacuaco No.1 (125) | | |
| 2023 | | | | | |
| 2024 | Caculo Cabaca(2172) | | Cacuaco No.2 (125) | | |
| 2025 | | | Sambizanga No.1 (125) | | |
| 2026 | Baynes (300) | | | | |
| 2027 | | Lobito1-1 (375) | Quileva No.1 (125) | | |
| 2028 | Quilengue (210) | | Quileva No.2 (125) | Beniamin (52) | Benguela (10) |
| 2029 | | Lobito1-2 (375) | | Cacula (88) | Cambongue (10) |
| 2030 | | | Quileva No.3 (125) Soyo-SS No.1 (125) | Chibia (78) | Caraculo (10) |
| 2031 | | Lobito2-1 (375) | | Calenga (84) | Catumbera (10) |
| 2032 | Zenzo (950) | | Cacuaco No.3 (125) Cacuaco No.4 (125) | Gasto (30) | Lobito (10) |
| 2033 | | | Sambizanga No.2 (125) Quileva No.4 (125) Quileva No.5 (125) Quileva No.6 (125) | Kiwaba Nzoji I (62) | Lubango (10) |
| 2034 | | Lobito2-2 (375) | | Kiwaba Nzoji II (42) | Matala (10) |
| 2035 | Genga (900) | | Soyo-SS No.2 (125) Cacuaco No.5 (125) | Mussede I (36) | Quipungo (10) |
| 2036 | | Namibe1-1 (375) | | Mussede II (44) Nharea (36) | Techamutete (10) |
| 2037 | | | Cacuaco No.6 (125) Sambizanga No.3 (125) Soyo-SS No.3 (125) | Tombwa (100) | Namacunde (10) |
| 2038 | Túmulo Caçador(453) | Namibe1-2 (375) | | | |
| 2039 | | | | | |
| 2040 | Jamba Ya Oma (79) Jamba Ya Mina (205) | Lobito3-1 (375) | | | |
| Total | 7,438 MW | 4,125 MW | 2,250 MW | 652 MW | 100 MW |

8. Study on Optimization of the Transmission System Development Plan

8.1 Transmission Development Planning Procedure

The development planning procedure is shown in the flowchart of the figure below.




(Source: JICA Survey Team)

Figure Flowchart of the Transmission Network Development Plan

8.2 The Transmission Development Plan for 2040

The results of the analysis using PSSE confirmed that there was no overload based on the n-1 standard for any of the transmission lines or S/Ss with voltages of 220 kV or more.



(Source: JICA Survey Team)

Figure Main power system in 2040 (400 kV, 220 kV)

8.3 Lists of Transmission Development Plan Projects

The tables below show recommended transmission development projects.

Table List of 400 kV Substation Projects

| Project# | Year of operation | Area | Voltage (kV) | Substation Name | Capacity (MVA) | Cost (MUSS) | Remarks |
|----------|-------------------|-------------|--------------|-----------------|----------------|-------------|-------------------------------------|
| 1 | 2020 | Cuanza Sul | 400 | Waco kungo | 450 | 40.5 | 450 x 1, under construction(China) |
| 2 | 2020 | Huambo | 400 | Belem do Huambo | 900 | 51.3 | 450 x 2, under construction(China) |
| 3 | 2022 | Luanda | 400 | Bitá | 900 | 51.3 | 450 x 2, under construction(Brazil) |
| 4 | 2025 | Cuanza Sul | 400 | Waco kungo | 450 | 40.5 | upgrade 450 x 1 |
| 5 | 2025 | Luanda | 400 | Bitá | 450 | 40.5 | upgrade 450 x 1 |
| 6 | 2025 | Zaire | 400 | N'Zeto | 450 | 40.5 | upgrade 450 x 1 |
| 7 | 2025 | Luanda | 400 | Viana | 2,790 | 96.6 | upgrade 930 x 3 |
| 8 | 2025 | Bengo | 400 | Kapary | 450 | 40.5 | upgrade 450 x 1 |
| 9 | 2025 | Huila | 400 | Lubango2 | 900 | 51.3 | 450 x 2, Pre-FS implemented* |
| 10 | 2025 | Huila | 400 | Capelongo | 900 | 51.3 | 450 x 2 |
| 11 | 2025 | Huila | 400 | Calukembe | 120 | 32.6 | 60 x 2 |
| 12 | 2025 | Benguela | 400 | Nova Biopio | 900 | 51.3 | 450 x 2 |
| 13 | 2025 | Southern | 400 | Cahama | 900 | 51.3 | 450 x 2 |
| 14 | 2025 | Eastern | 400 | Saurimo | 900 | 51.3 | 450 x 2, under Pre-FS |
| 15 | 2025 | Lunda Norte | 400 | Xa-Muteba | 360 | 38.3 | 180 x 2, under Pre-FS |
| 16 | 2025 | Huila | 400 | Quilengues | 120 | 32.6 | 60 x 2 |
| 17 | 2025 | Cuanza Sul | 400 | Gabela | 900 | 51.3 | 450 x 2 |
| 18 | 2025 | Luanda | 400 | Sambizanga | 2,790 | 96.6 | 930 x 3 |
| 19 | 2025 | Malanje | 400 | Lucala | 900 | 51.3 | 450 x 2 |
| 20 | 2025 | Chipindo | 400 | Chipindo | 360 | 38.3 | 180 x 2 |
| 21 | 2030 | Bengo | 400 | Kapary | 450 | 40.5 | upgrade 450 x 1 |
| 22 | 2030 | Luanda | 400 | Catete | 450 | 40.5 | upgrade 450 x 1 |
| 23 | 2035 | Cunene | 400 | Ondjiva | 900 | 51.3 | 450 x 2, Pre-FS implemented* |
| 24 | 2035 | Luanda | 400 | Bitá | 450 | 40.5 | upgrade 450 x 1 |
| 25 | 2035 | Malanje | 400 | Lucala | 450 | 40.5 | upgrade 450 x 1 |
| Total | | | | | 19,590 | 1,171.4 | |

Pre-FS implemented*:Candidate site were selected by USTDA and DBSA.

Table List of 400 kV Transmission Line Projects

| Project# | Year of operation | Area | Voltage (kV) | Starting point | End point | number of circuit | Power Flow (MVA) | Line Length (km) | Cost (MUSS) | Remarks |
|----------|-------------------|----------|--------------|-----------------|-----------------|-------------------|------------------|------------------|-------------|-------------------------------|
| 1 | 2020 | Central | 400 | Lauca | Waco kungo | 1 | 307 | 177 | 138.1 | under construction(China) |
| 2 | 2020 | Central | 400 | Waco kungo | Belem do Huambo | 1 | 242 | 174 | 135.7 | under construction(China) |
| 3 | 2020 | Northern | 400 | Cambutas | Bitá | 1 | 580 | 172 | 134.2 | under construction(Brazil) |
| 4 | 2022 | Northern | 400 | Catete | Bitá | 2 | 504 | 54 | 52.9 | under construction(Brazil) |
| 5 | 2025 | Northern | 400 | Cambutas | Catete | 1 | 791 | 123 | 95.9 | Dualization |
| 6 | 2025 | Northern | 400 | Catete | Viana | 1 | 579 | 36 | 28.1 | Dualization |
| 7 | 2025 | Northern | 400 | Lauca | Capanda elev. | 1 | 518 | 41 | 32.0 | Dualization |
| 8 | 2025 | Northern | 400 | Kapary | Sambizanga | 2 | 1130 | 45 | 44.1 | For New Substation |
| 9 | 2025 | Northern | 400 | Lauca | Catete | 2 | 868 | 190 | 186.2 | Changing Connection Plan |
| 10 | 2025 | Central | 400 | Lauca | Waco kungo | 1 | 307 | 177 | 138.1 | Dualization |
| 11 | 2025 | Central | 400 | Waco kungo | Belem do Huambo | 1 | 242 | 174 | 135.7 | Dualization |
| 12 | 2025 | Central | 400 | Cambutas | Gabela | 2 | 484 | 131 | 128.4 | Pre-FS implemented* |
| 13 | 2025 | Central | 400 | Gabela | Benga | 2 | 848 | 25 | 24.5 | Pre-FS implemented* |
| 14 | 2025 | Central | 400 | Benga | Nova Biopio | 2 | 550 | 200 | 196.0 | Pre-FS implemented* |
| 15 | 2025 | Southern | 400 | Belem do Huambo | Caluquembe | 2 | 606 | 175 | 171.5 | Pre-FS implemented* |
| 16 | 2025 | Southern | 400 | Caluquembe | Lubango2 | 2 | 666 | 168 | 164.6 | Pre-FS implemented* |
| 17 | 2025 | Southern | 400 | Belem do Huambo | Chipindo | 2 | 264 | 114 | 111.7 | |
| 18 | 2025 | Southern | 400 | Chipindo | Capelongo | 2 | 190 | 109 | 106.8 | |
| 19 | 2025 | Southern | 400 | Nova Biopio | Quilengues | 2 | 840 | 117 | 114.7 | Pre-FS implemented* |
| 20 | 2025 | Southern | 400 | Quilengues | Lubango2 | 2 | 772 | 143 | 140.1 | Pre-FS implemented* |
| 21 | 2025 | Southern | 400 | Lubango2 | Cahama | 2 | 450 | 190 | 186.2 | Pre-FS implemented* |
| 22 | 2025 | Eastern | 400 | Capanda elev | Xa-Muteba | 2 | 590 | 266 | 260.7 | |
| 23 | 2025 | Eastern | 400 | Xa-Muteba | Saurimo | 2 | 510 | 335 | 328.3 | under Pre-FS |
| 24 | 2027 | Southern | 400 | Capelongo | Ondjiva | 2 | 292 | 312 | 305.8 | |
| 25 | 2027 | Southern | 400 | Cahama | Ondjiva | 2 | 442 | 175 | 171.5 | |
| 26 | 2027 | Southern | 400 | Cahama | Ruacana | 2 | 409 | 125 | 122.5 | International Interconnection |
| Total | | | | | | | | 3,948 | 3,654.2 | |

Pre-FS implemented*:Candidate route were selected by USTDA and DBSA.

9. Long-term Investment Plan

9.1 Investment in terms of the Commissioning Year

The following table lists investment plans by commissioning year. The total investment comes to 32,449 million USD: hydropower (19,849 million USD), thermal power (6,413 million USD), renewable energy (0 million USD), transmission line (4,551 million USD) and sub-station (1,636 million USD).

Table Long-term Investment Planed up to 2040 (commissioning Year)

| | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
|--------------|------------|-----------|--------------|------------|--------------|--------------|------------|------------|--------------|------------|--------------|--------------|-----------|------------|
| Hydro | 0 | 0 | 5,589 | 34 | 0 | 0 | 0 | 0 | 5,864 | 810 | 0 | 567 | 0 | 0 |
| TPP | 300 | 0 | 0 | 0 | 1,050 | 531 | 0 | 531 | 81 | 0 | 81 | 450 | 81 | 163 |
| Renewable | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Transmission | 208 | 0 | 2 | 414 | 0 | 878 | 556 | 2 | 1,614 | 0 | 785 | 0 | 0 | 18 |
| Sub-station | 0 | 25 | 0 | 225 | 0 | 444 | 51 | 0 | 196 | 0 | 426 | 0 | 0 | 18 |
| total | 508 | 25 | 5,591 | 673 | 1,050 | 1,854 | 607 | 533 | 7,756 | 810 | 1,293 | 1,017 | 82 | 199 |

| | 2031 | 2032 | 2033 | 2034 | 2035 | 2036 | 2037 | 2038 | 2039 | 2040 | total |
|--------------|------------|--------------|------------|------------|--------------|------------|------------|--------------|-----------|------------|---------------|
| Hydro | 0 | 2,603 | 77 | 115 | 2,583 | 153 | 115 | 1,300 | 38 | 0 | 19,849 |
| TPP | 450 | 163 | 325 | 450 | 163 | 450 | 244 | 450 | 0 | 450 | 6,413 |
| Renewable | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Transmission | 34 | 0 | 0 | 8 | 6 | 0 | 6 | 0 | 18 | 2 | 4,551 |
| Sub-station | 129 | 0 | 0 | 0 | 103 | 0 | 0 | 0 | 18 | 0 | 1,636 |
| total | 613 | 2,766 | 402 | 573 | 2,855 | 603 | 365 | 1,750 | 74 | 452 | 32,449 |

9.2 Long-Run Marginal Cost (LRMC)

Following is the long run marginal cost (LRMC) calculated by the JICA Survey Team in accordance with the 'Internal Rate of Return (IRR) Manual for Yen Loan Projects' (JBIC):

$$\text{Long Run Marginal Cost (LRMC)} = \text{total project cost} \times \text{capital recovery factor} + \text{O\&M expenses}$$

$$\text{capital recovery factor} = r / (1 - (1+r)^{-n})$$

r : 10%

n : durable year (hydropower, 40 years; thermal power, 25 years (CCGT) and 20 years (GT))

O&M expenses = O&M expenses + fuel cost (thermal)

O&M expense: calculated to a certain percent of the total construction cost

Fuel cost: annual fuel cost for thermal power plants

The results indicate that the unit price for generation will reach 8.5 cents USD at maximum, while the unit price for transmission and substation will reach 2 cents USD.

Table Annual Unit Incremental Cost for Generation (hydro and thermal)

| | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
|-------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| incremental cost \$/kWh | 0.031 | 0.024 | 0.014 | 0.057 | 0.063 | 0.066 | 0.065 | 0.059 | 0.085 | 0.084 | 0.081 | 0.082 | 0.080 | 0.079 |

| type | 2031 | 2032 | 2033 | 2034 | 2035 | 2036 | 2037 | 2038 | 2039 | 2040 | total |
|-------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| incremental cost \$/kWh | 0.079 | 0.083 | 0.083 | 0.084 | 0.085 | 0.085 | 0.085 | 0.084 | 0.083 | 0.082 | — |

Table Annual Unit Incremental Cost for Transmission and Sub-station

| | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
|-------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| incremental cost \$/kWh | 0.002 | 0.003 | 0.003 | 0.006 | 0.006 | 0.013 | 0.016 | 0.015 | 0.019 | 0.018 | 0.022 | 0.021 | 0.020 | 0.019 |

| type | 2031 | 2032 | 2033 | 2034 | 2035 | 2036 | 2037 | 2038 | 2039 | 2040 | total |
|-------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| incremental cost \$/kWh | 0.018 | 0.018 | 0.017 | 0.016 | 0.015 | 0.014 | 0.014 | 0.013 | 0.013 | 0.012 | — |

These figures indicate that the unit cost of PRODEL needs to increase by 15 AOA, starting from the current 23.11 AOA. Likewise, the unit cost price of RNT needs to increase by 3.59 AOA, starting from the current 8.86 AOA.


Table Unit Prices and the Unit Incremental Costs

| | PRODEL | RNT |
|--|-------------------------------------|--------------------------------------|
| 1. unit revenue price in 2016 | @0.09 \$ /kWh (= @20.17 AOA/kWh) | @0.043 \$ /kWh (= @9.34 AOA/kWh) |
| 2. unit cost price in 2016 | @0.09\$ /kWh (= @19.74 AOA/kWh) | @0.039 \$ / kWh (= @8.45 AOA/kWh) |
| 3. incremental cost based on the long-term investment | @0.085\$/ kWh (= @18.3 AOA/kWh) | @0.02\$/ kWh (= @4.3 AOA/kWh) |
| 4. total cost (2+3) | @0.175 \$/kWh (= @38.04 AOA/kWh) | @ 0.059 \$/kWh (= @12.75 AOA/kWh) |
| 5. increase of tariff (unit cost of investment / current unit cost) | 17.9 AOA (1.92) | 3.41 AOA (1.51) |

※USD is converted using the official exchange rate of Nacional Banco de Angola as of March 12, 2018 (\$1=215.064 AOA (T.T.M))

10. Environmental and Social Considerations

10.1 Outline of the Strategic Environmental Assessment (SEA) Approach for the Power Development Master Plan



(Source: JICA Survey Team)

Figure Workflow for the SEA

10.2 Environmental Evaluation

The table below presents the results of SEA-based evaluations of the environmental and social considerations linked to power development, rated by indicator (degree of environmental impact).

The power sources ranked from lower negative impacts on the natural and social environment are as follows: (i). Biomass, (ii). Hydropower, (iii). Solar, (iv). Wind, (v). Thermal (LNG/Heavy Oil).


The relatively high total environmental impact assessed for wind power and solar power generation stems from the large negative impact on the local landscape caused by the appearance of huge artificial structures in the vast plains (mainly savanna, shrub vegetation) of the continent of Africa.

Table Environmental Indicators for the Different Types of Power Generation Plants

| | Type | HYPP | | | THPP | | | Wind PP | | | | | | | Solar PP | | | | | | | | | | | Bio. PP |
|---|------|-------|-------|-------|-------|-------|-------|---------|-------|--------|-------|-------|--------|--------|----------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--|---------|
| | Name | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | | |
| | MW | 960 | 40.8 | 212 | 52 | 88 | 84 | 30 | 62 | 36 | 36 | 100 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 3 | | |
| Topography & Geology | | -1.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| Soil | | -1.0 | 0.0 | -2.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | -1.0 | -1.0 | -1.0 | -1.0 | -1.0 | -1.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| Quality of Water | | -1.0 | -1.0 | -2.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | -1.0 | -1.0 | -1.0 | -1.0 | | |
| Quality of Air | | 0.0 | 0.0 | -2.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| Noise/Vibration | | 0.0 | 0.0 | -1.0 | -1.0 | -1.0 | 0.0 | 0.0 | -2.0 | -2.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| Waste | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | -2.0 | -2.0 | -2.0 | -2.0 | -2.0 | -2.0 | -2.0 | -2.0 | -2.0 | -2.0 | -2.0 | -2.0 | | |
| Subsidence | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| Flora | | -2.0 | -1.0 | -2.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | -1.0 | -1.0 | -2.0 | -2.0 | -2.0 | -2.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| Fauna/Fish/Coral | | -1.0 | 0.0 | -2.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | -1.0 | -1.0 | -2.0 | -1.0 | 0.0 | -1.0 | -1.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| Nature Protected Areas | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | -3.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| (Natural Environment) | | -0.60 | -0.20 | -1.10 | -0.40 | -0.40 | -0.30 | -0.30 | -0.50 | -0.50 | -0.40 | -0.70 | 0.50 | -0.60 | -0.70 | -0.60 | -0.30 | -0.40 | -0.40 | -0.30 | -0.30 | -0.30 | -0.30 | -0.50 | | |
| (Average) | | -0.40 | -1.10 | | | | | | -0.43 | | | | | | | | -0.44 | | | | | | | -0.50 | | |
| Resettlement | | -1.0 | -1.0 | -1.0 | 0.0 | -1.0 | -1.0 | 0.0 | -2.0 | -2.0 | 0.0 | 0.0 | -1.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| Ethnic/Indigenous pec | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| Land use | | 0.0 | 0.0 | 0.0 | -1.0 | -1.0 | -1.0 | 0.0 | 0.0 | 0.0 | -1.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | -1.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| Water Use | | -1.0 | -1.0 | -1.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | -1.0 | | |
| Landscape | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | 0.0 | | |
| Historical Heritage | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| (Social Environment) | | -0.33 | -0.33 | -0.33 | -0.66 | -0.83 | -0.66 | -0.50 | -0.83 | -0.83 | -0.66 | -0.50 | -0.66 | -0.50 | -0.50 | -0.50 | -0.50 | -0.50 | -0.50 | -0.66 | -0.50 | -0.50 | -0.50 | -0.15 | | |
| (Average) | | -0.33 | -0.33 | | | | | | -0.68 | | | | | | | | -0.53 | | | | | | | -0.15 | | |
| Ren House Gas | | 0.0 | 0.0 | -2.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| (Globale Environment) | | 0.00 | 0.00 | -2.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | | |
| (Average) | | 0.00 | -2.00 | | | | | | 0.00 | | | | | | | | 0.00 | | | | | | | 0.00 | | |
| Comprehensive Environmental Indexes | | -0.31 | -0.17 | -1.14 | -0.35 | -0.41 | -0.32 | -0.26 | -0.44 | -0.44 | -0.35 | -0.40 | -0.38 | -0.36 | -0.40 | -0.36 | -0.26 | -0.30 | -0.30 | -0.32 | -0.26 | -0.26 | -0.26 | -0.21 | | |
| Comprehensive Environmental Indexes (Average) | | -0.24 | | -1.14 | | | | | -0.31 | | | | | | | | -0.32 | | | | | | | -0.21 | | |
| Comprehensive Environmental Indexes/per MW (each Plant) * | | -0.32 | -4.16 | -5.37 | -6.73 | -4.65 | -3.80 | -8.66 | -7.08 | -12.22 | -9.72 | -4.00 | -38.00 | -36.00 | -40.00 | -36.00 | -26.00 | -36.00 | -30.00 | -32.00 | -26.00 | -26.00 | -26.00 | -70.00 | | |
| Comprehensive Environmental Indexes/per MW (Type of Generation) | | -2.24 | -5.37 | | | | | | -7.11 | | | | | | | | -32.00 | | | | | | | -70.00 | | |

*: For convenience sake, it is 1,000 times for comparison.

(Source: JICA Survey Team)



(Source: JICA Survey Team)

Figure Environmental Impact Analysis Diagram of Power Generation Type (Overall)

11. Drafting PDMP

The generation development plans and transmission development plans are summarized in the figure below.




Figure Summary of Generation Development Plans & Transmission Development Plans



Figure Project Map toward 2040

12. Advice to MINEA, RNT, PRODEL, ENDE and IRSEA on their Action Plans for the Power Development Master Plan

The following table summarizes Angolan action plans for the Power Development Master Plan.

Table Action Plans for the Power Development Master Plan

| Target | Item | Action Plan in Detail |
|---|--|--|
| Action plans related to maintenance of the Power Master Plan | Establishment of an organization to formulate the PDMP | ➤ Establishment of the Institute of Power Development Planning (IPDP) <tentative name> |
| | Revising the PDMP on an ongoing basis | Ongoing revision of the Power Demand Forecast ➤ Collection of necessary data such as economic indicators ➤ Collection of demand data and improve accumulation methods ➤ Sounding out customers |
| | | Ongoing revision of the Generation Development Plans ➤ Review of fuel procurement plans ➤ Collection of the latest technical information on hydropower & thermal power ➤ Ongoing study on occupancy hydropower potential ➤ Maintaining the Best Generation Mix |
| | | Ongoing revision of the Transmission Development Plan ➤ Ongoing analysis of the power supply-and-demand imbalance by region ➤ Review of transmission facility specifications ➤ Review of power flow analyses |
| Action plans related to the execution of development projects | Company Operation & Project management | ➤ Deployment and reflection of the PDMP in the medium-term plans of different entities |
| | Management and reform of fund procurement | ➤ Improvement of the tariff system ➤ Study on how to use foreign loans ➤ Study on how to introduce private sector funds |
| Others | Reform of dispatching organization | ➤ Introduction of SCADA ➤ Reform of central and regional dispatching organizations |

Table Schedule of Action Plans for the PDMP

| | | 2018-'20 | 2021-'25 | 2026-'30 | 2031-'35 | 2036-'40 |
|---|--------------------------------|--|---|----------|----------|----------|
| Establishment of Organization to Formulate PDMP | MINEA RNT PRODEL ENDE | Establishment of IPDP | | | | |
| Revision of PDMP | MINEA/IPDP | | ▼ | ▼ | ▼ | ▼ |
| ➤ Act on improve accuracy of Power Demand Forecast ✧ Organizing and accumulating information ✧ Hearing to customers | RNT ENDE | Design & introduction of SCADA | Efficient accumulation and analysis of data | | | |
| | | | Enhancement of customer hearing system; Continuation of hearing | | | |
| ➤ Revision of study on occupancy hydropower potential | | | ▼ | ▼ | ▼ | ▼ |
| Formulation of mid-term plan | RNT PRODEL ENDE | Review of the mid-term plan year by year | | | | |
| Design of electricity tariff structure | IRSEA | Tariff structure design | until the start of liberalization at the latest | | | |
| Institution design for IPP entry ➤ Concession system, PPA system etc. | IRSEA | Institution design for IPP entry | until the start of liberalization at the latest | | | |
| Renovation of load dispatching organization ➤ Reform of load dispatching offices ➤ Introduction of SCADA | RNT PRODEL | Reform of load dispatching offices | | | | |
| | | Introduction of SCADA | | | | |

Chapter 1 Outline of the Survey

1.1 Background of Survey

The economy of the Republic of Angola (hereinafter “Angola”) has grown steadily since the end of the civil war in 2002, achieving an average economic growth rate of 10.7% from 2002 to 2013. Under a long-term development policy (Vision 2025) and a development plan spanning from 2013 to 2017 (“National Development Plan”; NDP 2013-2017) formulated by the Government of Angola, the country seeks to achieve sustainable economic growth by diversifying its industries and reducing its excessive dependence on oil revenues.

NDP 2013-2017 designates the power sector as one of seven important sectors in Angola. Though power infrastructure destroyed during the civil war is rapidly being restored, progress is impeded by the following problems: a low electricity rate of about 5 kW/kWh versus a supply cost of about 40 kWh/kWh; a vulnerable power system dependent on hydropower generation with seasonal fluctuation (caused by drought), a system accounting for about 60% of total electricity generation; a low electrification rate of about 30% nationwide on average; transmission and distribution loss of 55% or higher (technical losses: 15%; non-technical losses 40%); and a low fee collection rate due to a lack of electric meters installed.

The Ministry of Energy and Water Affairs (hereinafter MINEA), the responsible policymaking body for the power sector, has formulated a “National Power Security Strategy and Policy” (NESSP 2011) and assigned top priority to formulating frameworks and policies for power sector reform, introducing PPP, and promoting power development (including gas-combined cycle power plant, hydropower plant), grid development, and renewable energy development. In order to realize these reforms, MINEA has formulated an “Electricity Sector Transformation Program” (PTSE) that clarifies the actions to be tackled in four phases from 2010 to 2025 step by step. PTSE targets an increase in the electricity access rate from 30% to 60% and the development of power facility capacity from 2,120 MW to 8,742 MW by 2025.

In order to promote PTSE, MINEA plays a role in encompassing the individual plans made by each public company, namely, the National Electricity Transportation Company (hereinafter “RNT”), Public Electricity Production Company (hereinafter “PRODEL”), and National Electricity Distribution Company (hereinafter “ENDE”), into a series of power development master plans. MINEA, however, has never formulated a comprehensive power development master plan based on highly accurate demand forecasts or Long Run Marginal Cost (LRMC) forecasts factoring in various conditions such as long-term production facilities. For stable power supply in Angola, it will be necessary to develop a power supply and grid system in line with power development master plans based on statistical data and scientific analysis. The formulation of such a master plan is an urgent issue.

Under these circumstances, the Angolan side asked the Japanese side to cooperate in the formulation of a long-term power development master plan up to the year 2040, in the expectation of benefiting from Japan's experience, knowledge, and technology in the power sector.

1.2 Purpose of the Survey

1.2.1 Purpose

The purpose of this Survey is to produce a master plan for the generation and transmission development of the whole of Angola up to the year 2040, and thereby contribute to the smooth implementation of power development to enable a stable power supply for the country. The outcomes of this survey are as follows:

- To formulate a comprehensive power development master plan (2018-2040) encompassing nationwide generation development plans and transmission development plans.
- To promote sufficient understanding of the master plan by related organizations (MINEA, RNT, PRODEL, ENDE) and build up the capacity of related organization staffs to formulate and revise power development master plans.

1.2.2 Implementing Organizations of the Partner Country

Competent Authority: The Ministry of Energy and Water Affairs (MINEA)

Department: National Directorate of Electricity Energy (hereinafter “DNEE”)

Implementing Organizations: National Electricity Transportation Company (RNT), Public Electricity Production Company (PRODEL), National Electricity Distribution Company, (ENDE), Instituto Regulador dos Serviços de Electricidade e Água (hereinafter “IRSEA”)

1.3 Activities

(1) Preparations at home and Discussion and Consultation on the Inception Report

- To collect relevant data and information and examine them
- To make the Inception Report
- To discuss and consult on the content of the Inception Report with the Government of Angola and the relevant organizations. And to confirm the demarcation of responsibility among the government, the implementing organization and JICA missions

(2) Review of the current situation in the power sector

- To review the current situation in the power sector (policy and strategy, legal and regulatory framework, power sector structure, and national development plans)
- To review the recent power sector development
- To review the current power demand and supply
- To review cooperation by development partners, including donors, and commercial activity by private sector partners
- To review the Intended Nationally Determined Contributions (INDC) relating to the power sector in Angola

(3) Power demand forecast

- To formulate power demand forecasts toward the year 2040 with sensitivity analysis, including the following:
 - demand forecast at the national level (and regional level if data are available)
 - sector-wise forecasts and impacts by major development projects/plans
 - daily load curves and load profiles

(4) Analysis on primary energy sources for generation development

- To analyze the potential of primary energy sources in Angola such as hydro, renewable, natural gas and oil
- To organize information on the primary energy facilities to be developed to promote generation development

(5) Formulation of a generation development plan based on an optimal power generation mix

- To analyze the current generation facilities
- To analyze the existing power development projects
- To formulate a long-term optimal generation development plan toward the year 2040 with sensitivity analysis, including the following:
 - ✓ To analyze the generation planning database, including latest technical and cost data
 - ✓ To prepare several development scenarios such as a base demand case, high demand case, etc.
 - ✓ To conduct sensitivity analysis
 - ✓ To estimate the amounts of GHG (Greenhouse Gas) emission for the respective development scenarios


(6) Study on optimization of the transmission system development plan

- To analyze the existing transmission facilities

- To analyze the latest system development strategies and plans prepared by MINEA, including the following:
 - ✓ To analyze the existing development strategies and projects
 - ✓ To analyze the update cost and technical data for the existing facilities
 - ✓ To analyze the transmission interconnection corridors with neighboring countries such as the Democratic Republic of the Congo (hereinafter “DR Congo”), Namibia, Zambia
- To conduct power flow analysis
- To select appropriate software for power system analysis
- To examine the reduction of transmission loss
- To formulate transmission development plans toward the year 2040
- (7) **Review of the framework and implementation of private investment**
 - To review the policy/strategy, legal and regulatory framework, and procedures for private investment in the power sector
 - To review the current status of private investment and identify bottlenecks
- (8) **Formulation of a long-term investment plan**
 - To undertake an economic and financial analysis of the implementation of the proposed development plans
 - To review and update the existing investment plan up to the year 2025
 - To formulate a long-term investment plan up to the year 2040 integrated with generation development plans and transmission development plans
- (9) **Economic and financial analysis**
 - To analyze the financial aspects of RNT, PRODEL, ENDE, including the present tariff levels, cost structures, and borrowing capacities of RNT, PRODEL, and ENDE
 - To formulate financial strategies
 - To analyze the financial sustainability of RNT, PRODEL, and ENDE
 - To recommend an optimal financial strategy
- (10) **Environmental and social considerations**
 - To analyze the legal and regulatory frameworks for environmental and social considerations
 - To identify the potential impacts associated with environmental and social issues in the updated plan and propose the possible mitigation measures based on Strategic Environmental Assessment (SEA)
- (11) **Drafting the Master Plan**
 - To draft comprehensive master plans toward the year 2040 integrating the above analysis
 - To advise the action plans of MINEA, RNT, PRODEL, ENDE, and IRSEA
- (12) **Capacity building**
 - To conduct technical transfer to MINEA, RNT, PRODEL, ENDE, and IRSEA via workshops and on-the-job training
 - To conduct relevant training in Japan

Chapter 2 Review of the Current Situation in the Power Sector

2.1 Location of Angola



2.2 Country overview


2.2.1 Social situation

Angola occupies an area of 1,246,700 km² (approximately triple the area of Japan) in the Western region of southern Africa with a coastline extending more than 1,600 km along the Atlantic Ocean. The country has land borders to the East with the Democratic Republic of Congo and Republic of Zambia, to the North with the Democratic Republic of the Congo, and to the South with the Republic of Namibia.

Although Angola is located in a tropical zone in the southern hemisphere, a confluence of three factors results in a climate uncharacteristic of the region: the orography in the countryside, the cold Benguela current along the South coast, and the Namib desert to the southeast of the territory.

The climate in Angola essentially contrasts between dry, hot conditions characterized by low precipitation along the coast from May to August and humid conditions characterized by milder temperatures with more abundant rainfall in the interior from October to April.

Angola has a total population of about 25,900,000 living in 18 provinces. Luanda is the most densely occupied province, accounting for 27% of the national population, followed by Huila (10%), Benguela and Huambo (8% each), Cuanza Sul (7%), and Bié and Uíge (6% each). The populations of these seven provinces account for 72% of the total population of the country.



| Provinces of Angola | |
|---------------------|-----------------|
| 1. Bengo | 10. Huíla |
| 2. Benguela | 11. Luanda |
| 3. Bié | 12. Lunda-Norte |
| 4. Cabinda | 13. Lunda-Sul |
| 5. Cuando Cubango | 14. Malange |
| 6. Kwanza-Norte | 15. Moxico |
| 7. Kwanza-Sul | 16. Namibe |
| 8. Cunene | 17. Uíge |
| 9. Huambo | 18. Zaire |

2.2.2 Economic condition

Figure 2-1 and 2-2 respectively show the historical records of Angola's GDP and GDP growth rate.

Angola's long-standing civil war from the independence of 1975 severely exhausted the country. From the end of the civil war in 2002, however, abundant mineral resources such as oil and diamonds helped Angola achieve high economic growth, especially from 2004 to 2008, mainly through the development of export industries of these resources. The country's GDP had reached 103 Billion USD as of 2015.

In recent years, however, declining oil prices have hit the Angolan economy severely. Economic growth has been stagnant and the GDP growth rate dropped to almost zero in 2016.

Figure 2-3 shows the sectoral GDP. As seen, the economy is largely made up of mining industries including that for oil, a factor that leaves the economic structure vulnerable to shifts in prices for international resources such as oil.

Encouraged by Angola's high potential for agriculture and fishery, the government has formulated a national development plan to curb the economic downturn by reducing its reliance on the oil industry while promoting other industries and diversifying their industry structure. The government is promoting the power sector under the development plan and struggling to achieve power sector reforms. Activities to liberalize the power generation sector and power distribution are ongoing.




Figure 2-1 GDP of Angola





Figure 2-2 GDP growth rate of Angola



(Source: African Economic Outlook 2017; AfDB, OECD, UNDP)

Figure 2-3 GDP of Angola by sector


2.3 Review of the current status of the power sector structure

The following chapters will describe the current status of the public companies involved in Angola's power sector. Prior to that, this chapter will outline the overall power sector, including the public power companies.

2.3.1 Electricity Sector Transformation Program (PTSE)

PTSE is a component of the Power Reform Support Program (PSRSP) conducted mainly by JICA and the African Development Bank (AfDB).

A PTSE roadmap on sector reform recommends the following based on a study the PTSE performed on an optimum model for the electricity market: a restructuring of the market into a classic single-buyer model, an unbundling of the power utilities into Generation, Transmission and Distribution core activities, the establishment of commercial contracts



(Sources: The Transformation Program for the Electricity)

Figure 2-4 Restructuring of the Electric Sector

among market participants, and amendments to the laws to improve the regulations and attract PPP. The study further proposed four (4) reform phases, each with specific deliverables:

- (i) Preparation Phase (2010-2013) for the design of a new market structure;
- (ii) Phase I (2014- 2017), a stabilization phase following the sector restructuring and unbundling of the power utilities;
- (iii) Phase II (2018-2021), transition to efficient operation with limited use of IPPs, mainly in RE using RE Feed-In tariffs;
- (iv) Phase III (2021-2025), partial liberalization of the power market with the introduction of the PPP and IPPs and limited concessions for the distribution system.

The transmission system, a natural monopoly, will remain a public sector entity. To improve rural access to electricity services and efficiency, the distribution system will be further unbundled into a total of 18 business units in 5 geographic regions.

2.3.2 Power sector organization after sector reform

(1) MINEA

Figure 2-5 shows the organization chart of MINEA, the administrative agency handling Angola's electric power business. MINEA basically consists of four divisions: National Directorate of Water (DNA), National Directorate of Electric Energy (DNEE), National Directorate of Renewable Energies (DNER), and National Directorate of Rural and Local Electrification (DNERL). According to an interview with MINEA, its members also include the Gabinete de Abinete de Aproveitamento do Médio Kwanza (GAMEK), Gabinete Para a Administração da Bacia Hidroelétrica do Cunene (GABHIC), and Instituto Regulador dos Serviços de e de Água (IRSEA).


MINEA is charged with the tasks of proposing, formulating, managing, executing, and controlling the Government's policy in the areas of energy, water, and sanitation. Amongst its responsibilities, the Ministry must propose and promote the execution of the following Energy and Water policies: establish clear strategies to exploit all energy resources in reasonable ways that ensure their sustainable development; plan and promote the national policy on electrification; foster research in its domains; create the necessary legislation to rule the sector's activities, etc.

DNEE occupies an important position among MINEA's organizations as the department in charge of electricity policy. DNEE is a planning department that summarizes the electric power development plan submitted by the planning departments of ENDE, RNT, and PRODEL every year, examines the plan, and prepares a budget proposal based on it.

GAMEK, a putative division of MINEA, is responsible for the planning of large projects related to power supply and power transmission up to the start of their operations. Once the power generation facilities and transmission facilities are commissioned, they are respectively transferred to PRODEL and RNT and operated and maintained by the two public companies.

While DNEE indicates that the public companies prepare the development plans up to the point of completion, GAMEK is the organization that actually carries out the large development projects. As the definitions for large-scale projects are themselves unclear, it can be difficult for third parties to discern which departments conduct the power development plans at their own initiative.

Apart from GAMEK, GABHIC, the organization in charge of hydropower plant development of the Cunene River in the south, also exists as an MINEA member.



(Source: Survey Team)


Figure 2-5 MINEA's Organization Chart

(2) IRSEA

IRSEA was created by Presidential decree nº 4/2002 on the 12th of March. One of IRSEA's responsibilities is to establish rules for the functioning of the electric sector through regulations such as the following: Tariff Regulation, Access to Network and Interconnections Regulation, Quality of Service Regulation, Commercial Relationship Regulation, and Dispatching Regulation. The main objectives of IRSEA's mission are to guarantee energy supply, protect consumers, promote conditions favorable to the economic and financial balance of the public companies managing the electric system, foster competition, and ensure a non-discriminatory commercial environment. IRSEA functions as an advisor to MINEA on all matters related to the energy industry. All of the sector's public companies are subject to its regulations.

(3) RNT

RNT is a new public company charged with managing and planning the transmission network for the whole country, integrating all of the Very-High-Voltage Transmission assets of the former ENE. Figure 2-6 shows the organization chart of RNT as of July 2017.




(Source: Survey Team)

Figure 2-6 RNT organization chart

The diagram in Figure 2-7 outlines the transmission system of the RNT as of July 2017. The power grid consists of transmission facilities of 400 kV, 220 kV, 150 kV, 132 kV, 110 kV, and 60 kV.

The Angolan power grid is divided into three parts, namely, the northern grid, the central grid, and the southern grid. Among them, the northern grid supplies electricity to Bengo, Malanje, Cuanza Norte, Cuanza Sul, Uige, etc. centered on the capital city Luanda, a major demand area. This grid covers 80% of Angola's power supply utilizing large hydropower plants such as Capanda HPP and Cambambe HPP.

The construction work for interconnection between Alto Chingo of the northern grid and Nova Biopio-Quileva of the central grid was completed as of July 2017, effectively uniting the facility bases of the northern and central grids. The transmission system between Alto Chingo and Nova Biopio-Quileva has yet to be activated, however, as the Cambambe-Gabela line transmitting electricity from the northern hydropower plants to Alto Chingo is aging and functionally impaired. Cambambe-Gabela, a new 220 kV line, is currently under construction toward a planned commissioning in 2017. The northern-central system will be substantially united when this new line is completed.




(Source: PNT)

Figure 2-7 RNT grid map (as of July 2017)

(4) PRODEL

PRODEL, the Public Company for Electricity Production, is a new entity responsible for operating and maintaining the generation facilities belonging to the state. PRODEL integrates Capanda Hydropower plant, a facility previously under the responsibility of GAMEK, and the generation assets of ENE, the former National Company of Electricity.

The PRODEL organization chart is shown in Figure 2-8.



(Source: Survey Team)

Figure 2-8 PRODEL organization chart

According to interviews with the public power companies, the installed capacity of the power plants in Angola as of June 2017 is as shown in Table 2-1. The total capacity of all plants combined is 3,055 MW, of which 2,560 MW is on grid. The public companies also indicate, however, that many of the thermal power plants are aging and some of them are suspending or reducing their outputs. Hence, the total plant output is surely smaller than the total nominal installed capacity.

By type of power source, hydropower plants and thermal power plants account for 56% and 42% of the installed capacity, respectively.

All of the thermal power plants are internal combustion engine power plants or GTs. Most of the fuel is diesel oil, and jet fuel is also used in part. On the other hand, large HPPs such as Capanda, Cambambe, and Cambambe-2 account for about 90% of the installed hydropower capacity.

Table 2-1 Installed capacity of power plants in Angola (as of the end of June 2017)


| Type | On grid (MW) | Off grid (MW) | Total (MW) | Composition (%) |
|--------------|-----------------|---------------|-----------------|-----------------|
| Hydropower | 1,671.00 | 36.40 | 1,707.40 | 55.9% |
| Thermal | 839.30 | 457.40 | 1,296.70 | 42.4% |
| Biomass | 50.00 | 0.00 | 50.00 | 1.6% |
| Mini hydro | 0.00 | 0.94 | 0.94 | 0.0% |
| Total | 2,560.30 | 494.74 | 3,055.04 | 100.0% |

(Source: Created by the Survey Team based on interviews with the public companies)

(5) ENDE

ENDE, the National Company for Electricity Distribution, is a new public company responsible for distributing electricity. ENDE integrates all of the activities and assets of the former EDEL and distributes the assets of the former ENE.

Figure 2-9 and Table 2-2 show the ENDE organization chart and a profile of the company, respectively.



(Source: Survey Team)

Figure 2-9 ENDE organization chart

Table2-2 ENDE company profile

| | |
|------------------------------|--|
| Number of employees | 4,652 (as of July 2017) |
| Number of contracts | 1,297,609 (as of July 2017) |
| Peak demand | 1,252 MW (in December 2016) |
| Supplying Electricity | 9,348 GWh (in 2016) |
| Electricity sales | 49,495 Million Kz (in 2016, including commercial losses) |


(Source: ENDE RELATÓ DE BALANÇO DAS ACTIVIDADES)

2.4 Review of the current power demand and supply

2.4.1 Demand status

(1) Energy consumption


Energy consumption rose at an annual average growth rate of 15.5% between 2008 and 2014. As a result, Angolan energy consumption attributed to production reached an estimated 9.48 TWh in 2014, when disregarding suppressed demand and self-generation in the calculation.



(Source: Long-Term Vision for the Angolan Power Sector: Angola Energia 2025)

Figure 2-10 Consumption energy

Energy consumption in Angola is mostly urban and residential. The residential sector demand accounts for an estimated 45% of total generation, followed by services (ca. 32%) and industry (ca. 9%).



*As perdas comerciais foram distribuídas pelos diferentes segmentos.

*Commercial losses were allocated to different segments.

(Source: Long-Term Vision for the Angolan Power Sector: Angola Energia 2025)


Figure 2-11 Consumption energy by sector and system

(2) Max. power demand

Figure 2-12 shows a record of the maximum power demand by month, where ◇ indicates the potential demand taking into account load shedding, ● indicates the demand for which power was actually supplied, and × indicates the supply deficit

The annual growth rate of the potential demand in the past two years was about 6% and that of the actual demand was about 12%.

As the potential demand has been steadily growing, the power supply capacity has been strengthened from 2016 to 2017. And shortages in supply are being resolved, so the actual demand growth has increased substantially.



(Source: Created by the Survey Team based on data provided by RNT)

Figure 2-12 Power demand in Angola

2.4.2 Power supply status

As mentioned earlier, the total installed capacity on grid is 2,560.30 MW as of June 2017.

However, the remaining shortage in the power supply (shown in Figure 2-12) leads to suspensions and reductions in output stemming from the aging of the power plants. At the same time, the power output of the hydropower plants is presumed to be decreasing due to shortages of river water.

Nonetheless, the commissioning of new power plants has been ongoing from 2016 to 2017 and the power supply is being steadily strengthened.

Table2-3 Power plants commissioned in 2016 & 2017

| Plant Name | Type | Installed Cap. (MW) | Commissioning Date |
|----------------------------------|------------|------------------------|-----------------------|
| Cambambe 2 | Hydropower | 700 | 2016 |
| Lauca unit 1 | Hydropower | 340 | Jul 21, 2017 |
| Soyo CCGT (partially) | CCGT | 125 | Aug, 2017 |

2.5 Review of cooperation by donors and activities by the private sector

2.5.1 Cooperation by donors

(1) African Development Bank

The donor most actively engaged in power sector activities in Angola is the African Development Bank. The bank also played a leading role in the power sector reform implemented in 2014.

The bank is currently focusing on technical assistance related to the power distribution sector and promoting the implementation of the following four FS.

- ✓ Fixed Asset Register Project
- ✓ Technical Loss Reduction Program
- ✓ Non-technical Loss Reduction Program
- ✓ Transmission Lines Program

(2) US Embassy

Under the direction of the Bureau of Energy Resources in the US Department of State, the US government is implementing technical assistance mainly for RNT from 2016 to 2017. The assistance focuses on the formulation of an interconnected transmission line plan encompassing the northern, central and southern grids, which as of now have yet to be interconnected.

Other than that, the US government is advancing a GT introduction program to establish emergency power supplies mainly in the central and south power system.

2.5.2 Activity by the private sector

(1) IPP

As mentioned earlier, the Angolan government announced that full-fledged IPP entry and the introduction of PPP will be implemented after 2021. IPPs operating small-scale diesel power plants as off-grid power plants are in place even now, but they are limited in number.

(2) PPP

The Angolan PPP law of 02/2011 was published on the 14th of March with the goal of attracting private sector investment in Angola. The law seeks to achieve its goal by defining general rules for the overall operation of public-private partnerships from the initial stages to adjudication and subsequent follow-up of the implemented projects.

The PPP law was to have been complemented by a set of regulations to make it function properly. This never came to be, however, and the law has never been effectively applied to this date. With the new General Electricity Act and Private Participation in the Electric Sector Program coming into action, it will be important for Angola to have all of the necessary mechanisms to successfully implement PPPs.

(3) Others

Currently, the major private activities in Angola are engineering, procurement, and construction (EPC). Following are several examples:

- ✓ Cambambe HPP : Odebrecht, Alstom, Voith, Semence
- ✓ LaucaHPP : Odebrecht
- ✓ Laúca-Huambo transmission line : CMEC (China Machinery Engineering Corporation)
- ✓ Soyo : CMEC (China Machinery Engineering Corporation), GE
- ✓ Soyo 2 lotto : AE energy, GE

As a Japanese participant, Sumitomo Corporation has signed an MOU with the Angolan government to build a diesel power plant utilizing diesel generators produced by a Japanese manufacturer.

2.6 Review of the Intended Nationally Determined Contributions (INDCs) relating to the power sector in Angola

A draft of Angola's Intended Nationally Determined Contribution (INDC) was published in December 2015. The contents can be outlined as follows:

(1) Reduction target

Angola plans to reduce GHG emissions by up to 35% unconditionally by 2030 as compared to the Business As Usual (BAU) scenario (base year 2005). And in a conditional mitigation scenario, the country is expected to be capable of reducing emissions by an additional 15% below the BAU emission levels by 2030. In achieving its unconditional and conditional targets, Angola expects to reduce its emissions trajectory by nearly 50% below the BAU scenario by 2030 at an overall cost of over 14.7billion USD.

In light of Angola's extreme vulnerability to Climate Change impacts in key economic sectors, the Angolan INDC also includes priority adaptation actions that will enable a strengthening of the resilience of the country towards the attainment of the Long-Term Strategy for the Development of Angola (2025).


(2) Base year period and baseline data

The year 2005 is used as the reference year.

Figure 2-13 shows GHG emissions by sector in Angola for the year 2005. According to this, GHG emissions from the fuel combustion of the energy sector accounted for the majority of the total (occupancy rate: 59%).

The next largest contributors were emissions from agriculture, from change in land-use, and from forestry sectors.

The figure also shows the emission amount in the energy sector. The contribution of fugitive emissions in the energy sector is very high, accounting for 85% of the total.



(source : DRAFT INDC of the Republic of Angola)


Figure 2-13 Baseline structure (2005) of GHG emissions in Angola by sector and emissions in the energy sector

(3) Reference scenario without mitigation policies

Therefore, the country is committed to stabilizing its emissions by reducing GHG emissions by up to 50% below the BAU emission levels by 2030 through unconditional and conditional actions targeting the following sectors:

- ✓ Power generation from renewable sources
- ✓ Reforestation.

Projection of GHG emissions in 2030



| | 2005 | 2020 | 2030 |
|--|--------|---------|-------------------|
| Emissions-BAU scenario (ktCO ₂ e) | | | 193,250 |
| Emissions-Unconditional scenario (ktCO ₂ e) | 66,812 | 125,778 | 125,612 (-35%) |
| Emissions-Conditional scenario (ktCO ₂ e) | | | 96,625 (-50%) |

(source : DRAFT INDC of the Republic of Angola)

Figure 2-14 Baseline scenario and projections of unconditional and conditional mitigation scenarios in Angola

(4) Outline of mitigation

An unconditional countermeasure is an ongoing project in which funding has been fully identified. The following three projects are specified as efforts in the power sector.

- Repowering of Cambambe I Hydroelectric Power Plant
- Cambambe Hydroelectric Second Power Plant
- Tombwa Wind Farm

A conditional countermeasure is a project that will be implemented after its performance is analyzed. MINEA has summarized the list of potential countermeasure project candidates in the power sector. The outline is as follows

- 681 MW for wind energy projects,
- 438 MW for solar energy projects
- 640 MW for biomass projects, and
- 6,732 MW hydroelectric projects

2.7 Some issues faced by the Angola power sector

Based on the review of the current status, the Survey Team will point out a number of issues facing the Angolan power sector.

2.7.1 Issues in term of the organization

(1) Entity in charge of the generation development plan

As plans stand, MINEA is to proceed with the power development plan in the following stages:

- ✓ First, ENDE implements the power demand assumption.
- ✓ Based on that, PRODEL formulates a generation development plan.
- ✓ Based on the above assumption and plan, the RNT formulates a transmission development plan.
- ✓ DNEE summarizes the foregoing plans in a draft budget plan for the country.

It seems, however, that PRODEL, the company responsible for the generation development plan, does not share this recognition. PRODEL's view of the process may stem from GAMEK's role as the organization actually in charge of large-scale power development and PRODEL's inability to actually become a responsible company.

After the Survey Team formulates the power development master plan in this work, the Angolan entities need to roll up the plan every year.

Hence, the technology for formulating the master plan in this study will also be transferred. This is a major problem with the organization, as it remains unclear whether the technology should be transferred to GAMEK or PRODEL.

(2) Insufficient accumulation of data

As the state-run power utilities were integrated and horizontally separated into three (3) public power companies only fairly recently, in 2015, none of them have accumulated or integrated extensive data as of this year, 2017.

While the data predating the reorganization has been handed over to the three public companies, much of the data was found to be inconsistent at the stage of compiling.

In the future, the Survey Team strongly recommends that MINEA and the headquarters of each public company clearly decide data collection policies and concentrate the following data mainly in their headquarters.

- ✓ Nationwide hourly demand data
- ✓ Operational records for all power plants
- ✓ Hydraulic data (river flow data, reservoir operation data, discharge data, etc.)
- ✓ Fuel usage records, etc.

2.7.2 Issues related to electric power system

(1) Excessive introduction of diesel & GT generators

Many diesel and GT generators are introduced in the Angolan power system, mainly in local substations. Ostensibly they have been installed to stabilize the system voltage at peak demand times, but they seem to be mainly operated to compensate for supply shortages. They tend to be operated in a high load factor as a result.

As described later, diesel or GT generation has economic merit if the power is generated in a low load factor. The operation of plants of these types for such long periods is likely to result in high generation costs.

(2) Dispatching center

The dispatching center office of Angolan power system is attached to the Camama substation. Currently, this office might have failed to make detailed dispatch for the power plants because the

power output of each power station cannot be monitored. For that reason, it is particularly problematic that dispatching the peak power plants for peak demand have not been made smoothly. In order to improve the reliability of the electric power system in the future, it is necessary to change the operating policy of power system and to innovate on facilities in the dispatching systems.

(3) Toll collection system

It is said that the current transmission and distribution loss of Angola is about 55% and the technical loss is presumed to be about 15%. That is, about 40% is non-technical loss. According to AfDB the vast majority of nontechnical losses are nonpayment of fees. It seems that the collecting rate of condominium, multi-tenant buildings is low in particular. In the future, measures to introduce prepaid cards system such as South Africa will be promoted.

2.7.3 Issues in terms of power policy

(1) Barriers to private entry

As mentioned above, PTSE is to promote private entry into the power sector from 2021, but detailed supplementary provisions are not planned. For that reason, IPP entrants are currently negotiating with the government individually, and seem to be developing according to the judgment of government respondents. Preparation for an early legal system is needed for the first year of entry into the private sector in 2021.

Chapter 3 Primary Energy Analysis for Power Development

3.1 General energy condition in Angola

3.1.1 Primary energy flow analysis

Angola is the second largest oil-producing country in Africa, after Nigeria. The confirmed crude oil reserves of Angola total 12.7 billion barrels (2014, BP statistics) and the production volume totals 177.2 million barrels/day (2015, JOGMEC). The confirmed natural gas reserve totals 9.7 trillion cubic feet (2014, Cedigaz) and commercial production totals 29.7 billion cubic feet (2014, OECD / IEA).

Figure 3-1 shows most of the primary energy flow. Most of the oil produced in the country is exported. Most of the natural gas produced (oil-associated natural gas), meanwhile, is reintroduced into oil fields or incinerated, as the country lacks liquefaction plants and equipment for transporting natural gas. As such, only a small amount of the natural gas is effectively used.

As the flow shows, none of the benefits of oil and natural gas reach the general public.





Figure 3-1 Primary energy flow in Angola

(1) Consumption of oil products

Figure 3-2 shows the transition in the consumption of oil products in Angola. Consumption has rapidly increased since 2003 after the end of the civil war. The increases in the consumption of middle distillates such as kerosene, jet fuel, and diesel have been especially rapid. This supports the assumption that fuel consumption is increasing in transportation and commerce.




(Source : IEA)

Figure 3-2 Consumption of oil products in Angola (consumption includes international bunker)

(2) Production of oil products

Figure 3-3 shows the transition in the production of oil products in Angola. The most abundantly produced oil product is clearly crude oil.

Crude oil production dropped to its lowest level in 2011. Then, it climbed back up to about 89 million tonnes in 2015.




(Source : IEA)

Figure 3-3 Oil production in Angola

(3) Import of oil products


Figure 3-4 and 3-5 respectively show the transitions in the amounts of oil products imported and exported to and from Angola. Domestically produced crude oil makes up the most of the exports, leaving very little left over to send to Angola’s domestic refineries.

On the other hand, diesel oil and gasoline make up more than 90% of the imports, and their import levels are increasing. These figures show the Angolan “distortion” wherein Angola, the leading oil producer of Africa, imports secondary oil products.



(Source : IEA)

Figure 3-4 Exported oil production from Angola




(Source : IEA)

Figure 3-5 Imported oil production into Angola

(4) Refined oil products

Figure 3-6 shows the transition in the amount of refined oil produced at domestic refineries. The amount is gradually increasing, but a failure of the domestic refineries in keeping up with domestic consumption has led to an increase in oil product imports.




(Source : IEA)

Figure 3-6 Refined oil production in Angola

(5) Converted oil products for power generation in Angola

Figure 3-7 shows the transition in converted oil products for power generation in Angola. The conversion amount is dramatically increasing and the oil product used for fuel is shifting from heavy oil to lighter oil.



(Source : IEA)


Figure 3-7 Converted oil products for power production in Angola

3.2 The potential of primary energy

For the analysis of the potential of primary energy in Angola, we confirmed the potentials of large hydro, oil, natural gas, and renewable energy.

3.2.1 Large hydropower

Angola has one of the highest potentials for hydropower among the countries of Africa. According to the Atlas and National Strategy for New Renewable Energies, the potential for hydropower is 18 GW, 86% of which is made up by the Kwanza River, Cunene River, Catumbela River, and Queve River Basin. Figure 3-8 shows the hydropower potential throughout Angola.



(Source : Atlas and National Strategy for the New Renewable Energies)


Figure 3-8 Hydropower potential throughout Angola

Table 3-1 lists Angola's new large hydropower plants, and Figure 3-9 shows the locations of existing/planned hydroelectric power plants in Energia 2025. According to our team's interview survey, however, the planned projects on the list have been reviewed by MINEA and GAMEK. The latest information is shown in Chapter 6.

Table 3-1 List of new large hydropower plants

| No. | Name | River Name | Capacity | Energy | Project Cost |
|-----|-------------------|------------|----------|------------|--------------|
| | | | [MW] | [GWh/year] | Mil \$ |
| 1 | Carianga | CUANZA | 381 | 1557 | 1295 |
| 2 | Bembeze | CUANZA | 260 | 1075 | 768 |
| 3 | Zenzo 1 | CUANZA | 460 | 2680 | 1206 |
| 4 | Zenzo 2 | CUANZA | 114 | 695 | 623 |
| 5 | TÚMULO DO CAÇADOR | CUANZA | 453 | 2759 | 1041 |
| 6 | QUISSONDE | CUANZA | 121 | 773 | 838 |
| 7 | Salamba | CUANZA | 48 | 194 | 324 |
| 8 | QUISSUCA | LONGA | 121 | 589 | 567 |
| 9 | Cuteca | LONGA | 203 | 873 | 734 |
| 10 | CAFULA | QUEVE | 403 | 1919 | 1121 |
| 11 | UTIUNDUMBO | QUEVE | 169 | 743 | 406 |
| 12 | DALA | QUEVE | 360 | 1686 | 1010 |
| 13 | CAPUNDA | QUEVE | 283 | 1200 | 741 |
| 14 | BALALUNGA | QUEVE | 217 | 1013 | 475 |
| 15 | MUCUNDI | CUBANGO | 74 | 368 | 538 |
| 16 | CAPITONGO | CATUMBELA | 41 | 249 | 239 |
| 17 | CALENGUE | CATUMBELA | 190 | 1136 | 471 |
| 18 | CALINDO | CATUMBELA | 58 | 340 | 187 |

(Source : Energia 2025)




(Source : Angola Energia 2025)

Figure 3-9 Locations of existing/planned hydroelectric power plants

3.2.2 Oil


Oil resources in Angola are managed by the state-owned company Sonangol, and development is undertaken jointly with international oil companies (BP, Chevron, ENI, ExxonMobil, Petrobras, Statoil, Total, etc.). The Confirmed crude oil reserves in Angola total 12.7 billion barrels (BP statistics at the end of 2014) and production (January-November 2015 average) comes to 17,720,000 barrels/day (JOGMEC). The regions of oil production and development are located mainly in coastal areas from the northern to central part of the country, and only partially on land. Specific points include the coastal state of Cabinda and Zaire province.

Figure 3-10 plots the crude oil production results in Angola. The diagram in Figure 3-11 gives an overview of oil development in the country.



(Source : Sonangol Annual Report : 2012 - 2016)

Figure 3-10 Crude oil production results in Angola (2012~2016)



(Source : Sonangol web page)

Figure 3-11 Oil development in Angola

3.2.3 Natural gas


Confirmed natural gas reserves in Angola total 9.7 trillion cubic feet (2014, Cedigaz) and the commercial production volume comes to 29.7 billion cubic feet (2014, OECD / IEA). Most of the natural gas produced is accompanying gas produced through oil drilling and is treated as backfill or flare and left unused due to the high cost of use.

In recent years, however, the demand for natural gas has been increasing worldwide due to the lower greenhouse gas emissions of natural gas products compared to oil products and technological advances enabling more stable transportation of natural gas. The effective use of natural gas has been considered in Angola.

The state-owned company Sonangol E.P. manages natural gas production in Angola and is constructing a pipeline to transport accompanying natural gas generated from oil production facilities to the natural gas plant. As of 2017, existing pipeline connects Blocks 15, 17, and 18 and new pipelines connecting Blocks 0 and 14 are under construction. According to Angola LNG, the natural gas plant is designed to produce up to 1.1 billion ft³/day or 5.2 million tons/year.

Angola has a plan to use natural gas as fuel for gas-fired thermal plants such as Soyo 1 CCGT (under construction as of 2017) and Soyo 2 CCGT (planned). Soyo 1 started operating in Unit 1 in July 2017 using diesel oil in a simple cycle. It will switch to gas generation once it is connected with the LNG plant in Soyo port Terminal via pipeline,

Figure 3-12 shows the amounts of natural gas produced in Angola.



(Source : Sonangol Annual Report 2012 - 2016)

Figure 3-12 Amounts of natural gas produced in Angola

3.2.4 Renewable energy

Figure 3-13 shows the total capacity of projects considered for each form of renewable energy (RE). As of 2017, high costs have curtailed any efforts to install RE plants. The total potential for RE,

however, is about 20.0 GW. The Angolan government has set concrete targets for renewable energy installs by 2025 and selected a priority project in Angola Energia 2025.

The details on each form of RE are summarized in (1) to (4).




(Source : Atlas and National Strategy for New Renewable Energies, 2015)

Figure 3-13 The total capacity of projects considered for each RE

(1) Small and middle hydropower

Figure 3-14 shows the potential diagram of medium- and small-sized hydropower generation.

According to the Atlas and National Strategy for New Renewable Energies, the potential of small-middle size hydropower plat projects totals 600 MW and the currently installed capacity totals 60 MW. Future plans on Angola Energia 2025 call for the installation of 30 MW of off-grid small hydropower plants, 70 MW of on-grid small hydropower plants, and 270 MW of medium-sized hydropower plants, in total, by 2025.




(Source : Angola Energia 2025)

Figure 3-14 the medium-small hydropower potential diagram in Angola

(2) Solar energy

The diagram in Figure 3-15 gives an overview of the RE potential in Angola. According to the Atlas and National Strategy for New Renewable Energies, Angola has a high solar resource potential, with an annual average global horizontal radiation ranging between 1.350 and 2.070 kWh/m²/year and photovoltaic power (PV) potential totaling 17.3 GW, with PV projects already under study. PV constitutes the largest and most uniformly distributed renewable resource of the country.

When considering the installation of PV generation as an alternative to diesel power generation, however, the need to install batteries has pushed up costs to levels prohibitive enough to postpone installation. In the eastern (Huambo, Kuito, etc.) and southern regions, meanwhile, the installation of medium- and large-scale PV generation facilities has clear cost advantages over diesel power generation. The PV installation target is 100 MW by 2025.




(Source : Angola Energia 2025)

Figure 3-15 Solar energy potential in Angola

(3) Wind energy

Figure 3-15 shows the Wind Energy potential diagram in Angola. According to Angola Energia 2025, locations with high potential for wind energy can be found at higher altitudes along a North-South axis of the country and in the southwest region, where the wind reaches high average speeds exceeding 6 meters per second at 80 meters above ground level. The wind resource in the rest of the country ranges between 3.5 and 5.5 meters per second, offering limited potential for electricity generation at competitive costs.

The 12 survey sites have a total capacity of 3.9 GW, and the capacity for wind generation with high economic efficiency at high-priority sites totals 0.6 GW. Looking ahead, plans are in place to introduce 100 MW of wind energy capacity by 2025. There are three main projects: the Tombwa wind project, a project in Cuanza Norte, and a project in Lubango.




(Source : Angola Energia 2025)

Figure 3-16 Wind Energy potential in Angola

(4) Biomass

The diagram in Figure 3-17 gives an overview of the biomass generation potential in Angola. Biomass resources in the country include forest resources and agricultural residues (mainly sugarcane). The sites with the highest potential for these resources are located in the central region (Huambo, Bie, Benguela) and eastern region (Moxico, Luanda-Sul, Luanda - Norte). The total capacity of biomass energy potential in Angola is 4 GW, and the total capacity of studied projects is 1.5 GW.

According to Angola Energia 2025, plans are in place to install 500 MW of biomass power generation capacity by 2025. The main projects mentioned are to generate 300 MW from hydrothermal power (hydrothermal) using existing forest resources, 100 MW from Malange in the Biocom Project using sugarcane production, and 50 MW from the incineration of solid waste discharged from cities represented by Luanda City and Benguela City.



(Source : Angola Energia 2025)

Figure 3-17 Biomass generation potential in Angola

3.2.5 Coal

Coal reserves have not been investigated in Angola and the country has no experience in the use of coal.

Hence, there is no coal-related data as of 2017.


3.3 Condition of energy supply facilities

3.3.1 Liquefied natural gas (LNG) plant

Figure 3-18 shows the actual production of LNG from 2012 to 2016.

Angola LNG, the only LNG plant in Angola, is located in Soyo Province of Zair State.

The plant is connected with an oil production plant and sends the associated gas it produces to a refinery by pipeline. The Angola LNG production facility has a capacity of 34 MSm³ / d.



(Source : Sonangol Annual Report 2012 - 2016)

Figure 3-18 Actual production of LNG from 2012 to 2016

The LNG now produced is primarily exported. The future LNG utilization scenario in Angola Energia 2025 has two components:

- Export the LNG to remote countries by large LNG carriers
- Transport the LNG to Lobito, Namibe, etc. and re-gasify it to produce fuel for a new type of large thermal power plant.

Incidentally, it is unclear whether the plan is commensurate with the cost generated by the regasification after the production of LNG using energy.

3.3.2 Oil refinery plant

Angola currently owns only one oil refining facility in the capital city of Luanda, but the refinery capacity is insufficient for oil production. So that, Angola, therefore relies on imports for more than 80% of its domestically consumption of oil products. To improve this situation, Sonangol has developed plans to build new refinery facility projects located in the central coastal city of Lobito, the State of Soyo in northern Zaire, and the coastal city of Namibe in the south.

Table 3-2 presents information on the existing/planned refinery facilities. The Lobito project was scheduled to start operation in 2018, but construction was halted in August 2016 due to a shortage of funds. The Soyo project, meanwhile, was launched, but the project never proceeded to the actual construction

stage. Construction for the Namibe project was started in July 2017 and is now underway.

On February 2018, Sonangol announced new plans to develop oil refining facilities in central Lobito and northern Cabinda province, along with an expansion plan for the existing Luanda Refinery. Proposals accepted from domestic and foreign companies under these plans are now being evaluated.

Sonangol has reported that it is targeting completion of a Lobito facility with a capacity of 200,000 bpd/day, the same level set in the previous plan, by 2022. Completion of a Cabinda facility with a smaller capacity is targeted for 2020.

In addition, an agreement with Italy's company ENI was already reached towards the end of last year for the execution of an expansion plan for the existing Luanda Refinery. Production will be expanded from the present 57,000 bpd/day to 65,000 bpd/day by 2020 under that plan.

Table 3-2 Information on existing/planned refinery facilities

| Refinery Name | Unit | Luanda | Lobito | Soyo | Namibe | Cabinda |
|-----------------|---------|-------------------|--------------------------|---------|------------|---------|
| Company | | Sonarel | Sonaref →N/A | N/A | Sonaref | N/A |
| Operation Start | year | 1958 →2020 | 2016(stop) →2022 | N/A | N/A | 2020 |
| Cost | USD | N/A | 8 billion →12 billion | N/A | 12 billion | N/A |
| Capacity | bpd/day | 57,000 →65,000 | 200,000 | 110,000 | 400,000 | N/A |

(Source : Sonangol Universo, and released information)

3.4 Price trends for each form of primary energy

In the study of the optimum power plan until 2040, the setting of the fuel cost is an important factor. When setting value from the perspective of a national economy, fuel costs are often based on international prices. Therefore, the team will investigate and consider costs based on prices in the international market.

The study refers to data from World Energy Outlook 2016 (WEO - 2016) published by the International Energy Agency (IEA) and World Bank (WB). Price fluctuations to the present and future forecasts up to 2040 are compared in three scenarios studied by the IEA.

The three scenarios in WEO-2016 are as follows:

- New Policies Scenario
- Current Policies Scenario
- 450 Scenario

In the New Policies Scenario, the country's adopted targets under the Paris Agreement adopted by the 2015 United Nations Climate Change Conference (COP 21), an agreement mandating greenhouse gas reductions by almost all countries, are fully or partially achieved. The use of fossil fuels is suppressed and the installation of renewable energy and other forms of clean energy is promoted.

In the current policy scenario, the Paris Agreement is not implemented or renegotiated, and the use of fossil fuels does not change from the present.

The 450 Scenario is a scenario for a decarbonized society proposed by the IEA's WEO. In this scenario, target of the average temperature is devised as an energy composition that can suppress a temperature rise of 2 °C from the Industrial Revolution era.


3.4.1 Crude oil

Figure 3-19 shows the changes in crude oil prices in the international market since 2000 and the future development in each scenario. The future oil price trend is expected to rise in every case. The current price is \$ 40/Barrel due to the discount from 2012.

However, a strong demand for crude oil in emerging markets is expected to remain in the future in all three scenarios. Crude oil is currently being purchased at low prices from OPEC member countries, but purchases at high prices from non-OPEC countries will increase. Hence, oil prices continue to edge gradually higher and ultimately reach \$ 80/Barrel in 2020 in every case.

In all three scenarios, the price fluctuation after 2020 will continue to rise with the ongoing development of oil resources and a decrease of inexpensive, high quality so-called "sweet spots" necessitating further moves into areas with expensive and low-quality oil.

Conversely, the 450 Scenario foresees lower prices accompanying reduced crude oil demand and price maintenance supported by a stronger push toward a decarbonized society, compared the other scenarios.



※WTI, tax excluded

(Source: IEA World Energy Outlook 2016)

Figure 3-19 Changes in crude oil prices in the international market


3.4.2 Natural gas

Natural gas has no international common price like crude oil, but there is a fixed price for each region, i.e., (1) USA, (2) Europe, (3) China, and (4) Japan. The (1) US price is based on the cost to transport and sell domestically produced products by pipeline, the prices in (2) Europe and (3) China are based on the

cost of importing raw gas in pipelines and processing it into LNG, and the price in (4) Japan is based on the import price for only LNG.

In the case of Angola, natural gas is produced domestically and will be connected to domestic consumption areas by pipeline in the future. The condition is similar in the (1) USA, so we refer to forecast fluctuation in both countries.

Figure 3-20 shows the forecast for price fluctuations of natural gas from 2000 up to 2040. Because the price of natural gas is correlated with the crude oil price, it is expected to rise to around \$ 4/MBtu against strong demand up to 2020, as with crude oil price. In the case of natural gas, however, the demand for LNG will increase worldwide in the future as a cleaner fuel with lower rates of CO₂ emission. Hence, the price of natural gas will continue to rise for both domestic consumption and exports in each scenario.



※US price, tax excluded

(Source: World Bank and IEA World Energy Outlook 2016)

Figure 3-20 Forecasted fluctuation of natural gas prices (2000 - 2040)

3.4.3 Selected fuel price for formulating the “Optimal Generation Mix”

Since Angola is also participating in the Paris Agreement, the team will adopt the New Policies Scenario base value as the fuel cost when considering the optimum power plan. Specific values for each fuel cost will be shown in the section on the power supply development plan.

3.5 Items to Prepare to Promote Power Development

When planning a power supply plan, especially a thermal power development plan, the fuel supply policy is important to consider. More specifically, the thermal power development plan must thoroughly consider the type of fuel to be used, the supplier of the fuel, the method for transporting it, and the equipment necessary for using it.

In this section we analyze and examine the options for thermal power plants in the optimum generation mix plan, the fuel(s) to be used in the plants, and the kinds of fuel supply facilities needed.

3.5.1 Options for Power Supply

In Chapter 6 we study power supply development plans in detail. As a result of examination, the following have been selected as available power supply options.

- Large hydropower plant
- CCGT
- GT
- Renewable energy power (small hydropower plant, wind power, solar power, biomass, etc.)

The thermal power options in the power supply plan in Angola are CCGT and GT.

3.5.2 Options for Fuel, and Fuel Characteristics

Natural gas, LNG, LPG and diesel oil are the assumed options for fuel. The characteristics of each fuel are summarized in Table 3-3.

Table 3-3 Fuel Characteristics

| Fuel | Characteristics | 2015 Price |
|--------------------|---|-------------------------|
| Natural Gas | <ul style="list-style-type: none"> ➤ In Angola, natural gas is produced as an associated gas from oil fields. ➤ Unless transportation costs are considered, the price per unit calorie is the cheapest. Therefore, application to mine-mouth power plants is economically advantageous. ➤ Gas supply facilities such as gas pipelines are necessary when locating power plants near demand areas. The cost for these facilities will increase the cost of electricity generation overall. ➤ The CO₂ emission factor of natural gas is about 20% lower than that of LPG. Hence, the use of natural gas is advantageous when considering CO₂ emissions. | Approx. 1 cent/Mcal |
| LNG | <ul style="list-style-type: none"> ➤ LNG is liquefied natural gas by cooling. Angola has an LNG plant in Soyo. ➤ The price per unit calorie is almost the same as that for LPG. For application to thermal power plants, a large-scale LNG tank will be required near the power plants. The high cost for this type of facility will increase power generation cost overall. | Approx. 4 cents/Mcal |

| | | |
|-------------------|--|-------------------------|
| | <ul style="list-style-type: none"> ➤ The CO₂ emission factor of LNG is about 20% lower than that of LPG. Therefore, the use of LNG is advantageous when considering CO₂ emissions. | |
| LPG | <ul style="list-style-type: none"> ➤ Besides being produced from associated gas in oil and gas fields, it is produced in the crude oil refinery process. ➤ The price per unit calorie is similar to that of LNG. ➤ The fuel supply facilities are minimal, so the supply cost can be low. ➤ The thermal efficiency when applied to CCGT and GT is comparable to that of natural gas or LNG. ➤ The unit of CO₂ emissions is about 20% higher than natural gas and LNG | Approx. 4 cents/Mcal |
| Diesel oil | <ul style="list-style-type: none"> ➤ It may be referred to as light oil in Japan. ➤ The price per unit calorie can be somewhat cheaper than or nearly equal to that of LNG. The thermal efficiency drops, however, so the cost of power generation rises. ➤ The fuel supply facilities are minimal, so the supply cost can be low. ➤ When applied to CCGT and GT, the thermal efficiency drops significantly compared to that of natural gas, LNG, or LPG. ➤ In addition, the CO₂ emission factor is about 40% higher than that of natural gas and LNG. In view of the thermal efficiency during power generation, CO₂ emissions will increase significantly. | Approx. 4 cents/Mcal |

Diesel oil is used in most GT and diesel power plants in Angola. The extensive use of diesel oil is thought to be due to the government's practice of providing diesel oil to power plants free of charge or at low cost. As you can see from the table above, the adoption of diesel oil would be disadvantageous both in terms of CO₂ emissions and the national economy. It will be important to switch to LPG, LNG, and natural gas in the future.

3.5.3 Setting of Thermal Power Generation Planning Scenarios and Selection of Fuel

In this section we will set scenarios for the thermal power development plans and assume which fuels can be used most realistically when the scenarios are realized.

(1) Middle Demand Power Supply

| |
|---|
| <p>< Basic Policy on Power Supply Development></p> <p>Mine-mouth power plants using natural gas are the most economical. => CCGT in Soyo is the most advantageous.</p> |
| <p><Issues></p> <ul style="list-style-type: none"> ➤ A relatively large power supply established in Soyo will be affected by the unilateral power flow from Soyo to Benguela (Soyo => Luanda => Benguela) in the structure of Angola's power system. |

| |
|--|
| <p>This point could partly impede system stability.</p> <ul style="list-style-type: none"> ➤ This point also requires an excessive current flow leading to an increase in power transmission loss. ➤ The line between Soyo and Luanda has a current capacity of 400 kV 2200 MW (N - 1 criteria) and can transmit only to two power plants of the Soyo CCGT (750 MW) class. If we are to build a third power plant, one more transmission line circuit will be required. |
| <p><Other information about Construction Costs: based on investigation in Japan></p> <p>Cost to Construct the Transmission Line: Approx. 1 millUSD/km</p> <p>Cost to Construct the Gas Pipeline: 4 – 13 millUSD</p> <p>Cost to Construct the LNG Tank: 100 – 150 millUSD/unit (Capacity 125,000m3).</p> <p>FSRU (Floating Storage Regasification Unit): 250 – 330 millUSD (Capacity 140,000m3)</p> <p>Cost to Construct the LPG Tank: 10-30 millUSD/unit (Capacity 20,000 m3).</p> |
| <p>< Prerequisites for Making the CCGT Development Scenario></p> <ul style="list-style-type: none"> ➤ Development up to a second CCGT in Soyo is reasonable. ➤ Regarding development beyond a third CCGT, it would be necessary to add transmission lines to the demand areas Luanda and Benguela. The construction cost in that case would be likely to reach at least 300 mill USD/circuit. ➤ Therefore, it will be necessary to compare the power generation near the demand site as well. ➤ In this case we can consider the supply of natural gas by a gas pipeline and supply of LNG after installation of the LNG tank and vaporization facility, etc. ➤ The cost of constructing a gas line pipeline is estimated to be at least 1,000 millUSD. Use devoted solely to power generation would also be burdensome, so joint use with other industries is considered a prerequisite. ➤ Regarding LNG supply, the preparation of two LNG tanks would cost up to 200 to 300 millUSD, which would be relatively inexpensive. ➤ While the FSRU would be more costly than an LNG tank, it would have the advantage of a short installation period. ➤ With the use of LPG, on the other hand, supply facilities would be very inexpensive. This is an option, given that the current LPG price is close to the LNG price. CO₂ emissions, however, would increase by about 20%. |
| <p>< CCGT Development Scenario></p> <ul style="list-style-type: none"> ➤ In Soyo, the development of CCGTs for two power stations takes top priority. Development surpassing three power plants depends on the transmission line extension cost. But in view of system stability, we recommend CCGT construction near the demand site. ➤ Considering the increase in demand, especially in Benguela and the rest of the central area, developing CCGT in Lobito port in Benguela has definite merits. ➤ Furthermore, with the growth of demand in the central and southern parts, it would be meaningful not only to construct a CCGT at Lobito Port additionally, but also to develop a CCGT at Namibe Port in the southern part. If CCGT development in the southern part progresses thus and international interconnection with Namibia is developed, it may be possible to sell power to the SAPP in the future. ➤ Considering the above points, after placing priority on building two 750 MW class power plants in |

| |
|---|
| Soyo, there is a plan to develop the subsequent CCGT at Lobito Port and Namibe Port. |
| <p>< Fuel supply scenario></p> <ul style="list-style-type: none"> ➤ We recommend setting the following fuel supply scenario according to the above CCGT development scenario. ➤ In Soyo, we continue to supply natural gas for the mine-mouth power plants. ➤ For the Lobito CCGT, we are preparing to supply LPG in the first step, and to supply LNG and switch from fuel to LNG in the second step, as soon as LNG supplying facilities are set up. |

(2) Peak Demand Power Supply

| |
|---|
| <p>< Basic Policy on Power Supply Development></p> <p>Mine-mouth power plants using natural gas are the most economical. => CCGT in Soyo is the most advantageous.</p> <p>Better system stability can be expected, however, if the peak demand power supply is located near the demand site.</p> |
| <p><Issues></p> <ul style="list-style-type: none"> ➤ With the installation of GT, the peak demand power supply, in Soyo, in addition to CCGT, the middle-demand power supply, the Angolan power system will generate an extremely unilateral current toward Soyo => Luanda => Benguela. This would be quite disadvantageous for the stability of the system. ➤ The dual installation above would also cause an excessive power flow leading to increased power transmission loss. ➤ The 400 kV line between Soyo and Luanda, however, has a current capacity of 2200 MW (N-1 criteria). If only two 750 MW class CCGTs are developed in Soyo, the margin of the transmission capacity would be about 700 MW. Given the sufficient room available, it would be possible to connect the GT of the output corresponding to the margin. |
| <p>< GT Development Scenario></p> <ul style="list-style-type: none"> ➤ It would be rational from an economic viewpoint to develop GT capacity of about 700 MW as mine-mouth power plants in Soyo. As a prerequisite for development, however, control by a dispatching center to secure system stability would be necessary. ➤ For further development, it will be important to connect to backbone lines near demand areas such as Luanda and Benguela. ➤ Considering the above points, the development of several GTs as mine-mouth power plants in Soyo cannot be ruled out, though the scale of GT plant that can be developed would have to be limited. ➤ As peak demand power supply, it is assumed that many GTs are placed in the main substation near Luanda or Lobito port in Benguela. The GT placed at Lobito port is also thought to be combined into a CCGT, as this would be effective as a countermeasure in the event of rise in the middle demand above the peak demand level due to changes in the load factor, etc. in the near future. |
| <p>< Fuel supply scenario></p> <ul style="list-style-type: none"> ➤ We recommend setting the following fuel supply scenario according to the above GT development scenario. |

- In Soyo, we continue to supply natural gas for the GT.
- Regarding the GTs near the demand sites of Luanda and Benguela, it would be difficult to supply natural gas by gas pipeline. Hence, in both cases we are preparing to supply LPG.
- An LNG relay station will be installed in the future. If it becomes possible to supply vaporized gas in the pipeline from there, we will switch to LNG.

3.5.4 Facilities to Prepare for Power Development Promotion

| | |
|-----------------|---|
| Soyo CCGT, GT | <ul style="list-style-type: none"> ➤ Soyo is located near the existing oil field, and mine-mouth power plants can use natural gas produced from associated gas. ➤ Construction of gas pipeline for the Soyo 1 power plant is already in progress. Operation is scheduled to start in 2018. ➤ It will be necessary to increase the current gas pipeline capacity. ➤ As the study focused beyond the fuel supply facilities themselves, it will be necessary to continue discussing the rationality of upgrading the transmission line to Luanda. It will also be necessary to consider the development of SCADA for power plant control. |
| Lobito CCGT, GT | <ul style="list-style-type: none"> ➤ In the first step, it will be necessary to improve the LPG supply facilities. ➤ It will be necessary to examine whether to import LPG or obtain it from a domestic refinery. When selecting procurement from a domestic refinery, it will be necessary to jointly consider reinforcement of the refinery with the relevant organizations. ➤ In the second step, it will be necessary to develop supply facilities such as LNG tanks. ➤ It will be necessary to establish a supplier portfolio by examining the ratio of domestic LNG and imported LNG to be used. |
| Luanda GT | <ul style="list-style-type: none"> ➤ Basically, assume the use of LPG and improve the LPG supply equipment accordingly. ➤ As a method for transportation to the LPG terminal, improved roads and railroads will also be required. ➤ Regarding the use of LNG, it will be necessary to raise the demand for an LNG relay station, including demand in other industries in the future. |

All of the aforesaid matters relate to the Angolan energy master plan now being formulated, so we will keep track of the details of the plan as they evolve.

Chapter 4 Procedure for Formulating a Power Master Plan based on the Optimal Generation Mix (“The Best Mix”)

4.1 Basic policy for an optimal generation mix

Before explaining the major components of the Power Development Master Plan such as the power demand forecast, generation development plan, and transmission development plan in the following chapters, we would like to confirm the procedure used to formulate the Master Plan in accordance with a policy for formulating a plan to obtain an optimal generation mix (“The Best Mix”).

The policy for an optimal generation mix is the first to formulate an optimal generation development plan from the particular viewpoints of Angola and to establish the most effective transmission development plan based on the generation plan. As a precondition for planning, it goes without saying that a highly accurate power demand forecast must be obtained by analyzing the economic situation and future vision of the country.

What, then, are the "particular viewpoints" of Angola? The most important viewpoint for Angola is economic. For some countries, in contrast, it may be energy security. The prevention of global warming is another viewpoint of rising importance.

The following are important considerations for examining the optimum power plan:

- ✓ Economic matters (reduction of supply cost (generation cost + transmission cost))
- ✓ Supply reliability (annual LOLE, etc.)
- ✓ Energy security (stability of fuel supply, stability of fuel cost)
- ✓ Environmental and social considerations (environmental impact assessment, greenhouse gas emission, etc.)
- ✓ Feasibility (social environment, development lead time, funds, etc.)

4.2 Items to examine

4.2.1 Economic matters

In formulating an optimal power development master plan from the viewpoint of economic efficiency, we will generally consider the following.

- ✓ To study the composition ratio of a power supply with minimized power generation costs, including fixed costs such as capital costs and variable costs such as fuel costs. The study is generally carried out using an analysis method such as a screening method and demand-supply operation simulation software such as PDPAT.
- ✓ Once the optimal generation mix ratio is obtained, a more specific power generation project plan is prepared. The plan also specifies where power plants are to be located on the power grid.
- ✓ Based on the generation development plan, to formulate an additional transmission development plan for transferring electricity from power plants to demand sites as efficiently as possible. The additional plan is also implemented to examine the transmission construction and calculate the transmission costs.

When implementing such a study, it is the generation development plan that most affects the economics of the power plan. And this is the most important point. There are mainly two analysis methods, namely, the screening method and PDPAT.

(1) Screening method

Figure 4-1 shows an example of an analysis result by the screening method.

The screening method is a method to obtain the required supply capacity of each power plant and analyze the optimal generation mix based on the relationship between the annual facility utilization rate and annual generation expenditure, and the annual duration curve reflecting the utilization rate of each power

source at different costs.

The upper figure shows annual expenses of each power supply. The Y intercept of the linear function indicates annual expenditure corresponding to fixed costs. The inclination indicates variable cost, mainly fuel cost. The lower figure shows the annual duration curve. In this example we focus only on hydropower, coal-fired thermal, CCGT, and Oil GT for simplification.

In this case, since hydropower plants can be generated at the lowest cost in the range of a facility utilization rate of 20% or more, the total power generation cost can be reduced by operating the hydropower plants at a high load factor. It is important to generate electricity with priority over other power supplies to cover power demand. In other words, it is important to operate hydropower plants to meet power demand in preference to other power sources.

Next, looking at coal-fired thermal power, we can see that the expenditure becomes cheaper at a utilization rate of 60% or more. To ensure that the load factor is at least 60% in operating the plants, we can improve the economic efficiency by installing the coal-fired thermal plant capacity sufficient to meet the demand of 60% or more of the annual occurrence probability. Incidentally, the demand, the basic part of the duration curve, is called the base demand, and the power supply that covers this is called the base power supply.

We can see, from the projection of the facility utilization rate of the base power supply to the duration curve, that the required installed capacity of the base power supply is about 4,200 MW. If hydropower plants with 2,200 MW capacity can be installed, it would be appropriate to introduce 2000 MW as coal-fired thermal power plants.


Considering the CCGT in the same way, it is economically advantageous to utilize a CCGT with a facility utilization rate of about 20% and 60%, so plants should meet the demand in an occurrence-probability range of between about 20% and 60% (middle demand). In this example, the installation of a CCGT with a capacity of about 1,300 MW is required.

In addition, it is advantageous for the Oil GT to meet the demand within an occurrence-probability range of about 20% or less (peak demand) because it is economically advantageous to use the Oil GT at a utilization rate of about 20% or less. In the example, the installation of plants with a capacity of only about 700 MW is required.

After the required installed capacity of each power source is obtained as described above, the optimal power supply ratio can be calculated based on the results. In the future generation development plan, the required installed capacity of each power supply will be examined with reference to the optimal power supply ratio.

The data necessary for these studies are shown below.

| Item | Required data | Note |
|----------------------------------|---|---|
| For power demand forecast | Duration curve of power demand forecast | Hourly data from 8,760 hours of demand forecast |
| For power supply | Construction cost of each power type (USD/kW) | |
| | Heat efficiency (%) | |
| | Annual expenditure rate (%) | Interest, Depreciation, O&M cost, etc. |
| | Fuel price (USD/kW) | |



(Sources: JICA Survey Team)

Figure 4-1 Example of a screening method**(2) PDPAT**

PDPAT (Power Development Planning Assist Tool) is a supply-and-demand operation simulation software application developed by Tokyo Electric Power Company (TEPCO). Supply-and-demand operation simulation software simulates how power plants should be dispatched to best meet the assumed daily demand.

Figure 4-2 shows an example of an analysis of the power supply situation.

PDPAT simulation analysis can determine how power plants can be dispatched to minimize the total costs of the fuel used by the plants. The analysis outputs the total fuel cost as well as the total annual expenditure of the power plants. Since the cost of the entire power system can be obtained in a given year, the software can examine the optimal generation mix by comparing the annual power generation cost for each development scenario.

As mentioned above, PDPAT analyzes the economics of power generation by simulating the dispatch of power plants in scenarios closer to reality. As such, the following data are required.

| Item | Required data | Note |
|----------------------------------|---|---|
| For power demand forecast | Duration curve of the power demand forecast | Hourly data from 8,760 hours of demand forecast |
| For power supply | Construction cost for each power plant (USD/kW) | |
| | Heat rate curve of each power type | |
| | Annual expenditure rate (%) | Interest, Depreciation, O&M cost, etc. |
| | Fuel price (USD/calorific value or volume) | |
| | Power plant specifications | Maximum output, Minimum output, etc. |
| | Hydropower plant operational data | Monthly power generation, etc. |





Figure 4-2 An example of output from PDPAT

When PDPAT conducts an economic analysis for the optimal generation mix, it obtains the approximate proper power supply ratio by the screening method and lists a power plant construction plan based on the results. PDPAT usually prepares the Best Mix Plan using the listed data.

4.2.2 Supply reliability

Supply reliability is often expressed by LOLP (loss of load probability) and LOLE (loss of load expectation). LOLP is the probability that the supply capacity will be insufficient against the demand within a given period or year. LOLE is the expectation of when the condition will occur. These two variables are basically synonymous.

The probability distribution of LOLP is mainly obtained by synthesizing the following probability distribution.



| Probability distribution | Characteristic |
|--|--|
| Demand distribution | Normal distribution |
| Hydropower output fluctuation by water discharge fluctuation | When the hydropower supply capacity is evaluated by firm output, it is distributed on the plus side. |
| Output fluctuation due to forced power plant outages | Binomial distribution. The values are distributed on the minus side. |

Figure 4-3 Probability distribution synthesized into LOLP

Since LOLE is the expectation of when the supply shortage will occur based on this probability distribution, it can be expressed by the formula shown in Figure 4-4.

Where,

Pi: Probability of supply shortage

Hi: Time at which demand occurs when the supply capacity is insufficient.




Figure 4-4 LOLP

From the experience of the Survey Team, we think it is appropriate to adopt a LOLE of 24 hours per year in emerging countries. That is to say, we aim for a power supply system that allows a total of one day of outage in a year.

Since the required supply capacity cannot be directly obtained from the supply reliability, we employ the concept of reserve margin rate. First, we obtain the relationship between LOLE and the supply reserve margin ratio. After determining the required reserve margin ratio based on the adopted supply reliability, we usually calculate the required total supply capacity from the reserve margin. We then formulate the power development master plan with the required supply capacity.

$$\text{Reserve margin rate} = \frac{\text{Supply Capacity} - \text{Demand}}{\text{Demand}}$$

Figure 4-5 shows the steps taken to create the relationship between LOLE and the reserve margin ratio. The calculated LOLE basically corresponds to the reserve margin, a changing parameter. And by summarizing these data sets, we can then obtain the correlation diagram. As you can see, a large reserve margin is needed to build a power supply system with high supply reliability, i.e., a low LOLE.




Figure 4-5 Relation between LOLE & the reserve margin rate

Since the required supply capacity can be calculated by the following equation, a power plan satisfying this capacity can be formulated.

$$\text{Supply capacity} = (1 + \text{Reserve margin rate}) \times \text{Demand}$$

Figure 4-6 shows an example of a formulated power supply plan. The blue line in this example plots the forecasted power demand. The power supply development plan, meanwhile, must satisfy the required supply capacity plotted by the red line, taking into account the reserve margin. This can be seen in the figure.




Figure 4-6 Required supply capacity and generation development plan (Example)

4.2.3 Energy security

When studying the plan for an optimal generation mix, considerations other than economy may sometimes be necessary. Energy security, for example, is an especially important consideration in countries not blessed with domestic resources, like Japan. The following points may be important to consider.

- ✓ Securing domestic energy
 - Development of domestic mineral resources (fossil fuel)
 - Nuclear power development as long-term usable energy

- Development of hydropower
- Development of solar power, wind power, geothermal power, biomass power, etc.
- ✓ Diversification of fossil fuel types; diversification of suppliers

In any case, many of the foregoing are ultimately decided by political judgments at high levels, so consistency with the national energy policies is important to ensure.

4.2.4 Environmental and social considerations

Environmental and social considerations are also important from viewpoints other than economic efficiency. Apart from the conventional EIA for each project, it has become increasingly important in recent years to evaluate the impact on global warming in each scenario in the overall power development master plan. This is why coal-fired thermal power plants, which are economically superior, are becoming difficult to introduce into master plans. Global environment issues take some degree of precedence.

In addition, many countries regard the use of renewable energies as important mitigations of global warming. The method by which these power supplies are to be incorporated into the power development master plan must be considered.

Consistency with national energy policies and INDC is important to ensure, as many of these problems are decided politically at very high levels.

4.3 Flow for formulating a power development master plan

Figure 4-7 shows a formulation procedure incorporating important items in the plan for an optimal generation mix described in the previous section. The power development master plan of Angola is also carried out according to this procedure.

The transmission development plan is greatly affected by the power generation scenario, especially the type of installed power plant and the location of the power plant in the national grid. Needless to say, optimization of the power transmission equipment must be studied for each scenario.




Figure 4-7 Flow for Formulating a Power Development Master Plan


Chapter 5 Power Demand Forecast

5.1 Power demand forecast in current plan and related data

5.1.1 Current power demand forecast

"Angola Energia 2025" describes officially the electricity demand forecast as shown in Figure 5-1. This power demand forecast is implemented in 2014 and forecasted power demand up to 2025.


Figure 5-2 shows the actual power demand records up to 2016. While the forecast assumed the annual maximum demand growth rate of 15 % from 2013 to 2017, the actual power demand (incl. latent demand) grew at a rate of 7 % - 25 % (an average of 13.3 %) from 2013 to 2016. In the event that the assumed growth rate is nearly equal to the actual rate, however, the prospect of the maximum electric power in 2017 is about 2.3 GW, falling about 0.5 GW below the forecasted value.



(Source: Angola Energia 2025)

Figure 5-1 Current Power Demand Forecast (annual maximum demand)

The mean growth rate of the generated energy before 2012 was about 10 %. Since 2012, the generated energy has increased rapidly at a mean growth rate of about 19 %. The maximum power demand increased by 500 MW (25 %) in the year 2016 alone.



(Source: Prepared by the JICA Survey Team based on the WB Data-base and Data from RNT, ENDE)

Figure 5-2 Actual records of power demand


5.1.2 Forecast of GDP and population growth

(1) Past records and forecast of GDP by IMF

Past records of the GDP (2010 Constant Price, local currency unit) are shown in Figure 5-3, based on WB Data and GDP estimates in the 2017 version from the IMF.

The Angolan economic structure depends on the oil sector. The real GDP in 2013 was 96.3 billion dollars, of which the oil sector accounted for about 40%. From 2010 to 2013, macroeconomic stability was restored and economic growth accelerated. In 2014, however, maintenance and restoration works in several oil fields brought crude oil production down to 1.66 million barrels from 1.8 million barrels the year before. As a result, the real GDP growth rate fell to 4.2% (IMF estimate) from 6.8% in the previous year.

Furthermore, since the crude oil price plummeted from 100 US\$/bbl. in 2014 to 50 US\$/bbl. in 2015, the real GDP growth rate further decelerated to 3.0% in 2015 and 0.0% in 2016. According to estimates in the 2017 version from the IMF, the GDP is expected to grow at a rate of about 1.4% after 2017.



(Source: JICA Study Team prepared based on IMF Prospect)


Figure 5-3 Past records and forecast of real GDP

(2) Population forecast

The total population in Angola is 25.9 million people (2014) according to population statistics from INE (Instituto Nacional de Estatística). Luanda has the highest population density within the country, at 100 heads/km² throughout the province.


Six other provinces have municipal cities with population densities exceeding 100 heads/km²: Uíge and Malanje in the northern region, Cuanza Sul, Benguela, and Huambo in the central region, and Huila in the southern region. None of the provinces in the eastern region have population densities at comparable levels.

The population density by region is shown in Figure 5-5. The population of the north is about 1.6 million, accounting for about half (45%) of the Angolan population.



(Source: Population Statistics 2014 (INE))


Figure 5-4 Population Density Map (2014)



(Source: Prepared by the JICA Survey Team based on population statistics 2014 (INE))

Figure 5-5 Population Density Distribution by Region (2014)

The population forecast (2014-2050) in Angola by INE is shown in Figure 5-6. The population nationwide in 2016 was estimated to be about 27.5 million people and to have grown at a rate of 3%. The total population in 2040 is forecasted to be about 54.3 million people and the growth rate will decrease up to 2.5%.




(Source: Population Projection 2014-2050 (INE))

Figure 5-6 Population Forecast in Angola

(3) Relationship between GDP growth rate and generated energy growth rate

The annual growth rates of the GDP and electricity demand after 2002, when the civil war ended, are shown in Figure 5-7. There is no correlation whatsoever between the annual GDP growth rate and generated energy growth rate. The elasticity (generated energy growth rate / GDP growth rate) varies from -1.0 to 6.0, showing considerably larger variation versus the general elasticity value of 1.0 to 2.0 in other developing countries. As such, it would be inappropriate to assume generated energy demand based on the GDP growth rate.



(Source: Prepared by the JICA Survey Team based on the WB Data-base)

Figure 5-7 Relationship between GDP Growth Rate and Generated Energy Growth Rate

(4) Changes in electrification rate

The changes in the electrification rate in Angola according to the WB data-base are shown in the table below. The development of large-scale generation facilities has not progressed since the civil war and the electrification rate has gradually decreased as the population grows.

The electrification rate is expected to begin to increase after 2016, however, as all units of Cambambe No. 2 (700 MW) were put into operation in 2016 and the transmission line network continues to expand. Angola Energia 2025 stipulates an electrification rate target of 60% by the end of 2025.

Table 5-1 Transition of Electrification Rate

| | 2005 | 2006 | 2007 | 2008 | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 |
|--------------------------|------|------|------|------|------|------|------|------|------|------|
| Electrification Rate (%) | 38.4 | 37.7 | 37.5 | 36.4 | 35.8 | 35.1 | 34.6 | 33.9 | 33.3 | 32.0 |

(Source: WB Data-base)

5.1.3 Relevance and problems of the current power demand forecast

The current demand forecast by MINEA seems to be carried out based on an assumed power demand (supplied power plus load shedding power) calculated by summing up the annual maximum power demand for each economic sector – domestic, industrial, commercial, and others. As will be described later, the statistical data in the economic model (GDP) and electrification plan are also unclear. In particular, since any hourly power demand data including load shedding power (latent demand) have not been organized, it makes difficult to predict the amount of generated energy in every month.

For these reasons, the JICA Survey Team decided to forecast the nationwide maximum power demand up to 2040 by assuming power demand for the domestic sector (electrification plan), the industrial sector, and the commercial sector for each power system (North, Central, South, East) and then summing the values up.


5.2 Power Demand Results and Regional Characteristics

5.2.1 Power Demand Results

(1) Load shedding (Latent power demand)

The supply and demand for electric power in Angola are imbalanced, which has resulted in supply power shortages for many years. Hourly records of load-shedding amounts (latent demand) have not been properly organized. As a consequence, it has only been possible to collect load-shedding data at the monthly maximum electric power in the North system after 2015 and in the Center and South system after 2016 (refer to Figure 5-8). Maximum load shedding of up to 400 MW took place from October 2015 to May 2016, but the level fell below 200 MW in 2017 due to the commissioning of the Cambambe No. 2 plant (700 MW) in 2016.

Load-shedding data for the East systems have not been unorganized and unknown.




(Source: Prepared by the JICA Survey Team based on Data from RNT (NLDC))

**Figure 5-8 Monthly Maximum Demand and Load-shedding Results
(North, Center and South System)**

(2) Changes of monthly maximum demand in the whole country

The nationwide power demand results (incl. latent demand) in recent years are shown in the aforementioned Figure 5-8. The ratios of the monthly maximum power demand (incl. latent demand) to the annual maximum power demand in the North system are shown in Figure 5-9.

The fluctuation in power demand between seasons is relatively large. The annual maximum power demand occurred in December, and the monthly maximum demand fell to about 80% over the four months from June to September in winter.




(Source: Prepared by the JICA Survey Team based on Data from RNT (NLDC))

Figure 5-9 Comparison of Monthly Maximum Demand Results in

(3) Daily load curve results

Regarding the North system, digital data on the hourly power generation results since October 2015, when SCADA was introduced, were collected from RNT (NLDC). The daily load curve for the 3-day highest power demand month by month in 2016 is shown in Figure 5-10.


The daily load curve is an electric light peak type that peaks from 19:00 to 20:00, but it remains nearly flat in all months but December. This is clearly assumed to be due to the load shedding aforementioned in (1) according to the supply shortage at peak times.



(Source: Prepared by the JICA Survey Team based on Data from RNT (NLDC))

Figure 5-10 Actual Daily Load Curves (North System: 2016)

Meanwhile, the daily load curve for the 3-day highest power demand by months in 2017 is shown in Figure 5-11. In order to impound water to the reservoir of Lauca HPP for commissioning, the Cambambe HPP in the lower stream had set limits to generation during daytime. Therefore, the curves cannot be referred.



(Source: Prepared by the JICA Survey Team based on Data from RNT (NLDC))

Figure 5-11 Actual Daily Load Curves (North System: 2016)




Figure 5-12 Location of Lauca Hydropower Plant

5.2.2 Regional characteristics of power demand

Currently the national power system in Angola is divided into 5 regional power systems: North region, Central region, South region, East region, and Cabinda province. The table below shows the maximum power demand (incl. latent demand), number of customers, electrification rate, and maximum power demand per customer for each province in 2016.

The maximum power demand in the country, excluding Cabinda, is 1,989 MW, of which the North system accounts for approximately 80%. The electrification rate is considerably low, below 10 %, in both the South and East systems.

The maximum demand per consumer can be stratified into 2.0 kW for Luanda, Bengo, and Cuando-Cubango provinces, 1.5 kW for Zaire province, and 1.0 kW for the other provinces.



Table 5-2 Electrification Rate and Maximum Power Demand by Province (2016)

| | Province | Real Maximum Demand (MW) | No. of Customers | Electrified Rate (%) | Demand/ Customer (kW) | Stratified Demand/ Customer |
|---|-----------------|--------------------------|------------------|----------------------|-----------------------|-----------------------------|
| N | Luanda | 1358.3 | 718,015 | | 1.892 | 2.000 |
| N | Bengo | 27.7 | 14,784 | | 1.874 | 2.000 |
| N | Cuanza Norte | 29.4 | 28,376 | | 1.036 | 1.000 |
| N | Malanje | 37.3 | 35,430 | | 1.053 | 1.000 |
| N | Uíge | 25.9 | 34,709 | | 0.746 | 1.000 |
| N | Zaire | 21.0 | 14,025 | | 1.517 | 1.500 |
| N | Cabinda | 46.4 | 49,048 | | 0.946 | 1.000 |
| | Subtotal | 1546.3 | | 50.8 | | |
| C | Cuanza Sur | 41.4 | 45,038 | | 0.919 | 1.000 |
| C | Benguela | 160.0 | 100,685 | | 1.589 | 1.500 |
| C | Huambo | 49.6 | 49,086 | | 1.011 | 1.000 |
| C | Bié | 15.0 | 15,545 | | 0.965 | 1.000 |
| | Subtotal | 266.0 | | 26.7 | | |
| S | Huíla | 69.0 | 74,244 | | 0.925 | 1.000 |
| S | Cunene | 15.4 | 16,545 | | 0.931 | 1.000 |
| S | Quando-Cubango | 19.2 | 7,832 | | 2.451 | 2.000 |
| S | Namibe | 31.9 | 27,766 | | 1.149 | 1.000 |
| | Subtotal | 135.1 | | 7.3 | | |
| E | Moxico | 11.3 | 11,515 | | 0.981 | 1.000 |
| E | Lunda Norte | 18.5 | 19,218 | | 0.963 | 1.000 |
| E | Lunda Sul | 12.0 | 11,767 | | 1.020 | 1.000 |
| | Subtotal | 41.8 | | 5.4 | | |
| | TOTAL | 1989.0 | 1,273,628 | 32.3 | 1.562 | |

(Source: Prepared by the JICA Survey Team based on Data from RNT and ENDE)

5.3 Power demand forecast up to 2040

5.3.1 Power demand forecasting methodology

As mentioned earlier, GDP growth and power demand growth are uncorrelated, and the power demand data, including that on latent demand, is poorly organized. Hence, the power demand in Angola is to be forecasted by another method according to the flow in the figure below.

First, the annual maximum power demand is forecasted based on INE's population growth forecast, electrification plan (government target), maximum power demand forecast for commercial and industrial sectors (assumption by ENDE), and the results for 2016 in Table 3-2. Second, daily load curves, including those for latent demand, are assumed for each month for each power system, and the annual load factors up to 2040 are estimated accordingly. Finally, the generated energy demand for each power system is forecasted for each year based on the annual maximum power demand forecast and annual load factor forecast.





Figure 5-13 Power Demand Forecasting Flow in Angola

5.3.2 Annual maximum power demand forecast

(1) Electrification plan

The electrification plan was formulated based on the electrification rate (32.3% nationwide) as of 2016, as shown in Figure 5-14. The plan assumes that electrification proceeds from an area with high population density, such that the electrification rate in 2025 can reach 60%, the government target.



(Source: JICA Survey Team)

Figure 5-14 Electrification Plan**(2) Incremental power demand forecast for commercial and industrial sectors**

Incremental power demand forecasts for the commercial and industrial sectors were assumed as shown in the table below, based on the incremental power demand (kW) up to 2025 estimated by ENDE, with the prerequisite that the incremental power demand for the commercial and industrial sectors can account for 20% of the maximum power demand in 2040.

Table 5-3 Incremental Power Demand Forecast for Commercial and Industrial Sectors

| Province | | 2020 | 2025 | 2030 | 2035 | 2040 |
|----------|----------------|-------|-------|---------|---------|---------|
| N | Luanda | 66.7 | 92.5 | 192.5 | 292.5 | 392.5 |
| N | Bengo | 3.9 | 20.8 | 40.8 | 60.8 | 80.8 |
| N | Cuanza Norte | 20.8 | 88.6 | 138.6 | 188.6 | 238.6 |
| N | Malanje | 16.4 | 20.8 | 40.8 | 60.8 | 80.8 |
| N | Uíge | 20.8 | 65.5 | 115.5 | 165.5 | 215.5 |
| N | Zaire | 22.9 | 49.2 | 79.2 | 109.2 | 139.2 |
| N | Cabinda | 16.39 | 20.8 | 40.8 | 60.8 | 80.8 |
| C | Cuanza Sul | 2.3 | 20.8 | 40.8 | 60.8 | 80.8 |
| C | Benguela | 10.4 | 20.8 | 40.8 | 60.8 | 80.8 |
| C | Huambo | 22.2 | 32.1 | 62.1 | 92.1 | 122.1 |
| C | Bié | 1.9 | 20.8 | 40.8 | 60.8 | 80.8 |
| S | Huíla | 10.5 | 20.9 | 40.9 | 60.9 | 80.9 |
| S | Cunene | 3.4 | 20.8 | 40.8 | 60.8 | 80.8 |
| S | Quando-Cubango | 3.8 | 20.8 | 40.8 | 60.8 | 80.8 |
| S | Namibe | 2.3 | 44.0 | 64.0 | 84.0 | 104.0 |
| E | Moxico | 7.4 | 44.0 | 64.0 | 84.0 | 104.0 |
| E | Lunda Norte | 7.4 | 44.0 | 64.0 | 84.0 | 104.0 |
| E | Lunda Sur | 6.4 | 20.8 | 40.8 | 60.8 | 80.8 |
| Total | | 246.0 | 668.3 | 1,188.3 | 1,708.3 | 2,228.3 |

(Source: JICA Survey Team)

(3) Annual maximum power demand forecast

Annual Maximum Demand for the domestic sector in each province was calculated by the following formula based on the electrification plan aforementioned.

$$\text{Max. Demand} = \frac{\text{Electrification rate} \times \text{population}}{\text{Mean population per customer} \times \text{Maximum power demand per customer}}$$

Where,

Mean population per customer: 6.8 heads / number (2016 results)


Maximum power demand per customer: Stratified maximum demand per customer in Table 5-2

In addition, by adding the annual maximum power demand for commercial and industrial sectors aforementioned, the region-wise (province-wise) annual maximum power demands up to 2040 were forecasted as shown in Table 5-4 and Figure 5-15.

Table 5-4 Annual Maximum Power Demand Forecast

| | Province | 2020 | | 2025 | | 2030 | | 2035 | | 2040 | |
|---|----------------|-------------------|------------------------|-------------------|------------------------|-------------------|------------------------|-------------------|------------------------|-------------------|------------------------|
| | | Population | Forecasted Demand (MW) | Population | Forecasted Demand (MW) | Population | Forecasted Demand (MW) | Population | Forecasted Demand (MW) | Population | Forecasted Demand (MW) |
| N | Luanda | 8,523,574 | 2122.9 | 9,920,997 | 2751.9 | 11,332,670 | 3541.8 | 12,723,054 | 4220.5 | 14,120,025 | 4733.5 |
| N | Bengo | 462,598 | 58.6 | 553,863 | 119.1 | 656,180 | 176.6 | 766,679 | 242.2 | 882,618 | 315.7 |
| N | Cuanza Norte | 524,569 | 67.4 | 602,893 | 151.0 | 692,367 | 220.5 | 791,241 | 288.1 | 896,755 | 358.0 |
| N | Malanje | 1,175,886 | 103.3 | 1,362,964 | 151.8 | 1,581,477 | 216.2 | 1,827,369 | 290.5 | 2,090,620 | 359.0 |
| N | Uíge | 1,761,367 | 72.9 | 2,039,752 | 156.0 | 2,376,167 | 256.1 | 2,771,516 | 370.4 | 3,212,593 | 500.5 |
| N | Zaire | 720,902 | 54.8 | 836,664 | 104.9 | 960,805 | 164.4 | 1,092,530 | 230.3 | 1,232,419 | 303.2 |
| N | Cabinda | 847,377 | 104.1 | 965,555 | 135.0 | 1,088,094 | 177.6 | 1,213,169 | 222.3 | 1,342,068 | 269.3 |
| | Subtotal | | 2584.0 | | 3569.8 | | 4753.3 | | 5864.2 | | 6839.2 |
| C | Cuanza Sur | 2,236,581 | 101.5 | 2,588,393 | 173.9 | 3,003,387 | 262.8 | 3,477,688 | 369.3 | 3,995,420 | 494.3 |
| C | Benguela | 2,611,074 | 299.9 | 2,965,850 | 415.5 | 3,361,497 | 562.6 | 3,793,794 | 733.9 | 4,250,235 | 882.0 |
| C | Huambo | 2,471,780 | 131.9 | 2,927,924 | 205.3 | 3,467,136 | 318.4 | 4,081,212 | 454.1 | 4,748,471 | 613.5 |
| C | Bié | 1,765,495 | 41.1 | 2,073,190 | 82.1 | 2,433,384 | 130.8 | 2,840,854 | 207.8 | 3,280,737 | 323.3 |
| | Subtotal | | 574.3 | | 876.8 | | 1274.7 | | 1765.2 | | 2313.2 |
| S | Huíla | 2,997,267 | 121.2 | 3,486,668 | 201.3 | 4,054,938 | 310.6 | 4,705,412 | 443.5 | 5,418,796 | 601.6 |
| S | Cunene | 1,194,495 | 38.8 | 1,395,546 | 82.7 | 1,625,997 | 137.0 | 1,886,099 | 200.3 | 2,170,008 | 273.3 |
| S | Cuando-Cubango | 638,615 | 41.6 | 738,518 | 86.3 | 849,591 | 141.3 | 969,408 | 204.2 | 1,096,109 | 275.3 |
| S | Namibe | 608,649 | 65.3 | 716,595 | 128.7 | 835,795 | 169.0 | 964,302 | 212.3 | 1,100,773 | 258.6 |
| | Subtotal | | 266.8 | | 499.1 | | 757.9 | | 1060.1 | | 1408.8 |
| E | Moxico | 907,681 | 27.6 | 1,056,030 | 75.2 | 1,228,578 | 109.4 | 1,420,377 | 157.5 | 1,623,913 | 224.0 |
| E | Lunda Norte | 1,030,631 | 37.9 | 1,185,039 | 96.5 | 1,357,513 | 144.2 | 1,549,313 | 198.5 | 1,757,670 | 259.9 |
| E | Lunda Sur | 649,133 | 25.6 | 754,520 | 77.4 | 871,618 | 92.4 | 996,379 | 134.5 | 1,124,767 | 180.6 |
| | Subtotal | | 91.1 | | 249.2 | | 346.0 | | 490.5 | | 664.5 |
| | TOTAL | 31,127,674 | 3516.3 | 36,170,961 | 5194.8 | 41,777,194 | 7131.9 | 47,870,396 | 9180.0 | 54,343,997 | 11225.7 |

(Source: JICA Survey Team)



| | 2016 | 2020 | 2025 | 2030 | 2035 | 2040 |
|---------|-------|-------|-------|-------|-------|--------|
| North | 1,546 | 2,584 | 3,570 | 4,753 | 5,864 | 6,839 |
| Central | 266 | 574 | 877 | 1,275 | 1,765 | 2,313 |
| South | 135 | 267 | 499 | 758 | 1,060 | 1,409 |
| East | 42 | 91 | 249 | 346 | 490 | 665 |
| Total | 1,989 | 3,516 | 5,195 | 7,132 | 9,180 | 11,226 |

(Source: JICA Survey Team)

Figure 5-15 Annual Maximum Power Demand Forecast

5.3.3 Daily load curve forecast

In order to predict the annual load factor, it is necessary to assume the daily load curve and maximum power in every month. This is problematic, however, as no organized hourly load-shedding data (latent demand data) are available in the North system. Furthermore, since SCADA has not yet been introduced in the other systems, no organized hourly load-shedding data (latent demand data) and also no hourly supplied power data are available.

(1) North System

The maximum power demand (including latent demand) for each month in the North system in the latest 3 years (shown in Figure 5-8) was normalized with annual maximum power demand, and the average was calculated as shown in Table 5-5. The annual maximum power occurs in December, the maximum power demand in July descends in the lowest level, about 77 % of the annual maximum power demand.




Table 5-5 Monthly Maximum Demand Fluctuation Normalized

| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|----------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|-------------|
| 2015 | 87% | 95% | 91% | 91% | 88% | 78% | 74% | 79% | 82% | 96% | 98% | 100% |
| 2016 | 95% | 96% | 100% | 94% | 95% | 83% | 81% | 77% | 82% | 89% | 92% | 99% |
| 2017 | 94% | 97% | 100% | 100% | 94% | 84% | 84% | 84% | 84% | — | — | — |
| Average | 92% | 96% | 97% | 96% | 93% | 85% | 77% | 80% | 84% | 93% | 96% | 100% |

(Source: Prepared by the JICA Survey Team based on Data from RNT (NLDC))

Next, the daily load curves (highest 3 days, weekdays, and holidays) every month as of 2016 were assumed by correcting the demand during the peak time (3 hours) based on the load curves in August and December 2016 and January 2017, when latent demand was relatively small (see Figure 5-8). The daily load curves on the highest 3 days, weekdays, and holidays assumed every month are shown in Figure 5-16 (normalized by the annual maximum power demand).

The annual load factor calculated from the above results is 70.3%.


Highest 3 Days**Weekday****Holiday**

(Source: JICA Survey Team)

Figure 5-16 Daily Load Curves as of 2016 (North System)

Since the North system has a large city of Luanda, it seems likely that the power demand in the daytime will rise somewhat above the peak demand in the evening in the future. The annual load factor as of 2016 (70.3%) is expected to increase to about 72% in 2040, from the experience of other developing countries.

The daily load curves (highest 3 days, weekdays, holidays) every month up to 2040 were forecasted according to the aforementioned assumption. Figure 5-17 shows the daily load curves on the highest 3 days in December, when monthly maximum power demand is the highest, and in July when the monthly maximum power demand is the lowest in the year.




(Source: JICA Survey Team)

Figure 5-17 Daily Load Curve Forecast up to 2040 (North System; Highest 3 days)**(2) Central, South and East Systems**

Since hourly generation data in the Center, South and East system have not been organized, the daily load curves in those systems are to be forecast based on the power supply records as of 2016 in the isolated subsystem in the North system.

The daily load curve for the highest 3 days by months as of 2016 in the isolated subsystem in the North system is shown in Figure 5-18.



(Source: JICA Survey Team)

Figure 5-18 Daily Load Curves of Isolated Subsystem in North System (2016)

The maximum power demand (including latent demand) for each month in the Center and South system in 2016 (see Figure 5-8) was normalized with annual maximum power demand, and the average was calculated as shown in Table 5-6. The annual maximum power occurs in December, the maximum power demand in June descends in the lowest level, about 77 % of the annual maximum power demand.


Table 5-6 Monthly Maximum Demand Fluctuation Normalized

| | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|---------|--------|-----|-----|-----|------|-----|-----|-----|-----|-----|-----|------|------|
| 2016 | Center | 82% | 84% | 82% | 80% | 75% | 73% | 81% | 90% | 84% | 94% | 100% | 96% |
| | South | 94% | 92% | 93% | 100% | 95% | 92% | 93% | 96% | 96% | 99% | 97% | 91% |
| Applied | | 92% | 89% | 87% | 92% | 81% | 77% | 78% | 82% | 78% | 94% | 96% | 100% |

(Source: Prepared by the JICA Survey Team based on Data from RNT (NLDC))

Since the mean latent demand as of 2016 in the Center system, which has a second largest demand scale, was 30% of the monthly maximum power demand as shown in Figure 5-8, this ratio is applied to modify the hourly demand during the peak demand (3 hours) and the monthly daily load curves are forecasted. The daily load curves on the highest 3 days, weekdays, and holidays assumed every month are shown in Figure 5-19 (normalized by the annual maximum power demand). modified and normalized by monthly maximum are shown.

The annual load factor calculated from the above results is 56.8%.



(Source: JICA Survey Team)

Figure 5-19 Daily Load Curves as of 2016 (Center+South+East System)

Since electrification will be promoted in the Center, the South and the East system until after 2040, It is expected that load curves for domestic demand will increase in the similar figure based on electrification and the ratio of demand for commerce, industry and commercial will not change. Accordingly, it seems likely that the annual load factor as of 2016 (56.8%) is no change up to 2040.

The total daily load curves in the Center, the South and the East System (highest 3 days, weekdays, holidays) every month up to 2040 were forecasted according to the aforementioned assumption. Figure 5-20 shows the daily load curves on the highest 3 days in December, when

monthly maximum power demand is the highest, and in July when the monthly maximum power demand is the lowest in the North system in the year.




Figure 5-20 Daily Load Curve Forecast (Center+South+East System; Highest 3 days)
(3) Whole country

According to the aforementioned results, the annual load factor in the whole country (North, Center, South and East system) as of 2016 (67.3%) will descend up to 66.1% in 2040. The main reason is that the share of maximum power demand in the North system will decline from 77.7 % in 2016 to 61.0 % 2040 due to promotion of electrification in Center, South and East system.

Figure 5-21 shows the daily load curves on the highest 3 days in December, when monthly maximum power demand is the highest, and in July when the monthly maximum power demand is the lowest in the year.




Figure 5-21 Daily Load Curve Forecast (Whole County; Highest 3 days)

5.3.4 Annual generated energy demand forecast

Generation energy demand is calculated by the following formula.


$$\text{Generated energy demand (kWh)} = \text{annual maximum power demand (kW)} \times 8,760 \text{ hours} \times \text{annual load factor}$$

Based on the forecast of the annual maximum power demand and the annual load factor aforementioned, the results for the generated energy demand forecast are shown in Table 5-7 and in Figure 5-22.

Table 5-7 Annual Generated Energy Demand Forecast by System
(Unit: GWh)

| | North | Center | South | East | Whole |
|------|--------|--------|-------|-------|--------|
| 2016 | 9,522 | 1,325 | 673 | 208 | 11,728 |
| 2017 | 11,131 | 1,708 | 837 | 269 | 13,946 |
| 2018 | 12,743 | 2,092 | 1,001 | 331 | 16,167 |
| 2019 | 14,359 | 2,476 | 1,165 | 392 | 18,392 |
| 2020 | 15,977 | 2,860 | 1,329 | 453 | 20,619 |
| 2021 | 17,214 | 3,161 | 1,560 | 611 | 22,546 |
| 2022 | 18,452 | 3,462 | 1,791 | 768 | 24,474 |
| 2023 | 19,693 | 3,763 | 2,023 | 926 | 26,405 |
| 2024 | 20,937 | 4,065 | 2,254 | 1,083 | 28,339 |
| 2025 | 22,183 | 4,366 | 2,485 | 1,241 | 30,275 |
| 2026 | 23,678 | 4,762 | 2,743 | 1,337 | 32,520 |
| 2027 | 25,175 | 5,158 | 3,001 | 1,434 | 34,768 |
| 2028 | 26,675 | 5,555 | 3,258 | 1,530 | 37,019 |
| 2029 | 28,179 | 5,951 | 3,516 | 1,626 | 39,272 |
| 2030 | 29,685 | 6,347 | 3,774 | 1,723 | 41,529 |
| 2031 | 31,103 | 6,836 | 4,075 | 1,867 | 43,881 |
| 2032 | 32,525 | 7,324 | 4,376 | 2,011 | 46,235 |
| 2033 | 33,949 | 7,813 | 4,677 | 2,154 | 48,593 |
| 2034 | 35,375 | 8,301 | 4,978 | 2,298 | 50,953 |
| 2035 | 36,805 | 8,790 | 5,279 | 2,442 | 53,316 |
| 2036 | 38,066 | 9,335 | 5,626 | 2,616 | 55,643 |
| 2037 | 39,330 | 9,881 | 5,973 | 2,789 | 57,974 |
| 2038 | 40,597 | 10,427 | 6,321 | 2,962 | 60,306 |
| 2039 | 41,865 | 10,973 | 6,668 | 3,136 | 62,641 |
| 2040 | 43,136 | 11,518 | 7,015 | 3,309 | 64,979 |

(Source: JICA Survey Team)




(Source: JICA Survey Team)

Figure 5-22 Generated Energy Demand Forecast

5.3.5 Macro-evaluation of power demand forecast

To confirm the validity of the power demand forecast results, they were compared with the results of other developing countries. The chart in Figure 5-23 plots the relationship between the results for GDP per capita and the electricity consumption per capita (1973 - 2013) in various developing countries, adding a prescript of Angola's results and the power demand forecast in Angola. The relationship between GDP and electricity consumption is gradually increasing in each country, although the gradient differs from one country to another, reflecting the differences in how electricity is used according to the countries' climatic conditions and industrial structures.

Since the growth rate of population is projected to decrease gradually from 3.0% in 2016 to 2.5% in 2040 whereas the growth rate of GDP is predicted to be constant after 2023 as 1.4% based on the IMF prediction until 2022, the GDP per capita will decline year by year. On the other hand, the electricity consumption per capita is forecasted to linearly increase as well as those of the other countries. Therefore, this demand forecast up to 2040 seems to be valid.



(Source: JICA Survey Team)

Figure 5-23 Relationship between GDP and Electricity Consumption per Capita

Chapter 6 Optimization of the Generation Development Plan

6.1 Current situation of power generation facilities

6.1.1 Existing power plants

(1) Composition of Power Plants

The installed capacity of the existing major power plants by type and by region is shown in Table 6-1. The composition of the generation types by region is shown in Figure 6-1.

Hydropower facilities have the largest share, accounting for more than half of the capacity in the whole country. The rest is supplied by thermal power, specifically, gas turbine and diesel plants. Meanwhile, most of the large hydropower plants are located in the north. The share of thermal power in the north is therefore higher than the shares in the central, south, and east regions.

Regarding the generation of the renewable energy, one biomass generation plant is in operation. Other large-scale development projects, including wind power and solar power plants, have yet to appear.

Table 6-1 Major power generation plants by region by type (MW)

| Region | Total | Hydropower (except small) | Thermal Power | | Renewable | | |
|----------------------|--------------|---------------------------------|---------------|------------|-----------|----------|----------|
| | | | GT | Diesel | Biomass | Wind | Solar PV |
| Whole Country | 4,339 | 2,365 | 1,181 | 743 | 50 | 0 | 0 |
| North Region | 3,527 | 2,172 | 899 | 407 | 50 | 0 | 0 |
| Central Region | 492 | 125 | 254 | 113 | 0 | 0 | 0 |
| South Region | 221 | 41 | 28 | 152 | 0 | 0 | 0 |
| East Region | 99 | 28 | 0 | 71 | 0 | 0 | 0 |




Figure 6-1 Composition of installed capacity

Meanwhile, aging of the power plants, in hydro/thermal/renewable power, have been progressed. There are many power plants that have stopped operation or are incapable of generating at the installed capacity. Particularly in the thermal power plants, the drop in the maximum available generation capacity is remarkable. The current available capacity of the thermal power plants is summarized in Table 6-2. Forty percent of the installed capacity of thermal power plants is restricted. Therefore, the current supply capacity should be evaluated based on the current available capacity.

Table 6-3 shows the available capacity by generation type and by region. Figure 6-2 shows the composition of available generation capacity by region. As the table and figure demonstrate, the share of hydropower generation exceeds 60%. Hence, power generation dominated by hydropower is more realistic than the ratio of installed capacity.

Table 6-2 Available capacity of thermal power (MW)

| Region | Thermal Power | | |
|----------------------|------------------------|------------------------|-------------------------|
| | Installed capacity (1) | Available capacity (2) | Available ratio (2)/(1) |
| Whole Country | 1,924 | 1,145 | 60% |
| North Region | 1,306 | 751 | 58% |
| Central Region | 367 | 226 | 61% |
| South Region | 180 | 130 | 72% |
| East Region | 71 | 38 | 53% |

Table 6-3 Available capacity by type by region (MW)

| Region | Total | Hydropower (except small) | Thermal Power | | Renewable | | |
|----------------------|--------------|---------------------------|---------------|------------|-----------|----------|----------|
| | | | GT | Diesel | Biomass | Wind | Solar PV |
| Whole Country | 3,441 | 2,286 | 739 | 406 | 10 | 0 | 0 |
| North Region | 2,941 | 2,150 | 549 | 202 | 10 | 0 | 0 |
| Central Region | 311 | 85 | 162 | 64 | 0 | 0 | 0 |
| South Region | 157 | 27 | 28 | 102 | 0 | 0 | 0 |
| East Region | 62 | 24 | 0 | 38 | 0 | 0 | 0 |




Figure 6-2 Composition of available generation capacity

(2) Ownership of power facilities

Table 6-4 shows the ownership of the existing power stations. Most of the O&M for existing power plants, including all of the large-scale hydropower stations with excellent capacity for adjustment of generation, has been conducted by PRODEL. Hence, PRODEL plays a significant role in providing a stable power supply.

Table 6-4 Ownership of power plants (MW)

| Region | Total | Hydropower | | Thermal Power | | Biomass | |
|----------------------|--------------|--------------|-----------|---------------|------------|----------|-----------|
| | | PRODEL | Others | PRODEL | Others | PRODEL | Others |
| Whole Country | 4,339 | 2,274 | 92 | 1,373 | 552 | 0 | 50 |
| North Region | 3,527 | 2,146 | 26 | 944 | 362 | 0 | 50 |
| Central Region | 492 | 75 | 50 | 337 | 30 | 0 | 0 |
| South Region | 221 | 41 | 0 | 28 | 152 | 0 | 0 |
| East Region | 99 | 12 | 16 | 63 | 7 | 0 | 0 |

(3) Hydropower stations

Basic information on the existing hydropower stations is shown in Table 6-5. The installed capacity of hydropower is 2,373 MW as of October 2017. Out of this capacity, 2,146 MW is provided by three (3) large-scale hydropower stations: Capanda, Cambambe, and Lauca hydropower. The Lauca power station is still under construction. Two (2) units have started commercial generation, and the others are to be completed in series, as described in the following section. The generation capacity of these three (3) hydropower stations has therefore been increasing.

All three (3) of these hydropower stations are located in Kwanza River. The Capanda hydropower station, which is located middle of the river, is the first developed hydropower plant in the river basin. The station has a large reservoir with 3,653 million m³ of effective storage and an installed capacity of 520 MW.

The Cambambe hydropower station is located downstream of the Capanda hydropower station. It began with an installed capacity of 180 MW. After completion, the dam was renovated to raise the height by 15m, and renovation of the existing plant for increasing the capacity to 260 MW, and also an additional power station of 700 MW was constructed. The renovation and expansion project are conducted by Odbrecht Angola, and Voith was in charge of power generation equipment and others.

The Lauca hydropower station is located midway between the above two hydropower stations. The Lauca hydropower station is a huge-scale plant with an installed capacity of 2,067 MW and reservoir capacity of 5,482 million m³. These three (3) hydropower stations currently play a very important role as major power sources in Angola.

(4) Thermal power stations

Basic information on the existing thermal power stations is shown in Table 6-6.

The Soyo thermal power station is the first combined cycle power plant introduced in Angola. Two (2) gas turbine generators with a total generation capacity of 250 MW have tentatively started generation at the plant using diesel oil for fuel. Completion of construction, with a natural gas supply for fuel, is slated for 2018.

The capacities of the other thermal plants are middle or small scale. There are about ten (10) gas turbine plants in the 20-to-40 MW class. The remaining plants are small-scale diesel power plants, some of which have not been connected to the main power grid.

Most of these gas turbine and diesel power plants are located in or near a substation of a local grid and used for stability of power voltage. Generation during peak time is reasonable, but the purpose of actual generation of these power plants seems to be for power shortage in a whole day. The generation cost therefore seems to be higher, which poses one of the important challenges to address in the Angolan power system.

Regarding the fuel type, Jet B is used for some gas turbines but the major fuel is diesel oil. Natural gas has not been used for generation so far. Plans for the utilization of natural gas for fuel cost reduction are under discussion with Sonangol but are not yet concluded.

Table 6-5 List of existing hydropower stations as of October 2017

| Plant name | Grid connecti on | Owner | Location | | | | | Installed capacity (MW) | Number of units / unit capacity (MW) | Available capacity (MW) | Year commission ed | Note |
|-----------------|------------------|--------|----------|--------------|---------------|---------------|---------------|-------------------------|--------------------------------------|-------------------------|--------------------|---|
| | | | Area | Province | Municip ality | Longitude | Latitude | | | | | |
| Lauca | on grid | PRODEL | North | Malanje | - | 15° 7'32.38"E | 9°44'30.58"S | 666.0 | 6x333,1x67 | 666.0 | 2017-2018 | #1,#2 completed, #3-#6 under construction, Total 2067MW |
| Capanda | on grid | PRODEL | North | Malanje | Cacuso | 15°27'48.85"E | 9°47'35.02"S | 520.0 | 4x 130 | 480.0 | 2004/2007 | - |
| Cambambe | on grid | PRODEL | North | Kwanza Norte | Dondo | 14°28'44.76"E | 9°45'4.40"S | 260.0 | 4x 65 | 240.0 | 2012 | - |
| Cambambe 2 | on grid | PRODEL | North | Kwanza Norte | Dondo | 14°29'1.08"E | 9°44'47.27" | 700.0 | 4x 175 | 640.0 | 2016 | - |
| Mabubas | on grid | IPP | North | Bengo | Dande | 13°42'0.57"E | 8°32'6.77"S | 25.6 | 4x 6.4 | 24.0 | 2012 | - |
| Biópio | on grid | PRODEL | Central | Benguela | Lobito | 13°43'36.24"E | 12°28'4.58"S | 14.58 | 4x 3.645 | 12.0 | 1955 | - |
| Lomaúum | on grid | IPP | Central | Benguela | Cubal | 14°23'8.39"E | 12°43'31.27"S | 50.0 | 2x10, 2x15 | 50.0 | 2015 | - |
| Gove | on grid | PRODEL | Central | Huambo | Caála | 15°52'12.72"E | 13°27'7.41"S | 60.0 | 3x 20 | 35.0 | 2012 | - |
| Matala | on grid | PRODEL | South | Huíla | Matala | 15° 2'30.93"E | 14°44'39.96"S | 40.8 | 3x 13.6 | 27.2 | 1959 | - |
| On grid Total= | | | | | | | | 2,337.0 | | 2,174.2 | | |
| Luachimo | off grid | PRODEL | East | Lunda Norte | Dundo | 20°50'35.45"E | 7°21'48.94"S | 8.4 | 4x 2.1 | 4.0 | - | - |
| Chicapa | off grid | IPP | East | Lunda Sul | Saurimo | 20°21'14.94"E | 9°29'8.64"S | 16.0 | 4x 4 | 14.0 | - | - |
| Chiumbe Dala | off grid | PRODEL | East | Lunda Sul | | 20°12'14.75"E | 11° 1'19.39"S | 12.0 | 2x4, 2x2 | 10.0 | 2017 | - |
| Off grid Total= | | | | | | | | 36.4 | | 28.0 | | |
| Hydro Total= | | | | | | | | 2,373.4 | | 2,202.2 | | |

Table 6-6 List of existing thermal power stations as of October 2017

| Plant name | Grid connection | Owner | Location | | | | | Installed capacity (MW) | Number of units / unit capacity (MW) | Available capacity (MW) | Year commissioned | Type | Fuel | Note |
|-----------------------|-----------------|--------|----------|----------|----------------|---------------|---------------|-------------------------|--------------------------------------|-------------------------|-------------------|--------|-----------|---------------------------------------|
| | | | Area | Province | Municipalities | Longitude | Latitude | | | | | | | |
| Soyo | on grid | PRODEL | North | Zaire | Soyo | 12°20'51.70"E | 6°10'40.60"S | 250.0 | GT 4x125, ST 2x125 | 250.0 | 2017-2018 | GT | Diesel/NG | #1,2 in operation, Total 750 MW(CCGT) |
| CD Benfica | on grid | PRODEL | North | Luanda | Belas | 13° 9'54.40"E | 8°57'14.73"S | 40.0 | 10x 4 | 24.0 | 2013 | Diesel | Diesel | N/A N/A N/A |
| CT Cazenga #1 | on grid | IPP | North | Luanda | Cazenga | 13°18'23.38"E | 8°48'53.54"S | 24.4 | 1x 24.4 | 0.0 | 1979 | GT | Diesel | |
| CT Cazenga #2 | on grid | IPP | North | Luanda | Cazenga | | | 32.0 | 1x 32.8 | 32.0 | 1985 | GT | Diesel | |
| CT Cazenga #3 | on grid | IPP | North | Luanda | Cazenga | | | 40.0 | 1x40 | 40.0 | 1993 | GT | Diesel | |
| CT Cazenga #4 | on grid | IPP | North | Luanda | Cazenga | | | 22.4 | 1x 22.45 | 0.0 | - | GT | Jet B | |
| CT Cazenga #5 | on grid | IPP | North | Luanda | Cazenga | | | 22.4 | 1x 22.45 | 0.0 | - | GT | Jet B | |
| CT Cazenga #6 | on grid | PRODEL | North | Luanda | Cazenga | | | 22.0 | 1x 22 | 18.00 | 2010 | GT | Jet B | |
| CT Cazenga #7 | on grid | PRODEL | North | Luanda | Cazenga | | | 22.0 | 1x 22 | 18.00 | 2010 | GT | Jet B | |
| CT CFL | on grid | PRODEL | North | Luanda | Cazenga | 13°16'36.78"E | 8°49'41.66"S | 125.0 | 5x 25 | 75.0 | 2012-2013 | Diesel | Diesel | #1,#3 N/A |
| CD Viana Km9 | on grid | PRODEL | North | Luanda | Viana | 13°18'59.68"E | 8°51'59.71"S | 40.0 | 24x 1.66 | 25.0 | 2013 | Diesel | Diesel | N/A N/A |
| CT Boa Vista I | on grid | PRODEL | North | Luanda | Luanda | 13°13'19.10"E | 8°49'20.40"S | 45.0 | 1x 45 | 0.0 | 2011 | GT | Diesel | |
| CT Boa Vista II | on grid | PRODEL | North | Luanda | Luanda | | | 45.0 | 1x 45 | 0.0 | 2011 | GT | Diesel | |
| CT Boa Vista III | on grid | PRODEL | North | Luanda | Luanda | | | 41.2 | 1x 41.2 | 24.0 | 2011 | GT | Diesel | |
| CT Refinaria | on grid | IPP | North | Luanda | Cazenga | 13°18'28.20"E | 8°46'56.37"S | 25.5 | - | 0.0 | - | GT | Diesel | |
| CT CIF Thermal | on grid | IPP | North | Luanda | Viana | 13°34'0.35"E | 9° 6'29.84"S | 50.0 | - | 0.0 | - | GT | Diesel | |
| CD Capopa 1 | on grid | PRODEL | North | Malanje | Malanje | - | - | 4.5 | - | 0.0 | 2013 | Diesel | Diesel | |
| CD Capopa 2 | on grid | PRODEL | North | Malanje | Malanje | - | - | 19.6 | 5x3.9 | 15.7 | 2015 | Diesel | Diesel | |
| CT Camama | on grid | PRODEL | North | Luanda | Belas | - | - | 50.0 | 2x25 | 50.0 | 2017 | GT | Diesel | |
| CT Biópio | on grid | PRODEL | Central | Benguela | Lobito | 13°43'21.66"E | 12°27'48.10"S | 22.0 | 1x22.0 | 0.0 | 1977 | GT | Diesel | |
| CT Quileva | on grid | PRODEL | Central | Benguela | Lobito | 13°35'23.96"E | 12°22'54.95"S | 182.3 | 6x15,3x30.78 | 112.3 | 2010-2017 | GT | Diesel | #2-5 N/A |
| CT Belem | on grid | PRODEL | Central | - | - | - | - | 50.0 | 2x25 | 50.0 | 2017 | GT | Diesel | |
| CD Quileva (Aggreko) | on grid | IPP | Central | Benguela | Lobito | 13°35'20.90"E | 12°22'58.58"S | 30.0 | 39x0.79 | 26.4 | - | Diesel | Diesel | |
| CD Lobito | on grid | PRODEL | Central | Benguela | Lobito | 13°32'29.78"E | 12°22'1.80"S | 20.0 | 4x5.0 | 0.0 | 1986 | Diesel | Diesel | N/A |
| CD Cavaco | on grid | PRODEL | Central | Benguela | Benguela | 13°25'57.06"E | 12°35'11.60"S | 20.0 | 5x4.1 | 8.0 | 2013 | Diesel | Diesel | #1,2,4,5 N/A |
| CD Benfica | on grid | PRODEL | Central | Huambo | Huambo | 15°44'45.10"E | 12°45'13.75"S | 15.0 | 4x 3.75 | 11.3 | 2013 | Diesel | Diesel | #3 N/A |
| CD Lubango | on grid | IPP | South | Huíla | Lubango | 13°30'52.08"E | 14°55'53.49"S | 40.0 | 11x2.61 | 29.1 | 2013 | Diesel | Diesel | |
| CD Arimba | on grid | IPP | South | Huíla | Lubango | 13°34'48.45"E | 14°57'7.87"S | 40.0 | 28x1.43 | 31.4 | 2012 | Diesel | Diesel | |
| On grid Total= | | | | | | | | 1,340.3 | | 840.2 | | | | |
| CD Morro Bento | off grid | IPP | North | Luanda | Belas | 13°11'21.47"E | 8°53'29.65"S | 40.0 | 40x1.05 | 0.0 | 2017 | Diesel | Diesel | N/A |
| CT Morro Bento 2 | off grid | PRODEL | North | Luanda | Belas | 13°11'21.47"E | 8°53'29.65"S | 50.0 | 2x 25 | 25.0 | 2017 | GT | Diesel | #1 stopped |
| CT Rocha Pinto | off grid | IPP | North | Luanda | Belas | - | - | 40.0 | 2x 20 | - | - | GT | Diesel | N/A |
| CD Quartéis | off grid | PRODEL | North | Luanda | Cazenga | 13°14'26.92"E | 8°50'24.79"S | 32.0 | 8x 3.75 | 16 | 2013-17 | Diesel | Diesel | |
| CD Cassaque | off grid | PRODEL | North | Luanda | Viana | 13°21'56.56"E | 9° 6'58.12"S | 20.0 | 18x 1.22 | 9.2 | 2013 | Diesel | Diesel | |
| CD Morro da Luz | off grid | IPP | North | Luanda | Belas | 13°11'50.09"E | 8°52'13.68"S | 20.0 | 29x1.38 | 0.0 | - | Diesel | Diesel | |
| CT Viana | off grid | PRODEL | North | Luanda | Viana | 13°18'59.68"E | 8°51'59.71"S | 22.0 | 1x22 | 22.0 | 2010 | GT | Diesel | |
| CD Kianganga | off grid | PRODEL | North | Zaire | Zaire | - | - | 19.7 | - | 11.13 | 2006-15 | Diesel | Diesel | |

| Plant name | Grid connection | Owner | Location | | | | | Installed capacity (MW) | Number of units / unit capacity (MW) | Available capacity (MW) | Year commissioned | Type | Fuel | Note |
|-------------------------|-----------------|--------|----------------------------|-------------|----------------|---------------|---------------|-------------------------|--------------------------------------|-------------------------|-------------------|--------|--------|----------|
| | | | Area | Province | Municipalities | Longitude | Latitude | | | | | | | |
| CD Tomboco | off grid | PRODEL | North | Zaire | Zaire | - | - | 1.0 | - | 1.016 | - | Diesel | Diesel | |
| CD Kaluapanda | off grid | PRODEL | Central | Bié | Kuito | - | - | 10.0 | 4x2.5 | 5.0 | 2011 | Diesel | Diesel | #1,2 N/A |
| CD Caála | off grid | PRODEL | Central | Huambo | Caála | - | - | 2.0 | - | 0.0 | 2004-09 | Diesel | Diesel | |
| CD Bailundo | off grid | PRODEL | Central | Huambo | Bailundo | - | - | 2.7 | - | 2.26 | 2013 | Diesel | Diesel | |
| CD Camacupa | off grid | PRODEL | Central | Bié | Camacupa | - | - | 3.2 | - | 1.2 | 2001 | Diesel | Diesel | |
| CD Chinguar | off grid | PRODEL | Central | Bié | Chinguar | - | - | 2.1 | - | 1.39 | 2008 | Diesel | Diesel | |
| CD Lossambo | off grid | PRODEL | Central | - | - | - | - | 8.0 | - | 8.0 | - | Diesel | Diesel | |
| CD Xitoto I | off grid | IPP | South | Namibe | Namibe | 12°10'14.86"E | 15° 8'44.90"S | 11.2 | 2x5.6 | 0.0 | - | Diesel | Diesel | N/A |
| CD Xitoto II | off grid | IPP | South | Namibe | Namibe | 12°10'14.85"E | 15° 8'42.01"S | 10.2 | 6x 1.66 | 6.8 | 2013 | Diesel | Diesel | |
| CT Xitoto III | off grid | PRODEL | South | Namibe | Namibe | 12°10'14.85"E | 15° 8'42.01"S | 28.0 | 1x28 | 28.0 | | GT | Diesel | |
| CD Airport | off grid | IPP | South | Namibe | Namibe | 12° 7'26.88"E | 15°14'20.56"S | 11.7 | 3x3.89 | 7.8 | 2013 | Diesel | Diesel | #2 N/A |
| CD Ondjiva | off grid | IPP | South | Cunene | Ondjiva | - | - | 10.2 | 3x 3.33 | 6.8 | 2013 | Diesel | Diesel | |
| CD Menongue | off grid | IPP | South | K. Kubango | Menongue | 17°41'52.31"E | 14°39'24.65"S | 11.9 | 7x1.71 | 8.5 | 2013 | Diesel | Diesel | |
| CD Tômbwa | off grid | IPP | South | Namibe | Tômbwa | 11°51'0.70"E | 15°48'17.30"S | 9.6 | 5x1.4, 2x 1.2 | 4.32 | 2014-15 | Diesel | Diesel | |
| CD Cuito Cuanavale | off grid | IPP | South | Kuando | Kubango | 19° 8'44.30"E | 15° 8'29.50"S | 7.5 | 5x 1.7 | 7.5 | 2015 | Diesel | Diesel | |
| | | | Off grid Total= | | | | | 372.9 | | 171.9 | | | | |
| CD Saurimo | off grid | PRODEL | East | Lunda Sul | Sumbe | 20°24'5.16"E | 9°38'32.58"S | 14.1 | 5x 2.5 | 4.1 | 2011-14 | Diesel | Diesel | |
| CD Dundo Nova | off grid | PRODEL | East | Lunda Norte | Dundo | 20°48'20.98"E | 7°22'55.82"S | 30.0 | 8x 3.75 | 22.5 | 2013-14 | Diesel | Diesel | |
| CD Luena (Hynday) | off grid | PRODEL | East | Moxico | Luena | 19°56'44.40"E | 11°45'39.72"S | 7.5 | 5x 1.7 | 3.0 | 2012 | Diesel | Diesel | |
| CD Luena (Catherpillar) | off grid | PRODEL | East | Moxico | Luena | 19°54'40.62"E | 11°47'30.00"S | 6.5 | 2x1.64+2x1.6 | 1.6 | 2013 | Diesel | Diesel | |
| CD Luau | off grid | PRODEL | East | - | - | - | - | 5.4 | - | 3.6 | 2015 | Diesel | Diesel | |
| CD Era | off grid | IPP | East | - | - | - | - | 7.4 | - | 3.0 | - | Diesel | Diesel | |
| | | | Off grid (East) Total= | | | | | 70.9 | | 37.8 | | | | |
| | | | Thermal (main land) Total= | | | | | 1,784.0 | | 1,050.0 | | | | |
| CD Chibodo | off grid | IPP | Cabinda | Cabinda | - | - | - | 30.6 | 18x1.67 | 15.3 | 2014 | Diesel | Diesel | |
| CT Malembo I / II / III | off grid | PRODEL | Cabinda | Cabinda | - | - | - | 95.0 | 2x35, 1x25 | 70 | 2012-15 | GT | Diesel | |
| CD Santa Catarina | off grid | IPP | Cabinda | Cabinda | - | - | - | 10.2 | 6x 1.7 | 6.8 | 2014 | Diesel | Diesel | |
| CD Belize | off grid | IPP | Cabinda | Cabinda | - | - | - | 2.2 | 2x 1.1 | 1.1 | 2014 | Diesel | Diesel | |
| CD Buco Zau | off grid | IPP | Cabinda | Cabinda | - | - | - | 2.2 | 2x 1.1 | 2.2 | 2014 | Diesel | Diesel | |
| | | | Off grid (Cabinda) Total= | | | | | 140.2 | | 95.4 | | | | |
| | | | Thermal Total= | | | | | 1,924.2 | | 1,145.4 | | | | |

6.1.2 Performance of large hydropower stations

As mentioned in the previous section 6.1.1(3), large-scale hydropower stations are developed in the Kwanza River. Two of the stations, the Capanda and Cambambe hydropower stations, operated as major power generation plants before the third station, Lauca, were constructed.

The Capanda power station is located in the middle of Kwanza River, upstream of the other two. The inflow record to the Capanda reservoir is shown in Figure 6-3. The inflow varies widely between the dry season and flood season, and also during the flood season year by year.

The generation record of the Capanda hydropower station is shown in Figure 6-4. The seasonal change in generation was regulated by use of the reservoir, but less power was generated during the dry season (September-October) than during the wet season. Inflow in 2011 and 2012, the driest years, was quite small, as was the generation during the dry season in those years. Inflow in the years 2016 to 2017 was also small, with similarly low generation in the dry season.

The available generation of hydropower depends on river discharge. Accordingly, a generation plan for reservoir usage to respond to shifting inflow during the flood season to dry season is important for a reservoir-type hydropower station. Given the large inflow gap between the flood and dry seasons in Angola, it will be necessary to estimate the available discharge of each month and reflect the estimates in the long-term development plan.




Figure 6-3 Inflow record of Capanda Hydropower Station




Figure 6-4 Generation record of Capanda Hydropower Station

6.1.3 Power stations under construction

(1) Hydropower stations

Two (2) large-scale hydropower stations are under construction: the Lauca hydropower station (2,167 MW) and Caculo Cabaca hydropower station (2,170 MW). Both stations are large reservoir types located in the Kwanza River between the Capanda and Cambambe hydropower stations.

<Lauca hydropower station>

As described in the previous section, The Lauca hydropower station is located downstream of Capanda hydropower station. One (1) turbine/generator utilizing maintenance flow and six (6) 333.3 MW Francis type turbine/generators are planned. The construction cost was financed from Brazil. The construction was carried out by ODLBRECHT, and ANDRIZ HYDRO took a role for hydro turbines/generators. The first generator was completed in July 2017 and the second started generating power from October 2017. The following units are scheduled to be completed one at a time at two-month intervals going forward.

<Caculo Cabaca hydropower station>

The Caculo Cabaca hydropower station is located downstream of the Lauca power station and consists of four (4) 530 MW Francis type hydro turbine/generators and one (1) turbine/generator using maintenance flow. The construction cost was prepared by the loan of the Chinese Industrial and Commercial Bank of China (ICBC), and the joint venture of CGGC (China Gezhouba Group Co., Ltd.), BOREAL INVESTMENTS LIMITED, CGGC & NIARA - HOLDING LDA was selected for the contractor. Preparations for construction have started and diversion works have been ongoing from August 2017. Construction for the main works is scheduled to take place over a period of 80 months.

(2) Thermal power stations

Construction of the Soyo 1 thermal power station, the first combined cycle thermal power plant in Angola, is progressing. The plants in this power station have higher capacity and efficiency than the previous thermal power plants.

<Soyo 1 Combined Cycle Power Plant >

The Soyo 1 CCGT is being constructed in Zaire province in the north-west of Angola (see Figure 6-5). One gas turbine is already commissioned. The plant has a capacity of 750 MW and runs on gas and diesel oil.

The Soyo 1 CCGT consists of 2 blocks of multi-shaft-type CCGTs. Each block has a capacity of 375 MW and consists of two (2) sets of gas turbine generators, two (2) sets of heat recovery steam generators (HRSGs), and one (1) set of steam turbine.

A gas pipeline running from Angola LNG terminal at the Congo River to the Soyo 1 CCGT will supply natural gas to the CCGT from November, 2017.




Figure 6-5 Location of Soyo 1 CCGT

Figure 6-6 Bird's-eye View of Soyo 1 CCGT

(Source) Energia 2025 and Soyo 1 CCPP construction office

The main specifications for Soyo 1 CCPP are shown in the table below.

(a) Specifications for the Main Equipment

| Equipment | Capacity and Number | Type | Manufacturer |
|----------------|---|--------------------------------|--------------|
| Gas Turbine | 125 MW x 4 sets | MS9001E | GE |
| Steam Turbine | 125 MW x 2 sets | TCDF | GE |
| Generator (GT) | 125 MVA x 4 sets | Hydrogen Cooling Synchronous | GE |
| Generator (ST) | 125 MVA x 2 sets | | |
| HRSG | HP= 145.27 t/h and LP=181.08 t/h x 4 sets | Horizontal Natural Circulation | Hangzhou |

(b) Performance

| Items | Guarantee Value |
|--------------------------|-------------------------------------|
| Plant Efficiency (LHV,%) | 49.6 % at 15°C, 60%RH, 1,013mbar |
| Output (MW) | 750 MW |
| Auxiliary Power (kW) | 21.100 kw at 15°C, 60%RH, 1,013mbar |
| NOx (ppm) | 41 ppm at 15% of O ₂ |

(c) Notices

- i) The gas turbine in the Soyo 1 CCGT can fire either gas or diesel oil. The generation started

using diesel oil and then after completion of the pipeline, the fuel was changed to gas. As of January 2018, completion inspection for 3 of 4 gas turbines has been completed. Construction work is carried out by GAMEEC and transferred to PRODEL after completion.

- ii) Sonogas, the constructor of the gas pipeline, completed the construction in October 2017. The pipeline has a 20 inch diameter and runs a distance of 8 km from LNG terminal to Soyo 1 CCGT. The gas supply volume is 114 MMscfd, a little more than one-tenth of the 1,000 MMscfd production capacity of the LNG terminal.
- iii) As for the gas price, the supplier (Sonogas) requires \$5 / MMBtu, while the operation side (PRODEL) requires \$3 / MMBtu. Finally the gas price was agreed as \$3 / MMBtu after negotiations.
- iv) The price of diesel oil is the same as that used in other areas of Angola.
- v) The National Bank of China is financing the Soyo 1 CCPP project.
- vi) Land for extension of the thermal power plant has already been prepared. Since the land Soyo 1 CCGT occupies is designated as an industrial zone by the government, the plants in the area (excluding a thermal power plant) will be continuously developed and the land occupied by the industrial zone will be expanded in the future.
- vii) The Soyo 2 CCGT is the only thermal power plant that construction is decided. Development of Soyo 2 is planned by IPP, and concession was given to an Angolan domestic capital (AE Energia). However, issues such as law improvement and PPA for IPP development are still remained, and the specific development schedule has not been determined.
- viii) At present, Sonangol is developing a Gas Master Plan. The plan calls for the development of a gas pipeline from Soyo LNG Terminal to a number of Angola's big port cities such as Luanda, Benguela, and Namibe, gas transportation by railway, and conversion from diesel oil to natural gas at the existing diesel power plants.
- ix) Some 570 persons are working on the construction of Soyo 1 CCPP, of whom 55% are locals.

(d) Photographs



View of Soyo 1 CCGT from the access road



No. 4 gas turbine



Steam turbine building



400 kV GIS

6.2 Current power development plan

There is no power development plan issued at present, and the year of development for each candidate generation plant necessary to meet the demand increase is undetermined.

A study on candidate generation plants has been conducted (listed in “Energia 2025”). Meanwhile, GAMEK is carrying out the design of the candidate power plants and revising the initial plans in the study. Therefore, GAMEK’s design is currently the latest plan.

(1) Candidate projects for hydropower

Candidate hydropower projects are listed in Table 6-7. Among these projects, large-scale projects above 2,000 MW, that is, the Lauca and Caculo Cabaca hydropower stations, have already reached the construction stage. The progress of the other alternatives ranges from the project-finding stage to feasibility study stage. Therefore candidate projects of the 1,000 MW class still remain in the list. Meanwhile, the number of large-scale projects is limited. The total installed capacity of the candidate projects, including medium- to small-scale projects, is only about 10 GW.

Table 6-7 Candidate hydropower projects

| Type | Plant name | Owner | Location | | Installed capacity (MW) | Project cost (Mill. USD) | Note |
|------------|---------------------------|--------------|----------|----------------|-------------------------|--------------------------|--------------------------|
| | | | Area | Province | | | |
| Hydropower | Lauca | PRODEL | North | Malanje | 2,067 | 4,300 | |
| | Caculo Cabaça | PRODEL | North | Kwanza Norte | 2,100 | 4,500 | |
| | Zenzo | PRODEL | North | Kwanza Norte | 950 | N/A | |
| | Tumulo do Cacador | PRODEL | North | Kwanza Norte | 453 | 1,041 | |
| | Cafula | PRODEL | North | Kwanza Sul | 403 | 1,121 | |
| | Genga | PRODEL | North | Kwanza Sul | | N/A | |
| | Benga | PRODEL | North | Kwanza Sul | 987 | N/A | |
| | Sanga | | North | Kwanza Sul | | N/A | |
| | Quilengue | PRODEL | North | Kwanza Sul | 217 | N/A | |
| | Cachoeira | | North | Kwanza Sul | | N/A | |
| | Carianga | | North | Kwanza Norte | 381 | 1,295 | |
| | Bembeze | | North | Kwanza Norte | 260 | 768 | |
| | Quissonde | | North | Kwanza Sul | 121 | 838 | |
| | Cuteca | | North | Kwanza Sul | 203 | 734 | |
| | Lomaúim (extension) | IPP | Central | Benguela | 160 | 385 | |
| | Cacombo | IPP | Central | Benguela | 29 | 319 | |
| | Calangue | IPP | Central | Benguela | 190 | 471 | |
| | Salamba | | Central | Bie | 48 | 324 | |
| | Cunje | | Central | Bie | 8 | | |
| | Quissuca | IPP | Central | Kwanza Sul | 121 | 567 | |
| | Capitongo | | Central | Benguela | 41 | 239 | |
| | Calindo | | Central | Benguela | 58 | 187 | |
| | Baynes | PRODEL (50%) | South | Namibe | 300 | 660 | 300 of 600 MW is Namibia |
| | Mucundi | | South | Cuando Cubango | 74 | 538 | |
| | Jamb Ya Oma | IPP | South | Huila | 75 | 500 | |
| | Jamb Ya Mina | IPP | South | Huila | 180 | 710 | |
| | HPP Chiumbe Dala | | East | Lunda Sul | 8 | 30 | |
| | Chicapa II (extension) | IPP | East | Lunda Sul | 100 | N/A | |
| | Luachimo (extension) | | East | Lunda Norte | 34 | N/A | |
| | Cuango | IPP | East | Lunda Norte | 30 | 158 | |
| | Luapasso (H.S.Luapasso) | IPP | East | Lunda Norte | 25 | 206 | |
| | Camanengue (H.S.Luapasso) | IPP | East | Lunda Norte | 29 | 173 | |
| | Samuela (H.S.Luapasso) | IPP | East | Lunda Norte | 15 | 93 | |
| | | | | Total = | 9,666 | | |

(2) Candidate projects for thermal power

Most of the candidate thermal power projects are planned as expansions or replacements of the existing small- to medium-scale thermal power stations running small diesel or gas turbines. Development for only one large-scale candidate project, the Soyo 2 thermal power station, has been decided. There are no other particular projects planned so far.

(3) Development plan for renewable energy plants

Currently only one biomass thermal plant and several small hydropower plants exist as renewable generation plants.

Small hydropower plants are mainly constructed and used for electricity supply to un-electrified areas. A further development by an IPP is planned, but the total capacity of the plan is only about 60 MW.

Regarding biomass generation, one 50 MW power station is in operation. “Energia 2025” describes a new 500 MW development, but the development plan at present is only 100 MW in total, including waste generation.

Regarding solar power and wind power generation, there are no power plants developed so far. Planning for a development based on a potential study has ongoing, however. Table 6-8 and Table 6-9 show the expected candidate projects listed by MINEA. “Energia 2025” describes the development of a 100 MW of solar power project and 100 MW wind power project. Several other plans for candidate projects have been progressed, but these are not included in the abovementioned list. It thus seems that development will be larger scale than the plans stated in “Energia 2025” overall.

Table 6-8 Candidate wind power generation projects

| No. | Name of Project | Capacity (MW) | Note |
|-------|-----------------|---------------|--------------|
| 1 | BENIAMIN | 52 | Benguela |
| 2 | CACULA | 88 | Huila |
| 3 | CHIBIA | 78 | Huila |
| 4 | CALENGA | 84 | Huambo |
| 5 | GASTAO | 30 | Kwanza Norte |
| 6 | KIWABA NZOJI I | 62 | Malanje |
| 7 | KIWABA NZOJI II | 42 | Malanje |
| 8 | MUSSEDE I | 36 | Kwanza Sul |
| 9 | MUSSEDE II | 44 | Kwanza Sul |
| 10 | NHAREA | 36 | Bie |
| 11 | TOMBWA | 100 | Namibe |
| Total | | 652 | |

Table 6-9 Candidate solar power projects

| No. | Name of Project | Capacity (MW) | Note |
|-------|------------------|---------------|----------|
| 1 | BENGUELA | 10 | Benguela |
| 2 | CAMBONGUE | 10 | Namibe |
| 3 | CARACULO | 10 | Namibe |
| 4 | CATUMBERA | 10 | Benguela |
| 5 | LOBITO/CATUMBERA | 10 | Benguela |
| 6 | LUBANGO | 10 | Huila |
| 7 | MATALA | 10 | Huila |
| 8 | QUIPUNGO | 10 | Huila |
| 9 | TECHAMUTETE | 10 | Huila |
| 10 | NAMACUNDE | 10 | Cunene |
| Total | | 100 | |

6.3 Preparation for a long-term power development plan by 2040

6.3.1 Setting conditions for an economic evaluations study using PDPAT

(1) Supply reliability

LOLP (Loss of Load Probability) and LOLE (Loss of Load Expectation) are both commonly used as indicators of the supply reliability of a power system. The latter LOLE has been popularly adopted around the world. Considering the sample LOLE values for foreign countries shown below, the target LOLE for the Angola power system is set at 24 hrs/year, that is a value used for many emerging countries.

- France, UK: 3 hours/year
- Developing country: 5 days/year
- Emerging country: 24 hours/year

(2) Construction cost of power stations

The construction cost of a new power station varies widely in accordance with the conditions of the development location. In some cases in present-day Angola, development studies have not been completed for the power stations to be considered in long-term development plans. Accordingly, a standard construction cost for each type of power station is assumed and used for the further study.

Standard construction costs have not been set, however, for wind power and solar power stations. In those cases, therefore, constant power price for all of the generated energy, a price equivalent to the power purchase cost for IPP developers, is adopted.

Table 6-10 Construction unit cost for each type of power

| Type | | unit capital cost (\$/kW) | Note |
|---------------|----------------|---------------------------|-------------------------------|
| Hydropower | Large scale | 2,700 | Average in Angola |
| | Medium/Small | 5,400 | ditto |
| Thermal power | Combined Cycle | 1,200 | Construction cost of SoyoTPP |
| | Gas Turbine | 650 | International price |
| | Diesel | 900 | International price |
| Renewable | Wind | - | Considered in generation cost |
| | Solar | - | Considered in generation cost |

(3) Fuel types and efficiencies of thermal power plants

The fuel types and heat efficiencies of the different candidate types of thermal power plant are set as shown in Table 6-11.

Table 6-11 Fuel types and efficiencies of thermal power plants

| Type of generation | | Fuel type | Heat efficiency (%) |
|--------------------|----------------|--------------|---------------------|
| Thermal power | Combined Cycle | NG, LPG, LNG | 56% |
| | Gas Turbine | NG, LPG | 38% |
| | | LFO | 36% |
| | Diesel | LFO | 42% |
| | Biomass | Bio fuel | 30% |

(4) Conditions for economic evaluation

There are no fixed ways to evaluate the finances of the power stations in Angola. Therefore, general calculation method and conditions for the calculations are adopted as shown in Table 6-12.

Table 6-12 Conditions for financial evaluation

| Type of generation | | Lifetime (years) | Depreciation | Interest (%) | Salvage (%) | O&M others (%) | Annual Expenditure Rate (%) |
|--------------------|----------------|------------------|----------------------|--------------|-------------|----------------|-----------------------------|
| Hydropower | | 40 | Straight line method | 10 | 0 | 1 | 11.2 |
| Thermal power | Combined Cycle | 25 | | | | 3 | 14.0 |
| | Gas Turbine | 20 | | | | 5 | 16.8 |
| | Diesel | 20 | | | | 5 | 16.8 |
| | Biomass | 20 | | | | 2 | 13.8 |
| Renewable | Wind | 20 | | | | 1 | 12.8 |
| | Solar | 20 | | | | 1 | 12.8 |

(5) Forced outage rate

Recent records of the forced outage rates of the existing power stations, that is the rates of stoppage hours per year (excluding scheduled maintenance), are shown in Figure 6-7. The forced outage rates for both hydropower and thermal power have been on downward trends. As of 2017, the rates for thermal power and hydropower stood at about 8% and 2%, respectively. It seems feasible to maintain the current level in the future. These current records are adopted for the development planning.




Figure 6-7 Actual records of the forced outage rates of power stations

(6) Calorific values and greenhouse gas emissions of thermal power

The calorific values and greenhouse gas emissions of the different fuels used for thermal power generation are assumed to be the general values shown in Table 6-13 below.

Table 6-13 Calorific values and greenhouse gas emissions per unit for different fuels

| Fuel | Calorific value (kcal/kg) | CO ₂ emission (kg-C/1000kcal) |
|---------|---------------------------|--|
| LNG | 13,000 kcal/kg | 0.05735 |
| NG | 9,800 kcal/m ³ | 0.05735 |
| LPG | 12,000 kcal/kg | 0.06857 |
| HFO | 9,200 kcal/L | 0.08087 |
| LFO | 9,100 kcal/L | 0.07865 |
| Biomass | 1,200 kcal/m ³ | - |

(7) Fuel cost

Future fuel prices for thermal power for the long-term power development planning in this study are set based on the current international price and the IEA's long-term forecast for the New Policy Scenario, as shown in Table 6-14 below.

Table 6-14 Fuel price for development planning

unit: UScent/Mcal

| Year | Crude Oil | LFO | HFO | LPG | NG | LNG |
|------|-----------|-------|-------|-------|-------|-------|
| 2015 | 3.281 | 3.948 | 3.919 | 4.041 | 1.036 | 4.087 |
| 2016 | 3.641 | 4.382 | 4.349 | 4.485 | 1.155 | 4.032 |
| 2017 | 4.001 | 4.815 | 4.780 | 4.928 | 1.275 | 3.976 |
| 2018 | 4.361 | 5.249 | 5.210 | 5.372 | 1.394 | 3.921 |
| 2019 | 4.722 | 5.682 | 5.640 | 5.816 | 1.514 | 3.865 |
| 2020 | 5.082 | 6.116 | 6.071 | 6.259 | 1.633 | 3.810 |
| 2021 | 5.288 | 6.363 | 6.316 | 6.513 | 1.685 | 3.901 |
| 2022 | 5.494 | 6.611 | 6.562 | 6.766 | 1.737 | 3.992 |
| 2023 | 5.699 | 6.859 | 6.808 | 7.020 | 1.789 | 4.083 |
| 2024 | 5.905 | 7.107 | 7.054 | 7.274 | 1.840 | 4.175 |
| 2025 | 6.111 | 7.354 | 7.300 | 7.527 | 1.892 | 4.266 |
| 2026 | 6.317 | 7.602 | 7.546 | 7.781 | 1.944 | 4.357 |
| 2027 | 6.523 | 7.850 | 7.792 | 8.034 | 1.996 | 4.448 |
| 2028 | 6.729 | 8.097 | 8.038 | 8.288 | 2.048 | 4.540 |
| 2029 | 6.934 | 8.345 | 8.284 | 8.541 | 2.099 | 4.631 |
| 2030 | 7.140 | 8.593 | 8.529 | 8.795 | 2.151 | 4.722 |
| 2031 | 7.224 | 8.694 | 8.629 | 8.898 | 2.211 | 4.742 |
| 2032 | 7.308 | 8.794 | 8.729 | 9.001 | 2.271 | 4.762 |
| 2033 | 7.391 | 8.895 | 8.829 | 9.104 | 2.330 | 4.782 |
| 2034 | 7.475 | 8.995 | 8.929 | 9.207 | 2.390 | 4.802 |
| 2035 | 7.558 | 9.096 | 9.029 | 9.310 | 2.450 | 4.822 |
| 2036 | 7.642 | 9.197 | 9.129 | 9.413 | 2.510 | 4.841 |
| 2037 | 7.726 | 9.297 | 9.229 | 9.516 | 2.569 | 4.861 |
| 2038 | 7.809 | 9.398 | 9.329 | 9.619 | 2.629 | 4.881 |
| 2039 | 7.893 | 9.499 | 9.428 | 9.722 | 2.689 | 4.901 |
| 2040 | 7.977 | 9.599 | 9.528 | 9.825 | 2.749 | 4.921 |

6.3.2 Selection of the generation type for use in development planning

Hydropower development has so far played the main role in development plans. As the potential of large hydropower remains and the generation costs are lower, constant development in the future is preferable. Meanwhile, even if priority is given to the development of large-scale hydropower, the supply capacity seems to be insufficient over the medium to long term. Hence, the development of power sources in addition to hydropower projects will be needed. The optimization of an

economically superior power source composition will therefore have to be considered. When selecting the candidate power types using the screening method described in Chapter 4, the conditions set in section 6.3.1 are used. The annual expenditure of each type of generation in the years 2018 and 2040 are shown in Figure 6-8 to Figure 6-11.

As a result of the examination discussed below, gas turbine (LPG), combined cycle (natural gas), and large hydropower are selected as the major types of candidate generation facility to be used in this master plan.

(1) Peak supply

Since the fuel cost of natural gas is somewhat lower, thermal power facilities using natural gas have an advantage for peak suppliers. Meanwhile, natural gas supply is currently available only at Soyo which is far from the demand center, and huge cost and time would be required for the development of gas supply facilities such as a new pipeline or new gas field. For the development of a peak supplier at a location other than Soyo, it will therefore be necessary to consider another type of fuel (LPG, Diesel oil etc.) that can be more easily transported as a realistic option.

Diesel and gas turbine (GT) are available as candidates for peak supply power using these gases as fuel, and GT is economical. Also, the difference between the use of diesel and LPG as fuel for GT is small (see Figure 6-10). Therefore, GT is selected as the peak supplier, and LPG is selected as fuel by virtue of the easier transport and facility maintenance associated with LPG.

Pumped-storage power plants (PSPP) are generally regarded as candidates for peaking power supply. At present, however, the effect of introducing PSPPs cannot be evaluated, as no low-cost or surplus electricity is available for pumping up water. It will be preferable, therefore, to evaluate the needs for PSPP in accordance with changes such as the generation cost reductions for solar/wind power and the introduction of large-scale development policies to combat global warming.

(2) Middle supply

Combined cycle gas turbine (CCGT) using natural gas for fuel is the most advantageous from an economic view point. Given the aforementioned supply restriction of natural gas, however, it will be necessary to consider the use of LPG/LNG as fuel for CCGT. In consideration of the choice of fuel, therefore, CCGT is taken as a promising candidate for the middle supply.

(3) Base supply

Large-hydropower is adopted as the base supplier.

The project cost and generated energy of a hydropower station vary widely in accordance with the site conditions. The light blue lines in the figures show the average of large hydropower based on Angola's development plans.

The average of medium/small-scale hydropower is also shown in the figures. As the annual expenditure of medium/small-scale hydropower is higher than that for other power sources, the preferred approach is to first evaluate economic characteristics of the particular plans individually and then decide on development when the project is found to be economically advantageous or when other factors such as remote locations would make it difficult to supply electricity by other mean. Therefore, medium/small scale hydropower is excluded from consideration in this master plan.




Figure 6-8 Annual expenditure by generation type (2018)




Figure 6-9 Annual expenditure by generation type (2040)




Figure 6-10 Character of peak facilities (2040)




Figure 6-11 Character of middle facilities (2040)

6.3.3 Basic conditions for optimization of development plan

The optimization study on the development plan will be conducted by applying PDPAT. The specifics of development planning and optimization will be studied under the following conditions.

(1) Candidate projects

The existing candidate projects listed in the development plan basically take priority, though there are few thermal power candidates with large-scale and high-efficiency. In the event of any shortage of candidate projects, a dummy project will be introduced.

(2) Monthly hydropower generation

Monthly generation data should be prepared for each hydropower station as a necessary step for the optimization studies using PDPAT.

Since river discharge in Angola changes widely in a year as described in section 6.1.2, it is necessary for a study of supply demand balance to prepare expected monthly generation of each hydropower station considering regulation effect of the reservoir. The following factors, however, make it difficult to prepare all of the necessary monthly inflow and generation data for each hydropower station under a uniform condition.

- Actual records on parameters such as the inflow discharge and generation of existing power stations have not yet to be organized and in some cases are missing.
- The monthly generation has not yet been planned for many of the candidate projects, especially the projects not yet extensively studied.

In consideration of the current situations, the expected monthly generation of each existing and candidate hydropower project is estimated by simple simulation study based on the available project features and typical river discharge data of the hydropower station as assumption.

6.4 The most economical power supply configuration in 2040

A study on the most economical power supply in the year 2040, the final year and achievement point set under the long-term power development plan, has been conducted using PDPAT based on the currently existing power supply facilities. Necessary power supply will be developed to meet the demand increase in consideration of the retirement of aged power facilities. The power sources to be newly developed in the study are (1) gas turbine (LPG fired), (2) combined cycle (natural gas fired), and (3) large-scaled hydropower, (the sources selected in the previous section).

6.4.1 Hydropower development plan

As described in section 6.3.2, since the potential of large hydropower remains and the generation cost is lower, constant development in the future will be preferable.

There are however, important issues to address in the development of large-scaled hydropower.

- Fund procurement is a challenge since project cost is enormous.
- Natural and social EIAs are essential. Mitigation measures according to local conditions are required even if development is evaluated as appropriate.

As both of the aforementioned issues require time-consuming steps in the procedures required to have project implementation improved, there are limits in reality to the number of simultaneous developments possible.

Therefore the largest/earliest hydropower development plan, thought to be feasible for development in this master plan, is set based on the following assumptions.

- The interval between new developments is set as 3 years in consideration of approval procedures etc.
- In order to avoid risks such as delays due to congestion of construction work, the construction of simultaneous projects at one river is avoided as much as possible. (If one power plant is constructed at each of the four major rivers where hydropower plants are planned, a maximum of four construction works will be conducted in parallel).
- The duration of construction is 8 years, including 1 year for EIA approval procedures.

Figure 6-12 shows the development pattern for hydropower up to 2040 (prepared in consideration of past development plans).




Figure 6-12 Development pattern for large hydropower by 2040

6.4.2 Relationship between LOLE and Reserve Capacity

LOLE, an indicator of the reliability of a power system, is not directly related to the power supply capacity (MW). For that reason, LOLE cannot be used to easily grasp how much power supply capacity needs to be developed in a power development plan to secure reliability. In Japan, the reserve margin rate is generally used instead of LOLE. The common practice is to obtain the relationship between the reserve margin rate and LOLE in advance, convert LOLE to the reserve margin rate, find the required supply capacity, and use it for the power development planning.

The reserve margin rate corresponding to the 24-hour of LOLE is formulated by PDPAT and RETICS. For the power development plan, the plan shown in Figure 6-12 is adopted for the hydropower development. Thermal power, which consists of CCGT and GT, will be developed to fill up the insufficient supply capacity. The composition ratio between CCGT and GT was set to the optimum ratio described in the next section. The relationship between LOLE and the reserve margin rate is calculated based on the above-mentioned development plan.

The calculation results are shown in Figure 6-13 and Figure 6-14. While the required reserve margin rate generally increases as the target LOLE gets smaller, this relationship varies in accordance with the power supply configuration, demand profile, etc. Figure 6-14 shows the necessary reserve margin rate for each year up to 2040. The required reserve margin gradually decreases, reaching about 11% after 2030. This value, 11%, is therefore set as the target.

The decrease in the required reserve margin rate year by year is mainly attributable to the yearly increases in the share of thermal power supply capacity and gradually decreasing influence of hydroelectric power generation with large variations due to river discharge fluctuations.




Figure 6-13 Relationship between LOLE and reserve margin rate




Figure 6-14 Necessary reserve margin rate equivalent to LOLE of 24 hrs

6.4.3 Most economical power supply composition ratio by using PDPAT

In this section, the power supply composition that minimizes the total cost in the year 2040, the final year of the power master plan, is considered.

As described in Chapter 5, peak demand in 2040 is forecasted to reach 11.2GW, or 2.7 times the actual peak demand recorded in 2017. Moreover, renovation of the existing power facilities is also required. Hence, the requirement of supply capacity appears to increase 13 GW. In this section, the most economical configuration in 2040 among large hydropower, combined cycle (CCGT), and gas turbine (GT) is examined.

The following assumptions are adopted for the calculation using PDPAT

- The target year is 2040
- The hydropower development pattern shown in 6.4.1, a realistic equivalent to the maximum, is adopted.
- The reserve margin rate is set at 11%, is the value selected in 6.4.2. GT shares the capacity for the reserve margin, as it has a lower fixed cost.
- The supply configuration ratio is calculated in the month with the lowest reserve margin in the year and defined as the ratio of the available supply (excluding the capacity corresponding to the reserve margin) of each power source to the peak demand of the month.

(1) Optimum share of GT

Figure 6-15 shows the relation between the total cost per year and the configuration ratio of GT, calculated using PDPAT. The annual cost is lowest when the configuration ratio of GT is 12%. When the ratio exceeds 12%, the cost sharply rises because the increased generation using the lower-efficiency GT pushes up the fuel cost. It seems therefore reasonable to set the configuration ratio of GT at 12%, and not to exceed that level in the development plans.

It is economical for GT, the power source with the lowest fixed cost, to share the supply capacity for the reserve margin, so the combined amount capacity of GT makes up 23% of the demand.




Figure 6-15 Configuration ratio of GT and total annual cost (year 2040)

(2) Minimum-cost configuration of power supply in the year 2040

Peak demand in the year 2040 appears in December. Meanwhile the supply-demand balance is the most severe in November in a year, since the supply capacity of hydropower declines during the drought period. Figure 6-16 shows the power configuration ratio when the ratio of GT is set to 12% in the November 2040 section. This configuration ratio corresponds to the future target value, and the

final power development plan formulated for each year up to 2040 needs to approach this power configuration ratio.




Figure 6-16 Cost minimum configuration of power supply in the year 2040 (November balance)

6.5 Formulation of the power development plan

6.5.1 Power development plan (Draft) by 2040

The power development plan (draft) for each year up to 2040 is formulated based on the following conditions. Figure 6-17 shows the proposed draft plan.

- The types of power plant newly developed are large hydropower, combined cycle (CCGT), and gas turbine (GT).
- The Reserve margin rate is set as 11% in November, when the supply-demand balance is strict. The supply shortage is acceptable, however, since new development will not be available in time by 2018.
- The retirement of power facilities at the end of their service lives is taken into account to the power supply capacity.
- Available supply capacity of hydropower calculated by PDPAT is used for evaluation of supply-demand balance every month.
- The development pattern shown in Figure 6-12 is adopted for hydropower development. If the supply capacity is still insufficient, a thermal power plant (GT, CCGT) will be developed.
- The configuration ratio of GT is set close to 12%, within a range not exceeding 12% of demand. The shortfall capacity is filled by CCGT.

As a result of the trial, the following developments of power facilities are required by 2040.

Hydropower: 7,150 MW, including the Lauca HPP now under construction

CCGT: 4,125 MW (750 MW class, 5.5 sets), including Soyo and Soyo2 TPP

GT: 2,250 MW (125 MW class, 18 sets)




Figure 6-17 Power development plan (Draft)

6.5.2 Impact of introducing renewable energy

As stated in Section 6.2(3), Angola is aiming at introducing wind power and solar power generation. At present, eleven (11) wind power projects (652 MW) and ten (10) solar power projects (100 MW) are nominated as priority candidates.

These project plans, however, have only reached preliminary phases. Because of this, the specifications of each project necessary for evaluating the supply-demand balance, such as expected monthly generation etc., have yet to be made public. Since the output of wind/solar power generation fluctuates with changes in natural conditions, a detailed evaluation based on measured data will be required for an accurate determination of the capacity is available to be counted towards the available peak supply capacity. It will be indispensable to evaluate feasibility and establish specific generation plan for each project in the future.

In this section, assuming supply capacity based on the proposed installed capacity and average plant factor, and then impact of introducing wind/solar power to the greenhouse gas reduction and the influence on the annual total cost increase of the development plan (Draft) described in the previous section are examined. (Comparison was made in the year 2040).

As a result, the introduction of wind/solar power is effective for greenhouse reduction as shown by the orange broken line/right axis in Figure 6-18 and Figure 6-19, since CO₂ emission decreases in step with increases in the wind/solar power capacity.

In this examination, generation cost is indicated by parameters centered on current cost (wind power, 14 UScents/kWh; solar power, 6 UScents/kWh) as assumption. The impact on the annual total cost depends on the generation cost for both wind and solar power. When 1000 MW is installed with the central cost, the increase of the annual total cost is slight for solar power, and stand at 5% for wind power.

Meanwhile, the reduction of greenhouse gas emissions by introducing renewable energy is an important policy in Angola. Further, the small capacity of the prioritized projects translates into a small influence on the development plan overall. Therefore, a power development plan including the prioritized wind/solar project is prepared and set as the basic plan.




Figure 6-18 Impact of introducing wind power (year 2040)




Figure 6-19 Impact of introducing solar power (year 2040)

Regarding biomass, project concepts have been conceived but no specific power generation plans have been determined. Hence, biomass will not be evaluated until a plan is concretized in the future. Biomass will thus be left out of the current development plan, as in the case with small and medium hydropower.

6.5.3 Power development plan with renewable energy (base plan)

(1) Power development plan

Power generation plan including wind/solar power has been established based on the draft plan described in the previous section.

Since the plan for wind/solar power is still in the preliminary stage, the nominated projects are assumed to develop during 10 years from 2028 after a planning period of ten years. The examination indicated no change in the development plan for thermal power and simply adding the wind/solar power projects to the draft plan becomes the optimum. This development plan is set as the basic plan.

The generation outputs of wind/solar power projects fluctuate widely since wind speed and solar radiation change under changing natural conditions. Output adjustments according to the requirements are therefore unavailable, and the available capacity necessary to secure the supply-demand balance is expected to be far smaller than the installed capacity. Also, the peak of electricity demand occurs at night, when solar power cannot generate. If on the other hand, the dispatching conditions are met, hydropower generation can be increased during the peak period as follows: (1) Store the water in the reservoir by reducing the generation of hydropower in accordance with the wind/solar generation, then (2) increase hydropower generation during peak periods using the stored water. Introducing wind/solar power projects into the power development plan is a complicated task. It will therefore be necessary to estimate the expected available monthly generation and hourly output for each candidate wind/solar power project. For the purpose, investigation and evaluation of the characteristics of hourly fluctuation of each month based on statistical review of the exact data of each planned location are desirable.

As of this time, however, none of the data necessary for evaluation is available. For this reason, the expected output in each hour of each month is assumed based on the installed capacity and average plant factor, making reference to the general characteristic values. Based on these assumed values, examination using PDPAT is conducted to grasp the influence. It will therefore be necessary to revise the power development plan when the design of each candidate project advances and specific generation plans are studied.

(2) Output of supply-demand simulation using PDPAD (base case)

Figure 6-20 to Figure 6-25 show the supply-demand balance in each month in 2040, the final year of the master plan, and an example of the load dispatching for one day.

(3) Power development of each year by 2040

The recommended power development plan, the base plan, is shown in Figure 6-26. The supply-demand balance of the most severe month in each year by 2040 is shown in Figure 6-27. The share of hydropower in the peak supply configuration decreases year by year, and hydropower and thermal power are about the same size in 2040.

Figure 6-28 shows the relationship between the maximum demand in a year and the installed capacity of the power stations, for reference. As the available supply capacity of hydropower is restricted by season, the amount of installed capacity exceeds the demand in the figure. In fact, however, the available supply capacity is sometimes lower than installed capacity by season. The evaluation of the supply-demand balance will therefore have to be based on the most severe month of the year, as shown in Figure 6-27.

The power generation cost for each year and the unit cost per kWh are shown in Figure 6-29 and Figure 6-30, respectively. The annual power generation cost increases year by year as the supply capacity increases in step with demand increases. The fuel cost will also gradually rise. On the other hand, the unit price remains stable over the long term.




Figure 6-20 kW balance of each month in 2040




Figure 6-21 kWh balance of each month in 2040




Figure 6-22 Example of load dispatch for one day <dry season, November 2040>




Figure 6-23 Example of load dispatch for one day <flood season, May 2040>




Figure 6-24 Example of weekly load dispatch <dry season, November 2040>




Figure 6-25 Example of weekly load dispatch <flood season, May 2040>




Figure 6-26 Power development plan (base case)




Figure 6-27 Supply–demand balance (base case, peak balance in November)




Figure 6-28 Supply–demand balance (base case, installed capacity-annual peak balance)




Figure 6-29 Annual generation cost (base case)




Figure 6-30 Unit cost of generation (base case)

6.5.4 Greenhouse gas emission in the base case

The annual amount of greenhouse gas emissions produced each year by power generation type is shown in Figure 6-31. As the figure illustrates, annual emissions are greatly reduced by the new development of large hydropower, while on the whole greenhouse gas emissions are on an increasing trend due to the increases in thermal power generation and electric power demand.

The figure also shows the impact of the introduction of wind/solar power (capacity: 752 MW in total) to the total emission. The amount of reduction in 2040 resulting from introduction of wind/solar power is about 600 kt-CO₂ (about 10%). The introduction mitigates the rise in emissions, but not enough to reverse the trend of overall increase. To suppress the increase in emissions, a larger scale of development will be required for renewable energy (wind/solar power) or hydropower.

Figure 6-32 and Table 6-15 show greenhouse gas emission from Angola's Intended Nationally Determined Contribution (DRAFT INDC) and that from power generation. The share of greenhouse gas emissions from power generation is low, totaling only about 3% (in 2030) of the assumed value of the "Conditional scenario" (target value) of INDC.




Figure 6-31 Greenhouse gas emission (base case)




Figure 6-32 Angolan reduction plan (DRAFT INDC) and base case emission

Table 6-15 Expected emission from power generation (base case) and DRAFT INDC

| | | 2005 | (2017) | 2020 | 2030 |
|---|------------------------|--------|-----------|---------|---------|
| Draft INDC | BAU scenario | 66,812 | (112,400) | 125,778 | 193,250 |
| | Unconditional scenario | | | | 125,612 |
| | Conditional scenario | | | | 96,625 |
| Expected emission from power generation (base case) | | - | 2,300 | 800 | 3,000 |

Remark: INDC value in 2017 is interpolated between 2005 and 2020

6.6 Scenario case studies

6.6.1 Setting the scenario

A number of case studies have been conducted based on the proposed power development plan discussed in the previous section as a base case scenario (base case). The background and focal points of these studies are as follows.

- Delays in the development schedules for the power stations
 - ✧ Process delays in power development have a great influence on the optimum power supply configuration. In the case of Angola, since the development scales of hydropower projects are large, the delay in hydropower development compounds the negative impacts on the reliability of the power system.
 - ✧ Development of hydropower projects are often subject to delays all over the world. This risk is never small.
 - ✧ Another power source such as CCGT can conceivably be developed as an additional mitigation measure, but doing so would increase greenhouse gas emissions. The degree of influence is therefore considered in the study.
- Development location of CCGT
 - ✧ The fuel price of natural gas for CCGT is relatively low. At present, 400 kV transmission lines with a capacity of 2,000 MW (N-1 criteria) have already connected Soyo and Luanda. Soyo, the fuel supply point, is therefore the most economical location for development of CCGT.
 - ✧ The third and subsequent developments, however, require additional 400 kV transmission lines, which is costly. The transmission loss also increases when electric power is transmitted from Soyo to Luanda, and even to Benguela, a demand center in the central area. Taking these points into consideration, the promotion of development at Soyo after the third project does not always seem to offer economic advantages. In addition, the

power flow of the power transmission system becomes a one-sided flow from north to south, which is unfavorable for system stability.

- ✧ As a countermeasure against these issues, CCGT could conceivably be developed near a demand center, especially Lobito port which is near Benguela, and/or Namibe port, which is near the south demand center. In that case, however, as mentioned in Chapter 3, it would be desirable to adopt LPG for the fuel for CCGT until a supply system for natural gas / LNG is established (first step). In such a scenario, greenhouse gas emissions would increase by an estimated 20% compared with LNG. This emission increase must be considered as a factor.
- Additional development of renewable energy
 - ✧ As stated in Section 6.5.4, greenhouse gas emissions in the base case are greatly increased by the development of power sources due to increased demand. Though the emissions from power generation are relatively small compared to the Draft INDC, a case with reduced emission is examined.
 - ✧ The development of large hydropower effectively reduces, but large hydropower is hampered by the various restrictions as stated in Section 6.4.1 and is practically difficult to develop in a short period.
 - ✧ Accordingly, a scenario to develop additional wind /solar power generation is examined in this section.

6.6.2 Delays in the development of the power stations

(1) Risk of delays in hydropower development

When the start of operation of a hydropower station is delayed, the supply power is reduced. Figure 6-33 shows the supply reserve ratio when hydropower development is delayed by 1, 2, and 3 years. Year when supply reserve cannot be secured are shown in orange in the figure, and years when the supply power is below demand are shown in red.

This examination reveals that the supply capacity decreases with development delay, and that the influence of delays is substantially larger in the nearest years. This conspicuous impact of delay seems to stem from the large scale of the hydropower relative to the demand scale. As the delay increases, the influence increases. Measures should therefore be promptly taken as soon as a delay is foreseen.




Figure 6-33 Influence of delays in hydropower development

(2) Risk of demand rises (equivalent to delay of hydro/thermal power development)

As in the preceding section, the effect in the case where the electric power demand exceeds the assumed value was examined. This is equivalent to the case where there are delays in the development of not only hydropower but in all the power sources including thermal power plants.

- Demand rise one year forward (= one-year delay of new power station development)
- Demand rise two years forward (= two-year delay of new power station development
= one-year development delay + one-year demand rise)
- Demand rise three years forward (= three-year delay of new power station development
= two-year development delay + one-year demand rise
= one-year development delay + two-year demand rise)

The reserve margin ratio for each case is shown in Figure 6-34. The supply reserve is reduced to about half of the required amount in almost all the subsequent years when the demand rise is forwarded by more than two years (power development is delayed by two years), which makes stable supply impossible. Moreover, a remarkable supply shortage continues when the demand rise is forwarded by three years. When the actual demand exceeds the assumed demand, therefore, the development plan must be revised from the next year to secure supply capacity.




Figure 6-34 Influence of demand rise (=delay in the development of all power station types)

(3) Mitigation measures and its influence

If the electric power demand fluctuates more than one year (or the start of the power plant operation is delayed for one year), measures such as the introduction emergency power supply should be implemented as soon as possible. In this section, additional cost and increase of CO₂ emission, in the case additional GT generated by LPG for fuel is introduced as an emergency measure, are examined.

As a result, the influence continues for longer than a single year. As shown in Figure 6-35 and Figure 6-36, expenses rise and greenhouse gas emissions increase. These increases appear continuously until the supply capacity is secured. Countermeasures must therefore be taken as soon as such an event is foreseen, including revision of demand forecasts and the power development plan itself.




Figure 6-35 Cost increase for introducing emergency power supply




Figure 6-36 Increase of CO₂ emission by introducing emergency power supply

6.6.3 Development location of CCGT

(1) Conditions and issues

Regarding the development plan for thermal power, the Soyo 2 TPP is posted after completion of the Soyo TPP currently under construction, but no specific plans follow. Specific plans have also yet to be formulated for the fuel supply, an issue with an important bearing on the siting of the CCGT thermal power plant.

As described in Section 6.6.1, the capacities of the existing 400 kV transmission line between Soyo and Luanda are 2,000 MW (N-1 criteria) in total, which is sufficient to transmit power from up to two of 750 MW-class plants. From the third plant onward, however, additional transmission lines will have to be constructed. Moreover, an uneven distribution of power generation equipment only in Soyo would be disadvantageous from the viewpoints of system stability and transmission loss.

Regarding fuel, Soyo is currently the only location available source of gas supply. It will therefore be necessary to consider the procurement plans for fuel when development of a TPP in another area. When plans call for the development of CCGT thermal power plants in the central/south areas, in particular, it will be necessary to consider a scheme for gradual fuel switching (see Section 3.5.4).

Table 6-15 shows general pros and cons in the case where the locations of future thermal power plants are concentrated in the northern part (Soyo) and when decentralized layout is taken.

Table 6-16 Pros and cons of the locations set for thermal power

| | Concentrated layout in North (Soyo) | Decentralized layout (Soyo, Benguela....) |
|-------------------|---|--|
| Fuel | ○ : Efficiency improvement is available since the location is near existing gas supply facilities. × : A larger area will be needed. ? : The availability of natural gas supply must be confirmed. | ○ : Location selection will be easier if the use of more easily transportable fuels such as diesel oil is acceptable up to completion of the natural gas supply facilities. × : Newly developed fuel supply facilities are needed. ? : Availability of fuels (oil, gas...). |
| Power grid | ○ : Temporary use of existing transmission lines will be possible. × : As large power plants are located only in the north, there appears to be a need for strengthened transmission lines. | ○ : The power flow is relatively smaller since power sources are located nearby both to the north and south of the demand center × : Transmission lines will have to be developed to connect the new power stations to the power grid. |
| Environment | — : Depends on the location. | — : Depends on the location. |
| Economy | ○ : Cost reduction is expected since the generation/fuel supply facilities are located nearby. × : The transmission loss and cost for additional transmission lines are higher. | ○ : Rescheduling of works to reinforce the transmission lines is expected. × : The cost of fuel supply facilities appears to be higher. ? : The need for integration of a port needs to be confirmed. |
| Energy Security | × : The concentrated layout heightens the risks to fuel procurement and reduces the power supply reliability. | ○ : A risk diversification effect can be expected compared to the concentrated layout |
| Early realization | ○ : Early development can be expected if the neighboring area is available for the new power plants. ? : Early utilization will be restricted if there are limits to the natural gas supply for generation fuel. | ○ : Early development is expected if heavy oil is used as the primary fuel (because a suitable location for the power plants would be easier to find). If the location of the power plants is near an oil refinery facility, the use of light fuel, etc. will be an available option. × : Any delay in the development of the refinery facilities would lead to further delays in TPP commencement. . |

○ : Advantages × : Disadvantages ? : Uncertain issues

(2) Candidate locations

If a new gas pipeline is laid, this location is advantageous because it will be possible to use cheap natural gas for fuel. On the other hand, a long time and huge cost would be required for the construction of a new gas pipeline. It would therefore be inappropriate to set pipeline as a condition for selection of site location at the present. Here, Lobito and Namibe are recommended as candidate locations that satisfy the following conditions. Both locations have construction plans for refinery facilities nearby, which is advantageous for the procurement of fuels such as LPG.

- Available space for construction of a power station close to the port used for fuel transportation
- Close to the main line and demand center
- Available site for construction of a LNG receiving facility, if necessary

(3) Influence of fuel cost differences

LPG or LNG is a candidate fuel for the CCGT plants in Lobito and Namibe, since providing natural gas is impossible. Both of these fuels, however, are more expensive than natural gas. In this section, the increment of fuel cost when using LPG and LNG as the fuel for the CCGT developed after the two CCGT power stations (Soyo and Soyo 2) that already are located in Soyo, is estimated using PDPAT.

The estimated annual cost is shown in Figure 6-37. At the beginning of introduction in 2029, the cost of LPG and LNG is higher than that of natural gas, but not by a big margin. Also, the difference between LPG and LNG is very small. However, the cost differences among the fuel types increase with the increase in the amount of thermal power generation and higher LPG costs. The annual cost using LPG surpasses that using natural gas by as much as 930 million USD in 2040, while that using LNG surpasses it by 310 million USD.




Figure 6-37 Cost increase when using LPG/LNG as fuel for CCGT
(Influence when the fuel for CCGT No. 3 or later is changed from NG to LPG/LNG)

(4) Comparison of candidate locations

Table 6-17 and Table 6-18 show the cost characteristics of the candidate sites for CCGT, including Soyo, and the development plan for a list of candidate locations narrowed down in consideration of the cost characteristics, respectively.

As a result of the comparison, the fuel cost difference has a greater influence than the transmission line and fuel tank construction cost, and Soyo site where natural gas can be used is advantageous from the cost aspect. This advantage premised on a low natural gas cost, which is an assumption formed based on international cost forecast. However, the cost of equipment such as fuel tanks may be reduced due to sharing with projects other than electric power, etc., so the cost differences does not necessarily mean larger as shown here.

On the other hand, decentralized layout has preferable properties as described in section (1). Especially energy security and risk diversification is an important factor for decision-making. Therefore, taking into account of this point, development of CCGT considering decentralized layout is the recommended option to consider, as shown in Table 6-18.

In addition, Soyo 2 is planned to be constructed by IPP, and it is decided to prepare necessary preparations including development of relevant laws etc. for the start of operation in 2021. To realize early development, however, it would be helpful to set up procedures for IPP development and establish a supporting scheme.

Table 6-17 Cost characteristics of candidate sites for CCGT

| Items | Soyo site | Lobito site | Namibe site |
|--|---|--|---|
| ① Construction cost for new transmission line for connecting to a main grid [Annual cost] (difference) | between SoyoTPP and Luanda (400 kV) 400 km, 392 million USD [40 million USD/year] (Base) | between LobitoTPP and Nova Biopio SS (400 kV) 23 km, 23 million USD [2.3 million USD/year] (-38 million USD/year) | between Namibe TPP and Namibe SS (220 kV) 17 km, 7 million USD [0.7 million USD/year] (-39 million USD/year) |
| ② Construction cost of fuel tank | - | LNG : 150 million USD (+15 million USD/year) | |
| ③ Additional fuel cost (in 2040, with assumed CCGT generation of 17,900GWh/y) | NG: 4.2 US\$/kWh (Base) | LPG: 15.1 US\$/kWh (+ 930 million USD/year) LNG: 7.6 US\$/kWh (+ 310 million USD/year) | |
| ④ Transmission loss | (Base) | Low (Slight) | Low (Slight) |
| ① + ② + ③ | (Base) | LPG: +907 million USD/year LNG: +287 million USD/year | LPG: +906 million USD/year LNG: +286 million USD/year |

Note: Fuel cost and annual generation: assumed values for 2040.

Service life of transmission lines and tanks: 40 years. Interest rate: 10%.

Table 6-18 Narrowing down and selection of CCGT location

| Power station | Development | Items | Soyo site | Lobito/Namibe site |
|---------------------------------------|---------------|----------------------|--|--|
| No.1 750 MW class (375x2) | 2017 /2018 | Evaluation | ◎ Soyo | × |
| | | Construction in time | ○ Under construction (partially completed) | × Construction cannot be completed in time |
| | | Fuel supply | ○ NG available by 2018 | × No fuel supply facility so far |
| | | Fuel cost | ○ Low (use of NG available) | △ Limited to trafficable fossil fuel |
| | | Transmission cost | ○ 400 kV TL completed | △ New construction required |
| No.2 750 MW class (375x2) | 2021 /2022 | Risk diversification | ○ First introduction of CCGT | ○ First introduction of CCGT |
| | | Evaluation | ◎ Soyo | × |
| | | Construction in time | △ Possible (Support to IPP is required) | × Lead time is too short |
| | | Fuel supply | ○ NG available by 2018 | × Short lead time for fuel facilities |
| | | Fuel cost | ○ Low (use of NG available) | △ Limited to trafficable fossil fuel |
| No.3 750 MW class (375x2) | 2024 /2029 | Transmission cost | ○ 400kV TL completed | △ New construction required |
| | | Risk diversification | × Concentrated layout | ○ Diversification effect expected |
| | | Evaluation | △ | ○ Lobito, △ Namibe |
| | | Construction in time | ○ Possible | ○ Possible |
| | | Fuel supply | ○ NG available by 2018 | ○ Available by construction of fuel facility |
| No.4 750 MW class (375x2) | 2031 /2034 | Fuel cost | ○ Low (use of NG available) | △ LPG/LNG cost is higher |
| | | Transmission cost | △ TL construction cost higher | ○ TL construction cost lower |
| | | Risk diversification | × Concentrated layout | ○ Diversification effect expected |
| | | Evaluation | △ | ○ Lobito, △ Namibe |
| | | Construction in time | ○ (same as No.3) | ○ (same as No.3) |
| No.5 750 MW class (375x2) | 2036 /2038 | Fuel supply | ○ (same as No.3) | ○ (same as No.3) |
| | | Fuel cost | ○ (same as No.3) | ○ (same as No.3) |
| | | Transmission cost | △ (same as No.3) | △ (same as No.3) |
| | | Risk diversification | △ Long-distance transmission risk remains | ○ New construction required |
| | | | | ○ Lower long-distance transmission risk |
| No.6 750 MW class (375x1) | 2040 | | | Diversification effect expected |
| | | Evaluation | ○ Soyo | ○ Lobito, ○ Namibe |
| | | Construction in time | ○ (same as No.3) | ○ (same as No.3) |
| | | Fuel supply | ○ (same as No.3) | ○ (same as No.3) |
| | | Fuel cost | ○ (same as No.3) | △ (same as No.3) |
| | | Transmission cost | △ (same as No.3) | △ Available to use TL for No.3 |
| | | Risk diversification | △ (same as No.4) | ○ Lower long-distance transmission risk |

NG: Natural Gas, TL: Transmission Line

6.6.4 Additional development of renewable energy

The amount of greenhouse gas emissions reduced through the development of the wind/solar power (752 MW in total) currently planned is about 600 kt-CO₂, or about 10% of the total emission (see section 6.5.4).

As mentioned earlier, the accuracy of this calculation is low because conditions of generation are assumed as the generation plans of the projects are at the initial stage. It seems likely however, that the further installation of wind/solar power will be necessary to realize reduced (or avoid increased) greenhouse gas emissions. In this section, therefore, a case of adding wind/solar power generation is examined as a reference.

(1) Greenhouse gas reduction effect

The greenhouse gas emission is examined in the case where wind/solar power is developed under the following conditions. We find that when both 300 MW of wind power and 300 MW of solar power are developed and installed every year from 2028, 10 years from now, onward, the expected greenhouse gas emission can be reduced to the same level as the current level in 2018 (see Figure 6-38).

There is a possibility, however, that the reduction effect may be overestimated, as this calculation is based on assumptions of the characteristics of the wind/solar power generation. The capacity of the development, meanwhile, is rather large compared with the potential of renewable energy, which is 20 GW in total (3.9 GW of wind power (of which 0.6 GW is prioritized in economy) and 17.3 GW of solar power), as described in section 3.2.4.

< Assumptions >

| | |
|-----------------|--|
| Wind power: | Development at 300 MW/year pace from 2028 to 2040, 3,900 MW in total |
| Solar power: | ditto |
| Reserve margin: | CCGT/GT development postponed within 11% of securing the reserve margin |
| Generations: | The expected hourly generation of wind/solar power is assumed based on the average of the current plans. |




Figure 6-38 CO₂ reduction effect of large-scale introduction of wind/solar power

(2) Influence of additional wind/solar power development

In accordance with the additional development of wind/solar power examined in section (1) above, the generation cost increases. As shown in Figure 6-39, the total generation cost in a year increases with the introduction of wind /solar power. Compared with the base case, the amount of increase reaches 900 million USD/year in 2040.

Figure 6-40 shows the generation cost, which are about 1.4 UScents/ kWh higher in 2040 than in the base case.




Figure 6-39 Increase of generation cost by introducing wind/solar power




Figure 6-40 Increase of unit cost by introducing wind/solar power

6.7 Recommended project list

The recommended long-term power development plan is summarized in the table below.

Table 6-19 Long-term power development plan

| Year | Long-term Power Development Plan | | | | |
|-------|--|-----------------|---|--------------------------------|------------------|
| | Hydropower | CCGT | GT | Wind power | Solar power |
| 2017 | | Soyo1-1 (250) | | | |
| 2018 | Lauca (2070) Lomaun ext.(65) | Soyo1-2 (500) | | | |
| 2019 | | | | | |
| 2020 | Luachimo ext.(34) | | | | |
| 2021 | | Soyo2-1 (375) | | | |
| 2022 | | Soyo2-2 (375) | Cacuaco No.1 (125) | | |
| 2023 | | | | | |
| 2024 | Caculo Cabaça(2172) | | Cacuaco No.2 (125) | | |
| 2025 | | | Sambizanga No.1 (125) | | |
| 2026 | Baynes (300) | | | | |
| 2027 | | Lobito1-1 (375) | Quileva No.1 (125) | | |
| 2028 | Quilengue (210) | | Quileva No.2 (125) | Beniamin (52) | Benguela (10) |
| 2029 | | Lobito1-2 (375) | | Cacula (88) | Cambongue (10) |
| 2030 | | | Quileva No.3 (125) Soyo-SS No.1 (125) | Chibia (78) | Caraculo (10) |
| 2031 | | Lobito2-1 (375) | | Calenga (84) | Catumbera (10) |
| 2032 | Zenzo (950) | | Cacuaco No.3 (125) Cacuaco No.4 (125) | Gasto (30) | Lobito (10) |
| 2033 | | | Sambizanga No.2 (125) Quileva No.4 (125) Quileva No.5 (125) Quileva No.6 (125) | Kiwaba Nzoji I (62) | Lubango (10) |
| 2034 | | Lobito2-2 (375) | | Kiwaba Nzoji II (42) | Matala (10) |
| 2035 | Genga (900) | | Soyo-SS No.2 (125) Cacuaco No.5 (125) | Mussede I (36) | Quipungo (10) |
| 2036 | | Namibe1-1 (375) | | Mussede II (44) Nharea (36) | Techamutete (10) |
| 2037 | | | Cacuaco No.6 (125) Sambizanga No.3 (125) Soyo-SS No.3 (125) | Tombwa (100) | Namacunde (10) |
| 2038 | Túmulo Caçador(453) | Namibe1-2 (375) | | | |
| 2039 | | | | | |
| 2040 | Jamba Ya Oma (79) Jamba Ya Mina (205) | Lobito3-1 (375) | | | |
| Total | 7,438 MW | 4,125 MW | 2,250 MW | 652 MW | 100 MW |

Chapter 7 Study on optimization of the transmission system development plan

7.1 Current power system in Angola

Figure 7-1 shows the transmission system map of Angola as of July 2017. The transmission network has a maximum voltage of 400 kV and is composed of transmission voltages of 220 kV, 150 kV, 132 kV, 110 kV, and 60 kV. The maximum demand is slightly less than 2,000 MW. In RNT, where the voltage classes are being organized, there are expected to be three levels of building in the future: 400 kV, 220 kV, and 60 kV.


The transmission network of Angola country is currently divided into three parts: the northern part, central part, and southern part. In the northern power system, large hydroelectric power plants such as Capanda and Cambambe supply power to provinces such as Bengo, Malanje, Cuanza Norte, Cuanza Sul, Uíge, and Zaire, as well as the capital city of Luanda (which has the highest demand). The northern part covers 80% of the power supply of all of Angola and accounts for nearly 80% of the total demand.

In 2018, Alto Chingo SS in the northern part, the Novo Biopio SS - Quileva SS - Lomaum hydro power station network, and Benguela sul SS in central Benguela province are expected to be interconnected to 220 kV transmission lines. The west coast side of the northern part and central part are linked as one network. The network, however, is unavailable due to aging of the Cambambe HPS - Gabela SS transmission line transmitting hydroelectric power from the north to the Alto Chingo SS. For the reasons above, the power systems are not interconnected. A new 220 kV transmission line under construction at Cambambe HPS - Gabela SS began operating in 2017. When the line was completed, the northern-central system was connected and united.

Huanbo and Bie provinces in the central part have the Gove hydroelectric power plant - Dango SS - Kuito SS transmission line, a network connected with a single circuit 220 kV transmission line. The demand rate of the central region is forecasted to compose about 10% of the total demand rate for all of Angola, provided that the demand in Benguela province is included in the calculation.

Double circuit 400 kV transmission lines have already been completed from N'Zeto SS to Soyo Thermal Power Station currently under construction in the northern end of the country. Kapary SS has been completed, and a single circuit 400 kV transmission line from Kapary SS to Catete SS has been completed. Preparations for electric power transmission from the Soyo TPS to the capital city Luanda, the largest demand site, are progressing. In addition, the 400 kV transmission line constitutes a single circuit transmission line loop system that returns from Catete SS to Catete SS via Viana SS - Lucala SS - Canpanda Elevadora HPS - Lauca HPS - Cambutas HPS. As a result, a 400 kV transmission system interconnecting large hydraulic and thermal power plants and high-demand areas has already been established.

The Namibe SS, Lubango SS, and Matala SS in Namibe and Huila provinces of the southern lineage are interconnected with Namibe SS - Lubango SS 150 kV transmission line and Lubango SS - Matala SS 60 kV transmission line. Overall, the demand in the south accounts for less than 10% of total demand in Angola. As described above, the power system of Angola is currently divided into three main electric power systems, all of which will be interconnected in the future.




(Source: RNT)

Figure 7-1 Transmission system map of Angola (July 2017)

7.2 Transmission system of the capital city Luanda

FIGURE 7-2 shows the current transmission system in the center of the capital city Luanda. Six 220 kV substations (Camama, Cacuo, Sambizang, Cazenga, Filda and Futungo) operate under two 400 kV substations (Kapary, Viana) interconnected with the 400 kV Catete substation. The substations provide electric power to the center of the city from sites located around it.

The 400 kV Kapary substation has been supplied mainly from Soyo thermal power plant since it began full-scale operation as a power source. The 400 kV Viana substation is mainly supplied from the Cambambe hydro power station and partly supplied from the Lucala hydro power station.



(Source: RNT, JICA Survey Team)

Figure 7-2 Transmission system map of the center of the capital city Luanda


7.3 Power system enhancement plan by RNT

Figure 7-3 and Figure 7-4 the power network system in 2025 and 2027, respectively.

According to RNT, a plan slightly different from that shown in FIGURE 7-1 is in place. Specifically, 400 kV transmission lines will be extended from Lauca to WakoKungo SS -Dango SS -Lubango SS -Biopio SS as well as Cabaca SS - Biopio SS in 2022, while the 400 kV transmission lines will be extended from Canpanda Elevadora HPS to east side and be connected to XaMuteba SS - Saurimo SS.

As a result, the four power systems of Angola (north system, central system, south system, and east system) will be interconnected by 400 kV transmission lines. In addition, 200 kV transmission lines will connect Saurimo in LuandaSul province to Luena in Moxio province. RNT assumes that maximum demand will be about 4200 MW.

Four hundred kV transmission lines will interconnect Biopio SS - Dango SS, and Biopio SS - Lubango SS to constitute a 400 kV loop system in 2025. Moreover, an enhancement of the 220 kV transmission line system is being developed to connect Menogue SS in CuandoCubango province, and a 400 kV- 200 kV



(Source: RNT)

Figure 7-4 Transmission system map of Angola (2027)

7.4 Characteristics of the main power system in Angola

The RNT plan for 2027 describes a bulk power system mainly constituting a single circuit transmission line, with 400 kV double circuit transmission lines linking Soyo SS - N'zeto SS - Kapary SS - Catete SS. Hence, the bulk power system will constitute a 400 kV - 200 kV loop system.

As a result, the power flow will become very complicated and troublesome to evaluate if the N-1 criteria are met.

7.4.1 Voltage reference

Voltage reference is defined as follows in the planning criteria of RNT power system:

Table 7-1 Voltage criteria

| Voltage class (kV) | Normal operating condition "n" | | | | Single contingency condition "n-1" | | | |
|---------------------|--------------------------------|------|---------|------|------------------------------------|------|---------|------|
| | Minimum | | Maximum | | Minimum | | Maximum | |
| | kV | p.u. | kV | p.u. | kV | p.u. | kV | p.u. |
| 400 | 380 | 0.95 | 420 | 1.05 | 360 | 0.9 | 420 | 1.05 |
| 220 | 209 | 0.95 | 231 | 1.05 | 198 | 0.9 | 242 | 1.1 |
| 150 | 142 | 0.95 | 157 | 1.05 | 135 | 0.9 | 165 | 1.1 |
| 110 | 104.5 | 0.95 | 115.5 | 1.05 | 99 | 0.9 | 121 | 1.1 |

(Source: RNT)

7.5 Information gathering and analysis of the existing transmission facilities in Angola

7.5.1 Outline

The JICA Survey Team confirmed the existing transmission lines when moving within Luanda city or surveying the local area (such as Benguela, Huambo, and Soyo). The team also conducted hearings with transmission engineers from RNT and then gathered information about the transmission lines in Angola. In parallel, the team confirmed the status of the substation equipment in Angola by meeting with RNT and visiting substations in field surveys.

7.5.2 The existing transmission lines

The supporting structures for the 66 kV transmission lines consisted of concrete poles (see Figure 7-5), steel angle towers (see Figure 7-6 and Figure 7-7), and steel pipe towers (see Figure 7-8). The 220 kV transmission lines were mainly supported by steel angle towers, though many steel pipe towers were also built along the roads. There were both single and double circuits, and in one case we observed a single circuit tower and double circuit tower (one circuit is empty) mixed in one circuit transmission line.

According to RNT, trees in contact with electric wires cause many accidents. At the same time, extensive tree trimming under the wires is prohibitively expensive. It seems that ground clearance from the electric wires and the height of the transmission line tower were designed to be lower. For the transmission lines along the roads, however, the ground clearance was sufficient.

The insulators used were mainly glass. In some cases, polymer insulators were used for transmission lines below 220 kV.

The conductors used were mainly copper for 60 kV transmission lines, and ACSR and AAAC for 220 kV or 400 kV transmission lines (the latter mainly for the large-capacity transmission lines).

As for the ground wires, OPGW (optical fiber composite overhead ground wire) and AW (aluminum-clad steel overhead ground wire) were used.



Figure 7-5 66 kV concrete pole



Figure 7-6 66 kV one circuit angle tower



Figure 7-7 60 kV underground cable branch tower



Figure 7-8 60 kV steel pipe tower



Figure 7-9 220 kV steel pipe tower (tension)




Figure 7-10 220 kV steel pipe tower (suspension)



Figure 7-11 220 kV Transmission line along the road



Figure 7-12 220 kV steel angle tower



Figure 7-13 400 kV one circuit transmission lines (distant view)

Table 7-2 and Table 7-3 list the 400 kV and 220 kV transmission lines of Angola, respectively. As shown in the outline of the Angola power system of August 2016, the country's 400 kV transmission lines ran a total distance of 281 km on 2 lines and the country's 24 kV transmission lines ran a distance of 1964.1 km on 24 lines. As of October 2017, less than a year later, the 400 kV transmission lines spanned 1183 km on 11 lines and the 220 kV transmission lines spanned 2597.4 km on 36 lines. The quantity of transmission line facilities is rapidly increasing.

Table 7-2 List of 400 kV transmission lines (as of October 2017)

| Area | Name of Transmission line | Start point | End point | Voltage[kV] | Circuit | Length [Km] | Type of Conductor |
|---|---------------------------|--------------|--------------|-------------|---------|-------------|---------------------------------------|
| North | Capanda_elv – Lucala | Capanda_elve | Lucala | 400 | 1 | 61 | 3 x ACSR Crow 409 mm ² |
| | Lucala – Viana | Lucala | Viana | 400 | 1 | 220 | 3 x ACSR Crow 409 mm ² |
| | Cambutas – Catete | Cambutas | Catete | 400 | 1 | 123 | 2 x AAAC Sorbus 659,4 mm ² |
| | Soyo TPS – Soyo | Soyo TPS | Soyo | 400 | 2 | 40 | 3 x AAAC Sorbus 659,4 mm ² |
| | Soyo – N'Zeto | Soyo | N'Zeto | 400 | 2 | 142 | 3 x AAAC Sorbus 659,4 mm ² |
| | N'Zeto – Kapary | N'Zeto | Kapary | 400 | 2 | 194 | 3 x AAAC Sorbus 659,4 mm ² |
| | Kapary – Catete | Kapary | Katete | 400 | 2 | 57 | 3 x AAAC Sorbus 659,4 mm ² |
| | Catete – Viana | Catete | Viana | 400 | 1 | 39 | 2 x AAAC Sorbus 659,4 mm ² |
| | Lauca – Capanda_elve | Lauca | Capanda_elve | 400 | 1 | 41 | 2 x AAAC Sorbus 659,4 mm ² |
| | Lauca – Cambutas | Lauca | Cambutas | 400 | 1 | 76 | 3 x AAAC Sorbus 659,4 mm ² |
| | Lauca – Catete | Lauca | Catete | 400 | 1 | 190 | 2 x AAAC Sorbus 659,4 mm ² |
| Total Length of 400kV Transmission lines [Km] | | | | | | 1183 | |

(Source: RNT, JICA Survey Team)

Table 7-3 List of 220 kV transmission lines (as of October 2017)

| Area | Name of Transmission line | Start point | End point | Voltage [kV] | Circuit | Length [Km] | Type of Conductor |
|---|---------------------------------|----------------|------------------------|--------------|---------|-------------|------------------------------------|
| North | Cambambe – Catete | Cambambe | Catete | 220 | 1 | 116 | ACSR Crow 54/7 409 mm ² |
| | Catete – Camama | Catete | Camama | 220 | 1 | 64 | ACSR Crow 54/7 409 mm ² |
| | Cambambe – Catete | Cambambe | Catete | 220 | 1 | 116 | ACSR Crow 54/7 409 mm ² |
| | Catete – Viana | Catete | Viana | 220 | 1 | 42 | ACSR Crow 54/7 409 mm ² |
| | Cambambe – Viana | Cambambe | Viana | 220 | 1 | 158 | AAAC Yew 479 mm ² |
| | Cambambe – Cambutas | Cambambe | Cambutas | 220 | 2 | 1.3 | ACSR Crow 54/7 409 mm ² |
| | N' Dalatando – Cambutas | N' Dalatando | Cambutas | 220 | 1 | 73 | ACSR Crow 54/7 409 mm ² |
| | Cambambe – Gabela | Cambambe | Gabela | 220 | 1 | 130 | ACSR Crow 54/7 409 mm ² |
| | Gabela – Alto chingo | Gabela | Alto Chingo | 220 | 1 | 81 | 2xAAAC Yew 479 mm ² |
| | Viana – Camama | Viana | Camama | 220 | 1 | 34.5 | ACSR Crow 54/7 409 mm ² |
| | Viana – Cazenga I | Viana | Cazenga | 220 | 1 | 21.5 | ACSR Crow 54/7 409 mm ² |
| | Viana – Cazenga II | Viana | Cazenga | 220 | 1 | 18 | ACSR Crow 54/7 409 mm ² |
| | Viana – Cazenga III | Viana | Cazenga | 220 | 1 | 18 | AAAC Yew 479 mm ² |
| | Viana – Cacucaco | Viana | Cacucaco | 220 | 1 | 14.5 | ACSR Crow 54/7 409 mm ² |
| | Cacucaco – Sambizanga | Cacucaco | Sambizanga | 220 | 2 | 19.3 | AAAC Yew 479 mm ² |
| | Viana – Filda I | Viana | Filda | 220 | 1 | 18 | AAAC Yew 479 mm ² |
| | Viana – Filda II | Viana | Filda | 220 | 1 | 18 | AAAC Yew 479 mm ² |
| | Capanda – Cambutas | Capanda | Cambutas | 220 | 1 | 120 | ACSR Crow 54/7 409 mm ² |
| | Capanda – Lucala | Capanda | Lucala | 220 | 1 | 70.7 | ACSR Crow 54/7 409 mm ² |
| | Capanda – Capanda Elev A | Capanda | Capanda Elev. | 220 | 1 | 3.6 | ACSR Crow 54/7 409 mm ² |
| | Capanda – Capanda Elev B | Capanda | Capanda Elev. | 220 | 1 | 3.6 | ACSR Crow 54/7 409 mm ² |
| | Lucala – N' Dalatando | Lucala | N' Dalatando | 220 | 1 | 35.7 | ACSR Crow 54/7 409 mm ² |
| | Lucala – Pambos de Sonhe – Uíge | Lucala | Pambos de Sonhe – Uíge | 220 | 1 | 211 | ACSR Crow 54/7 409 mm ² |
| | Uíge – Maquela do Zombo | Uíge | Maquela do Zombo | 220 | 1 | 200 | ACSR Crow 54/7 409 mm ² |
| | Kapary – Cacucaco | Kapary | Cacucaco | 220 | 1 | 26.7 | AAAC Yew 479 mm ² |
| | Kapary – Ada | Kapary | Ada | 220 | 1 | 14 | AAAC Yew 479 mm ² |
| | Camama – Futungo de Belas | Camama | Futungo de Belas | 220 | 2 | 14.5 | AAAC Yew 479 mm ² |
| | Catete – Ramiros | Catete | Ramiros | 220 | 2 | 91 | AAAC Yew 479 mm ² |
| | N'Zeto – M'Banza Congo | N'Zeto | M'Banza Congo | 220 | 1 | 181 | AAAC Yew 479 mm ² |
| Central | Alto Chingo – Novo Biopio | Alto Chingo | Novo Biopio | 220 | 1 | 156 | 2xAAAC Yew 479 mm ² |
| | Lomaum HPS – Novo Biopio | Lomaum HPS | Novo Biopio | 220 | 2 | 95.8 | ACSR Crow 54/7 409 mm ² |
| | Novo Biopio – Quileva | Novo Biopio | Quileva | 220 | 1 | 18 | 2xAAAC Yew 479 mm ² |
| | Novo Biopio – Benguela Sul | Novo Biopio | Benguela Sul | 220 | 1 | 57 | AAAC Yew 479 mm ² |
| | Gove HPS – Belém do Dango | Gove HPS | Belém do Dango | 220 | 1 | 93 | ACSR Crow 54/7 409 mm ² |
| | Belém do Dango – Kuíto | Belém do Dango | Kuíto | 220 | 1 | 150 | ACSR Crow 54/7 409 mm ² |
| | Lomaum HPS – Quileva | Lomaum HPS | Quileva | 220 | 1 | 114 | ACSR Crow 54/7 409 mm ² |
| Total Length of 220kV Transmission lines [Km] | | | | | | 2598.7 | |

(Source: RNT, JICA Survey Team)

7.5.3 The existing substations

Transformers made in China were mainly used for the new substations in the capacity range from 60 kV to 400 kV (see Figure 7-14), though some made in Germany were also seen. At the newly constructed 400 kV Soyo substation, four single-phase transformers were set as one unit. One was left on reserve as a spare for later use for any phase. A variable compensation reactor (manufactured by Siemens AG, see Figure 7-15) was also installed for phase modification.

The circuit breakers used were insulator types for 66 kV substations and vertical type polymer-insulated gas circuit breakers made in China (see Figure 7-16) for 220 kV substations. There was no big difference, however, from the usual outdoor substation. Specifically, a gas-insulated switchgear (GIS, manufactured by ABB; see Figure 7-17) was used at the 400 kV switchgear of the Soyo thermal power plant.

In addition, the bus configuration was standardized as a double bus configuration (see Figure 7-18), a highly reliable type.



Figure 7-14 66 kV/15 kV transformer made in China





Figure 7-15 Control screen for variable compensation reactor



Figure 7-16 220 kV vertical type gas-insulated circuit breaker



Figure 7-17 Indoor type gas-insulated switchgear



(Source: RNT)

Figure 7-18 Example of a multiple bus configuration (220 kV Futungo substation)

Table 7-4 and Table 7-5 list Angola's 400 kV and 220 kV substations, respectively. As shown in the Angola Electric Power System Outline of August 2016, one 400 kV substation with a total generation capacity of 420 MVA in one facility and fifteen 220 kV substations with a total capacity of 2129 MVA were in operation. As of October 2017, nine 400 kV substations with 4950 MVA capacity and twenty-three 220 kV substations with 4086 MVA capacity were in operation. The quantity of substation facilities is also rapidly increasing.

Table 7-4 List of 400 kV substations (as of October 2017)

| Area | Province | Substation Name | Voltatge[kV] | Transformer | Capacity[MVA] |
|-------|--|--------------------------|--------------|-------------|---------------|
| North | Luanda | Viana substation | 400/220 | 210 x 2 | 420 |
| | | Catete substation | 400/220 | 450 x 2 | 900 |
| | Bengo | Kapary substation | 400/220 | 450 x 2 | 900 |
| | Zaire | Soyo substation | 400/60 | 120 x 2 | 240 |
| | | N'Zeto substation | 400/220 | 90 x 1 | 90 |
| | Kwanza Norte | Cambutas substation | 220/400 | 930 x 2 | 1860 |
| | | Capanda elev. substation | 220/400 | 270 x 2 | 540 |
| | Total Capacity of 400kV substation facilities[MVA] | | | | 4950 |

(Source: RNT, JICA Survey Team)

Table 7-5 List of 220 kV substations (as of October 2017)

| Area | Province | Substation Name | Voltage[kV] | Transformer | Capacity[MVA] |
|--|--------------------------|------------------------------|-------------|-------------|---------------|
| North | Luanda | Catete substation | 220/60 | 120 x 2 | 240 |
| | | Cazenga substation | 220/60/15 | 60 x 5 | 300 |
| | | Viana substation | 220/60 | 60 x 5 | 300 |
| | | Filda substation | 220/60 | 120 x 2 | 240 |
| | | Camama substation | 220/60 | 120 x 3 | 360 |
| | | Cacuaco substation | 220/60 | 60 x 2 | 120 |
| | | Sambizanga substation | 220/60 | 120 x 2 | 240 |
| | | Futungo de Belas substation | 220/60 | 120 x 2 | 240 |
| | | Ramiro's substation | 220/60 | 120 x 2 | 240 |
| | Bengo | kapary substation | 220/60 | 120 x 2 | 240 |
| | | Ada substation | 220/15 | 25,40 | 65 |
| | Kwanza Norte | N' Dalatando substation | 220/30 | 40 x 1 | 40 |
| | | Pambos de Sonhe substation | 220/30 | 30 x 1 | 30 |
| | | Cambutas substation | 220/60 | 120 x 2 | 240 |
| | Malanje | Capanda Elevadora substation | 220/400 | 270 x 2 | 590 |
| | | | 220/30 | 30 x 1 | |
| | | | 220/110 | 20 x 1 | |
| | Uíge | Uíge substation | 220/60 | 40 x 1 | 40 |
| | | Maquela do Zombo substation | 220/30/15 | 10 x 1 | 40 |
| | | | 220/60/15 | 30 x 1 | |
| Zaire | N'Zeto substation | 220/60 | 63 x 1 | 63 | |
| | M'Banza Congo substation | 220/60 | 63 x 1 | 63 | |
| Central | Benguela | Quileva substation | 220/64/32 | 100 x 2 | 200 |
| | Kwanza Sul | Alto Chingo substation | 220/60 | 60 x 1 | 60 |
| | | Gabela substation | 220/60/30 | 35 x 1 | 35 |
| | Huambo | Belém do Dango substation | 220/60/30 | 60 x 1 | 60 |
| | | Kuito substation | 220/60/10 | 20 x 1 | 40 |
| Total Capacity of 220kV substation facilities[MVA] | | | | | 4086 |

(Source: RNT, JICA Survey Team)

7.6 Information gathering and analysis of the latest transmission development plan

7.6.1 Existing development strategies and plans

Based on Angola Energia 2025, the plan through 2027 is currently under consideration at RNT.

The skeletal system from the northernmost Soyo thermal power plant to Luanda and the transmission line from the hydraulic power plant in the Kuwanza River basin to Luanda are already being completed. A 400 kV core line to transmit this electricity to the central and southern regions is planned for the future. Under the plans by SAPP, this line will eventually be connected to the international linkage line with Namibia, the neighboring country to south of Angola. For this purpose, electricity sales to the African electricity market and interchange during the drought period are considered. Moreover, the 400 kV transmission line also plays a role as a power supply line for a newly developed large-scale power plant.

The current plans for the 400 kV main transmission lines and substations are shown in Table 7-7 and Table 7-6.

The 220 kV lines now connect the northern system and central system, but they will take on a growing role as a regional supply lines from the main 400 kV substation in each province. They also serves as a power line for small-scale thermal power plants.

Similarly, the existing plans for the 220 kV transmission lines and substations are shown in Table 7-9 and Table 7-8.

Table 7-6 Existing 400 kV main power transmission plans by RNT (~ 2027)

| Project# | Area | Voltage (kV) | Starting point | End point | number of circuit | Line Length (km) | Year of operation | Project Status | Donar |
|----------|----------|--------------|---------------------------|-----------------|-------------------|------------------|-------------------|---------------------------------|--------|
| 1 | Central | 400 | Lauca | Waco kungo | 1 | 177 | 2020 | Under Construction(Cmec) | China |
| 2 | " | 400 | Waco kungo | Belem do Huambo | 1 | 174 | 2020 | " | China |
| 3 | Northern | 400 | Catete | Bitá | 1 | 54 | 2022 | Project in progress(Odebrecht) | Brazil |
| 4 | " | 400 | Cambutas | Bitá | 1 | 167 | 2022 | " | Brazil |
| 5 | Central | 400 | Belem do Huambo | Lubango | 1 | 337 | 2022 | Plannning(or No information) | — |
| 6 | " | 400 | Belem do Huambo | Capelongo | 1 | 202 | 2022 | " | — |
| 7 | Northern | 400 | Cambutas | Caculo Cabaca | 1 | 49 | 2023 | " | — |
| 8 | " | 400 | Caculo Cabaca | Bitá | 1 | 214 | 2023 | " | — |
| 9 | Central | 400 | Caculo Cabaca | Nova Biopio | 1 | 348 | 2025 | " | — |
| 10 | " | 400 | Nova Biopio | Lubango | 1 | 317 | 2025 | " | — |
| 11 | Southern | 400 | Lubango | Cahama | 1 | 179 | 2025 | " | — |
| 12 | " | 400 | Cahama | Baynes | 1 | 312 | 2025 | " | — |
| 13 | Eastern | 400 | Capanda_elev | Xa-Muteba | 2 | 266 | 2025 | " | — |
| 14 | " | 400 | Xa-Muteba | Surimo | 2 | 335 | 2025 | " | — |
| 15 | Southern | 400 | Capelongo | Ondjiva | 1 | 312 | 2027 | " | — |
| 16 | " | 400 | Cahama | Ondjiva | 1 | 175 | 2027 | " | — |
| 17 | " | 400 | Nova Biopio - Lubango | Caluquembe | 2 | 5 | 2027 | " | — |
| 18 | " | 400 | Belem do Huambo - Lubango | Quilengues | 2 | 5 | 2027 | " | — |
| 19 | " | 400 | Cahama | Ruacana | 2 | 125 | 2027 | " | — |
| Total | | | | | | 3753 | | | |

(Source: RNT, JICA Survey Team)

Table 7-7 Existing 400 kV main substation plans by RNT (~ 2027)

| Project# | Area | Voltage (kV) | Substation Name | Capacity (MVA) | Year of operation | Project Status | Donar |
|----------|--------------|--------------|-----------------|----------------|-------------------|---------------------------------|--------|
| 1 | Cuanza Sul | 400 | Waco kungo | 450 | 2020 | Under Construction(Cmec) | China |
| 2 | Huambo | 400 | Belem do Huambo | 900 | 2020 | " | China |
| 3 | Luanda | 400 | Bitá | 900 | 2020 | Project in progress(Odebrecht) | Brazil |
| 4 | Huíla | 400 | Lubango | 900 | 2022 | Plannning(or No information) | — |
| 5 | " | 400 | Capelongo | 900 | 2022 | " | — |
| 6 | Benguela | 400 | Nova Biopio | 900 | 2025 | " | — |
| 7 | Southern | 400 | Cahama | 420 | 2025 | " | — |
| 8 | Eastern | 400 | Saurimo | 900 | 2025 | " | — |
| 9 | Luanda Norte | 400 | Xa-Muteba | 240 | 2025 | " | — |
| 10 | Cunene | 400 | Ondjiva | 420 | 2027 | " | — |
| 11 | Huíla | 400 | Caluquembe | 180 | 2022 | " | — |
| 12 | " | 400 | Quilengues | 180 | 2027 | " | — |
| Total | | | | 7290 | | | |

(Source: RNT, JICA Survey Team)

Table 7-8 Existing 220 kV main power transmission line plans by RNT (~ 2027)

| Project# | Area | Voltage (kV) | Starting point | End point | number of circuit | Line Length (km) | Year of operation | Project Status | Donar |
|----------|----------|--------------|------------------|--------------|-------------------|------------------|-------------------|------------------------------|-------|
| 1 | Northern | 220 | Kapary | Caxito | 1 | 18 | 2022 | Plannning(or No information) | — |
| 2 | " | 220 | Filda | Golf | 2 | 7 | 2022 | " | — |
| 3 | " | 220 | Bitá | Camama | 1 | 17 | 2022 | " | — |
| 4 | " | 220 | Bitá | Rammiros | 1 | 23 | 2022 | " | — |
| 5 | " | 220 | Capanda | Marange | 1 | 101 | 2022 | " | — |
| 6 | Central | 220 | Cambambe | Gabela | 1 | 134 | 2022 | " | — |
| 7 | " | 220 | Gabela | Alto Chingo | 1 | 64 | 2022 | " | — |
| 8 | " | 220 | Gabela | Quibala | 1 | 64 | 2022 | " | — |
| 9 | " | 220 | Quibala | Waco Kungo | 1 | 68 | 2022 | " | — |
| 10 | " | 220 | Lomaum | Cubal | 1 | 4 | 2022 | " | — |
| 11 | " | 220 | Belem do Huambo | Cubal | 1 | 146 | 2022 | " | — |
| 12 | Southern | 220 | Lubango | Namibe | 2 | 151 | 2022 | " | — |
| 13 | " | 220 | Namibe | Tombwa | 1 | 110 | 2022 | " | — |
| 14 | " | 220 | Lubango | Matala | 1 | 154 | 2022 | " | — |
| 15 | " | 220 | Matala HPS | Matala | 1 | 15 | 2022 | " | — |
| 16 | " | 220 | Capelongo | Cuchi | 2 | 71 | 2022 | " | — |
| 17 | " | 220 | Cuchi | Menongue | 2 | 77 | 2022 | " | — |
| 18 | Northern | 220 | Viana | PIV | 1 | 4 | 2027 | " | — |
| 19 | " | 220 | Cazenga | PIV | 1 | 21 | 2027 | " | — |
| 20 | " | 220 | Sambizanga | Chicala | 1 | 5 | 2027 | " | — |
| 21 | " | 220 | Futungo de Belas | Chicala | 1 | 12 | 2027 | " | — |
| 22 | " | 220 | Catete | Maria Teresa | 2 | 50 | 2027 | " | — |
| 23 | Central | 220 | Alto Chingo | Cuacra | 2 | 15 | 2027 | " | — |
| 24 | " | 220 | Alto Chingo | Port Amboim | 2 | 50 | 2027 | " | — |
| 25 | " | 220 | Quileva | Catumbela | 1 | 8 | 2027 | " | — |
| 26 | " | 220 | Benguela Sul | Catumbela | 1 | 33 | 2027 | " | — |
| 27 | " | 220 | Nova Biopio | Bocoio | 1 | 5 | 2027 | " | — |
| 28 | " | 220 | Lomaum | Bocoio | 1 | 5 | 2027 | " | — |
| 29 | " | 220 | Cubal | Ukuma | 1 | 5 | 2027 | " | — |
| 30 | " | 220 | Belem do Huambo | Ukuma | 1 | 5 | 2027 | " | — |
| 31 | " | 220 | Belem do Huambo | Catchiungo | 1 | 9 | 2027 | " | — |
| 32 | " | 220 | Kuito | Catchiungo | 1 | 9 | 2027 | " | — |
| 33 | " | 220 | Belem do Huambo | Kuito | 1 | 144 | 2027 | " | — |
| 34 | " | 220 | Kuito | Andulo | 1 | 110 | 2027 | " | — |
| 35 | Southern | 220 | Cahama | Xangongo | 1 | 88 | 2027 | " | — |
| 36 | " | 220 | Ondjiva | Xangongo | 1 | 90 | 2027 | " | — |
| 37 | " | 220 | Capelongo | Matala | 1 | 158 | 2027 | " | — |
| 38 | " | 220 | Matala | Jamba Mina | 2 | 83 | 2027 | " | — |
| 39 | " | 220 | Jamba mina | Jamba Oma | 2 | 49 | 2027 | " | — |
| 40 | " | 220 | Capelongo | Tchamutete | 2 | 93 | 2027 | " | — |
| 41 | Eastern | 220 | Saurimo | Lucapa | 1 | 157 | 2022 | " | — |
| 42 | " | 220 | Lucapa | Dundo | 1 | 135 | 2022 | " | — |
| 43 | " | 220 | Saurimo | Luena | 1 | 246 | 2027 | " | — |
| 44 | " | 220 | Saurimo | Muconda | 1 | 169 | 2027 | " | — |
| 45 | " | 220 | Muconda | Luau | 1 | 100 | 2027 | " | — |
| 46 | " | 220 | Luau | Cazombo | 1 | 187 | 2027 | " | — |
| Total | | | | | | 3269 | | | |

(Source: RNT, JICA Survey Team)

Table 7-9 Existing 220 kV main substation plans by RNT (~ 2027)

| Project# | Area | Voltage (kV) | Substation Name | Capacity (MVA) | Year of operation | Project Status | Donar |
|----------|----------------|--------------|-----------------|----------------|-------------------|------------------------------|-------|
| 1 | Bengo | 220 | Caxito | 120 | 2022 | Plannning(or No information) | — |
| 2 | Luanda | 220 | Golf | 240 | 2022 | „ | — |
| 3 | „ | 220 | Bitá | 240 | 2022 | „ | — |
| 4 | Maranje | 220 | Maranje | 200 | 2022 | „ | — |
| 5 | Cuanza Sul | 220 | Gabela | 120 | 2022 | „ | — |
| 6 | „ | 220 | Quibala | 60 | 2022 | „ | — |
| 7 | „ | 220 | Waco Kungo | 60 | 2022 | „ | — |
| 8 | Benguela | 220 | Cubal | 120 | 2022 | „ | — |
| 9 | Huambo | 220 | Belem do Huambo | 240 | 2022 | „ | — |
| 10 | Huíla | 220 | Lubango | 240 | 2022 | „ | — |
| 11 | Namibe | 220 | Namibe | 120 | 2022 | „ | — |
| 12 | „ | 220 | Tombwa | 120 | 2022 | „ | — |
| 13 | Huíla | 220 | Matala | 120 | 2022 | „ | — |
| 14 | Cuando Cubango | 220 | Cuchi | 40 | 2022 | „ | — |
| 15 | „ | 220 | Menongue | 240 | 2022 | „ | — |
| 16 | Luanda | 220 | PIV | 240 | 2027 | „ | — |
| 17 | „ | 220 | Chicala | 240 | 2027 | „ | — |
| 18 | Bengo | 220 | Maria Teresa | 120 | 2027 | „ | — |
| 19 | Cuanza Sul | 220 | Cuacra | 60 | 2027 | „ | — |
| 20 | „ | 220 | Port Amboim | 120 | 2027 | „ | — |
| 21 | Benguela | 220 | Catumbela | 240 | 2027 | „ | — |
| 22 | „ | 220 | Bocoio | 120 | 2027 | „ | — |
| 23 | Huambo | 220 | Ukuma | 120 | 2027 | „ | — |
| 24 | „ | 220 | Catchiungo | 120 | 2027 | „ | — |
| 25 | Bie | 220 | Andulo | 120 | 2027 | „ | — |
| 26 | Cunene | 220 | Xangongo | 120 | 2027 | „ | — |
| 27 | „ | 220 | Tchamutete | 180 | 2027 | „ | — |
| 28 | Moxito | 220 | Luená | 240 | 2027 | „ | — |
| 29 | Luanda Sul | 220 | Muconda | 40 | 2027 | „ | — |
| 30 | Moxito | 220 | Luau | 120 | 2027 | „ | — |
| 31 | „ | 220 | Cazombo | 80 | 2027 | „ | — |
| Total | | | | 4560 | | | |

(Source: RNT, JICA Survey Team)

For reference, the transmission system diagrams as of 2022 and 2027 obtained from RNT are shown in Figure 7-19 to Figure 7-22.




Figure 7-19 Existing plan for the northern system as of 2022 by RNT




Figure 7-20 Existing plan for the northern system as of 2027 by RNT




Figure 7-21 Existing plan for the central, southern and western systems as of 2022 by RNT




Figure 7-22 Existing plan for the central, southern and western systems as of 2027 by RNT

7.6.2 Analysis of the technical data and the latest cost in existing facilities

In order to confirm the design content of the existing facilities, we asked for technical information on the transmission lines and substations by questionnaire, during interviews, etc. We were only able, however, to obtain fragmentary technical standards and technical specifications on individual projects. The information confirmed that the transmission line and substation designs were basically based on IEC standards.

We examined details related to the transmission lines and substations from two packages of materials obtained from RNT: "ESPECIFICAÇÕES TÉCNICAS GERAIS Redes de Distribuição Technical specifications for AT, MT e BT (high voltage (60 kV - 35 kV), medium voltage (35 kV - 1 kV), low voltage (less than 1 kV) distribution equipment ET - E - 001 to 008, 2014.10)" and "ESPECIFICA ES TÉCNICAS GERAIS Rede de Transporte MAT (General technical specifications for special high-voltage (60 kV or higher) transmission system, ET-E-101 to 121, 2014.7)."

By examining the contents of "Projectos de Linhas aéreas de MAT" (project of special high-voltage overhead transmission line: ET-E-110) and "Projects de Substitution de E de Postos de Seccionamento de MAT" (project of special high-voltage substation or switch station: ET-E-119), we confirmed the design methods and parameters used in the world standard 400 kV or 220 kV transmission lines and substations, based on IEC standards, etc.

Regarding the cost of the transmission lines and substations in Angola, only one example of 220 kV transmission line and substation construction work was available locally. For the cost estimation, we therefore considered the recent international procurement prices in developing countries that have installed transmission lines and substations based on IEC standards.

To estimate the cost per km of the 400 kV transmission line, we adopted a cost estimate used in a Bangladesh country project based on the recent international procurement price. To estimate the cost per km of the 220 kV transmission line we referred to the result in the Angola project.


As this cost estimate was for a two circuit transmission line, the cost per km of a one-circuit transmission line was estimated to be 80% of that for a two-circuit line, from the past record. The estimated cost per km for the transmission lines is shown in Table 7-10

Table 7-10 Estimated transmission line cost per km

| Voltage | Number of cct | TL cost per km (Unit: MUSD/km) |
|---------|---------------|-----------------------------------|
| 400kV | 1 | 0.78 |
| | 2 | 0.98 |
| 220kV | 1 | 0.36 |
| | 2 | 0.45 |

(Source: JICA Survey Team)


As for the cost of the substations, five cost estimates for 400 kV substation constructions were available from recent cases (3 in Mozambique and 2 in Bangladesh). The cost of substations is known to correlate with the transformer capacity. By knowing this correlation, we were able to linearize the cost of the 400 kV substations by the least squares method and make estimations from the data.



(Source: JICA Survey Team)

Figure 7-23 Estimated 400 kV substation cost

Likewise, the two recent cost estimates for 220 kV substations elsewhere (Angola 1 case, Mozambique 1 case) allowed us to linearize the value by the least squares method and make an estimate.



(Source: JICA Survey Team)

Figure 7-24 Estimated 220 kV substation cost

According to the above results, the cost per substation based on the transformer total capacity is as shown in Table 7-11.

Table 7-11 Cost per substation based on the total transformer capacity

| Voltage | Cost per substation based on total transformer capacity P (Unit: MUS\$ /substation) |
|---------|--|
| 400kV | $0.024 \times P(\text{MVA}) + 29.67$ |
| 220kV | $0.054 \times P(\text{MVA}) + 11.58$ |

(Source: JICA Survey Team)

7.6.3 Analysis based on international interconnection with neighboring countries (Democratic Republic of Congo, Namibia, Zambia)

We studied the international interconnection plan with neighboring countries (Democratic Republic of Congo, Namibia, and Zambia) described in Angola Energia 2025.

The international interconnections described in Angola Energia 2025 cover the following four areas.

- I. Democratic Republic of Congo Inga Hydroelectric Power Station and Soyo Substation
- II. International ties with Western strains from the Kananga substation in the Democratic Republic of Congo
- III. International interconnection with western strains from the Copper Belt substation in Zambia
- IV. Interconnection with an SAPP interconnection transmission line via the Ruakana substation in Namibia

Figure 7-25 outlines the interconnections.




Figure 7-25 Outline of international interconnections with Angol
(Source: RNT, JICA Survey Team)

Turning to the current status of the examination, information gathered from RNT reveals the following contact points with SAPP (Southern Africa Power Pool) in the field. The concept for I is as follows: the electric power produced by the large-scale development of the Inga hydropower station in the Democratic Republic of Congo is transmitted through the power system of Angola, then onward through the SAPP international interconnection line, and finally to South Africa.

The investigation has been suspended, however, because of political problems with the Democratic Republic of Congo. When the investigation is resumed, the SAPP team currently examining the feasibility study for interconnection with Namibia will to do the same for this interconnection plan.

As for II, there is no power transmission system that can be connected to the Congo side at present. There are reports that electric power is being received by a private line from a small hydropower station on the Congo side. A similar scheme will be conducted after the development of the Western transmission line. Thus, we confirmed that international connection with Congo would not take place.


As for III, there were once plans to sell electricity to the Copper Belt region, a mining development zone in Zambia. Those plans are now abandoned.

As for IV, the purposes are to sell electricity to South Africa through the international interconnection line passing through Namibia and to aim to ensure a stable supply of electricity by receiving power in drought periods. The SAPP team is currently considering a feasibility study. The concept study has been completed, and international linkage is judged to be possible. The final report of the feasibility study is scheduled to be submitted in FY 2018, after financing. We believe that the project will be started in 2025 after the environmental impact assessment procedure is completed.

The concept for the international interconnection line consists of establishing a new 400 kV transmission line from the Cahama substation in Angola to the Ruakana substation in Namibia, boosting the 330 kV transmission line between the Ruakana substation and Omburu substation in Namibia to 400 kV, establishing a new 400 kV transmission line from the Omburu substation to the Auasa substation in Namibia, the end point of the international interconnection line between South Africa and Namibia, and connecting to the existing 400 kV international interconnection line.

Figure 7-26 shows the concept for the international interconnected transmission lines.

Since the international interconnection line from Angola to South Africa will be a long distance transmission line of over 2,000 km, it will be necessary to carefully consider the system stability problem. While the stability problem falls outside the direct scope of this survey, we want to call attention to it. An interchange power of 400 MW is assumed. If the power development is carried out smoothly in Angola, we believe that there will be no big influence on the electricity supply and demand.



(Source: RNT, JICA Survey Team)

Figure 7-26 Outline of the international interconnection plan concept with SAPP

Under these circumstances, cases I and IV are considered to be international interconnections affecting the future interconnection of Angola.

This situation is not considered ideal from a general perspective, as the tidal current control becomes difficult when interconnecting at two or more connection points with a power system based on alternative current. It would be inappropriate, however, to form a direct current interconnection. Doing so would be costly for the conversion facilities and poorly suited to the selling of electricity. There therefore seems to be no problem with case IV, whose feasibility study is currently advancing.

Furthermore, when interconnecting I, it is advisable to connect a part of the generator of the Inga hydroelectric power plant as a power source with a dedicated line, without interconnection with the power system of the Republic of Congo.

The Angola side was apprised of this situation at the JCC meeting and workshop.

Moreover, in order to conduct international interconnection, it will be necessary to first establish a plan to monitor and control the domestic power system. The maintenance of power frequency and economic operations seems to be severely challenged in the current monitoring and control system in Angola.

At the workshop, therefore, we urged the Angola side to understand the need for system monitoring and control. In this report we also introduced the SCADA system to the central dispatching center, the entity supervising and controlling the entire system, in order to enhance the grid monitoring control we would like to propose.

7.7 Transmission network development plan

7.7.1 Policy

First, as for the 220 kV system, a 220 kV substation representing the regional load has been determined to ensure consistency with the regional demand assumption. The 220 kV substation is connected with the 400 kV substation via a 220 kV transmission line, and the existing 220 kV transmission lines, substations, and 220 kV transmission lines connecting the power plant are adjusted as needed to make a plan.

Regarding the 400 kV core system, since RNT is already planning to form a skeleton by 2027, we basically adopt that plan to the system and check the consistency of the new 400 kV transmission lines connecting a power plant and 220 kV power lines with the plan to revise it.

Ultimately, the substation capacity, transmission line capacity, and capacity of the phase modifying facility are determined by a power system analysis.

The development planning procedure is shown in the flowchart of Figure 7-27.




Figure 7-27 Flowchart of the Transmission Network Development Plan
(Source: JICA Survey Team)

7.7.2 Regional supply substation plan based on demand forecasts

The following table outlines the required substations and capacity for each province (Province) based on the annual maximum electric power demand forecast.

Table 7-12 220 kV Substation plan based on demand forecast of northern region

| Provincia | Capital | Year | 2020 | 2025 | 2030 | 2035 | 2040 | Remarks (Operation Year) |
|--------------|-------------|-----------------------------|--------------------------|-------|--------|-------|-------|-----------------------------|
| Luanda | Luanda | Forecasted Demand (MW) | 2123 | 2752 | 3183 | 4220 | 4734 | |
| | | > 220kV Gnenrator (MW) | 614 | 0 | 0 | 0 | 0 | |
| | | Neccesary Capacity (MVA) | 1,677 | 3,058 | 3,537 | 4,689 | 5,259 | |
| | | Existing Capacity(MVA) | 2520 | 2520 | 4920 | 5160 | 6000 | |
| | | Insufficient capacity (MVA) | — | 538 | -1,383 | -471 | -741 | |
| | | Total Planned Capacity(MVA) | 2520 | 4920 | 5160 | 6000 | 6240 | |
| | | Substation Name | Substation Capacity(MVA) | | | | | |
| | | Catete | 240 | 240 | 240 | 240 | 240 | exsitng |
| | | Cazeniza | 300 | 300 | 300 | 420 | 420 | exsitng upgrade2035 |
| | | Viana | 300 | 300 | 300 | 300 | 300 | exsitng upgrade2025 |
| | | Filda | 240 | 240 | 240 | 240 | 240 | exsitng |
| | | Camama | 360 | 360 | 480 | 480 | 480 | exsitng upgrade2025 |
| | | Cacuaco | 120 | 480 | 480 | 720 | 720 | exsitng upgrade2021 2034 |
| | | Sambizanga | 240 | 480 | 480 | 480 | 720 | exsitng upgrade2025 2036 |
| | | Futunco de Belas | 240 | 240 | 360 | 360 | 360 | exsitng upgrade2030 |
| | | Ramiro | 240 | 240 | 240 | 240 | 240 | exsitng |
| | | Bitá | 240 | 240 | 240 | 240 | 240 | 2020 |
| | | Zango | | 360 | 360 | 360 | 360 | 2022 |
| | | Golfe | | 360 | 360 | 360 | 360 | 2022 |
| | | Chicara | | 480 | 480 | 480 | 480 | 2025 |
| | | PIV | | | | 480 | 480 | 2035 |
| Bengo | Caxito | Forecasted Demand (MW) | 59 | 119 | 177 | 242 | 316 | |
| | | > 220kV Gnenrator (MW) | | | | | | |
| | | Neccesary Capacity (MVA) | 65 | 132 | 197 | 269 | 351 | |
| | | Existing Capacity(MVA) | 305 | 305 | 425 | 425 | 425 | |
| | | Insufficient capacity (MVA) | -240 | -173 | -228 | -156 | -74 | |
| | | Total Planned Capacity(MVA) | 305 | 425 | 425 | 425 | 545 | |
| | | Substation Name | Substation Capacity(MVA) | | | | | |
| | | Kapary | 240 | 240 | 240 | 240 | 360 | exsitng upgrade2035 |
| | | ADA | 65 | 65 | 65 | 65 | 65 | exsitng |
| | | Caxito | | 60 | 60 | 60 | 60 | 2025 |
| Kuanza Norte | N'dalatando | Forecasted Demand (MW) | 67 | 151 | 221 | 288 | 358 | |
| | | > 220kV Gnenrator (MW) | | | | | | |
| | | Neccesary Capacity (MVA) | 75 | 168 | 246 | 320 | 398 | |
| | | Existing Capacity(MVA) | 310 | 310 | 390 | 390 | 510 | |
| | | Insufficient capacity (MVA) | — | -142 | -144 | -70 | -112 | |
| | | Total Planned Capacity(MVA) | 310 | 390 | 390 | 510 | 510 | |
| | | Substation Name | Substation Capacity(MVA) | | | | | |
| | | Cambutas | 240 | 240 | 240 | 240 | 240 | exsitng |
| | | N' Dalatando | 40 | 120 | 120 | 120 | 120 | exsitng upgrade2025 |
| | | Pambos de Sonhe | 30 | 30 | 30 | 30 | 30 | exsitng |
| Malanje | Malanje | Forecasted Demand (MW) | 103 | 152 | 216 | 290 | 359 | |
| | | > 220kV Gnenrator (MW) | | | | | | |
| | | Neccesary Capacity (MVA) | 115 | 169 | 240 | 323 | 399 | |
| | | Existing Capacity(MVA) | 130 | 130 | 370 | 370 | 370 | |
| | | Insufficient capacity (MVA) | — | 39 | -130 | -47 | 29 | |
| | | Total Planned Capacity(MVA) | 130 | 370 | 370 | 370 | 490 | |
| | | Substation Name | Substation Capacity(MVA) | | | | | |
| | | Capanda Elevadora | 130 | 130 | 130 | 130 | 130 | exsitng upgrade2020 |
| | | Malanje2(Catapa) | | 240 | 240 | 240 | 360 | 2022 Upgrade2040 |
| | | Lucala | | | | 120 | 120 | 2035 |
| Uíge | Uíge | Forecasted Demand (MW) | 73 | 156 | 256 | 370 | 501 | |
| | | > 220kV Gnenrator (MW) | | | | | | |
| | | Neccesary Capacity (MVA) | 81 | 173 | 284 | 412 | 556 | |
| | | Existing Capacity(MVA) | 80 | 80 | 280 | 280 | 280 | |
| | | Insufficient capacity (MVA) | — | 93 | 4 | 132 | 276 | |
| | | Total Planned Capacity(MVA) | 80 | 280 | 460 | 580 | 620 | |
| | | Substation Name | Substation Capacity(MVA) | | | | | |
| | | Uíge | 40 | 240 | 240 | 240 | 240 | exsitng upgrade2022 |
| | | Maquela do Zombo | 40 | 40 | 40 | 40 | 80 | exsitng upgrade2036 |
| | | Negaze | | | 180 | 180 | 180 | 2030 |
| Zaire | Zaire | Forecasted Demand (MW) | 55 | 105 | 164 | 230 | 303 | |
| | | > 220kV Gnenrator (MW) | | | | | | |
| | | Neccesary Capacity (MVA) | 61 | 117 | 182 | 256 | 337 | |
| | | Existing Capacity(MVA) | 366 | 406 | 406 | 406 | 523 | |
| | | Insufficient capacity (MVA) | — | -289 | -224 | -150 | -186 | |
| | | Total Planned Capacity(MVA) | 406 | 406 | 406 | 523 | 523 | |
| | | Substation Name | Substation Capacity(MVA) | | | | | |
| | | Soyo | 240 | 240 | 240 | 240 | 240 | exsitng |
| | | N'Zeto | 63 | 63 | 63 | 63 | 63 | exsitng |
| | | M'Banza Congo | 63 | 63 | 63 | 180 | 180 | exsitng upgrade2031 |
| Cabinda | Cabinda | Forecasted Demand (MW) | 104 | 135 | 178 | 222 | 269 | |
| | | > 220kV Gnenrator (MW) | 104 | 135 | 0 | 0 | 0 | |
| | | Neccesary Capacity (MVA) | 0 | 0 | 198 | 247 | 299 | |
| | | Existing Capacity(MVA) | 0 | 0 | 0 | 360 | 360 | |
| | | Insufficient capacity (MVA) | — | 0 | 198 | -113 | -61 | |
| | | Total Planned Capacity(MVA) | 0 | 0 | 360 | 360 | 360 | |
| | | Substation Name | Substation Capacity(MVA) | | | | | |
| | | Cabinda | | | 240 | 240 | 240 | 2030 |
| | | Cacong | | | 120 | 120 | 120 | 2030 |
| | | Subtotal | 3751 | 6791 | 7571 | 8768 | 9288 | |

(Source: JICA Survey Team)

Based on the anticipated demand for each province, the JICA Survey Team chose the location of the demand center and decided the substation position, working in consultation with RNT. In areas

small-scale demand will continue in the future, the substation capacity (originally set to less than 60 MVA) was standardized to 120 MVA or 240 MVA according to the demand scale. For heavy load areas in Luanda area, 480 MVA or 720 MVA was adopted.

In Table 7-12, the red indicates the existing substation and its capacity, and the blue indicates the new substation and its capacity and the capacity of the substation after expansion. The year of new establishment and year of enhancement are stated in the remarks column.

The same applies to Table 7-13 to Table 7-15.

Table 7-13 220 kV Substation plan based on the demand forecast for the central region

| Table 7-15 220 kV Substation plan based on the demand forecast for the central region | | | | | | | | | | | | |
|---|-----------------------------|--------------------------|-----------------------------|--------------------------|-----------------------------|--------------------------|------|------|-----------------------------|----------------------|-----------------------------|-----------------------------|
| Area | Provincia | Capital | Year | 2020 | 2025 | 2030 | 2035 | 2040 | | | | |
| Central | Cuanza Sul | Sumbe | Forecasted Demand (MW) | 101 | 174 | 263 | 369 | 494 | Remarks (Operation Year) | | | |
| | | | > 220kV Gnenrator (MW) | | | | | | | | | |
| | | | Neccesary Capacity (MVA) | 113 | 193 | 292 | 410 | 549 | | | | |
| | | | Existing Capacity(MVA) | 240 | 240 | 480 | 480 | 480 | | | | |
| | | | Insufficient capacity (MVA) | — | -47 | -188 | -70 | 69 | | | | |
| | | | Total Planned Capacity(MVA) | 240 | 480 | 480 | 480 | 600 | | | | |
| | | | Substation Name | Substation Capacity(MVA) | | | | | | | | |
| | | | Alto Chingo | 120 | 120 | 120 | 120 | 120 | | exsitng | | |
| | | | Gabela | 120 | 120 | 120 | 120 | 180 | | exsitng upgrade 2037 | | |
| | | | Waco Kungo | | 60 | 60 | 60 | 60 | | 2022 | | |
| | | | Quibala | | 60 | 60 | 60 | 120 | | 2022 | | |
| | | | Porto Amboim | | 120 | 120 | 120 | 120 | | 2025 | | |
| | | | Cuacra | | 60 | 60 | 60 | 60 | | 2025 | | |
| | | | Benguela | Benguela | Forecasted Demand (MW) | 300 | 415 | 563 | | 734 | 882 | Remarks (Operation Year) |
| | | | | | > 220kV Gnenrator (MW) | | | | | | | |
| | | | | | Neccesary Capacity (MVA) | 333 | 462 | 625 | | 815 | 980 | |
| | | | | | Existing Capacity(MVA) | 550 | 550 | 910 | | 1150 | 1270 | |
| | | | | | Insufficient capacity (MVA) | — | -88 | -285 | | -335 | -290 | |
| | Total Planned Capacity(MVA) | 550 | | | 910 | 1150 | 1270 | 1390 | | | | |
| | Substation Name | Substation Capacity(MVA) | | | | | | | | | | |
| | Quileva | 310 | | | 310 | 310 | 310 | 310 | exsitng | | | |
| | Benguela Sul | 240 | | | 240 | 240 | 240 | 240 | 2018 | | | |
| | Catumbela | | | | 120 | 120 | 240 | 240 | 2025 upgrade2035 | | | |
| | Cubal | | | | 120 | 120 | 120 | 240 | 2022 upgrade2038 | | | |
| | Alto Catumbela | | | | | 120 | 120 | 120 | 2030 | | | |
| | Baria Farta | | | | | 120 | 120 | 120 | 2030 | | | |
| | Bocoio | | | | 120 | 120 | 120 | 120 | 2025 | | | |
| | Huambo | Huambo | | | Forecasted Demand (MW) | 132 | 205 | 318 | 454 | 614 | Remarks (Operation Year) | |
| | | | | | > 220kV Gnenrator (MW) | | | | | | | |
| | | | | | Neccesary Capacity (MVA) | 147 | 228 | 354 | 505 | 682 | | |
| | | | | | Existing Capacity(MVA) | 240 | 240 | 420 | 540 | 540 | | |
| | | | Insufficient capacity (MVA) | — | -12 | -66 | -35 | 142 | | | | |
| | | | Total Planned Capacity(MVA) | 240 | 420 | 540 | 540 | 780 | | | | |
| | | | Substation Name | Substation Capacity(MVA) | | | | | | | | |
| | | | Belém do Dango | 240 | 240 | 240 | 240 | 480 | exsitng upgrade2036 | | | |
| | | | Ukuma | | 60 | 60 | 60 | 60 | 2025 | | | |
| | | | Catchiungo | | 120 | 120 | 120 | 120 | 2025 | | | |
| | | | Bailundo | | | 120 | 120 | 120 | 2030 | | | |
| | | | Bié | Kuito | Forecasted Demand (MW) | 41 | 82 | 131 | 208 | 323 | | Remarks (Operation Year) |
| | | | | | > 220kV Gnenrator (MW) | | | | | | | |
| | | | | | Neccesary Capacity (MVA) | 46 | 91 | 145 | 231 | 359 | | |
| | | | | | Existing Capacity(MVA) | 120 | 120 | 180 | 300 | 360 | | |
| | | | | | Insufficient capacity (MVA) | — | -29 | -35 | -69 | -1 | | |
| | | | | | Total Planned Capacity(MVA) | 120 | 180 | 300 | 360 | 480 | | |
| | | | | | Substation Name | Substation Capacity(MVA) | | | | | | |
| | Kuito | 120 | | | 120 | 240 | 240 | 360 | exsitng upgrade2027 2037 | | | |
| | Andulo | | | | 60 | 60 | 60 | 60 | 2025 | | | |
| | Camacupa | | | | | | 60 | 60 | 2035 | | | |
| Subtotal | | | | | 1150 | 1990 | 2470 | 2650 | 3250 | | | |

(Source: JICA Survey Team)

Table 7-14 220 kV Substation plan based on the demand forecast for the southern region

| Table 7-14 220 kV Substation plan based on the demand forecast for the southern region | | | | | | | | | | | |
|--|-----------------------------|--------------------------|-----------------------------|--------------------------|-----------------------------|------|------|------|-----------------------------|------|-----------------------------|
| Area | Provincia | Capital | Year | 2020 | 2025 | 2030 | 2035 | 2040 | | | |
| Southern | Huila | Lubango | Forecasted Demand (MW) | 121 | 201 | 311 | 443 | 602 | Remarks (Operation Year) | | |
| | | | > 220kV Gnenrator (MW) | 121 | | | | | | | |
| | | | Neccesary Capacity (MVA) | 0 | 224 | 345 | 493 | 668 | | | |
| | | | Existing Capacity(MVA) | 0 | 0 | 780 | 840 | 840 | | | |
| | | | Insufficient capacity (MVA) | — | 224 | -435 | -347 | -172 | | | |
| | | | Total Planned Capacity(MVA) | 0 | 780 | 840 | 840 | 900 | | | |
| | | | Substation Name | Substation Capacity(MVA) | | | | | | | |
| | | | Lubango | | 240 | 240 | 240 | 240 | | 2022 | |
| | | | Nova Lubango | | 120 | 120 | 120 | 120 | | 2025 | |
| | | | Matala | | 120 | 120 | 120 | 120 | | 2022 | |
| | | | Caluquembe | | 60 | 60 | 60 | 120 | 2025 upgrade2040 | | |
| | | | Quilengues | | 60 | 60 | 60 | 60 | 2025 | | |
| | | | Tchamutete | | 120 | 120 | 120 | 120 | 2025 | | |
| | | | Capelongo | | 60 | 60 | 60 | 60 | 2022 | | |
| | | | Chipindo | | | 60 | 60 | 60 | 2030 | | |
| | | | Cunene | Ondjiva | Forecasted Demand (MW) | 39 | 83 | 137 | 200 | 273 | Remarks (Operation Year) |
| | | | | | > 220kV Gnenrator (MW) | 39 | | | | | |
| | | | | | Neccesary Capacity (MVA) | 0 | 92 | 152 | 223 | 304 | |
| | | | | | Existing Capacity(MVA) | 0 | 0 | 240 | 240 | 360 | |
| | | | | | Insufficient capacity (MVA) | — | 92 | -88 | -17 | -56 | |
| | Total Planned Capacity(MVA) | 0 | | | 240 | 240 | 360 | 360 | | | |
| | Substation Name | Substation Capacity(MVA) | | | | | | | | | |
| | Ondjiva | | | | 120 | 120 | 240 | 240 | 2025 upgrade2032 | | |
| | Cahama | | | | 60 | 60 | 60 | 60 | 2025 | | |
| | Xangongo | | | | 60 | 60 | 60 | 60 | 2025 | | |
| | Cuando-Cubango | Menongue | Forecasted Demand (MW) | 42 | 86 | 141 | 204 | 275 | Remarks (Operation Year) | | |
| | | | Planned Gnenrator (MW) | 42 | | | | | | | |
| | | | Neccesary Capacity (MVA) | 0 | 96 | 157 | 227 | 306 | | | |
| | | | Existing Capacity(MVA) | 0 | 0 | 300 | 300 | 360 | | | |
| | | | Insufficient capacity (MVA) | — | 96 | -143 | -73 | -54 | | | |
| | | | Total Planned Capacity(MVA) | 0 | 300 | 300 | 360 | 420 | | | |
| | | | Substation Name | Substation Capacity(MVA) | | | | | | | |
| | | | Cuchi | | 60 | 60 | 60 | 60 | | 2022 | |
| | | | Menangue | | 240 | 240 | 240 | 240 | | 2022 | |
| | | | Cuito Cuanavale | | | | 60 | 60 | | 2035 | |
| | | | Mavinga | | | | | 60 | | 2040 | |
| | Namibe | Namibe | Forecasted Demand (MW) | 65 | 129 | 169 | 212 | 259 | Remarks (Operation Year) | | |
| | | | Planned Gnenrator (MW) | 65 | | | | | | | |
| | | | Neccesary Capacity (MVA) | 0 | 143 | 188 | 236 | 287 | | | |
| | | | Existing Capacity(MVA) | 0 | 0 | 360 | 360 | 360 | | | |
| | | | Insufficient capacity (MVA) | — | 143 | -172 | -124 | -73 | | | |
| | | | Total Planned Capacity(MVA) | 0 | 360 | 360 | 360 | 360 | | | |
| | | | Namibe | | 240 | 240 | 240 | 240 | | 2022 | |
| | | | Tombwa | | 120 | 120 | 120 | 120 | | 2022 | |
| | Subtotal | | | 0 | 1680 | 1740 | 1920 | 2040 | | | |

(Source: JICA Survey Team)

Table 7-15 220 kV Substation plan based on the demand forecast for the western region

| Table 7-15 220 kV Substation plan based on the demand forecast for the western region | | | | | | | | | | | | |
|---|-------------|---------|-----------------------------|--------------------------|-------|-------|-------|-------|-----------------------------|------------------|------|--|
| Area | Provincia | Capital | Year | 2020 | 2025 | 2030 | 2035 | 2040 | Remarks (Operation Year) | | | |
| Eastern | Moxico | Luena | Forecasted Demand (MW) | 28 | 75 | 109 | 157 | 224 | | | | |
| | | | Planned Gnenrator (MW) | 28 | | | | | | | | |
| | | | Neccesary Capacity (MVA) | 0 | 84 | 122 | 175 | 249 | | | | |
| | | | Existing Capacity(MVA) | 0 | 0 | 240 | 360 | 360 | | | | |
| | | | Insufficient capacity (MVA) | — | 84 | -118 | -185 | -111 | | | | |
| | | | Total Planned Capacity(MVA) | 0 | 240 | 360 | 360 | 360 | | | | |
| | | | Substation Name | Substation Capacity(MVA) | | | | | | | | |
| | | | Luena | | 240 | 240 | 240 | 240 | | | 2025 | |
| | | | Cazombo | | | 60 | 60 | 60 | | | 2027 | |
| | | | Luau | | | 60 | 60 | 60 | | 2027 | | |
| | Lunda Norte | Lucapa | Forecasted Demand (MW) | 38 | 97 | 144 | 198 | 260 | | | | |
| | | | Planned Gnenrator (MW) | 38 | | | | | | | | |
| | | | Neccesary Capacity (MVA) | 0 | 107 | 160 | 221 | 289 | | | | |
| | | | Existing Capacity(MVA) | 0 | 0 | 300 | 300 | 300 | | | | |
| | | | Insufficient capacity (MVA) | — | 107 | -140 | -79 | -11 | | | | |
| | | | Total Planned Capacity(MVA) | 0 | 300 | 300 | 300 | 420 | | | | |
| | | | Substation Name | Substation Capacity(MVA) | | | | | | | | |
| | | | Lucapa | | 60 | 60 | 60 | 60 | | 2022 | | |
| | | | Dundo | | 120 | 120 | 120 | 240 | | 2022 upgrade2036 | | |
| | | | Xa-Muteba | | 120 | 120 | 120 | 120 | | 2025 | | |
| | Lunda Sur | Saurimo | Forecasted Demand (MW) | 26 | 77 | 92 | 135 | 181 | | | | |
| | | | Planned Gnenrator (MW) | 26 | | | | | | | | |
| | | | Neccesary Capacity (MVA) | 0 | 86 | 103 | 149 | 201 | | | | |
| | | | Existing Capacity(MVA) | 0 | 0 | 120 | 180 | 300 | | | | |
| | | | Insufficient capacity (MVA) | — | 86 | -17 | -31 | -99 | | | | |
| | | | Total Planned Capacity(MVA) | 0 | 120 | 180 | 300 | 300 | | | | |
| Substation Name | | | Substation Capacity(MVA) | | | | | | | | | |
| Saurimo | | | | 120 | 120 | 240 | 240 | | 2022 upgrade2032 | | | |
| Muconda | | | | | 60 | 60 | 60 | | 2027 | | | |
| Subtotal | | | 0 | 660 | 840 | 960 | 1080 | | | | | |
| TOTAL | | | | 4901 | 10941 | 12081 | 14058 | 15418 | | | | |

(Source: JICA Survey Team)

7.7.3 220 kV power transmission line plan based on the regional supply substation plan

Based on the result of 7.7.2, the connections between the regional supply substations and main system in the existing plan are decided based on the geographical positions and the starting year of operation. Table 7-17 shows the power transmission line plan compiled based on the result of the power flow analysis.

With regard to the connecting transmission line, a two-line connection was basically adopted in consideration of the N-1 reliability criteria.

Also, a loop circuit formed with a 220 kV system could cause unexpected overloads at the time of an accident. Power transmission lines with one circuit connection were removed to reduce the complexity of the system and make the system as easy to operate as possible.

Regarding the substations located nearby the existing transmission line, we decided to divide the power transmission line into 4 lines π .

Finally, we formed an appropriate power transmission equipment plan by considering these factors and working through a process of repeated trials and errors.

Projects stricken out by red line lines in Table 7-16 are deleted to avoiding the aforementioned loop circuit.

Projects stated in blue are new substation facility plans derived from the demand forecast up to the 2040 fiscal year. All have been added to the existing plans.

The revised number of lines and operation starting years in the existing plan are written in blue.

According to the review of the plan based on the substation supply plan, the length of the transmission line work increased by about 500 km, from 3,269 km to 3,766 km.

Table 7-16 Review of the Transmission Line plan accompanying the regional supply substation plan

| Project# | Area | Voltage (kV) | Starting point | End point | number of circuit | Line Length (km) | Year of operation | Remarks |
|----------|----------|--------------|------------------|-----------------|-------------------|------------------|-------------------|-----------------------|
| 1 | Northern | 220 | Filda | Golfe | 2 | 7 | 2022 | |
| 2 | Northern | 220 | Bitá | Camama | 2 | 21 | 2022 | |
| | Northern | 220 | Bitá | Ramires | + | | 2022 | Avoiding Loop circuit |
| 3 | Northern | 220 | Catete | Zango | 2 | 40 | 2022 | |
| 4 | Northern | 220 | Capanda elev. | Maranje | 2 | 110 | 2022 | |
| 5 | Northern | 220 | Kapary | Caxito | 2 | 26 | 2025 | |
| 6 | Northern | 220 | N'Zeto | Tomboco | 2 | 5 | 2025 | Substation inserted |
| 7 | Northern | 220 | M'banza Congo | Tomboco | 2 | 5 | 2025 | Substation inserted |
| 8 | Northern | 220 | Sambizanga | Chicala | 2 | 7 | 2025 | |
| | Northern | 220 | Futundo de Belas | Chicala | + | | 2025 | Avoiding Loop circuit |
| 9 | Northern | 220 | Catete | Maria Teresa | 2 | 51 | 2025 | |
| 10 | Northern | 220 | Viana | PIV | 2 | 7 | 2035 | |
| | Northern | 220 | Gazanga | PIV | + | | 2035 | Avoiding Loop circuit |
| 11 | Northern | 220 | Uige | Negage | 2 | 5 | 2030 | Substation inserted |
| 12 | Northern | 220 | Pambos de Sonhe | Negage | 2 | 5 | 2030 | Substation inserted |
| 13 | Northern | 220 | Negage | Sanza Pombo | 2 | 109 | 2035 | |
| | Central | 220 | Gambambo | Gabela | + | | 2022 | Avoiding Loop circuit |
| 14 | Central | 220 | Gabela | Alto Chingo | 1 | 81 | 2022 | Dualization |
| | Central | 220 | Gabela | Quibala | + | | 2022 | Avoiding Loop circuit |
| 15 | Central | 220 | Quibala | Waco Kungo | 2 | 92 | 2022 | |
| 16 | Central | 220 | Lomaum | Cubal | 2 | 2 | 2022 | |
| | Central | 220 | Belem do Dango | Cubal | + | | 2022 | Avoiding Loop circuit |
| 17 | Central | 220 | Alto Chingo | Cuacra | 2 | 25 | 2025 | |
| 18 | Central | 220 | Alto Chingo | Port Amboim | 2 | 60 | 2025 | |
| 19 | Central | 220 | Quileva | Nova Biopio | 1 | 18 | 2025 | Dualization |
| 20 | Central | 220 | Quileva | Catumbela | 2 | 8 | 2025 | |
| 21 | Central | 220 | Nova Biopio | Bocoio | 2 | 5 | 2025 | Substation inserted |
| 22 | Central | 220 | Lomaum | Bocoio | 2 | 5 | 2025 | Substation inserted |
| | Central | 220 | Cubal | Ukuma | + | | 2025 | Avoiding Loop circuit |
| 23 | Central | 220 | Belem do Huambo | Ukuma | 2 | 66 | 2025 | |
| 24 | Central | 220 | Belem do Huambo | Catchiungo | 2 | 9 | 2025 | Substation inserted |
| 25 | Central | 220 | Kuito | Catchiungo | 2 | 9 | 2025 | Substation inserted |
| | Central | 220 | Belem do Dango | Kuito | + | | 2027 | Avoiding Loop circuit |
| 26 | Central | 220 | Kuito | Andulo | 2 | 124 | 2025 | |
| 27 | Central | 220 | Cubal | Alto Catumbela | 2 | 47 | 2030 | |
| 28 | Central | 220 | Benguela Sul | Catumbela | 2 | 26 | 2025 | |
| 29 | Central | 220 | Catchiungo | Bailundo | 2 | 66 | 2030 | |
| 30 | Central | 220 | Benguela Sul | Baia Farta | 2 | 30 | 2030 | |
| 31 | Central | 220 | Kuito | Chitembo | 2 | 145 | 2035 | |
| 32 | Southern | 220 | Lubango2 | Lubango | 2 | 30 | 2020 | |
| 33 | Southern | 220 | Lubango2 | Namibe | 2 | 162 | 2020 | |
| 34 | Southern | 220 | Namibe | Tombwa | 2 | 97 | 2020 | |
| 35 | Southern | 220 | Lubango2 | Matala | 2 | 168 | 2022 | |
| 36 | Southern | 220 | Matala HPS | Matala | 1 | 5 | 2022 | |
| 37 | Southern | 220 | Capelongo | Cuchi | 2 | 91 | 2022 | |
| 38 | Southern | 220 | Cuchi | Menongue | 2 | 94 | 2022 | |
| 39 | Southern | 220 | Cahama | Xangongo | 2 | 97 | 2025 | |
| 40 | Southern | 220 | Ondjiva | Xangongo | 1 | 97 | 2025 | |
| | Southern | 220 | Capelongo | Matala | + | | 2027 | Avoiding Loop circuit |
| 41 | Southern | 220 | Matala | Jamba Mina | 1 | 86 | 2035 | |
| 42 | Southern | 220 | Jamba mina | Jamba Oma | 1 | 37 | 2035 | |
| 43 | Southern | 220 | Capelongo | Tchamutete | 2 | 98 | 2025 | |
| 44 | Southern | 220 | Menongue | Cuito Cuanavale | 2 | 189 | 2035 | |
| 45 | Southern | 220 | Cuito Cuanavale | mavinga | 2 | 176 | 2035 | |
| 46 | Eastern | 220 | Saurimo | Lucapa | 2 | 157 | 2020 | |
| 47 | Eastern | 220 | Lucapa | Dundo | 2 | 135 | 2020 | |
| 48 | Eastern | 220 | Saurimo | Lue na | 2 | 265 | 2025 | |
| 49 | Eastern | 220 | Saurimo | Muconda | 2 | 187 | 2027 | |
| 50 | Eastern | 220 | Muconda | Luau | 2 | 115 | 2027 | |
| 51 | Eastern | 220 | Luau | Cazombo | 2 | 264 | 2027 | |
| | | | | | Total | 3,766 | | |

(Source: JICA Survey Team)

7.7.4 Transmission Development plan based on the Generation Development Plan

Based on the Generation Development Plan, we considered connection to the substation or the transmission line in the voltage class transmission system at the closest point from the power generation site, vis-à-vis the generation capacity. The results are shown in Table 7-17.

The connecting transmission lines are omitted for the hydroelectric power plants not scheduled to start operation by 2040.

Table 7-17 Result of Transmission Line connection based on the power generation plan

| Hydropower Plant | (River) | Area | Installed | 2017 | 2018 | 2020 | 2025 | 2030 | 2035 | 2040 | Transmission Line | | |
|------------------------------------|-----------|---------|-----------|-------|------|------|------|------|------|------|-------------------|----------------------|---------------|
| <Existing PP (Available Capacity)> | - | - | 1,699 | 1699 | 1649 | 1649 | 1594 | 1594 | 1594 | 1594 | Voltage | Connected Substation | Distance (km) |
| <Development Plan> | | | | 931.5 | 1928 | 2169 | 4341 | 4851 | 6701 | 7154 | | | |
| HPP Lauca | Kwanza | North | 2,070 | 931.5 | 1863 | 2070 | 2070 | 2070 | 2070 | 2070 | 400kV | Cambutas | 224 |
| HPP Caculo Cabaça | Kwanza | North | 2,172 | | | | 2172 | 2172 | 2172 | 2172 | 400kV | Cambutas | 54 |
| HPP Zenzo | Kwanza | North | 950 | | | | | | 950 | 950 | 400kV | Cambutas | 41 |
| HPP Tímulo Caçador | Kwanza | North | 453 | | | | | | | 453 | 220kV | Cambutas | 16 |
| HPP Quissonde | Kwanza | North | 121 | | | | | | | | 220kV | — | — |
| HPP Genga ② | Quive | North | 900 | | | | | | 900 | 900 | 400kV | Benga Switch-yard | 30 |
| HPP Benga | Quive | North | 1,000 | | | | | | | | 400kV | — | — |
| HPP Quilengue ⑤ | Quive | North | 210 | | | | | 210 | 210 | 210 | 220kV | Gabera | 37 |
| HPP Lomaum Extension | Catumbela | Central | 215 | | 65 | 65 | 65 | 65 | 65 | 65 | 220kV | Nova_Biopio | 81 |
| HPP Lomaum2 | Catumbela | Central | 150 | | | | | | | | 220kV | — | — |
| HPP Baynes (50% Angola) | Cunene | South | 300 | | | | | 300 | 300 | 300 | 400kV | Cahama | 195 |
| HPP Jamba Ya Oma | Cunene | South | 79 | | | | | | | | 220kV | HPP Jamba Ya Mina | 37 |
| HPP Jamba Ya Mina | Cunene | South | 205 | | | | | | | | 220kV | Matala | 86 |
| HPP Luachimo (extention) | | East | 34 | | | 34 | 34 | 34 | 34 | 34 | 60kV | Dundo | 5 |
| Candidate Total = | | | 7,154 | 2631 | 3577 | 3818 | 5935 | 6445 | 8295 | 8748 | | | |

| Thermal Power Plant | Type | Area | (MW) | 2017 | 2018 | 2020 | 2025 | 2030 | 2035 | 2040 | Transmission Line | | |
|----------------------|------|----------|-------|------|------|------|-------|-------|-------|-------|-------------------|----------------------|---------------|
| <Development Plan> | | | | | | | | | | | Voltage | Connected Substation | Distance (km) |
| TPP Soyo 1 | CCGT | Zaire | 750 | 250 | 750 | 750 | 750 | 750 | 750 | 750 | 400kV | Soyo_SS | 5 |
| TPP Soyo 2 | CCGT | Zaire | 750 | | | | 750 | 750 | 750 | 750 | 400kV | Soyo_SS | 5 |
| TPP Lobito CCGT No.1 | CCGT | Benguela | 750 | | | | 375 | 750 | 750 | 750 | 400kV | Nova_Biopio_SS | 23 |
| TPP Lobito CCGT No.2 | CCGT | Benguela | 750 | | | | | | 750 | 750 | 400kV | Nova_Biopio_SS | 23 |
| TPP Namibe CCGT No.3 | CCGT | Namibe | 750 | | | | | | | 750 | 220kV | Namibe_SS | 17 |
| TPP Lobito CCGT No.4 | CCGT | Benguela | 375 | | | | | | | 375 | 400kV | Nova_Biopio_SS | 23 |
| TPP Cacuaco GT No.1 | GT | Luanda | 375 | | | | 125 | 250 | 375 | 375 | 220kV | Cacuaco | 5 |
| TPP Cacuaco GT No.2 | GT | Luanda | 375 | | | | 125 | 125 | 250 | 375 | 220kV | Cacuaco | 5 |
| TPP Boavista GT No.3 | GT | Luanda | 375 | | | | 125 | 125 | 250 | 375 | 220kV | Sambizanga | 5 |
| TPP Quileva GT No.4 | GT | Benguela | 250 | | | | | 125 | 250 | 250 | 220kV | Quileva | 1 |
| TPP Quileva GT No.5 | GT | Benguela | 250 | | | | | 125 | 250 | 250 | 220kV | Quileva | 1 |
| TPP Quileva GT No.6 | GT | Benguela | 250 | | | | | 125 | 250 | 250 | 220kV | Quileva | 1 |
| TPP Soyo GT No.7 | GT | Zaire | 375 | | | | | 125 | 250 | 375 | 400kV | Soyo_SS | 5 |
| Candidate Total = | | | 6,375 | 250 | 750 | 750 | 2,250 | 3,250 | 4,875 | 6,375 | | | |


(Source: JICA Survey Team)

The following pages show schematic figures of each transmission line connecting to the power station.




(Source: JICA Survey Team)

Figure 7-28 System connection status of Soyo thermal power station




(Source: JICA Survey Team)

Figure 7-29 Status of connection of Luachimo hydroelectric power station




(Source: JICA Survey Team)

Figure 7-30 Connection status of thermal power stations in the Luanda area




(Source: JICA Survey Team)

Figure 7-31 Connection status of hydropower stations in the Cuanza River area




(Source: JICA Survey Team)

Figure 7-32 Connection status of hydropower stations in the Quive River area



(Source: JICA Survey Team)

Figure 7-33 System connection status around the Lobito thermal power plant



(Source: JICA Survey Team)

Figure 7-34 System connection status of the Namibe thermal powerplant and Baynes hydropower plant

7.7.5 400 kV main Transmission Line and Substation Plan based on electric power system analysis

Based on the existing power grid development plan for RNT and subsequent studies, we determined the load from the demand assumption for each region, determined the capacity of the regional supply substation, and analyzed the data using the power system analysis program (PSSE), the de facto world standard.

A review of the 400 kV transmission and transformation plan described in 7.6.1 based on the results is shown in Table 7-18 and Table 7-19.

With respect to the 400 kV substation plan, based on the demand assumption of 2040, we plan to establish four (4) new substations and review the capacities and operation years of the planned substations. The required incremental capacities of existing substations were also added.

The total capacity of the new substation is 12,720 MVA, that is, about 5,500 MVA more than the 7,290 MVA capacity of the existing plan up to 2027. In 2040, the rapid increase in the scale of the system will bring the capacity up to 21,840 MVA. The main factor will be the approximately 2,000 MVA increase in the existing substation to meet increased demand from the capital Luanda, about 5,000 MVA (mainly Viana substation). It will be necessary to strengthen the local system by about 2,000 MVA.

Table 7-18 400 kV main Substation plan based on electric power system analysis

| Project# | Area | Voltage (kV) | Substation Name | Capacity (MVA) | Year of operation | Upgrade | | | | Final Capacity (MVA) |
|-------------------------------|-------------|--------------|-----------------|----------------|-------------------|---------|-------|------|------|----------------------|
| | | | | | | 2025 | 2030 | 2035 | 2040 | |
| 1 | Cuanza Sul | 400 | Waco kungo | 450 | 2020 | 450 | | | | 900 |
| 2 | Huambo | 400 | Belem do Huambo | 1,350 | 2020 | | | | | 1,350 |
| 3 | Luanda | 400 | Bitá | 900 | 2022 | 450 | | 450 | | 1,800 |
| 4 | Huíla | 400 | Lubango | 900 | 2025 | | | | | 900 |
| 5 | Huíla | 400 | Capelongo | 900 | 2025 | | | | | 900 |
| 6 | Huíla | 400 | Caluquembe | 120 | 2025 | | | | | 120 |
| 7 | Benguela | 400 | Nova Biopio | 900 | 2025 | | | | | 900 |
| 8 | Southern | 400 | Cahama | 900 | 2025 | | | | | 900 |
| 9 | Eastern | 400 | Saurimo | 900 | 2025 | | | | | 900 |
| 10 | Lunda Norte | 400 | Xa-Muteba | 360 | 2025 | | | | | 360 |
| 11 | Cunene | 400 | Ondjiva | 900 | 2035 | | | | | 900 |
| 12 | Huíla | 400 | Quilengues | 120 | 2025 | | | | | 120 |
| 13 | Cuanza Sul | 400 | Gabela | 900 | 2025 | | | | | 900 |
| 14 | Luanda | 400 | Sambizanga | 1,860 | 2025 | | | | | 1,860 |
| 15 | Malanje | 400 | Lucala | 900 | 2025 | | | 450 | | 1,350 |
| 16 | Chipindo | 400 | Chipindo | 360 | 2025 | | | | | 360 |
| 17 | Zaire | 400 | N'Zeto | 450 | existing | 450 | | | | 900 |
| 18 | Luanda | 400 | Viana | 210 | existing | 2,790 | 930 | | | 3,720 |
| 19 | Bengo | 400 | Kapary | 450 | existing | 450 | 450 | | | 1,350 |
| 20 | Luanda | 400 | Catete | 900 | existing | | 450 | | | 1,350 |
| New Substation capacity Total | | | | 12,720 | Sub Total | 4,590 | 1,830 | 900 | 0 | 21,840 |

(Source: JICA Survey Team)

As for the 400 kV transmission lines, we will satisfy the N-1 reliability criteria by dualizing the transmission lines connecting to important large-scale hydropower stations and adding a new construction of 6 transmission lines. We reexamined several single circuit transmission lines connecting to the large-scale hydropower station to be changed to double circuit. Also, in response to the addition of four (4) substations to the plan, we re-examined the plan with a total of (10) related transmission lines. We also decided to construct two (2) lines for connection of the Caculo Cabaca hydropower station and to transmit to the Catete substation via the Lauca substation.

Table 7-19 400 kV main Transmission Line plan based on electric power system analysis

| Project# | Area | Voltage (kV) | Starting point | End point | number of circuit | Line Length (km) | Year of operation | Remarks |
|----------|---------------------|----------------|---------------------------|------------------------|-------------------|------------------|-------------------|-------------------------------|
| 1 | Northern | 400 | Catete | Bitá | 2 | 54 | 2022 | |
| | Northern | 400 | Cambutas | Bitá | + | | 2022 | |
| 2 | Northern | 400 | Cambutas | Caculo Cabaca | 2 | 54 | 2023 | Dualization |
| 3 | Northern | 400 | Caculo Cabaca | Bitá | + | | 2023 | |
| 4 | Northern | 400 | Cambutas | Catete | 1 | 123 | 2025 | Dualization |
| 5 | Northern | 400 | Catete | Viana | 1 | 36 | 2025 | Dualization |
| 6 | Northern | 400 | Lauca | Capanda elev. | 1 | 41 | 2025 | Dualization |
| 7 | Northern | 400 | Kapary | Sambizanga | 2 | 45 | 2025 | For New Substation |
| 8 | Northern | 400 | Lauca | Catete | 2 | 190 | 2025 | Changing Connection Plan |
| 9 | Northern | 400 | Lauca | Caculo Cabaca | 2 | 25 | 2025 | Changing Connection Plan |
| 10 | Central | 400 | Lauca | Waco kungo | 1 | 177 | 2020 | |
| 11 | Central | 400 | Waco kungo | Belem do Huambo | 1 | 174 | 2020 | |
| | Central | 400 | Belem do Dango | Lubango | + | | 2022 | |
| | Central | 400 | Belem do Dango | Capelongo | + | 202 | 2022 | |
| 12 | Central | 400 | Lauca | Waco kungo | 1 | 177 | 2025 | Dualization |
| 13 | Central | 400 | Waco kungo | Belem do Huambo | 1 | 174 | 2025 | Dualization |
| | Central | 400 | Caculo Cabaca | Nova Biopio | + | | 2025 | |
| 14 | Central | 400 | Cambutas | Gabela | 2 | 131 | 2025 | For New Substation |
| 15 | Central | 400 | Gabela | Benga | 2 | 25 | 2025 | For New Substation |
| 16 | Central | 400 | Benga | Nova Biopio | 2 | 200 | 2025 | For New Substation |
| | Central | 400 | Nova Biopio | Lubango | + | | 2025 | |
| 17 | Central | 400 | Benga | Genga | 2 | 30 | 2035 | |
| 18 | Southern | 400 | Belem do Huambo | Caluquembe | 2 | 175 | 2025 | For New Substation |
| 19 | Southern | 400 | Caluquembe | Lubango2 | 2 | 168 | 2025 | For New Substation |
| 20 | Southern | 400 | Belem do Huambo | Chipindo | 2 | 114 | 2025 | For New Substation |
| 21 | Southern | 400 | Chipindo | Capelongo | 2 | 109 | 2025 | For New Substation |
| 22 | Southern | 400 | Nova Biopio | Quilengues | 2 | 117 | 2025 | For New Substation |
| 23 | Southern | 400 | Quilengues | Lubango2 | 2 | 143 | 2025 | For New Substation |
| 24 | Southern | 400 | Lubango2 | Cahama | 2 | 190 | 2025 | |
| 25 | Southern | 400 | Capelongo | Ondjiva | 1 | 312 | 2035 | |
| 26 | Southern | 400 | Cahama | Ondjiva | 1 | 175 | 2035 | |
| | Southern | 400 | Biopio—Lubango | Caluquembe | 2 | 5 | 2027 | |
| | Southern | 400 | Dango—Lubango | Quilengues | 2 | 5 | 2027 | |
| 27 | Southern | 400 | Cahama | Ruacana | 2 | 125 | 2027 | International Interconnection |
| 28 | Southern | 400 | Cahama | Baynes | 2 | 195 | 2030 | |
| 29 | Eastern | 400 | Capanda elev | Xa-Muteba | 2 | 266 | 2025 | |
| 30 | Eastern | 400 | Xa-Muteba | Surimo | 2 | 335 | 2025 | |
| | | | | | Total | 4,292 | | |

(Source: JICA Survey Team)

7.7.6 The future vision of the main power system

Power plants are generally located far from the demand center. To resolve regional power demand unbalance, the transmission lines in the power supply system must have the appropriate specifications to cope with this issue. Thus, the main power system development plan should be basically considered in consideration of the demand from the respective regions and ensure the supply of surplus power efficiently for the regions at times of electricity shortage.

Extending the vision of the main power system over a time frame of at least 20 years is very important for avoiding double investment, given the span of 20 or more years once the transmission lines are built. For the reason above, 2040 is the final year considered under the power master plan.

7.7.7 Demand assumptions for the substations

Based on the load of the substation modeled in the 2037 PSSE data received from RNT, we estimate loads such as those for the 110 kV, 60 kV systems for 2025, 2030, 2035, and 2040 by adjusting to the total demand and the demand of each province in each year, respectively. The estimated load (active power load, Pload; reactive power load, Qload) of each substation is shown in Table 7-20.

Table 7-20 Substation load data

| Bus Number | Bus Name | Zone Name | 2025 | | 2030 | | 2035 | | 2040 | |
|------------|----------------------|--------------|------------|--------------|------------|--------------|------------|--------------|------------|--------------|
| | | | Pload (MW) | Qload (Mvar) | Pload (MW) | Qload (Mvar) | Pload (MW) | Qload (Mvar) | Pload (MW) | Qload (Mvar) |
| 10011 | M CONGO 60 60.000 | ZAIRE | 29.06 | 9.07 | 52.16 | 16.29 | 79.28 | 24.75 | 115.63 | 36.10 |
| 10013 | NZETO 15 15.000 | ZAIRE | 5.77 | 1.80 | 10.28 | 3.21 | 11.87 | 3.71 | 16.79 | 5.24 |
| 10018 | SOYO 60 1 60.000 | ZAIRE | 68.05 | 21.25 | 98.29 | 30.69 | 129.47 | 40.43 | 151.82 | 47.41 |
| 10031 | TOMBOCO 30 30.000 | ZAIRE | 2.03 | 0.63 | 3.70 | 1.15 | 9.72 | 3.04 | 18.95 | 5.92 |
| 11001 | UIGE 60 60.000 | UIGE | 139.82 | 43.66 | 187.84 | 58.65 | 175.63 | 54.84 | 203.45 | 64.24 |
| 11008 | M ZOMBO 60 60.000 | UIGE | 16.18 | 5.05 | 21.81 | 6.81 | 20.43 | 6.38 | 44.82 | 14.15 |
| 11013 | NEGAGE 60 60.000 | UIGE | 0.00 | 0.00 | 46.42 | 14.49 | 125.35 | 39.14 | 144.47 | 45.62 |
| 11018 | S POMBO 60 60.000 | UIGE | 0.00 | 0.00 | 0.00 | 0.00 | 31.19 | 9.74 | 81.74 | 25.81 |
| 11021 | DAMBA 30 30.000 | UIGE | 0.00 | 0.00 | 0.00 | 0.00 | 17.82 | 5.56 | 26.04 | 6.46 |
| 12001 | CACUACO 60 60.000 | LUANDA | 304.86 | 95.19 | 386.60 | 120.72 | 517.88 | 161.71 | 557.44 | 174.06 |
| 12003 | CAMAMA 60 60.000 | LUANDA | 271.93 | 84.91 | 333.47 | 104.13 | 415.85 | 129.85 | 418.94 | 130.81 |
| 12006 | CAZENGA 60 60.000 | LUANDA | 163.32 | 51.00 | 208.49 | 65.10 | 281.24 | 87.82 | 300.37 | 93.79 |
| 12008 | FILDA 60 60.000 | LUANDA | 108.88 | 34.00 | 138.99 | 43.40 | 187.49 | 58.54 | 200.25 | 62.53 |
| 12010 | VIANA 60 60.000 | LUANDA | 623.39 | 194.65 | 798.05 | 249.19 | 672.06 | 209.85 | 666.65 | 208.16 |
| 12127 | SAMBZANG 60 60.000 | LUANDA | 270.79 | 84.56 | 368.45 | 115.05 | 42.35 | 13.22 | 489.18 | 152.75 |
| 12133 | M BENTO 60 60.000 | LUANDA | 203.95 | 63.68 | 250.10 | 78.09 | 311.89 | 97.39 | 314.20 | 98.11 |
| 12138 | CATETE 60 60.000 | LUANDA | 30.98 | 9.67 | 43.63 | 13.62 | 55.60 | 17.36 | 56.89 | 17.76 |
| 12140 | RAMIROS 60 60.000 | LUANDA | 75.79 | 23.67 | 95.10 | 29.70 | 118.74 | 37.08 | 119.72 | 37.38 |
| 12143 | BITA 60 60.000 | LUANDA | 135.97 | 42.46 | 166.74 | 52.06 | 207.93 | 64.93 | 209.47 | 65.41 |
| 12146 | PIV 60 60.000 | LUANDA | 0.00 | 0.00 | 0.00 | 0.00 | 403.23 | 125.91 | 399.99 | 124.90 |
| 12268 | ZANGO 60 60.000 | LUANDA | 155.85 | 48.66 | 199.51 | 62.30 | 268.82 | 83.94 | 266.66 | 83.26 |
| 12301 | CHICALA 60 60.000 | LUANDA | 236.94 | 73.99 | 322.40 | 100.67 | 430.14 | 134.31 | 428.04 | 133.65 |
| 12306 | GOLF 60 60.000 | LUANDA | 169.25 | 52.85 | 230.28 | 71.91 | 307.24 | 95.94 | 305.74 | 95.47 |
| 13006 | KAPARY 60 60.000 | BENGO | 88.91 | 27.76 | 135.29 | 42.25 | 203.53 | 63.55 | 267.05 | 83.39 |
| 13007 | DANDE 220 220.000 | BENGO | 20.68 | 6.46 | 27.17 | 8.48 | 24.18 | 7.55 | 28.48 | 8.89 |
| 13031 | CAXITO 110 110.000 | BENGO | 9.51 | 2.97 | 14.19 | 4.43 | 14.47 | 4.52 | 20.18 | 6.30 |
| 14010 | NDALAT 60 60.000 | KWANZA NORTE | 52.51 | 16.39 | 77.90 | 24.32 | 46.56 | 14.54 | 60.40 | 18.86 |
| 14012 | P.SONHE 30 30.000 | KWANZA NORTE | 8.47 | 2.64 | 14.98 | 4.68 | 15.30 | 4.78 | 25.47 | 7.95 |
| 14024 | CAMBUTAS 60 60.000 | KWANZA NORTE | 66.04 | 20.62 | 94.69 | 29.57 | 111.38 | 34.78 | 141.40 | 44.15 |
| 14044 | M TERESA 60 60.000 | KWANZA NORTE | 23.98 | 7.49 | 32.96 | 10.29 | 41.44 | 12.94 | 47.67 | 14.89 |
| 14070 | LUCALA 60 60.000 | KWANZA NORTE | 0.00 | 0.00 | 0.00 | 0.00 | 73.39 | 22.92 | 83.02 | 25.92 |
| 15017 | MALANJE 110 110.000 | MALANGE | 95.43 | 29.80 | 140.14 | 43.76 | 189.35 | 59.12 | 237.14 | 74.05 |
| 15020 | CAP ELEV 110 110.000 | MALANGE | 51.38 | 16.04 | 67.90 | 21.20 | 89.60 | 27.98 | 104.00 | 32.47 |
| 15021 | K NZOJI 110 110.000 | MALANGE | 0.00 | 0.00 | 0.00 | 0.00 | 0.97 | 0.30 | 2.20 | 0.69 |
| 15022 | CANGNDAL 110 110.000 | MALANGE | 4.99 | 1.56 | 8.15 | 2.54 | 10.55 | 3.30 | 15.68 | 4.89 |

| Bus Number | Bus Name | Zone Name | 2025 | | 2030 | | 2035 | | 2040 | |
|------------|--------------------|-------------|------------|--------------|------------|--------------|------------|--------------|------------|--------------|
| | | | Pload (MW) | Qload (Mvar) | Pload (MW) | Qload (Mvar) | Pload (MW) | Qload (Mvar) | Pload (MW) | Qload (Mvar) |
| 20027 | KILEVA 60 60.000 | BENGUELA | 106.25 | 33.18 | 144.68 | 45.18 | 151.28 | 47.24 | 147.09 | 45.93 |
| 20053 | CATUMB 1 60 60.000 | BENGUELA | 74.22 | 23.17 | 94.28 | 29.44 | 121.48 | 37.93 | 121.76 | 38.02 |
| 20066 | B.SUL 60 60.000 | BENGUELA | 169.94 | 53.06 | 183.63 | 57.34 | 196.91 | 61.49 | 222.54 | 69.49 |
| 20072 | CUBAL 60 60.000 | BENGUELA | 52.54 | 16.40 | 53.11 | 16.58 | 78.86 | 24.63 | 119.84 | 37.42 |
| 20075 | BOCOIO 60 60.000 | BENGUELA | 12.56 | 3.92 | 17.91 | 5.59 | 69.69 | 21.76 | 116.93 | 36.51 |
| 20077 | B.FARTA 60 60.000 | BENGUELA | 0.00 | 0.00 | 46.91 | 14.65 | 64.93 | 20.27 | 69.46 | 21.69 |
| 20079 | A.CATUMB 60 60.000 | BENGUELA | 0.00 | 0.00 | 22.13 | 6.91 | 50.72 | 15.84 | 84.36 | 26.34 |
| 21014 | DANGO 60 60.000 | HUAMBO | 150.72 | 47.06 | 224.73 | 70.17 | 313.48 | 97.88 | 394.64 | 123.23 |
| 21025 | UKUMA 60 60.000 | HUAMBO | 11.56 | 3.61 | 17.27 | 5.39 | 23.71 | 7.40 | 44.54 | 13.91 |
| 21031 | CATCH 60 60.000 | HUAMBO | 43.02 | 13.43 | 40.38 | 12.61 | 59.25 | 18.50 | 86.08 | 26.88 |
| 21036 | BAILUNDO 60 60.000 | HUAMBO | 0.00 | 0.00 | 36.04 | 11.25 | 57.70 | 18.02 | 88.27 | 27.56 |
| 22001 | KUITO 60 60.000 | BIE | 69.77 | 21.79 | 103.59 | 32.35 | 174.09 | 54.36 | 254.15 | 79.36 |
| 22009 | ANDULO 60 60.000 | BIE | 12.33 | 3.85 | 27.19 | 8.49 | 28.24 | 8.82 | 50.33 | 15.72 |
| 22021 | CHITEMBO 30 30.000 | BIE | 0.00 | 0.00 | 0.00 | 0.00 | 5.50 | 1.72 | 18.87 | 5.89 |
| 23002 | GABELA 60 60.000 | KWANZA SUL | 60.93 | 19.02 | 88.76 | 27.71 | 107.68 | 33.62 | 138.80 | 43.34 |
| 23005 | A.CH.RNT 60 60.000 | KWANZA SUL | 35.59 | 11.11 | 63.56 | 19.85 | 70.93 | 22.15 | 97.85 | 30.55 |
| 23011 | W.KUNGO 60 60.000 | KWANZA SUL | 10.77 | 3.36 | 17.19 | 5.37 | 22.27 | 6.95 | 43.43 | 13.56 |
| 23013 | CUACRA 60 60.000 | KWANZA SUL | 14.68 | 4.58 | 23.59 | 7.37 | 28.14 | 8.79 | 29.38 | 9.17 |
| 23018 | P.AMBOIM 60 60.000 | KWANZA SUL | 38.46 | 12.01 | 47.89 | 14.95 | 95.75 | 29.90 | 97.45 | 30.43 |
| 23021 | QUIBALA 60 60.000 | KWANZA SUL | 13.47 | 4.21 | 21.85 | 6.82 | 34.97 | 10.92 | 66.86 | 20.88 |
| 23022 | MUSSENDE 110110.00 | KWANZA SUL | 0.00 | 0.00 | 0.00 | 0.00 | 9.57 | 2.99 | 20.54 | 6.41 |
| 30013 | NAMIBE 60 2 60.000 | NAMIBE | 93.69 | 29.26 | 125.99 | 39.34 | 174.16 | 54.38 | 212.68 | 66.41 |
| 30017 | TOMBWA 60 60.000 | NAMIBE | 35.01 | 10.93 | 43.01 | 13.43 | 38.12 | 11.90 | 45.89 | 14.33 |
| 31018 | LUBANG 3 60 60.000 | HUILA | 67.50 | 21.08 | 92.73 | 28.96 | 142.21 | 44.40 | 198.53 | 61.99 |
| 31030 | MATALA 60 60.000 | HUILA | 18.38 | 5.74 | 25.83 | 8.06 | 43.68 | 13.64 | 64.22 | 20.05 |
| 31044 | TCHAMUTE 60 60.000 | HUILA | 41.02 | 12.81 | 46.43 | 14.50 | 56.33 | 17.59 | 61.63 | 19.24 |
| 31056 | KALUKEMB 60 60.000 | HUILA | 13.34 | 4.17 | 25.43 | 7.94 | 35.78 | 11.17 | 58.70 | 18.33 |
| 31061 | QUILENGS 60 60.000 | HUILA | 11.12 | 3.47 | 22.70 | 7.09 | 32.69 | 10.21 | 54.20 | 16.92 |
| 31303 | NOVO LUB 60 60.000 | HUILA | 30.14 | 9.41 | 41.78 | 13.05 | 65.40 | 20.42 | 87.16 | 27.21 |
| 31503 | CAPLONGO 60 60.000 | HUILA | 19.80 | 6.18 | 25.35 | 7.91 | 31.41 | 9.81 | 36.35 | 11.35 |
| 31512 | CHIPINDO 60 60.000 | HUILA | 0.00 | 0.00 | 30.38 | 9.49 | 35.96 | 11.23 | 40.80 | 12.74 |
| 32001 | CUCHI 30 30.000 | K.KUBANGO | 17.05 | 5.32 | 23.43 | 7.32 | 23.98 | 7.49 | 24.12 | 7.53 |
| 32004 | MENONGUE 60 60.000 | K.KUBANGO | 69.25 | 21.62 | 117.89 | 36.81 | 172.45 | 53.85 | 214.51 | 66.98 |
| 32016 | C.CUANVL 30 30.000 | K.KUBANGO | 0.00 | 0.00 | 0.00 | 0.00 | 7.72 | 2.41 | 22.31 | 6.97 |
| 32018 | MAVINGA 30 30.000 | K.KUBANGO | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 14.34 | 4.48 |
| 33002 | CAHAMA 30 30.000 | CUNENE | 3.18 | 0.99 | 8.93 | 2.79 | 9.31 | 2.91 | 12.81 | 3.97 |
| 33004 | XANGONGO 60 60.000 | CUNENE | 9.73 | 3.04 | 15.94 | 4.98 | 28.26 | 8.82 | 51.06 | 12.04 |
| 33006 | ONDJIVA 60 60.000 | CUNENE | 69.79 | 21.79 | 112.12 | 35.01 | 162.69 | 50.80 | 209.45 | 69.34 |
| 40011 | DUNDO 60 60.000 | LUNDA NORTE | 38.61 | 12.06 | 56.51 | 17.65 | 95.90 | 29.94 | 123.95 | 38.70 |
| 40021 | LUCAPA 60 60.000 | LUNDA NORTE | 24.83 | 7.75 | 33.82 | 10.56 | 38.96 | 12.17 | 50.43 | 15.75 |
| 40031 | X7 MUTBA 110110.00 | LUNDA NORTE | 33.05 | 10.32 | 53.91 | 16.83 | 63.63 | 19.87 | 85.51 | 26.70 |
| 41021 | SAURIMO 60 60.000 | LUNDA SUL | 77.40 | 24.17 | 89.14 | 27.84 | 130.45 | 40.73 | 171.55 | 53.57 |
| 41041 | MUCONDA 30 30.000 | LUNDA SUL | 0.00 | 0.00 | 3.24 | 1.01 | 4.04 | 1.26 | 9.06 | 2.83 |
| 42000 | LUENA 110 110.00 | MOXICO | 75.20 | 23.48 | 77.93 | 24.33 | 122.12 | 38.13 | 172.14 | 53.75 |
| 42031 | LUAU 110 110.00 | MOXICO | 0.00 | 0.00 | 16.28 | 5.08 | 17.91 | 5.59 | 26.60 | 8.31 |
| 42041 | CAZOMBO 30 30.000 | MOXICO | 0.00 | 0.00 | 15.18 | 4.74 | 17.45 | 5.45 | 25.27 | 7.89 |
| Total | | | 5059.60 | 1579.86 | 6954.31 | 2171.48 | 8957.75 | 2797.06 | 10956.37 | 3421.13 |

(Source: JICA Survey Team)

7.7.8 The transmission development plan for 2040

We determined the power system model for 2040 based on the 2040 PSSE data offered from RNT. We then applied the model to the power plan and demand assumptions of the JICA Survey Team. At the same time, we conducted power flow calculations and considered the power system plan up to 2040.

In planning the power transmission, we basically prepared double circuit for the routes for the 440 kV and 220 kV transmission lines, the main components of the power system, to meet the N-1 reliability criteria. Note that a different voltage loop system, such as 400 kV and 220V, is operating in the main power system of Angola. If, under such circumstances, an N - 1 contingency occurs on a 400 kV transmission line, an unexpected event could lead to an overload on the 220 kV transmission line. We attempt to avoid such a complex situation by composing a loop system only for the 400 kV system, that with the highest voltage. The 200 kV system, meanwhile, is to be a radial interconnected system.

Currently, many small diesel generators are installed in Luanda and other cities. However, considering the power generation efficiency etc., it is uneconomical, so we will gradually abolish it.

Currently, electric power is supplied to the center of Luanda mainly from the 400/220 kV substations (Viana, Kapary, Catete) using 220 kV T/L. In addition, this system is a loop system of 400/220 kV, with many small DGs connected in the loop.

In 2040, the demand for this area will be more than 4,000MW, which is about four times the current level demand, so it is planned to establish 400/220 kV substation (Bita, Sambizanga) and others several 220/60 kV substations.

In the future, we propose to abolish the DG in order, and introduce CCGT into the 220 kV power system and make the system configuration simple by making it a radial system.




Figure 7-35 Main power system of the center of Luanda in 2017 (400 kV, 220 kV)

According to the plan of RNT, Golfe substation (the new 220/60 kV substation) is planned to be connected to the 400/220 kV Viana substation. In this plan, the load will be concentrated on the Viana substation.




Figure 7-36 Main power system of the center of Luanda in 2040 (RNT's draft)

The connection between the Golfe substation to the Sambizanga substation results in a balanced system structure as shown in the figure below.

The distance between the Golfe substation and the Sambizanga substation is about 5 km, but because it is a densely populated residential area, it is considered difficult to construct an overhead power transmission line.

However, according to the RNT, in the future there is also a land readjustment plan in this area, in which case, there is a possibility that it is possible to construction of overhead transmission lines. Moreover, construction is possible if it is an underground transmission line.

Therefore, JICA survey team adopted this plan as a master plan.




Figure 7-37 Main power system of the center of Luanda in 2040 (JICA's draft)

Even in 2040, in the state of two lines, there is no problem in both voltage and load flow, but if it becomes one line, the voltage sensitivity of the bus becomes extremely high as shown in the following table, and It may be very difficult to operate this network.

Therefore, the three-line configuration is a measure for securing the situation of two lines even in the situation of N-1 (one line stop).

Table 7-21 Sensitivity of 400kV Saurimo Bus

| SC | Capacity (MVA) | Bus Voltage (kV) | sensitivity (kV/MVA) |
|----|----------------|------------------|----------------------|
| 75 | | 409.1 | |
| 74 | | 407.1 | 1.8 |
| 73 | | 404.3 | 2.9 |
| 72 | | 400.1 | 4.2 |
| 71 | | Unconvergence | |

The following figure shows the situation when the Capanda = Xa - Mutenba T/L and the Mutenba = Saurimo T/L each become one line in the case where the SVC is installed at the 400 kV bus of the Saurimo substation.




Figure 7-38 Eastern bulk power system calculation result in 2040 (Capanda=Xa-Mutenba T/L : N-1)





Figure 7-39 Eastern bulk power system calculation result in 2040 (Mutenba = Saurimo T/L : N-1)

The following table shows the cost comparison of Statcom type SVC installation and one line enhancement of a 400 kV transmission line (making this Capanda = Xa - Mutenba = Saurimo T/L 3 circuit lines).

Just to be sure, even if two units of SVC are installed as troubleshooting measures, since the cost of installing SVC is significantly lower, JICA survey team proposes a SVC installation plan.

Table 7-22 Cost Comparison

| Item | Voltage (kV) | Rating | Unit Cost (MUSD) |
|--|--------------|---------------------|------------------|
| Statcom SVC Including bay with transformer & switchgear | 400 | ±150MVA | 33 |
| Stactom SVC × 2 | 400 | ±150MVA × 2units | 66 |
| Capanda =Xa-Xutenba =Sautemo T/L | 400 | 700km × 1cct | 546 |



7.7.9 The evaluation for the power system analysis

PSSE verified that there is no overload with transmission lines and transformers under the n-1 contingency. All of the transmission lines above have capacities of 400 kV, 220 kV and over, and all of the primary transformers have capacities of 220 kV and over (such as 400 kV/220 kV, and 220 kV/60 kV). As mentioned above, the 400 kV system is a loop system, while the 200 kV system is arranged as a radial interconnected system to avoid the operation of a very complicated system consisting of different voltage loop systems of 400 kV and 220 kV. This arrangement makes it possible for the system operator to understand the operating condition of the main system of 400 kV and 220 kV facilities even when the system outages of a system differ from ordinary system outages due to transmission line maintenance, etc.

7.7.10 Validity of distributed installation of CCGT

In that case where CCGT is intensively installed at Soyo, the additional construction of 400 kV transmission lines (approximately 330km) is required between Soyo S/S and KAPARY S/S.

The draft adopted by the JICA Survey Team at this time calls for concentrated CCGT installation not only in Soyo, but also dispersed CCGT installation in LOBITO and NABIBE for securing energy security and avoiding long distances between the transmission lines in place.

The draft values for distributed installations and concentrated installations are shown in Table 7-23. To compare them, there shall be no difference among substation's demand in this condition. The output of the power plants (Soyo, LOBITO, NABIBE and other power plants), shown in Table 7-23, is basically the same.

Table 7-23 Transmission losses of each CCGT installed site in 2040

| | CCGT Soyo, Lobito, Nabibe Distributed installation (Plan of JICA Survey Team) | | | CCGT Soyo Concentrated installation | | |
|--------|---|----------------|---------------------------|---|----------------|---------------------------|
| | CCGT Generation Soyo:600 MW Lobito:1800 MW Nabibe:720 MW | | | CCGT Generation Soyo:3120 MW Lobito:0 MW Nabibe:0 MW | | |
| Region | Generation (MW) | Demand (MW) | Transmission loss (MW) | Generation (MW) | Demand (MW) | Transmission loss (MW) |
| NORTE | 7075.7 | 6569.9 | 159.8 | 9100.5 | 6569.9 | 163.8 |
| CENTRO | 3024.0 | 2313.2 | 58.0 | 1224.0 | 2313.2 | 67.6 |
| SUL | 1438.0 | 1408.8 | 67.1 | 1198.0 | 1408.8 | 38.2 |
| LESTE | 138.0 | 664.5 | 27.8 | 138.0 | 664.5 | 27.8 |
| SAPP | 0.0 | 400.0 | 6.6 | 0.0 | 400.0 | 6.6 |
| TOTAL | 11675.7 | 11356.4 | 319.3 | 11660.5 | 11356.4 | 304.0 |

(Source: JICA Survey Team)

As the comparison of transmission loss in Table 7-23 shows, the draft values for distributed installation and concentrated installation are 319.3 MW and 304.0 MW, respectively. Thus, the transmission loss from the distributed installation is 15.3 MW higher than that from the concentrated one, and totals the equivalent of about 105% of the transmission loss of the concentrated installation draft value. There is no obvious difference between two plans. This comparison is considered one index showing the adequacy of the distributed power plant installation plan in the power system if the viewpoint of avoiding enhancement of long-distance transmission lines and securing energy security are considered.

7.7.11 Consideration for measures to reduce power transmission loss

Figure 7-36 shows the main power system plan for 2040 formulated using data provided PSSE.




Figure 7-41 RNT's power system plan in 2040 (400 kV, 220 kV)
(Source: JICA Survey Team)

Table 7-22 shows the results of a comparison of the transmission loss between the drafts of the JICA Survey Team and RNT. There is no difference in the substation demand condition between the two plans in the comparison. The power plant outputs (Soyo power plant included) are basically the same.

Table 7-24 Transmission losses in 2040

| Region | JICA Survey Team's plan | | | RNT's plan | | |
|--------|-------------------------|-------------|------------------------|-----------------|-------------|------------------------|
| | Generation (MW) | Demand (MW) | Transmission loss (MW) | Generation (MW) | Demand (MW) | Transmission loss (MW) |
| NORTE | 7437.0 | 6569.9 | 174.0 | 7524.2 | 6569.9 | 213.6 |
| CENTRO | 2664.0 | 2313.2 | 49.8 | 2664.0 | 2313.2 | 88.9 |
| SUL | 1438.0 | 1408.8 | 62.4 | 1438.0 | 1408.8 | 70.8 |
| LESTE | 138.0 | 664.5 | 27.8 | 138.0 | 664.5 | 27.8 |
| SAPP | 0.0 | 400.0 | 6.6 | 0.0 | 400.0 | 6.6 |
| TOTAL | 11677.0 | 11356.4 | 320.7 | 11764.2 | 11356.4 | 407.8 |

(Source: JICA Survey Team)

According to the transmission loss comparison shown in Table 7-24, the values for the RNT and JICA Survey Team drafts are 407.8 MW and 320.7 MW, respectively. Hence, the transmission loss of the JICA Survey Team's draft is 87.1MW less than the RNT's (or approximately 80% of the loss in the RNT draft). This result is one indicator showing the validity of the JICA study team draft.

7.7.12 Annual plan for transmission development system

The following shows the transmission development plans (2025, 2030, and 2035) in the main power system formulated based on the generator plan in Table 7-17 and substation plan in Table 7-20. Basically, the 400 kV transmission line system will have a loop configuration and the 220 kV system will be radial.

PSSE verified that there is no overload with transmission lines or transformers under the n-1 contingency. All of the above transmission lines have capacities of 400 kV, 220 kV and over, and all of the primary transformers have capacities of 220 kV and over (such as 400 kV/220 kV, and 220 kV/60 kV).




Figure 7-42 Main power system in 2025 (400 kV, 220 kV)
(Source: JICA Survey Team)




Figure 7-43 Main power system in 2030 (400 kV, 220 kV)
(Source: JICA Survey Team)





Figure 7-44 Main power system in 2035 (400 kV, 220 kV)
(Source: JICA Survey Team)



7.7.13 Required volume of reactive power compensators

The required volume of reactive power compensators of bulk power system, in each voltage class for every five years are shown below.

Table 7-25 Required Volume of Reactive Power Compensators in each Substation

| Bus No. | Substation MANE | Bus Voltage to be controlled (kV) | Shunt Reactor (MVA) | | | | Shunt Capacitor (MVA) | | | |
|---------|-----------------|-----------------------------------|----------------------|------|------|------|-----------------------|------|------|------|
| | | | 2025 | 2030 | 2035 | 2040 | 2025 | 2030 | 2035 | 2040 |
| 12118 | VIANA | 400 | 0 | 0 | 0 | 0 | 250 | 400 | 450 | 450 |
| 12125 | SAMBZANG_400 | 400 | 0 | 0 | 0 | 0 | 50 | 400 | 450 | 450 |
| 12141 | BITA_400 | 400 | 0 | 0 | 0 | 0 | 50 | 100 | 200 | 250 |
| 13004 | KAPARY_400 | 400 | 0 | 0 | 0 | 0 | 300 | 300 | 450 | 450 |
| 20100 | N.BIOPIO_400 | 400 | 50 | 50 | 50 | 50 | 0 | 0 | 0 | 0 |
| 23016 | W.KUNGO_400 | 400 | 350 | 350 | 350 | 350 | 0 | 0 | 0 | 0 |
| 31024 | LUBANGO_400 | 400 | 300 | 300 | 300 | 300 | 0 | 0 | 0 | 0 |
| 31501 | CAPLONGO_400 | 400 | 200 | 200 | 200 | 200 | 0 | 0 | 0 | 0 |
| 31510 | KALUKEMB_400 | 400 | 250 | 250 | 250 | 250 | 0 | 0 | 0 | 0 |
| 33000 | CAHAMA_400 | 400 | 150 | 150 | 200 | 200 | 0 | 0 | 0 | 0 |
| 33020 | ONDJIVA_400 | 400 | – | – | 150 | 150 | – | – | 0 | 0 |
| 40030 | XA.MUTBA_400 | 400 | 350 | 350 | 350 | 350 | 0 | 0 | 0 | 0 |
| 41019 | SAURIMO_400 | 400 | 150 | 150 | 150 | 150 | 0 | 0 | 0 | 0 |
| 10010 | M.CONGO_220 | 220 | 20 | 20 | 20 | 20 | 0 | 0 | 40 | 40 |
| 11000 | UIGE_220 | 220 | 0 | 0 | 0 | 0 | 40 | 100 | 180 | 180 |
| 11007 | M.ZOMBO_220 | 220 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 40 |
| 11017 | S.POMBO_220 | 220 | 0 | 0 | 0 | 0 | 0 | 0 | 40 | 100 |
| 11020 | DAMBA_220 | 220 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 12002 | CAMAMA_220 | 220 | 0 | 0 | 0 | 0 | 100 | 100 | 250 | 250 |
| 12005 | CAZENGA_220 | 220 | 0 | 0 | 0 | 0 | 60 | 140 | 140 | 180 |
| 12132 | M.BENTO_220 | 220 | 0 | 0 | 0 | 0 | 120 | 200 | 200 | 200 |
| 20065 | B.SUL_220 | 220 | 0 | 0 | 0 | 0 | 100 | 100 | 100 | 100 |
| 22000 | KUITO_220 | 220 | 100 | 100 | 100 | 100 | 0 | 0 | 40 | 180 |
| 32003 | MENONGUE_220 | 220 | 100 | 100 | 100 | 100 | 0 | 0 | 20 | 100 |
| 42040 | CAZOMBO_220 | 220 | 50 | 50 | 50 | 50 | 0 | 0 | 0 | 0 |
| | Total | | 2090 | 2090 | 2290 | 2290 | 1090 | 1860 | 2580 | 2970 |
| | SVC | 400 | ±150(MVA) at SAURIMO | | | | | | | |

7.7.14 Fault Current

The three-phase short circuit fault currents of the 400kV and 220kV buses of the Angola electric power system are shown below.

Calculations are carried out under the following conditions.

- ☐ Automatic sequencing fault calculation function of PSSE is used.
- ☐ All generators installed in the system in each year are being operated.
- ☐ In order to obtain a severe calculation result, a virtual power source of 40 kA was connected to Namibia's international interconnection line..

In each year, the three phase short circuit fault current is within the specified 40kA or less.

Table 7-26 Three-Phase Short Circuit Fault Currents

| Bus | Bus Name | Voltage | Fault Current (kA) | | | | Bus Number | Bus Name | Voltage (kV) | Fault Current (kA) | | | |
|-------|---------------|---------|--------------------|------|------|------|------------|--------------|--------------|--------------------|------|------|------|
| | | | 2025 | 2030 | 2035 | 2040 | | | | 2025 | 2030 | 2035 | 2040 |
| 10005 | SOYO 400 | 400 | 10.1 | 10.6 | 11.2 | 11.6 | 20071 | CUBAL 220 | 220 | 2.8 | 3.8 | 4.3 | 4.3 |
| 10006 | SOYO 400 2 | 400 | 10.0 | 10.5 | 11.1 | 11.5 | 20073 | CATUMB 220 | 220 | 3.4 | 6.2 | 8.7 | 8.8 |
| 10007 | NZETO 400 | 400 | 8.9 | 9.1 | 9.6 | 9.7 | 20074 | BOCOIO 220 | 220 | 3.2 | 4.7 | 5.6 | 5.7 |
| 10008 | NZETO 220 | 220 | 9.1 | 9.2 | 9.4 | 9.3 | 20076 | B.FARTA 220 | 220 | - | 4.1 | 5.0 | 5.1 |
| 10010 | M CONGO 220 | 220 | 2.4 | 2.4 | 2.4 | 2.4 | 20078 | A.CATUMB 220 | 220 | - | 2.9 | 3.2 | 3.3 |
| 10030 | TOMBOCO 220 | 220 | 3.6 | 3.6 | 3.6 | 3.6 | 20100 | N BIOPIO 400 | 400 | 7.1 | 8.6 | 13.7 | 15.3 |
| 11000 | UIGE 220 | 220 | 2.0 | 2.0 | 2.3 | 2.4 | 20110 | LOBITO PS | 400 | 6.8 | 8.1 | 13.3 | 15.1 |
| 11007 | M ZOMBO 220 | 220 | 1.2 | 1.2 | 1.3 | 1.4 | 21003 | GOVE 4 220 | 220 | 2.4 | 2.4 | 2.6 | 2.5 |
| 11012 | NEGAGE 220 | 220 | 2.1 | 2.2 | 2.5 | 2.6 | 21013 | DANGO 1 220 | 220 | 4.3 | 4.6 | 5.6 | 5.7 |
| 11017 | S POMBO 220 | 220 | - | - | 1.7 | 1.8 | 21021 | DANGO 400 | 400 | 5.9 | 6.5 | 7.7 | 8.0 |
| 11020 | DAMBA 220 | 220 | - | - | 1.7 | 1.7 | 21024 | UKUMA 220 | 220 | 3.0 | 3.1 | 3.4 | 3.5 |
| 12000 | CACUACO 220 | 220 | 10.7 | 13.0 | 15.4 | 16.4 | 21030 | CATCH 220 | 220 | 2.9 | 3.2 | 3.5 | 3.7 |
| 12002 | CAMAMA 220 | 220 | 10.4 | 10.6 | 11.9 | 11.9 | 21035 | BAILUNDO 220 | 220 | - | 2.2 | 2.3 | 2.3 |
| 12005 | CAZENGA 220 | 220 | 11.3 | 11.6 | 13.7 | 13.8 | 22000 | KUITO 220 | 220 | 2.4 | 2.7 | 2.8 | 2.9 |
| 12007 | FILDA 220 | 220 | 13.0 | 13.5 | 13.7 | 13.8 | 22008 | ANDULO 220 | 220 | 1.6 | 1.8 | 1.8 | 1.8 |
| 12009 | VIANA 220 | 220 | 18.1 | 19.0 | 19.4 | 19.7 | 22020 | CHITEMBO 220 | 220 | - | 1.6 | 1.7 | 1.6 |
| 12100 | CACUACO GT | 220 | 10.3 | 12.5 | 15.0 | 16.0 | 23001 | GABELA 220 | 220 | 10.1 | 10.4 | 11.3 | 11.4 |
| 12118 | VIANA 400 | 400 | 13.8 | 14.5 | 15.3 | 15.6 | 23004 | A.CH.RNT 220 | 220 | 5.0 | 5.1 | 5.3 | 5.3 |
| 12125 | SAMBZANG 400 | 400 | 10.1 | 10.4 | 11.6 | 12.3 | 23010 | W.KUNGO 220 | 220 | 8.8 | 9.0 | 9.4 | 9.4 |
| 12126 | SAMBZANGA 220 | 220 | 13.1 | 13.4 | 16.4 | 17.1 | 23012 | CUACRA 220 | 220 | 4.1 | 4.2 | 4.4 | 4.4 |
| 12128 | SAMBZANGA GT | 220 | 12.3 | 12.6 | 15.3 | 16.1 | 23016 | W.KUNGO 400 | 400 | 7.9 | 8.2 | 8.9 | 9.1 |
| 12132 | M BENTO 220 | 220 | 7.9 | 8.0 | 8.7 | 8.8 | 23017 | P AMBOIM 220 | 220 | 3.3 | 3.4 | 3.5 | 3.5 |
| 12136 | CATETE 400 | 400 | 17.7 | 18.6 | 20.4 | 20.9 | 23019 | GABELA 400 | 400 | 9.7 | 10.4 | 13.1 | 13.3 |
| 12137 | CATETE 220 | 220 | 13.0 | 13.0 | 13.4 | 13.9 | 23020 | QUIBALA 220 | 220 | 3.6 | 3.7 | 3.8 | 3.8 |
| 12139 | RAMIROS 220 | 220 | 7.1 | 7.2 | 7.8 | 7.8 | 23023 | BENGA 400 | 400 | - | - | 12.6 | 13.0 |
| 12141 | BITA 400 | 400 | 12.1 | 12.4 | 13.2 | 13.3 | 23024 | GENGA 400 | 400 | 7.5 | 8.0 | 10.6 | 10.8 |
| 12142 | BITA 220 | 220 | 13.0 | 13.2 | 15.3 | 15.4 | 30012 | NAMIBE 220 | 220 | 2.8 | 3.1 | 3.4 | 9.7 |
| 12145 | PIV 220 | 220 | - | - | 16.8 | 17.0 | 30016 | TOMBWA 220 | 220 | 1.9 | 2.0 | 2.1 | 3.7 |
| 12267 | ZANGO 220 | 220 | 7.0 | 7.1 | 7.2 | 7.3 | 30112 | NABIBE CCGT | 220 | - | - | - | 10.0 |
| 12300 | CHICALA 220 | 220 | 11.9 | 12.1 | 14.5 | 15.0 | 31015 | MATALA 4 220 | 220 | 1.8 | 1.9 | 3.6 | 3.7 |
| 12305 | GOLF | 220 | 12.0 | 12.1 | 14.5 | 15.1 | 31024 | LUBANGO 400 | 400 | 5.5 | 7.6 | 9.1 | 10.4 |
| 13004 | KAPARY 400 | 400 | 14.0 | 14.6 | 16.3 | 17.3 | 31027 | LUBANGO 220 | 220 | 5.5 | 6.6 | 8.2 | 8.6 |
| 13005 | KAPARY 220 | 220 | 13.3 | 16.6 | 18.8 | 19.4 | 31029 | MATALA 220 | 220 | 1.9 | 2.0 | 3.9 | 4.0 |
| 13007 | DANDE 220 | 220 | 10.3 | 12.2 | 13.3 | 13.6 | 31031 | J MINA 220 | 220 | 1.4 | 1.5 | 3.9 | 4.0 |
| 13030 | CAXITO 220 | 220 | 9.1 | 10.6 | 11.4 | 11.5 | 31036 | J.OMA 220 | 220 | - | 0.9 | 2.3 | 2.3 |
| 14005 | CAMBAMBE 220 | 220 | 24.3 | 24.7 | 26.1 | 26.1 | 31043 | TCHAMUTE 220 | 220 | 1.9 | 1.8 | 2.0 | 2.0 |
| 14007 | LUCALA 220 | 220 | 4.0 | 3.9 | 5.4 | 5.5 | 31060 | QUILENGS 400 | 400 | 5.9 | 7.3 | 9.5 | 10.4 |
| 14008 | LUCALA 400 | 400 | 13.0 | 13.2 | 13.6 | 13.7 | 31300 | NOVO LUB 220 | 220 | 7.0 | 8.7 | 10.6 | 13.3 |
| 14009 | NDALAT 220 | 220 | 6.1 | 6.2 | 6.2 | 6.2 | 31501 | CAPLONGO 400 | 400 | 3.2 | 3.3 | 4.9 | 5.0 |
| 14011 | P.SONHE 220 | 220 | 2.9 | 2.9 | 3.5 | 3.6 | 31502 | CAPLONGO 220 | 220 | 2.8 | 2.6 | 3.1 | 3.0 |
| 14016 | CAMBUTAS 220 | 220 | 27.1 | 27.6 | 29.5 | 29.5 | 31510 | KALUKEMB 400 | 400 | 5.2 | 6.2 | 7.0 | 7.4 |
| 14017 | CAMBUTAS 400 | 400 | 21.5 | 22.2 | 26.2 | 26.6 | 31511 | CHIPINDO 400 | 400 | - | 4.3 | 5.6 | 5.8 |
| 14025 | CBB 2 1 | 220 | 18.4 | 18.6 | 19.4 | 19.3 | 32000 | CUCHI 220 | 220 | 1.8 | 1.8 | 2.1 | 2.1 |
| 14026 | CBB 2 2 | 220 | 18.4 | 18.6 | 19.4 | 19.3 | 32003 | MENONGUE 220 | 220 | 1.4 | 1.4 | 1.6 | 1.6 |
| 14027 | CBB 2 3 | 220 | 18.4 | 18.6 | 19.4 | 19.3 | 32015 | C CUANVL 220 | 220 | - | - | 1.0 | 0.9 |
| 14028 | CBB 2 4 | 220 | 18.4 | 18.6 | 19.4 | 19.3 | 32017 | MAVINGA 220 | 220 | - | - | 0.8 | 0.7 |
| 14043 | M TERESA 220 | 220 | 5.5 | 5.5 | 5.5 | 5.6 | 33000 | CAHAMA 400 | 400 | 3.6 | 6.7 | 8.0 | 8.4 |
| 14051 | LAUCA 400 | 400 | 28.6 | 28.5 | 31.5 | 31.7 | 33001 | CAHAMA 220 | 220 | 2.6 | 3.2 | 3.4 | 3.5 |
| 14053 | LAUCA EC 220 | 220 | 3.9 | 3.9 | 3.9 | 3.9 | 33003 | XANGONGO 220 | 220 | 1.8 | 2.1 | 2.2 | 2.2 |
| 14054 | C CABAÇA 400 | 400 | 28.1 | 27.2 | 31.0 | 31.2 | 33005 | ONDJIVA 220 | 220 | 1.1 | 1.2 | 3.0 | 3.0 |
| 14071 | ZENZO | 400 | - | - | 16.5 | 16.5 | 33007 | BAYNES 400 | 400 | 2.4 | 3.1 | 4.5 | 4.6 |
| 14074 | CE GASTÃO | 220 | 3.0 | 3.0 | 3.8 | 3.9 | 33020 | ONDJIVA 400 | 400 | - | - | 5.1 | 5.2 |
| 15004 | CAPANDA 220 | 220 | 18.0 | 18.1 | 18.1 | 18.0 | 40010 | DUNDO 220 | 220 | 1.5 | 1.5 | 1.5 | 1.5 |
| 15006 | CAP ELEV 220 | 220 | 18.5 | 18.6 | 18.6 | 18.5 | 40020 | LUCAPA 220 | 220 | 1.8 | 1.8 | 1.8 | 1.8 |
| 15008 | CAP ELEV 400 | 400 | 19.0 | 19.0 | 20.1 | 20.2 | 40030 | XA MUTBA 400 | 400 | 3.8 | 3.9 | 3.9 | 3.9 |
| 15016 | MALANJE 220 | 220 | 5.1 | 5.1 | 4.8 | 4.9 | 41019 | SAURIMO 400 | 400 | 2.1 | 2.1 | 2.0 | 2.1 |
| 20025 | KILEV 4 220 | 220 | 3.7 | 6.9 | 10.3 | 10.3 | 41020 | SAURIMO 220 | 220 | 2.5 | 2.5 | 2.6 | 2.6 |
| 20034 | LMAUM 3 220 | 220 | 2.8 | 3.8 | 4.4 | 4.4 | 41040 | MUCONDA 220 | 220 | 1.4 | 1.4 | 1.4 | 1.4 |
| 20052 | N BIOP 1 220 | 220 | 4.0 | 6.9 | 9.7 | 9.8 | 42010 | LUENA 220 | 220 | 1.3 | 1.3 | 1.3 | 1.3 |
| 20065 | B.SUL 220 | 220 | 3.1 | 5.1 | 6.8 | 6.8 | 42030 | LUAU 220 | 220 | 1.1 | 1.2 | 1.1 | 1.1 |
| 20067 | KILEVA GT | 220 | 3.6 | 6.9 | 10.5 | 10.5 | 42040 | CAZOMBO 220 | 220 | 0.8 | 0.8 | 0.8 | 0.8 |

7.7.15 Summary of the power transmission system development plan up to 2040

The results up to the previous section are compiled into the following project list. The power supply line relation for the transmission lines is shown separately. Here, the standard capacity of the transformer at the 400 kV substation is set to 450 MVA, 930 MVA, and the standard capacity of the transformer at the 220 kV substation is set to 60 MVA, 120 MVA, 240 MVA, and in principle, the development will be carried out in line with this lineup.

Table 7-27 List of 400 kV Substation Projects

| Project# | Year of operation | Area | Voltage (kV) | Substation Name | Capacity (MVA) | Cost (MUS\$) | Remarks |
|----------|-------------------|-------------|--------------|-----------------|----------------|--------------|-------------------------------------|
| 1 | 2020 | Cuanza Sul | 400 | Waco kungo | 450 | 40.5 | 450 x 1, under construction(China) |
| 2 | 2020 | Huambo | 400 | Belem do Huambo | 900 | 51.3 | 450 x 2, under construction(China) |
| 3 | 2022 | Luanda | 400 | Bitá | 900 | 51.3 | 450 x 2, under construction(Brazil) |
| 4 | 2025 | Cuanza Sul | 400 | Waco kungo | 450 | 40.5 | upgrade 450 x 1 |
| 5 | 2025 | Luanda | 400 | Bitá | 450 | 40.5 | upgrade 450 x 1 |
| 6 | 2025 | Zaire | 400 | N'Zeto | 450 | 40.5 | upgrade 450 x 1 |
| 7 | 2025 | Luanda | 400 | Viana | 2,790 | 96.6 | upgrade 930 x 3 |
| 8 | 2025 | Bengo | 400 | Kapary | 450 | 40.5 | upgrade 450 x 1 |
| 9 | 2025 | Huila | 400 | Lubango2 | 900 | 51.3 | 450 x 2, Pre-FS implemented* |
| 10 | 2025 | Huila | 400 | Capelongo | 900 | 51.3 | 450 x 2 |
| 11 | 2025 | Huila | 400 | Calukembe | 120 | 32.6 | 60 x 2 |
| 12 | 2025 | Benguela | 400 | Nova Biopio | 900 | 51.3 | 450 x 2 |
| 13 | 2025 | Southern | 400 | Cahama | 900 | 51.3 | 450 x 2 |
| 14 | 2025 | Eastern | 400 | Saurimo | 900 | 51.3 | 450 x 2, under Pre-FS |
| 15 | 2025 | Lunda Norte | 400 | Xa-Muteba | 360 | 38.3 | 180 x 2, under Pre-FS |
| 16 | 2025 | Huila | 400 | Quilengues | 120 | 32.6 | 60 x 2 |
| 17 | 2025 | Cuanza Sul | 400 | Gabela | 900 | 51.3 | 450 x 2 |
| 18 | 2025 | Luanda | 400 | Sambizanga | 2,790 | 96.6 | 930 x 3 |
| 19 | 2025 | Malanje | 400 | Lucala | 900 | 51.3 | 450 x 2 |
| 20 | 2025 | Chipindo | 400 | Chipindo | 360 | 38.3 | 180 x 2 |
| 21 | 2030 | Bengo | 400 | Kapary | 450 | 40.5 | upgrade 450 x 1 |
| 22 | 2030 | Luanda | 400 | Cate te | 450 | 40.5 | upgrade 450 x 1 |
| 23 | 2035 | Cunene | 400 | Ondjiva | 900 | 51.3 | 450 x 2, Pre-FS implemented* |
| 24 | 2035 | Luanda | 400 | Bitá | 450 | 40.5 | upgrade 450 x 1 |
| 25 | 2035 | Malanje | 400 | Lucala | 450 | 40.5 | upgrade 450 x 1 |
| Total | | | | | 19,590 | 1,171.4 | |

Pre-FS implemented*:Candidate site were selected by USTDA and DBSA.

(Source: JICA Survey Team)

Table 7-28 List of 220 kV Substation Projects (1)

| Project# | Year of operation | Area | Voltage (kV) | Substation Name | Capacity (MVA) | Cost (MUSS) | Remarks |
|----------|-------------------|----------------|--------------|-------------------|----------------|-------------|-------------------------------------|
| 1 | 2018 | Benguela | 220 | Benguela Sul | 240 | 24.5 | 120 x 2, under construction(China) |
| 2 | 2020 | Luanda | 220 | Bitá | 240 | 24.5 | 120 x 2, under construction(Brazil) |
| 3 | 2020 | Zaire | 220 | Tomboco | 40 | 13.7 | 20 x 2 |
| 4 | 2020 | Malanje | 220 | Capanda Elevadora | 130 | 18.6 | 65 x 2, upgrade |
| 5 | 2021 | Luanda | 220 | Cacuaco | 480 | 37.5 | 240 x 2, upgrade |
| 6 | 2022 | Luanda | 220 | Zango | 360 | 31.0 | 120 x 3 |
| 7 | 2022 | Malanje | 220 | Malanje2 | 240 | 24.5 | 120 x 2 |
| 8 | 2022 | Cuanza Sul | 220 | Waco Kungo | 60 | 14.8 | 60 x 1 |
| 9 | 2022 | Cuanza Sul | 220 | Quibala | 120 | 18.1 | 60 x 2 |
| 10 | 2022 | Benguela | 220 | Cubal | 120 | 18.1 | 60 x 2 |
| 11 | 2022 | Huíla | 220 | Lubango | 240 | 24.5 | 120 x 2, Pre-FS implemented* |
| 12 | 2022 | Huíla | 220 | Matala | 120 | 18.1 | 60 x 2, Pre-FS implemented* |
| 13 | 2022 | Huíla | 220 | Capelongo | 60 | 14.8 | 60 x 1 |
| 14 | 2022 | Cuando-Cubango | 220 | Cuchi | 60 | 14.8 | 60 x 1 |
| 15 | 2022 | Cuando-Cubango | 220 | Menangue | 240 | 24.5 | 120 x 2 |
| 16 | 2022 | Namibe | 220 | Namibe | 240 | 24.5 | 120 x 2, Pre-FS implemented* |
| 17 | 2022 | Namibe | 220 | Tombwa | 120 | 18.1 | 60 x 2, Pre-FS implemented* |
| 18 | 2022 | Lunda Norte | 220 | Lucapa | 60 | 14.8 | 60 x 1 |
| 19 | 2022 | Lunda Norte | 220 | Dundo | 120 | 18.1 | 60 x 2, under Pre-FS |
| 20 | 2022 | Lunda Sur | 220 | Saurimo | 120 | 18.1 | 60 x 2, under Pre-FS |
| 21 | 2022 | Uíge | 220 | Uíge | 240 | 24.5 | 120 x 2, upgrade |
| 22 | 2025 | Luanda | 220 | Golfe | 360 | 31.0 | 120 x 3 |
| 23 | 2025 | Luanda | 220 | Chicara | 480 | 37.5 | 240 x 2 |
| 24 | 2025 | Bengo | 220 | Caxito | 60 | 14.8 | 60 x 1 |
| 25 | 2025 | Bengo | 220 | Maria Teresa | 60 | 14.8 | 60 x 1 |
| 26 | 2025 | Cuanza Sul | 220 | Porto Amboim | 120 | 18.1 | 60 x 2 |
| 27 | 2025 | Cuanza Sul | 220 | Cuacra | 60 | 14.8 | 60 x 1 |
| 28 | 2025 | Benguela | 220 | Catumbela | 120 | 18.1 | 60 x 2 |
| 29 | 2025 | Benguela | 220 | Bocoio | 120 | 18.1 | 60 x 2 |
| 30 | 2025 | Huambo | 220 | Ukuma | 60 | 14.8 | 60x 1, Pre-FS implemented* |
| 31 | 2025 | Huambo | 220 | Catchiungo | 120 | 18.1 | 60 x 2, Pre-FS implemented* |
| 32 | 2025 | Bié | 220 | Andulo | 60 | 14.8 | 60 x 1 |
| 33 | 2025 | Huíla | 220 | Nova Lubango | 120 | 18.1 | 60 x 2 |
| 34 | 2025 | Huíla | 220 | Caluquembe | 60 | 14.8 | 60 x 1 |
| 35 | 2025 | Huíla | 220 | Quilengues | 60 | 14.8 | 60 x 1 |
| 36 | 2025 | Huíla | 220 | Tchamutete | 120 | 18.1 | 60 x 2, Pre-FS implemented* |
| 37 | 2025 | Cunene | 220 | Ondjiva | 120 | 18.1 | 60 x 2, Pre-FS implemented* |
| 38 | 2025 | Cunene | 220 | Cahama | 60 | 14.8 | 60 x 1, Pre-FS implemented* |
| 39 | 2025 | Cunene | 220 | Xangongo | 60 | 14.8 | 60 x 1, Pre-FS implemented* |
| 40 | 2025 | Moxico | 220 | Luna | 240 | 24.5 | 120 x 2, under Pre-FS |
| 41 | 2025 | Lunda Norte | 220 | Xa-Muteba | 120 | 18.1 | 60 x 2 |
| 42 | 2025 | Luanda | 220 | Viana | 600 | 44.0 | 300 x 2, upgrade |
| 43 | 2025 | Luanda | 220 | Camama | 120 | 18.1 | 120 x 1, upgrade |
| 44 | 2025 | Luanda | 220 | Sambizanga | 240 | 24.5 | 240 x 1, upgrade |
| 45 | 2025 | Kuanza Norte | 220 | N' Dalatando | 80 | 15.9 | 40 x 2, upgrade |
| 46 | 2027 | Moxico | 220 | Cazombo | 60 | 14.8 | 60 x 1 |
| 47 | 2027 | Moxico | 220 | Luau | 60 | 14.8 | 60 x 1 |
| 48 | 2027 | Lunda Sur | 220 | Muconda | 60 | 14.8 | 60 x 1 |
| 49 | 2027 | Bié | 220 | Kuito | 120 | 18.1 | 120 x 1, upgrade |
| 50 | 2030 | Luanda | 220 | Futungo de Belas | 120 | 18.1 | 120 x 1, upgrade |

Pre-FS implemented*:Candidate site were selected by USTDA and DBSA.

(Source: JICA Survey Team)

Table 7-29 List of 220 kV Substation Projects (2)

| Project# | Year of operation | Area | Voltage (kV) | Substation Name | Capacity (MVA) | Cost (MUSS) | Remarks |
|----------|-------------------|----------------|--------------|------------------|----------------|-------------|------------------|
| 51 | 2030 | Uíge | 220 | Negage | 180 | 21.3 | 60 x 3 |
| 52 | 2030 | Cabinda | 220 | Cabinda | 240 | 24.5 | 120x 2 |
| 53 | 2030 | Cabinda | 220 | Cacongo | 120 | 18.1 | 60 x 2 |
| 54 | 2030 | Benguela | 220 | Alto Catumbela | 120 | 18.1 | 60 x 2 |
| 55 | 2030 | Benguela | 220 | Baria Farta | 120 | 18.1 | 60 x 2 |
| 56 | 2030 | Huambo | 220 | Bailundo | 120 | 18.1 | 60 x 2 |
| 57 | 2030 | Huíla | 220 | Chipindo | 60 | 14.8 | 60 x 1 |
| 58 | 2031 | Zaire | 220 | M'Banza Congo | 180 | 21.3 | 60 x 3, upgrade |
| 59 | 2032 | Cunene | 220 | Ondjiva | 120 | 18.1 | 120 x 1, upgrade |
| 60 | 2032 | Lunda Sur | 220 | Saurimo | 120 | 18.1 | 120 x 1, upgrade |
| 61 | 2034 | Luanda | 220 | Cacuaco | 240 | 24.5 | 240 x 1, upgrade |
| 62 | 2035 | Luanda | 220 | PIV | 480 | 37.5 | 240 x 2 |
| 63 | 2035 | Kuanza Norte | 220 | Lucala | 120 | 18.1 | 60 x 2 |
| 64 | 2035 | Uíge | 220 | Sanza Pombo | 120 | 18.1 | 60 x 2 |
| 65 | 2035 | Bié | 220 | Camacupa | 60 | 14.8 | 60 x 1 |
| 66 | 2035 | Cuando-Cubango | 220 | Cuito Cuanavale | 60 | 14.8 | 60 x 1 |
| 67 | 2035 | Luanda | 220 | Cazenga | 120 | 18.1 | 120 x 1, upgrade |
| 68 | 2035 | Bengo | 220 | Kapary | 120 | 18.1 | 120 x 1, upgrade |
| 69 | 2035 | Benguela | 220 | Catumbela | 240 | 24.5 | 120 x 2, upgrade |
| 70 | 2036 | Luanda | 220 | Sambizanga | 240 | 24.5 | 240 x 1, upgrade |
| 71 | 2036 | Uíge | 220 | Maquela do Zombo | 40 | 13.7 | 40 x 1, upgrade |
| 72 | 2036 | Huambo | 220 | Belém do Dango | 240 | 24.5 | 240 x 1, upgrade |
| 73 | 2036 | Lunda Norte | 220 | Dundo | 120 | 18.1 | 120 x1, upgrade |
| 74 | 2037 | Cuanza Sul | 220 | Gabela | 60 | 14.8 | 60 x 1, upgrade |
| 75 | 2038 | Benguela | 220 | Cubal | 240 | 24.5 | 120 x 2, upgrade |
| 76 | 2040 | Cuando-Cubango | 220 | Mavinga | 60 | 14.8 | 60 x 1 |
| 77 | 2040 | Malanje | 220 | Malanje2 | 120 | 18.1 | 120 x 1, upgrade |
| 78 | 2040 | Huíla | 220 | Caluquembe | 60 | 14.8 | 60 x 1, upgrade |
| Total | | | | | 11,810 | 772.4 | |

(Source: JICA Survey Team)

Table 7-30 List of 400 kV Transmission Line Projects

| Project# | Year of operation | Area | Voltage (kV) | Starting point | End point | number of circuit | Power Flow (MVA) | Line Length (km) | Cost (MU\$) | Remarks |
|----------|-------------------|----------|--------------|-----------------|-----------------|-------------------|------------------|------------------|-------------|-------------------------------|
| 1 | 2020 | Central | 400 | Lauca | Waco kungo | 1 | 307 | 177 | 138.1 | under construction(China) |
| 2 | 2020 | Central | 400 | Waco kungo | Belem do Huambo | 1 | 242 | 174 | 135.7 | under construction(China) |
| 3 | 2020 | Northern | 400 | Cambutas | Bitá | 1 | 580 | 172 | 134.2 | under construction(Brazil) |
| 4 | 2022 | Northern | 400 | Catete | Bitá | 2 | 504 | 54 | 52.9 | under construction(Brazil) |
| 5 | 2025 | Northern | 400 | Cambutas | Catete | 1 | 791 | 123 | 95.9 | Dualization |
| 6 | 2025 | Northern | 400 | Catete | Viana | 1 | 579 | 36 | 28.1 | Dualization |
| 7 | 2025 | Northern | 400 | Lauca | Capanda elev. | 1 | 518 | 41 | 32.0 | Dualization |
| 8 | 2025 | Northern | 400 | Kapary | Sambizanga | 2 | 1130 | 45 | 44.1 | For New Substation |
| 9 | 2025 | Northern | 400 | Lauca | Catete | 2 | 868 | 190 | 186.2 | Changing Connection Plan |
| 10 | 2025 | Central | 400 | Lauca | Waco kungo | 1 | 307 | 177 | 138.1 | Dualization |
| 11 | 2025 | Central | 400 | Waco kungo | Belem do Huambo | 1 | 242 | 174 | 135.7 | Dualization |
| 12 | 2025 | Central | 400 | Cambutas | Gabela | 2 | 484 | 131 | 128.4 | Pre-FS implemented* |
| 13 | 2025 | Central | 400 | Gabela | Benga | 2 | 848 | 25 | 24.5 | Pre-FS implemented* |
| 14 | 2025 | Central | 400 | Benga | Nova Biopio | 2 | 550 | 200 | 196.0 | Pre-FS implemented* |
| 15 | 2025 | Southern | 400 | Belem do Huambo | Caluquembe | 2 | 606 | 175 | 171.5 | Pre-FS implemented* |
| 16 | 2025 | Southern | 400 | Caluquembe | Lubango2 | 2 | 666 | 168 | 164.6 | Pre-FS implemented* |
| 17 | 2025 | Southern | 400 | Belem do Huambo | Chipindo | 2 | 264 | 114 | 111.7 | |
| 18 | 2025 | Southern | 400 | Chipindo | Capelongo | 2 | 190 | 109 | 106.8 | |
| 19 | 2025 | Southern | 400 | Nova Biopio | Quilengues | 2 | 840 | 117 | 114.7 | Pre-FS implemented* |
| 20 | 2025 | Southern | 400 | Quilengues | Lubango2 | 2 | 772 | 143 | 140.1 | Pre-FS implemented* |
| 21 | 2025 | Southern | 400 | Lubango2 | Cahama | 2 | 450 | 190 | 186.2 | Pre-FS implemented* |
| 22 | 2025 | Eastern | 400 | Capanda elev | Xa-Muteba | 2 | 590 | 266 | 260.7 | |
| 23 | 2025 | Eastern | 400 | Xa-Muteba | Saurimo | 2 | 510 | 335 | 328.3 | under Pre-FS |
| 24 | 2027 | Southern | 400 | Capelongo | Ondjiva | 2 | 292 | 312 | 305.8 | |
| 25 | 2027 | Southern | 400 | Cahama | Ondjiva | 2 | 442 | 175 | 171.5 | |
| 26 | 2027 | Southern | 400 | Cahama | Ruacana | 2 | 409 | 125 | 122.5 | International Interconnection |
| Total | | | | | | | | 3,948 | 3,654.2 | |

Pre-FS implemented*:Candidate route were selected by USTDA and DBSA.

(Source: JICA Survey Team)

Table 7-31 220 kV List of Transmission Line Projects

| Project# | Year of operation | Area | Voltage (kV) | Starting point | End point | number of circuit | Required Capacity (MVA) | Line Length (km) | Cost (MU\$) | Remarks |
|----------|-------------------|----------|--------------|-----------------|-----------------|-------------------|-------------------------|------------------|-------------|-------------------------|
| 1 | 2020 | Southern | 220 | Lubango2 | Lubango | 2 | 360 | 30 | 13.5 | Pre-FS implemented* |
| 2 | 2020 | Southern | 220 | Lubango2 | Namibe | 2 | 360 | 162 | 72.9 | Pre-FS implemented* |
| 3 | 2020 | Southern | 220 | Namibe | Tombwa | 2 | 120 | 97 | 43.7 | Pre-FS implemented* |
| 4 | 2020 | Eastern | 220 | Saurimo | Lucapa | 2 | 300 | 157 | 70.7 | Pre-FS implemented* |
| 5 | 2020 | Eastern | 220 | Lucapa | Dundo | 2 | 240 | 135 | 60.8 | Pre-FS implemented* |
| 6 | 2022 | Northern | 220 | Bitá | Camama | 2 | 840 | 21 | 9.5 | |
| 7 | 2022 | Northern | 220 | Catete | Zango | 2 | 360 | 40 | 18.0 | |
| 8 | 2022 | Northern | 220 | Capanda elev. | Maranje | 2 | 360 | 110 | 49.5 | |
| 9 | 2022 | Central | 220 | Gabela | Alto Chingo | 1 | 300 | 81 | 29.2 | Dualization |
| 10 | 2022 | Central | 220 | Quibala | Waco Kungo | 2 | 120 | 92 | 41.4 | |
| 11 | 2022 | Central | 220 | Lomaum | Cubal | 2 | 360 | 2 | 0.9 | |
| 12 | 2022 | Southern | 220 | Lubango | Matala | 2 | 120 | 168 | 75.6 | Pre-FS implemented* |
| 13 | 2022 | Southern | 220 | Matala HPS | Matala | 1 | 41 | 5 | 1.8 | upgarade |
| 14 | 2022 | Southern | 220 | Capelongo | Cuchi | 2 | 420 | 91 | 41.0 | |
| 15 | 2022 | Southern | 220 | Cuchi | Menongue | 2 | 360 | 94 | 42.3 | |
| 16 | 2025 | Northern | 220 | Sambizanga | Golfe | 2 | 360 | 7 | 3.2 | |
| 17 | 2025 | Northern | 220 | Kapary | Caxito | 2 | 60 | 26 | 11.7 | |
| 18 | 2025 | Northern | 220 | N'Zeto | Tomboco | 2 | 220 | 5 | 2.3 | For Substation inserted |
| 19 | 2025 | Northern | 220 | M'banza Congo | Tomboco | 2 | 220 | 5 | 2.3 | For Substation inserted |
| 20 | 2025 | Northern | 220 | Sambizanga | Chicala | 2 | 480 | 7 | 3.2 | |
| 21 | 2025 | Northern | 220 | Catete | Maria Teresa | 2 | 60 | 51 | 23.0 | |
| 22 | 2025 | Central | 220 | Alto Chingo | Cuacra | 2 | 60 | 25 | 11.3 | |
| 23 | 2025 | Central | 220 | Alto Chingo | Port Amboim | 2 | 120 | 60 | 27.0 | |
| 24 | 2025 | Central | 220 | Quileva | Nova Biopio | 1 | 550 | 18 | 6.5 | Dualization |
| 25 | 2025 | Central | 220 | Quileva | Catumbela | 2 | 240 | 8 | 3.6 | |
| 26 | 2025 | Central | 220 | Nova Biopio | Bocoio | 2 | 120 | 5 | 2.3 | For Substation inserted |
| 27 | 2025 | Central | 220 | Lomaum | Bocoio | 2 | 120 | 5 | 2.3 | For Substation inserted |
| 28 | 2025 | Central | 220 | Belem do Huambo | Ukuma | 2 | 60 | 66 | 29.7 | |
| 29 | 2025 | Central | 220 | Belem do Huambo | Catchiungo | 2 | 720 | 76 | 34.2 | Strengthen |
| 30 | 2025 | Central | 220 | Catchiungo | Kuito | 2 | 480 | 85 | 38.3 | Strengthen |
| 31 | 2025 | Central | 220 | Kuito | Andulo | 2 | 60 | 110 | 49.5 | |
| 32 | 2025 | Southern | 220 | Cahama | Xangongo | 2 | 180 | 97 | 43.7 | Pre-FS implemented* |
| 33 | 2025 | Southern | 220 | Ondjiva | Xangongo | 1 | 120 | 97 | 34.9 | Pre-FS implemented* |
| 34 | 2025 | Southern | 220 | Capelongo | Tchamutete | 2 | 120 | 98 | 44.1 | |
| 35 | 2025 | Eastern | 220 | Saurimo | Luna | 2 | 240 | 265 | 119.3 | Pre-FS implemented* |
| 36 | 2027 | Eastern | 220 | Saurimo | Muconda | 2 | 180 | 187 | 84.2 | |
| 37 | 2027 | Eastern | 220 | Muconda | Luau | 2 | 120 | 115 | 51.8 | |
| 38 | 2027 | Eastern | 220 | Luau | Cazombo | 2 | 60 | 264 | 118.8 | |
| 39 | 2030 | Central | 220 | Cubal | Alto Catumbela | 2 | 120 | 47 | 21.2 | |
| 40 | 2030 | Central | 220 | Catchiungo | Bailundo | 2 | 120 | 66 | 29.7 | |
| 41 | 2030 | Central | 220 | Benguela Sul | Baia Farta | 2 | 120 | 30 | 13.5 | |
| 42 | 2030 | Northern | 220 | Uige | Negage | 2 | 620 | 5 | 2.3 | For Substation inserted |
| 43 | 2030 | Northern | 220 | Pambos de Sonhe | Negage | 2 | 620 | 5 | 2.3 | For Substation inserted |
| 44 | 2035 | Northern | 220 | Viana | PIV | 2 | 480 | 7 | 3.2 | |
| 45 | 2035 | Northern | 220 | Negage | Sanza Pombo | 2 | 120 | 109 | 49.1 | |
| 46 | 2035 | Central | 220 | Kuito | Camacupa | 2 | 60 | 145 | 65.3 | |
| 47 | 2035 | Southern | 220 | Menongue | Cuito Cuanavale | 2 | 120 | 189 | 85.1 | |
| 48 | 2035 | Southern | 220 | Cuito Cuanavale | mavinga | 2 | 60 | 176 | 79.2 | |
| Total | | | | | | | | 3,746 | 1,667.6 | |

Pre-FS implemented*:Candidate route were selected by USTDA and DBSA.

(Source: JICA Survey Team)

Table 7-32 List of Power Supply Transmission Line Projects

| Project# | Year of operation | Area | Voltage (kV) | Starting point | End point | number of circuit | Generation Capacity (MVA) | Line Length (km) | Cost (MUSS) | Remarks |
|----------|-------------------|----------|--------------|--------------------|-------------------|-------------------|---------------------------|------------------|-------------|---------------------------|
| 1 | 2025 | Northern | 400 | HPP Caculo Cabaça | Cambutas | 2 | 496 | 54 | 52.9 | under construction(China) |
| 2 | 2025 | Northern | 400 | HPP Caculo Cabaça | Lauca | 2 | 1326 | 25 | 24.5 | |
| 3 | 2025 | Northern | 400 | TPP Soyo 2 | Soyo | 2 | 750 | 5 | 4.9 | |
| 4 | 2025 | Central | 400 | TPP Lobito CCGT #1 | Nova Biopio | 2 | 750 | 23 | 22.5 | |
| 5 | 2025 | Northern | 220 | TPP Cacuaco GT #1 | Cacuaco | 2 | 375 | 5 | 2.3 | |
| 6 | 2025 | Northern | 220 | TPP Cacuaco GT #2 | Cacuaco | 2 | 375 | 5 | 2.3 | |
| 7 | 2025 | Northern | 220 | TPP Boavista GT #3 | Sambizanga | 2 | 375 | 5 | 2.3 | |
| 8 | 2030 | Northern | 220 | HPP Quilengue ⑤ | Gabera | 2 | 210 | 37 | 16.7 | |
| 9 | 2030 | Southern | 400 | HPP Baynes | Cahama | 2 | 300 | 195 | 191.1 | |
| 10 | 2030 | Central | 220 | TPP Quileva GT #4 | Quileva | 2 | 250 | 1 | 0.5 | |
| 11 | 2030 | Central | 220 | TPP Quileva GT #5 | Quileva | 2 | 250 | 1 | 0.5 | |
| 12 | 2030 | Central | 220 | TPP Quileva GT #6 | Quileva | 2 | 250 | 1 | 0.5 | |
| 13 | 2030 | Northern | 400 | TPP Soyo GT #7 | Soyo | 2 | 375 | 5 | 4.9 | |
| 14 | 2035 | Northern | 400 | HPP Zenzo | Cambutas | 2 | 950 | 41 | 40.2 | |
| 15 | 2035 | Northern | 400 | HPP Genga | Benga Switch-yard | 2 | 900 | 30 | 29.4 | |
| 16 | 2035 | Central | 400 | TPP Lobito CCGT #2 | Nova Biopio | 2 | 720 | 23 | 22.5 | |
| 17 | 2035 | Southern | 220 | HPP Jamba Ya Mina | Matala | 1 | 205 | 86 | 31.0 | |
| 18 | 2035 | Southern | 220 | HPP Jamba Ya Oma | HPP Jamba Ya Mina | 1 | 79 | 37 | 13.3 | |
| 19 | 2040 | Northern | 220 | HPP Túmulo Caçador | Cambutas | 2 | 453 | 16 | 7.2 | |
| 20 | 2040 | Southern | 220 | TPP Namibe CCGT #3 | Namibe | 2 | 750 | 17 | 7.7 | |
| 21 | 2040 | Central | 400 | TPP Lobito CCGT #4 | Nova Biopio | 2 | 375 | 23 | 22.5 | |
| Total | | | | | | | | 635 | 499.4 | |

(Source: JICA Survey Team)

Chapter 8 Review on Private Investment Environment

8.1 Report on private Investment

(1) ‘Doing Business 2017’ from the World Bank

First, the JICA Survey Team reviews the ‘Doing Business 2017’ Report to learn about the business environment of Angola.

The World Bank (WB) publishes a ‘Doing Business’ report on the ease of doing business based on indicator sets every year. The latest ‘Doing Business 2017’ report evaluates data such as the days necessary to complete the application process and the required fees. Out of 190 countries covered in a country ranking, Angola ranks 182nd (versus rankings of 25th for Portugal, 74th for South Africa, 137th for Mozambique, and 169 for Nigeria).




Figure 8-1 Ranking of Angola and other comparator countries

Item by item, Angola ranks 181st in ‘Getting Credit,’ 183rd in ‘Trading across Borders,’ 186th in ‘Enforcing Contracts,’ and 169th in ‘Resolving Insolvency.’ The rankings are based on the distance to the frontier score for each topic: i.e., the best country on the frontier is scored 100 and the other countries are scored from 0 to 100 according to their absolute distances to the frontier.

Figure 1.3 Rankings on *Doing Business* topics - Angola
(Scale: Rank 190 center, Rank 1 outer edge)





Figure 1.4 Distance to frontier scores on *Doing Business* topics - Angola
(Scale: Score 0 center, Score 100 outer edge)



Source: *Doing Business* database.

Note: The rankings are benchmarked to June 2016 and based on the average of each economy's distance to frontier (DTF) scores for the 10 topics included in this year's aggregate ranking. The distance to frontier score benchmarks economies with respect to regulatory practice, showing the absolute distance to the best performance in each *Doing Business* indicator. An economy's distance to frontier score is indicated on a scale from 0 to 100, where 0 represents the worst performance and 100 the frontier. For the economies for which the data cover 2 cities, scores are a population-weighted average for the 2 cities.

(Source: *Doing Business* database)

Figure 8-2 Ranks and scores for each topic

The JICA Survey Team understands that the problems of Angola concentrate around these low-scored items. The World Bank issued the following explanations in this regard.

- ✓ Credit information systems are not widely used. → Collateral laws or Bankruptcy law are not enacted. Borrower financial credit histories are not shared. Financial statements are not used effectively in providing credit.
- ✓ Contracts are not widely enforced. → no commercial dispute resolution system is established.
- ✓ Liquidation or insolvency systems are not well established. → Angola has not experienced any liquidation or insolvency.

8.2 Review of the Private Investment Environment Report

This section identifies bottlenecks in the private investment environment and summarizes plans to develop a private electric power project.

8.2.1 Private investment environment in Angola

(1) Private Sector Country Profile: Angola

The report describes problems in Angola's private investment environment broken down into three factors: the 'institutional factor,' 'economical factor,' and 'other factors.' The problems are summarized in the table below.

The JICA Survey Team reviewed the 'Private Sector Country Profile: Angola in 2012,' the first comprehensive business guidebook on Angola. The profile began with the geographical conditions of the country and then moved onto the recent political conditions, economic conditions, and finally the conditions of the investment environment. In 2015, the African Development Bank published its Portuguese edition. Unlike the 'Doing Business Report' from the World Bank, the contents of the Portuguese edition have not been updated.

The report describes problems in Angola's private investment environment organized into three factors: the 'institutional factor,' 'economical factor,' and 'other factors.' The problems are summarized in the table below.

Table 8-1 Problems in Angola's investment environment

| | Problems in the private investment environment |
|-----------------------------|--|
| <u>institutional factor</u> | <ul style="list-style-type: none"> • Laws and contracts tend not to be observed. • Infrastructures such as power and water supply are not properly established. • It takes much time to obtain approvals for applications. |
| <u>economical factor</u> | <ul style="list-style-type: none"> • All daily products are imported by exporting oil. The official foreign currency reserves therefore depend on the oil price. • No stock market exists. • A monetary market exists, but is weak and vulnerable. • Credit evaluations for borrowers are poorly executed. Accounting data that reflect financial conditions is insufficiently used. |
| <u>other factors</u> | <ul style="list-style-type: none"> • The labor market for skilled workers is immature. |

(Sources: AfDB 'Private Sector Country Profile: Angola' in 2012')

8.2.2 Legal system in Angola

The legal system in Angola is principally based on Portuguese law. Laws, Decrees, and Acts restated to private investment, meanwhile, are being enacted apart from basic laws such as the Civil Law, Labor Law, etc.

The National Bank of Angola (BNA) has a statutory authority to adopt the accounting standards for financial institutions. Especially banks that meet at least one of the criteria in 2015 must adopt IFRS. Other banks also must adopt IFRS issued by IASB but may do so voluntarily from 2016. Many companies other than financial institutions mentioned above do not adopt IFRS. They are said to prepare the financial statements in conformity with the Angolan Accounting Law and the General Accounting Plan (PGC) that was adopted by the Presidential Decree as of 2001.

In this section the JICA Survey Team extracts the laws and regulations it considers important for private investment in Angola, out of those described in the report on the business environment. Note, however, that no laws intended for specific sectors other than the power sector are selected. The new Private Investment Law (newPIL), a law that will be important for private investment, will be reviewed in a later section.

Table 8-2 Names of laws related to the private investment environment

| Name | year | contents |
|---|------------|---|
| Anti money Laundering Law | 2010 | set up a penalty on Money Laundering |
| Countering Financial of Terrorism Law No.34/11 | 2010 | Penalty on Public Probity |
| Public Asset Managing Law, with Presidential Decree | Aug. 2010 | for inventory of State Petimnoy, in bidding process |
| President Decree 177/10 | ditto | |
| New Private Investment Law | May, 2011 | New PILwas enacted in 2015. |
| | →Aug. 2015 | ANIPwas establishe in 2003 |
| Exchange Law No.5/97 | Jun. 1997 | Trade activity : President Decree No.265/10 (Nov. 2010), specific rules: BNA's Notice No.19/2012 (Apr. 2012) |
| | | |
| Commercial Societes Law Law 01/04 | Feb. 2004 | defines types of fims |
| | | |

(Sources: AfDB 'Private Sector Country Profile: Angola in 2012')

8.3 Interviews with Japanese companies

8.3.1 Interviews with Japanese Companies in Angola

In October 2017, the JICA Survey Team interviewed three Japanese companies doing business in Angola: Sumitomo Corporation (Sumitomo Syoji), Marubeni, and Toyota de Angola, S.A (Toyota Tusho). Sumitomo Corporation and Marubeni operate Representative Offices in the country, and Toyota de Angola, S.A. is a Joint Stock Company. Sumitomo Corporation is said to have concluded a Minutes of Understanding (MOU) with the Government of Angola for the construction of Japan-made diesel power plants, but the details of the plan are not known.

Issues

- ① What hardships are they going through in doing business in Angola?
- ② What bottlenecks are there in Angola's legal system?
- ③ Is the New Private Investment Law (new PIL) of help in developing new projects?
- ④ Other

(results)

| |
|---|
| ① Hardships in doing business |
| <ul style="list-style-type: none"> • The low oil price binds the foreign reserves of Angola. Private companies are therefore unable to freely remit money outside of Angola. (Nacional Banco of Angola conducts a bid every week and only companies awarded bids are entitled to remit money.) • The laws are drafted in Portuguese, the official language, which makes them hard to read and understand. |
| ② Legal bottlenecks |
| <ul style="list-style-type: none"> • New Presidential Decrees are being enacted. Actual business follows not the basic laws but the Decrees. • Interpretation of law varies. |
| ③ Request and opinions on the newPIL |
| <ul style="list-style-type: none"> • Laws are enacted, but direct negotiations will prevail. |

④ Other

- The monetary market in Angola is weak and provides no good financial products
- Chinese companies doing business in Angola are said to settle their services not by cash but barter for oil. They are therefore immune to the influences of the strict regulations on bank remittance.

8.4 New Private Investment Law

8.4.1 New Private Investment Law (2015)

The New Private Investment Law, a law expected to have strong influence on private investment and project formation in Angola, was approved on August 11, 2015. It was entered into force on the same day that the former private investment law was repealed (Law No.20/11 of May 20, 2011).

A new agency called APITEX (Angolan Investment and Export Promotion Agency) was also formed to promote investments and exports.

An outline of the New Private Investment Law follows.

- ✓ The newPIL no longer includes minimum thresholds for investments. But to qualify for tax benefits and incentives, a foreign investor must invest at least \$1 million and a domestic investor must invest at least \$500,000.
- ✓ Decisions regarding private investments are in principle taken by the ministers responsible for the main sectors in which the investments are made, or by the Angolan executive (i.e., the President).
- ✓ The New Private Investment Law restricts indirect investment.
- ✓ An investor can be granted certain tax benefits and incentives, albeit no longer automatically.
- ✓ In the electricity and water sectors, the Angolan party should retain an interest of at least 35% in a joint venture.
- ✓ An investor can repatriate dividends, profits, and royalties. Any portion of a repatriated amount exceeding the funds of the company is subject to an additional tax.

8.4.2 Private power project in accordance with the New Private Investment Law

The details of a private electric power project are outlined below.

- ✓ In order to qualify for tax benefits and incentives, a foreign investor must invest at least \$1 million and a domestic investor must invest at least \$500,000. Negotiations are held directly with the Minister of Energie and Aqua (MINEA) or the Angolan executive (i.e., the President).
- ✓ Any tax incentives are decided and applied through negotiation.
- ✓ A foreign investor forms a joint venture with Angolan individuals or an Angolan company. The Angolan party retains an interest of at least 35% in the joint venture.
- ✓ After paying additional taxes, a foreign investor is eligible to repatriate dividends, profits, and royalties.

At present, the private investment environment in Angola is still underdeveloped. While every country and company recognizes the big potential of Angola, they are still reluctant to go ahead.

A power project by a private sector differs from an ODA project, in general, as no guarantees from the government are obtained. The private sector must therefore bear all of the risks such as the fluctuating prices of fuel and materials, foreign exchange, interest rates, etc. by itself.

Finally, the following are requested when private electric power projects are formed in Angola.

- Every party member observes and acts in accordance with the contract.
- The political system in Angola is stable and assets will not be nationalized.
- A reasonable long-term PPA (Power Purchase Agreement) is concluded. Tariffs are set to adequately secure a certain profit level over the long term.
- Profits earned are allocated in accordance with equity or the contract.
- A foreign investor is free to remit profit and dividends outside of Angola irrespective of the economy of Angola. (※)
- Funds from the monetary market of Angola are preferred: reasonable interest rates (not so high) and longer repayment periods.

※The auction system to settle payments for foreign countries re-started in 2018, with which the winner of the auction is entitled to receive foreign currencies for remittance. However this system seems to work only for a winner so that it does not meet requests from all import companies in Angola.

8.5 Summary and Bottlenecks

- Factors apart from the private investment issues tend to affect candidate projects. As a consequence, there seems to be little incentive to develop private investments overall. The Government needs to promote the observance of contracts and high transparency in appraising and approving projects.
- The lack of actual private investment projects to date leaves Angola with little experience in completing specific PPA agreements. As a result, negotiations and approvals may take longer.

Chapter 9 Long-term Investment Plan

9.1 Premise for fundraising

The progress of power development in Angola is mainly driven by PRODEL, RNT, and ENDE in an environment where private companies lack strong inclination to develop power projects by themselves. Under these circumstances, PRODEL will become a major implementing agency for generation, while ENDE will become the main implementing agency for transmission and distribution.

The JICA Survey Team reviews the financial statements for PRODEL, RNT, and ENDE. Given the apparent difficulty these companies would have in investing more with their own profits, they are likely to request funds from outside.

9.2 Fundraising for investment

First, the JICA Survey Team reviews whether it will be able to raise funds by issuing a bond or taking out a loan in a monetary market of Angola. As for the recent market condition, the official website of Banco Nacional de Angola (BNA) as of October 26, 2017 indicates a loan condition in terms of AOA, with an interest rate of 20.04% and repayment period of 1-3 years. The average interest rates for Treasury Bills with maturities of 91, 182, and 364 days, meanwhile, have been 16.12% (91 days), 23.19% (182 days), and 23.94% (364 days). In 2015 Angola raised \$1.5 billion by selling its first Eurobond, offering a yield of 9.5% with a maturity of 10 years. Considering this information, conditions for a non-sovereign bond would be more difficult.

Note: Fitch assigned the bond a “highly speculative” rating of B+ in line with Angola’s sovereign ratings at the time. Angola was rated Ba2 by Moody’s and B+ by Standard & Poor’s and Fitch.

The issue of stock in Angola is improbable, as no stock market exists in the country. Actual fundraising must therefore depend on international monetary intermediaries such as the World Bank (WB), African Development Bank (AfDB), and Japan International Corporation Agency (JICA).

9.2.1 ODA loan

According to the definition of the Development of Co-operation Directorate (DAC), an ODA loan is a loan that includes a grant element of more than 25%. A loan with a greater grant element is advantageous to the borrower or borrowing country. International donor organizations such as the World Bank, AfDB, and JICA are eligible to extend such ODA loans.

Note: The grant element reflects the concessionary nature (i.e., softness) of a loan. The ratio of the grant element rises as the interest rate falls and the repayment period lengthens.

(1) Loan Conditions Extended by the International Financial Institutions

The World Bank (WB), European Bank for Reconstruction and Development (EBRD), and African Development Bank (AfDB) are all international financial institutions that provide ODA loans. Among them, however, the AfDB would be more familiar to Angola, a country located in the Sub-Saharan Region. The JICA Study Team visited the official website of AfDB to review the conditions of a Sovereign Guaranteed Loan (SGL) from the bank.

- Currency :USD, EUR, JPY, and others
- repayment period: maximum 20 years (grace: maximum 5 years)
- interest: 6MLIBOR (float) +Funding Margin+Lending Margin (60bp)
- principal: equal installments after the end of the grace period (other methods are acceptable)
- front end fee: none
- commission fee: charged
- other: other conditions added depend on the project

Characteristics of an SGL: ① a comparatively long maturity of up to 20 years, including a grace period; ② the borrower can choose a currency out of a few choices; ③ the interest rate is defined as 6MLIBOR (USD, JPY)+ funding margin + lending margin (currently 60bp); ④ a 5-year grace period is extended to the borrower.

According to the official website of AfDB on March 12, 2018, the 6MLIBOR (Fixed Spread Loan in USD), including the lending spread, was set at 1.85%, and the front-end fee was 25bp.

(2) ODA Loan by JICA

Japan International Corporation Agency (JICA) provides ODA loans, including Yen loans, under the frameworks of bilateral corporation between Japan and recipient countries. The JICA Study Team visited the official website of JICA on March 12, 2018 to review the loan conditions for Yen loans. According to the website, Angola is classified as an LDC country. The following conditions are applied to LDC countries.

- currency: JPY (Japanese Yen)
- repayment period: 30 year (grace: 10 year)
- interest: 1.0% (fixed), applied after October 17, 2017
- principal: equal installment of 20 years

Characteristics of a Yen Loan: ① long maturity of 30 years, including the grace period; ② JPY currency; ③ low interest rate (1%), ④ payment of principal not required during the grace period.

(3) Some Remarks on ODA Loan

Several points must be considered when receiving an ODA loan.

- AfDB can only extend an SGL loan to a regional member country (RMC).

- A guarantee from the Government of Angola is needed when AfDB provides a loan to a project in Angola.
- A certain procedure is required to conclude a JICA Yen Loan. First, the Government of Angola must send an official request for an ODA loan. Next, the Government of Japan appraises the candidate project. Next, the Government of Japan exchanges an E/N with the Government of Angola and finally concludes the L/A. It will actually take at least 2-3 years to conclude the L/A.
- A guarantee from the Government of Angola is needed when JICA provides a loan to a project in Angola.

In a case where the implementing agency does not expect the ODA loan or may not receive the ODA loan, it may request Export Credit from Export Credit Agencies (ECA) in foreign countries as an alternative option. When Angola plans to import plants from Japanese manufacturing companies, it requests export credit from the Japan Bank for International Corporation (JBIC), the ECA of Japan.

The provision of Export Credit needs a guarantee from the Government. An ECA loan is faster than an ordinary ODA loan when the implementation agency successfully obtains the Government's guarantee and commercial banks forming a syndicate with JBIC are ready to provide co-financing. Moreover all OECD member countries, including Japan, are to provide the Export Credit in accordance with '*the Arrangement on Officially Supported Export Credits.*' Consequently, the condition of Export Credit provided by each OECD member country shall be the same.

Meanwhile, historically Angola has been receiving loans or ECAs from the Chinese Export-Import Bank. As a country outside of the OECD, China can provide loans with different loan conditions. When the JICA Study Team visited the official website of the China Export-Import Bank to find the specific loan conditions, no specific loan conditions with figures were disclosed.

Here is the ECA condition JBIC provides as of March 12, 2018, based on information from the official website of JBIC. Commercial Interest Reference Rates (CIRR) is as follows.

- currency: USD (\$)
- repayment period: over 8.5 years
- interest: 3.780%
- principal: equal installments or another method
- Beside the interest, the borrower needs to pay an up-front fee as a risk premium. As Angola is classified in Category 6 as of February 2, 2018, Angola needs to pay 12.88% of the up-front fee.
- Candidate borrower (i.e., the implementing agency in Angola) needs to be covered with the insurance issued by NEXI, the Export Insurance Company of Japan, when it requests export credit from JBIC. A visit to the official website of NEXI on March 9, 2018 confirmed that Angola is classified in Category G. The premium calculated with the attached calculation sheet from NEXI is 15.832%.

9.2.2 Typical Loan Conditions

The table below summarizes typical loan conditions for ① an AfDB Loan (AfDB), ② Yen Loan (JICA), ③ commercial loan in Angola, ④ ECA. Each of the foregoing types has its own procedures, appraisal system, and conditions. While it is difficult at this juncture to determine which of the above types is best, a loan with a longer repayment period and lower interest would impose a lighter financial burden.

Note also that the funds are provided with a sub-loan instead of an original loan the implementation agency may lose the merit of the latter.

Table 9-1 Typical Loan Conditions

| | type | loan condition |
|---------------------------|-----------------|---|
| 1 <u>AfDB loan (AfDB)</u> | ODA | currency: USD, EURO, JPY and others interest rate: 2.16444% (estimated) (6MLIBOR +fund margin +lending margin (60bp)) maturity: up to 20 years (grace period up to 5 year) principal: equall installments other conditions: commitment fee etc. |
| 2 <u>Yen Loan (JICA)</u> | ODA | currency: JPY interest rate: 1.0% maturity: 30 years (grace period: 10year) principal: equall installments others: - |
| 3 <u>Commercial Loan</u> | commercial loan | currency: AoA interest rate: 20% (estimated) maturity: 3 years principal: - others: - |
| 4 <u>Export Credit</u> | commercial loan | currency: JPY, USD, EURO etc. interest rate: 3.78% (USD, over 8.5 years) maturity: over 8.5 years principal: equall installments other conditions: pay the front-end fee, insurance may be needed. |

9.3 Long-term Investment Plan

9.3.1 Summary of the Long-term Investment Plan

The JICA Study Team reviewed the long-term power development plan as of March, 2018. The development plan has two parts: the power development plan to meet the demand forecast and the development plan for the transmission lines and sub-stations.

The table below shows the unit prices necessary to construct power plants, transmission lines, and sub-stations. (The unit prices for hydro and thermal power plants are shown in section 6.3.)

The power development plan up to Year 2040 consists of hydropower projects, thermal power projects (CCGT and GT), transmission line projects (220 kV and 400 kV), and sub-station projects (220 kV and 400 kV). Meanwhile, construction of the renewable energy (wind and solar) facilities will be left to other developers, and power will be purchased from them.

Table 9-2 Unit Prices for Construction

| Type | | unit capital cost (\$/kW) | Note |
|---------------|----------------|------------------------------|--------------------------------|
| Hydro power | Large scale | 2,700 | Average in Angola |
| | Medium/Small | 5,400 | ditto |
| Thermal power | Combined Cycle | 1,200 | Construction cost of SoyoTPP |
| | Gas Turbine | 650 | International price |
| | Diesel | 900 | International price |
| Renewable | Wind | - | Considered in generation cost |
| | Solar | - | Considered in generation cost |
| Transmission | 220 kV | 0.36 mil/ km 0.45 mil/ km | 1line 2 nd line |
| | 400 kV | 0.78 mil./km 0.98 mil/ km | 1 line 2 nd line |
| Sub-station | 200 kV | 0.054*(MVA)+11.58mil | per station |
| | 400 kV | 0.024*(MVA)+29.67mil | per station |

(1) Investment in terms of the Commissioning Year

Following are investment plans by the commissioning year. The total investment comes to 31,548 million USD: hydropower (19,083 million USD), thermal power (6,413 million USD), renewable energy (0 million USD), transmission lines (4,417 million USD) and sub-stations (1,636 million USD).

Table 9-3 Long-term Investment Plan up to 2040 (commissioning Year)

| | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
|--------------|------------|-----------|--------------|------------|--------------|--------------|------------|------------|--------------|------------|--------------|--------------|-----------|------------|
| Hydro | 0 | 0 | 5,589 | 34 | 0 | 0 | 0 | 0 | 5,864 | 810 | 0 | 567 | 0 | 0 |
| TPP | 300 | 0 | 0 | 0 | 1,050 | 531 | 0 | 531 | 81 | 0 | 81 | 450 | 81 | 163 |
| Renewable | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Transmission | 208 | 0 | 2 | 279 | 0 | 878 | 556 | 2 | 1,614 | 0 | 785 | 0 | 0 | 18 |
| Sub-station | 0 | 25 | 0 | 225 | 0 | 444 | 51 | 0 | 196 | 0 | 426 | 0 | 0 | 18 |
| total | 508 | 25 | 5,591 | 539 | 1,050 | 1,854 | 607 | 533 | 7,756 | 810 | 1,293 | 1,017 | 82 | 199 |

| | 2031 | 2032 | 2033 | 2034 | 2035 | 2036 | 2037 | 2038 | 2039 | 2040 | total |
|--------------|------------|--------------|------------|------------|--------------|------------|------------|--------------|-----------|------------|---------------|
| Hydro | 0 | 2,565 | 0 | 0 | 2,430 | 0 | 0 | 1,223 | 0 | 0 | 19,083 |
| TPP | 450 | 163 | 325 | 450 | 163 | 450 | 244 | 450 | 0 | 450 | 6,413 |
| Renewable | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Transmission | 34 | 0 | 0 | 8 | 6 | 0 | 6 | 0 | 18 | 2 | 4,417 |
| Sub-station | 129 | 0 | 0 | 0 | 103 | 0 | 0 | 0 | 18 | 0 | 1,636 |
| total | 613 | 2,728 | 325 | 458 | 2,701 | 450 | 250 | 1,673 | 36 | 452 | 31,548 |




Figure 9-1 Annual Investment up to 2040 (in terms of the Construction Schedule)

The following describes the JICA Study Team's review of the scale of the long-term investment plan. As PRODEL is responsible for generation and RNT is responsible for transmission and sub-stations, the review estimates the size of the investment amounts compared to the sales and net profit levels of PRODEL and RNT in 2016.

Table 9-4 Long-term Investment and 2016 Sales and Net Profit levels of PRODEL and RNT

| total investment amount up to 2040 | Financial Statement (2016) (b) | (a)/(b) |
|--|---|---------------------------------|
| investment for generation: <u>26,262 mil. \$</u> | PRODEL sales: 1,025 mil. \$ (=220,420.7 mil. AOA) net profit: 8.66 mil. \$ (=1,862.6 mil. \$) | <u>25,6</u> <u>3,032</u> |
| investment for transmission & sub-station: <u>6,187 mil. \$</u> | R N T sales : 405.9 mil. \$ (=87,297.665 mil. AOA) net profit: 20.3 mil. \$ (=4,381.762 mil. AOA) | <u>15,2</u> <u>304,8</u> |

※USD is converted using the official exchange rate of Nacional Banco de Angola as of March 12, 2018 (\$1=215.064 AOA (T.T.M))

The total investment in hydro and thermal power is 24.9 times the sales of PRODEL in 2016, or 2,944 times the net profit of PRODEL in the same year. The total investment in transmission and sub-stations is 14.9 times the sales of RNT in 2016, or 298.1 times the net profit of RNT in the same year. The investment amounts are so big, neither PRODEL nor RNT seems capable of obtaining the necessary funds with its current retained earnings. Thus, the new investment must be funded through borrowings from financial institutions.

(2) Long-term Investment in terms of the Construction Schedule

The agency implementing the new project will not need all of the funds in the commissioning year. Rather, it will require the funds year by year in accordance with the construction schedule. A standardized construction schedule for each facility is shown below.

Table 9-5 Standardized Annual Construction Schedule during the Construction Period.

| | -8 | -7 | -6 | -5 | -4 | -3 | -2 | -1 |
|----------------------|------------------------------------|-----|-----|-----|-----|-----|-----|-----|
| Hydro (Large) | 5% | 10% | 15% | 20% | 20% | 15% | 10% | 5% |
| TPP 1 (CC) | | | | | 25% | 30% | 30% | 15% |
| TPP 2 (Gas) | | | | 15% | 25% | 20% | 15% | 25% |
| Renewable (wind) | no construction but purchase power | | | | | | | |
| Renewable (solar) | no construction but purchase power | | | | | | | |
| Transmission (220kV) | | | | | 5% | 40% | 45% | 10% |
| Transmission (400kV) | | | | | 5% | 40% | 45% | 10% |
| Sub-station (220kV) | | | | | 5% | 40% | 45% | 10% |
| Sub-station (400kV) | | | | | 5% | 40% | 45% | 10% |

The total investment amount over the construction schedule is 26,023 million USD, consisting of 14,867 million USD for hydropower projects, 6,113 million USD for thermal power projects, 0 million USD for renewable energy projects, 3,339 million USD for transmission projects, and 1,705 million USD for sub-station projects.

Table 9-6 Long-term Investment Amount up to 2040 (in terms of the Construction Schedule)

| (unit: mil. \$) | | | | | | | | | | | | | | |
|-----------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|------------|---------------|--------------|--------------|--------------|
| | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
| Hydro | 857 | 1,469 | 962 | 1,323 | 1,392 | 1,127 | 821 | 616 | 382 | 441 | 663 | 756 | 749 | 804 |
| TPP | 275 | 448 | 478 | 450 | 259 | 176 | 120 | 161 | 192 | 212 | 249 | 269 | 289 | 294 |
| Renewable | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Transmission | 113 | 170 | 407 | 752 | 419 | 702 | 765 | 470 | 347 | 78 | 9 | 22 | 17 | 4 |
| Sub-station | 93 | 124 | 203 | 220 | 77 | 135 | 161 | 190 | 192 | 44 | 14 | 60 | 60 | 13 |
| total | 1,337 | 2,210 | 2,051 | 2,745 | 2,148 | 2,139 | 1,868 | 1,437 | 1,113 | 776 | 935 | 1,106 | 1,116 | 1,114 |
| (unit: mil. \$) | | | | | | | | | | | | | | |
| | 2031 | 2032 | 2033 | 2034 | 2035 | 2036 | 2037 | 2038 | 2039 | 2040 | total | | | |
| Hydro | 737 | 548 | 488 | 366 | 183 | 122 | 61 | 0 | 0 | 767 | 15,634 | | | |
| TPP | 265 | 398 | 288 | 337 | 239 | 308 | 203 | 135 | 68 | 0 | 6,113 | | | |
| Renewable | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | | | |
| Transmission | 3 | 6 | 4 | 3 | 3 | 8 | 9 | 3 | 0 | 0 | 4,314 | | | |
| Sub-station | 5 | 41 | 46 | 10 | 1 | 7 | 8 | 2 | 0 | 0 | 1,705 | | | |
| total | 1,010 | 993 | 825 | 716 | 427 | 446 | 281 | 139 | 68 | 767 | 27,766 | | | |

The following study assumes that the necessary funds will be borrowed in accordance with the annual construction schedule. Depreciation and O&M expenses are incurred after the commissioning year. The interest and principal payments take place in accordance with the repayment schedule.

(3) Presumptions for borrowing

The presumed loans and loan conditions are summarized as follows.

- In other countries, the agency implementing a project generally becomes both the borrower and repayer of the loan. This means that the implementing agency is responsible for repaying the loan. In Angola, however, GAMEK seems to be responsible for construction with a loan

obtained from an outside party. The newly constructed facility is to be handed over to PRODEL, RNT, or ENDE after commissioning, and the Government of Angola is responsible for repaying the loan. In this case, we cannot clearly discern who will borrow the loan and who will pay it off afterwards.

- It does not appear that PRODEL, RNT, and ENDE will be directly responsible for repaying the loan. This study assumes, however, that the implementing agency will be both the borrower and the repayer. It also assumes that all financial costs related from the borrowings, along with depreciation and O&M costs, will be debited in the financial statements of PRODEL and RNT.
- Considering the current financial conditions of PRODEL and RNT, they are very unlikely to be able to develop new projects with their own retained earnings. Thus, all projects are assumed to be developed through borrowings.
- The following three loans will be available for projects of Angola: (1) a Yen loan extended by JICA, (2) an ODA loan extended by African Development Bank (AfDB), (3) Export Credit extended by JBIC. Over the past few years, ODA agencies have tended to provide ODA loans to hydropower projects, transmission projects, and sub-station projects that have slim prospects for high profitability. Conversely, the agencies are unlikely to provide ODA loans to thermal power projects that have strong prospects for commercial profitability and are expected to be developed as IPP projects.
- The study therefore assumes that the hydropower projects and transmission and sub-station projects will be developed with ODA loans, while the thermal power projects will be developed with ECAs.
- The Yen loan extended by JICA and the ODA loan extended by AfDB are assumed to have upper ceilings of 85% of the total borrowing. This means that the implementing agency must fill the remaining 15% by itself while requesting to borrow 85% of the total investment. Likewise, the Export Credit is also assumed to be capped by a ceiling of 85% of the total investment.
- The study also considers the Interest During Construction (IDC) as part of the total asset after the commissioning year.

Table 9-7 Loan Conditions for Candidate Loans

| | type | interest rate | currency | maturity year | grace year | front end fee | reference |
|----------------------------------|------|---------------|----------|---------------|------------|---------------|-----------|
| Yen Loan | 1 | 1.00% | JPY | 30 | 10 | 0.20% | up to 85% |
| AfDB/(WB) loan (AfDB FSL USD) | 2 | 1.855% | USD | 20 | 5 | 0.25% | up to 85% |
| JBIC ECA USD | 3 | 3.78% | USD | 10 | 0 | 12.88% | |

The total loan amount up to 2040 is 22,120 million USD. The interest, front-end fee, and repayment of principal respectively come to 2,963 million USD, 674 million USD, and 3,936 million USD.

Table 9-8 Borrowings up to 2040 and Financial Expenses

| (unit: mil. \$) | | | | | | | | | | | | | | |
|-----------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
| loan amount | 1137 | 1878 | 1743 | 2333 | 1826 | 1818 | 1587 | 1222 | 946 | 659 | 794 | 941 | 948 | 947 |
| interest | 0 | 28 | 54 | 84 | 103 | 120 | 132 | 141 | 148 | 151 | 156 | 163 | 170 | 177 |
| f-end fee | 0 | 52 | 55 | 56 | 32 | 23 | 16 | 20 | 23 | 24 | 28 | 31 | 33 | 34 |
| principal | 0 | 38 | 79 | 119 | 141 | 156 | 167 | 180 | 197 | 215 | 236 | 296 | 346 | 428 |
| total | 0 | 118 | 187 | 260 | 276 | 298 | 315 | 341 | 367 | 390 | 420 | 489 | 549 | 639 |

| (unit: mil. \$) | | | | | | | | | | | |
|-----------------|------|------|------|------|------|------|------|------|------|------|---------------|
| | 2031 | 2032 | 2033 | 2034 | 2035 | 2036 | 2037 | 2038 | 2039 | 2040 | total |
| loan amount | 859 | 844 | 702 | 609 | 363 | 379 | 238 | 118 | 58 | 652 | 23,601 |
| interest | 109 | 124 | 135 | 145 | 149 | 154 | 155 | 152 | 147 | 140 | 3,035 |
| f-end fee | 30 | 45 | 32 | 38 | 26 | 34 | 22 | 15 | 7 | 0 | 676 |
| principal | 28 | 61 | 86 | 114 | 135 | 161 | 178 | 190 | 195 | 195 | 3,941 |
| total | 166 | 230 | 253 | 297 | 310 | 349 | 355 | 357 | 350 | 335 | 7,653 |




Figure 9-2 Borrowings up to 2040 and Financial Expenses

(4) Presumptions for O&M expense and depreciation

The presumptions after commissioning are as follows.

- New facilities are commissioned on the 1st of January of the commissioning year. Construction of transmission lines to be connected to newly constructed power plant will be completed one year in advance of the commissioning year of the power plant.
- Annual depreciation is calculated by the straight-line method. The residual value is zero.
- The O&M expense for a power plant, a transmission line, and a sub-station is to be calculated based on a certain percentage of the newly constructed asset. The O&M expense for a thermal power plant consists of the O&M expense and cost of fuel consumed at the power plant. The O&M expense for renewable power (wind power and solar power) includes no cost for plant construction, as construction is left to other parties. PRODEL is assumed to purchase power from other parties with a pre-determined power tariff.
- Interest during construction (IDC) is counted as a part of an asset after commissioning. Depreciation and the O&M expense are based on the abovementioned asset.

Table 9-9 Details on Depreciation and IDC

| | project period | O&M cost (%) | IDC (%) /100mil.\$ | construction period (years) |
|----------------------|----------------|--------------|--------------------|-----------------------------|
| Hydro (Large) | 40 | 1 | 4.6 | 8 |
| TPP 1 (CC) | 25 | 3 | 10.41 | 4 |
| TPP 2 (Gas) | 20 | 5 | 11.51 | 5 |
| Renewable (wind) | 20 | — | — | 3 |
| Renewable (solar) | 20 | — | — | 3 |
| Transmission (220kV) | 40 | 2 | 2.42 | 4 |
| Transmission (400kV) | 40 | 2 | 2.42 | 4 |
| Sub-station (220kV) | 40 | 2 | 2.42 | 4 |
| Sub-station (400kV) | 40 | 2 | 2.42 | 4 |

9.3.2 Long-Run Marginal Cost (LRMC)

(1) Calculation of the Long-Run Marginal Cost (LRMC)

The JICA Survey Team hereby calculates a long-run marginal cost (LRMC) in accordance with the ‘*Internal Rate of Return (IRR) Manual for Yen Loan Projects*’ (JBIC). LRMC is calculated as follows.

$$\text{Long Run Marginal Cost (LRMC)} = \text{total project cost} \times \text{capital recovery factor} + \text{O\&M expenses}$$

$$\text{capital recovery factor} = r \div (1 - (1+r)^{-n})$$

r : 10%

n : durable years (hydropower, 40 years; thermal power, 25 years (CCGT) and 20 years (GT))

O&M expense = O&M expense + fuel cost (thermal)

O&M expense: calculated for a certain percent of the total construction cost

Fuel cost: annual fuel cost for thermal power plants

(2) The Total Investment Cost and LRMC for Generation, Transmission, and Sub-station

The total Investment Cost and unit cost per kWh shown below indicate the LRMC of the long-term investment plan. The unit cost may vary, but generally stays near 5-6 cents per kWh.




Figure 9-3 Total Annual Cost and Unit Cost for Generation

annual construction cost and unit cost for transmission lines and sub-stations are shown below. Unlike the thermal power plants, the transmission lines and sub-stations have fixed costs (e.g. construction and O&M costs) but no variable costs (e.g., fuel costs). The annual construction cost and unit cost for transmission lines and sub-stations are as follows. The unit cost peaks (1.5 cents/kWh) in 2027 and then falls to 0.8 cents/kWh in ensuing years.




Figure 9-4 Total Annual Cost and Unit Cost for Transmission and Sub-station

(3) Review on the Proper Tariff

From here we review how much the incremental cost will rise based on the investment and O&M cost up to 2040, as well as the repayment schedule. (*)The cost consists of the construction cost, O&M cost, and depreciation. Thermal power plants bear fuel costs, as well. The payment of the interest, principal, and IDC will be considered after borrowings.

*: Actual construction cost for each year may fluctuate, depending on the construction schedule and repayment schedules. For this study, however, we adjust the annual cost for each candidate project to an equal level by applying the capital recovery factor.

The results are as follows. The unit price for generation will reach 8.5 cents USD at maximum, while the unit price for transmission and substation will reach 2 cents USD.

Table 9-10 Annual Unit Incremental Cost for Generation (hydro and thermal)

| | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
|-----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| incremental cost /kWh | 0.002 | 0.003 | 0.003 | 0.006 | 0.006 | 0.013 | 0.016 | 0.015 | 0.019 | 0.018 | 0.022 | 0.021 | 0.020 | 0.019 |

| type | 2031 | 2032 | 2033 | 2034 | 2035 | 2036 | 2037 | 2038 | 2039 | 2040 | total |
|-----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| incremental cost /kWh | 0.018 | 0.018 | 0.017 | 0.016 | 0.015 | 0.014 | 0.014 | 0.013 | 0.013 | 0.012 | = |




Figure 9-5 Annual Unit Incremental Cost for Generation

Table 9-11 Annual Unit Incremental Cost for Transmission and Sub-station

| | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
|-------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| incremental cost \$/kWh | 0.002 | 0.003 | 0.003 | 0.006 | 0.006 | 0.013 | 0.016 | 0.015 | 0.019 | 0.018 | 0.022 | 0.021 | 0.020 | 0.019 |

| type | 2031 | 2032 | 2033 | 2034 | 2035 | 2036 | 2037 | 2038 | 2039 | 2040 | total |
|-----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| incremental cost /kWh | 0.018 | 0.018 | 0.017 | 0.016 | 0.015 | 0.014 | 0.014 | 0.013 | 0.013 | 0.012 | = |




Figure 9-6 Annual Unit Incremental Cost for Transmission and Sub-station

From here we review the current unit revenue prices for PRODEL and RNT to cover the incremental cost as well as the existing cost.

The unit cost for PRODEL in 2016 is 19.86 AOA/kWh, which equals 0.09 \$/kWh. The unit cost for RNT in 2016 is 8.15 AOA/kWh, which equals 0.037 \$/kWh.

A guest attending the workshop in 2018 pointed out that PRODEL did not debit the fuel cost. With this factored in, the total cost for PRODEL in 2016 seems to be smaller, as its unit price cost is also smaller than the real unit price cost, reflecting the missing fuel cost. (※)

※A guest attending the workshop held in January 2018 pointed out that PRODEL did not debit the fuel cost in its P/L. The JICA Study Team interpreted this as an indication that PRODEL did not count the fuel cost because it receives the fuel for free. Meanwhile, the JICA Study Team found amounts of 25,152 AOA listed under ‘fuel cost’ in the ‘Other Costs’ component of PRODEL’s P/L in 2016. This guest must have meant that the fuel was consumed by offices and buildings for administration activities, not by thermal power plants for generation.

Table 9-12 Unit Revenue Price/kWh and Unit Cost Price/kWh

| | | (AOA, AOA/kWh) |
|--|-------------------|------------------|
| | 2016 | 2015 |
| PRODEL | | |
| sales (kWh) | 10,929,810,809.00 | 6,308,876,489.00 |
| @revenue unit price /kWh | 20.17 | 18.49 |
| @cost unit price /kWh | 19.74 | 20.10 |
| R N T | | |
| sales (kWh) | 9,348,186,285.76 | 6,136,127,637.00 |
| @revenue unit price /kWh | 9.34 | 8.93 |
| @cost unit price /kWh | 8.45 | 7.39 |
| ENDE | | |
| sales (kWh) | 9,348,186,285.76 | 5,829,423,620.07 |
| @revenue unit price /kWh | 13.59 | 12.19 |
| @revenue unit price (without subsidy) /kWh | 6.27 | 3.78 |
| @cost unit price /kWh | 13.28 | 13.39 |

(Source: JICA Survey Team)

Meanwhile, the unit revenue price (generation) derived from the long-term investment is 18.3 AOA, and the total unit cost consisting of the current unit cost and long-term investment cost will be 38.19 AOA, or 0.177 \$. Likewise, the unit revenue price (transmission) derived from the long-term investment is 4.3 AOA, and the total unit cost consisting of the current unit cost and long-term investment cost will be 12.45 AOA, or 0.57 \$/kWh. (conversion rate: \$1=215.064 AOA (T.T.M))

These figures indicate that the unit cost price for PRODEL needs to increase by 15 AOA, starting from the current 23.11 AOA. Likewise for RNT, the unit cost price needs to increase by 3.59 AOA, starting from the current 8.86 AOA.

Table 9-13 Unit Prices and Unit Incremental Costs

| | PRODEL | RNT |
|--|------------------------------------|-------------------------------------|
| 1. unit revenue price in 2016 | @0.09 \$ /kWh (=@20.17 AOA/kWh) | @0.043 \$ /kWh (=@9.34 AOA/kWh) |
| 2. unit cost price in 2016 | @0.09\$ /kWh (=@19.74 AOA/kWh) | @0.039 \$ / kWh (=@8.45 AOA/kWh) |
| 3. incremental cost based on the long-term investment | @0.085\$/ kWh (=@18.3 AOA/kWh) | @0.02\$/ kWh (=@4.3 AOA/kWh) |
| 4.. Total cost (2+3) | @0.175 \$/kWh (=@38.04AOA/kWh) | @ 0.059 \$/kWh (=@12.75 AOA/kWh) |
| 5. increase of tariff (unit cost of investment / current unit cost) | 17.9 AOA (1.92) | 3.41 AOA (1.51) |

※USD is converted using the official exchange rate of Nacional Banco de Angola as of March 12, 2018 (\$1=215.064 AOA (T.T.M))

Following is a summary of the current power tariffs (announced in the national gazette as of December 2015). ENDE collects the sales revenue with these tariffs.

Table 9-14 Summary of Power Tariffs as of December 2015

| voltage | type | reference | calculation formula |
|-----------------------|------------------------------|--|---|
| <u>Low Voltage</u> | Domestic | contracted power: 1.3 kVA contracted power: 3.0 kVA | ~120kWh : @2.46 AOA/kWh ~200kWh : @3.00 AOA/kWh |
| | Public lighting | supplied less than 1KV | $T = (1.80 \times d + 4.73 \times W)$ AOA |
| | General and Special Domestic | contracted power: 3.0 kVA~9.9 kVA | Single phase : $T = (3.10 \times d \times pc + 6.53 \times W)$ AOA Three phase : $T = (4.20 \times d \times pc + 7.05 \times W)$ AOA |
| | Commercial and Industry | commercial: industry: | $T = (4.20 \times d \times pc + 7.05 \times W)$ AOA $T = (4.20 \times d \times pc + 7.053 \times W)$ AOA |
| <u>Middle Voltage</u> | Commercial and Industry | voltage: less than 30 kV | $T = (538.93 \times P + 5.88 \times W)$ AOA |
| | | voltage: more than 30 kV | $T = (538.93 \times P + 5.13 \times W)$ AOA |
| <u>High Voltage</u> | Industry and Distributors | industry: more than 30 kV | $T = (598.36 \times P + 4.70 \times W)$ AOA |
| | | distributor: more than 30 kV | $T = (598.36 \times P + 4.70 \times W)$ AOA |

d : days passed after issuance of the bill

pc : contracted power (kVA)

P : maximum power (KW) recorded at 15-minute meter

W : power (kWh) consumed

T : sales calculated with the formula (AOA)

The characteristics are as follows:

- Domestic in Low Voltage (contracted power: up to 3.0 kVA) is based on a gradual increase of prices. Consumed power per kWh is divided into two stages: up to 120 kWh and 120 kWh to 200 kWh. The unit price goes up from 2.46 AOA /kWh to 3.0 AOA /kWh.
- The unit price for General and Special Domestic (contracted power: more than 3.0 kVA) is double that of Domestic in Low Voltage (contracted power: up to 3.0 kVA). The calculation assumes that the amount the customer pays rises as the customer uses more power. The customer also has to pay more when the customer takes more days to pay the electricity bill.
- The formula for Commerce and Industry in Middle Voltage and in High Voltage considers the number of days (d) passed. The bill gets bigger as more days pass.
- Sales of Commerce and Industry in Middle Voltage and in High Voltage do not increase in proportion to the number of days (d). Rather, the figure increases with P (the maximum power (KW)) and W (power (kWh) consumed).
- The current level of tariff per kWh is around 7 AOA, while the unit cost price calculated with the accounting figures of ENDE is 13.28 AOA. The unit cost price calculated with the accounting figures of ENDE is double that of the current tariff. This reflects the national policy not to impose a high tariff on Angolan nationals, and to compensate the loss with subsidies.
- The tariff of ENDE shall generally include all costs of PRODEL and RNT, and the investment- related costs of the long-term investment plan is to be added to the existing costs for distribution. In line with this approach, the incremental cost of the long-term investment is 0.232 \$ (=50.64 AOA). In this sense, decision-making on the subsidy shall be separated from the calculation of the necessary revenue and cost.

※Table 9-13 The incremental unit cost of the long-term investment consists of one component coming from PRODEL and one component coming from RNT.

$$@0.175 \$ /kWh + @ 0.057 \$ /kWh = @0.232 \$ /kWh$$

When expressed in AOA,

$$@38.19 \text{ AOA} /kWh + @ 12.45 \text{ AOA} /kWh = @50.64 \text{ AOA} /kWh$$

9.3.3 Recommendations on the Optimal Financial Strategy

(1) Recommendations

(a) Price Hike

As stated in the section 9.3.2, the unit cost caused by the investment up to 2040 is estimated at 0.175\$ for generation and 0.057\$ for transmission and sub-station. These estimates imply that the tariff must be raised to meet the increasing cost.

(b) Review of the candidate loans

Considering the current financial condition of PRODEL and RNT, it will be difficult for both to go on investing solely with their own retrained earnings. The study therefore assumes that both will depend on borrowing, and explains the candidate loan conditions available. Note, meanwhile, that some loans will need government guarantees and data on the project cycles and time by which the loans must be received.

(c) Proper Equity Ratio

If the agency implementing the project goes on borrowing, the equity ratio will decrease. A decreasing equity ratio would be unfavorable from a financial viewpoint, as it would increase the default risk. In this case, equity must be injected at the proper time. A 20-30% of equity ratio is generally favorable, though there seems to be no standard for a proper equity ratio in the power sector.

The table below shows the total assets, total equity, and equity ratios for PRODEL and RNT in 2016. The equity ratios for PRODEL and RNT were higher than 40% in 2016, which would be. If both companies go on investing solely with borrowing, their equity ratios will decrease: PRODEL (47.0%→3.8%) and RNT (41.1%→5.3%).

Table 9-15 Equity Ratios with Long-term Investment

| accounting data in 2016 (equity ratio) | total investment up to 2040 | total asset + total investment (equity ratio) |
|--|--------------------------------|--|
| <u>PRODEL</u> total asset: 2,838 million \$ (47.0%) | 26,262 million \$ | 29.100 million \$ (4.6%) |
| <u>RNT</u> total asset: 1,150 million \$ (41.1%) | 6,187 million \$ | 7,337 million \$ (6.4%) |

(2) **Conclusion**

(a) Price Hike

The key implementing agencies in the Power Sector of Angola are PRODEL (generation), RNT (transmission and sub-station), and ENDE (distribution). ENDE receives a subsidy, which helps to lessen the financial burden for Angolan nationals.

The long-term investment plan consists of the generation development plan and transmission and the sub-station development plan. The plan requires increases in the unit revenue prices for PRODEL and for RNT, while direct tariff increases will not necessarily be required for ENDE. Revenue and expenditure will have to be calculated in each sector, but this might not lead to a higher tariff. This calculation of revenue and expenditure will be necessary even if a subsidy is provided to the distribution sector.

(b) Decision of the borrowings

As each financial institution has its own project-formation cycle and appraisal procedure, the implementation agency will select the financial institutions that are to be requested to provide loans. Taking the example of a project-formation cycle of JICA, the implementation agency may also request a grant to complete an Implementation Report (I/P) in the process of a project cycle.

If the candidate project needs a guarantee from the Government, the implementation agency has to pass through a step-by-step approval process within the Government. This implies that the Government of Angola sets up an official approval procedure internally.

(c) Maintain a Proper Equity Ratio

Compulsive injection of equity to a new project would be useful to maintain a certain equity ratio. An implementing agency for a new power project in India, for example, is requested to raise funds with a ratio of 70% (borrowing) and 30% (equity). In India, either the Central Government or the State Government provides equity to the implementing agency out of the budget or the long-term borrowing.

In fact, both the Central Government and the State Government in India are suffering from a red-ink budget and would be hard-pressed to provide equity from the start. The Government often provides funds to the implementing agency as long-term borrowing at the beginning but waives the liability if the implementing agency meets certain conditions. Thus, the implementing agency is finally able to keep a certain equity ratio by changing the status of the long-term liability into equity in future. (*)

*: India's '*Accounting for Government Grants and Disclosure of Government Assistance*' Accounting Standard (IND AS20) defines a forgivable loan. This standard allows the Government, the lender of the loan, to waive repayment under certain prescribed conditions. In this context, a certain prescribed condition would be one that allowed the borrower of the loan to complete the construction on schedule. Important conditions for the implementing agency are a possible future cancellation of the borrowing at the beginning and the ability to convert the liability into equity.

Chapter 10 Economic and Financial Analysis

10.1 Financial Analysis of RNT • PRODEL • ENDE

The JICA Survey Team received financial statements for RNT, PRODEL, and ENDE. While the financial statements in 2015 and in 2014 are now available for all three companies, the Profit and Loss Statement for ENDE is only available in 2017 (January to June). To keep consistency among the three companies, the JICA Survey Team only analyzes the statements of 2015 and 2014.

Two types of the financial statements are prepared: the first in the national currency (AOA) and the other in USD converted at the official rate as of 25 April, 2018. (\$1= 270.68 AOA)

10.1.1 RNT

(1) Financial Analysis of RNT

The financial statements of RNT report figures in units of 1000 AOA.

(a) P/L

Operating Income in 2016 consisted of Sales (82,297 million AOA), other operating income (4,489 million AOA), and other. The main component of Costs in 2016 was the cost of goods (67,206 million AOA). Gross profit totaled 8,293 million AOA after deducting financial costs (-859 million AOA) and Corporate income tax (2,145 million AOA). Finally, RNT posted net profit 4,381 million AOA for the Year (2016).

Table 10-1 Profit and Loss Statement (P/L)

| | unit: 1000 AOA | | | (unit: 1000 USD) | |
|---|-------------------|-------------------|---|------------------|----------------|
| | 2016 | 2015 | | 2016 | 2015 |
| Operating Incomes | 87,297,665 | 54,811,737 | Operating Incomes | 322,598 | 202,550 |
| Sales | 82,791,700 | 51,450,377 | Sales | 305,947 | 190,129 |
| Provision of service | 16,760 | 22,478 | Provision of service | 62 | 83 |
| Other operating profits | 4,489,205 | 3,338,882 | Other operating profits | 16,589 | 12,338 |
| Operating Costs | 79,004,626 | 45,341,594 | Operating Costs | 291,952 | 167,555 |
| Changes in inventories of finished goods and work in progress | 0 | 0 | Changes in inventories of finished goods and work in progress | 0 | 0 |
| Works capitalized | 0 | 0 | Works capitalized | 0 | 0 |
| Cost of goods sold and the materials consumed | 67,206,922 | 37,787,871 | Cost of goods sold and the materials consumed | 248,355 | 139,641 |
| Personnel costs | 4,391,321 | 3,127,136 | Personnel costs | 16,228 | 11,556 |
| Amortizations | 4,614,278 | 3,392,712 | Amortizations | 17,052 | 12,537 |
| Other operationa costs and loss | 2,792,105 | 1,033,875 | Other operationa costs and loss | 10,318 | 3,821 |
| Gross Profit | 8,293,039 | 9,470,143 | Gross Profit | 30,646 | 34,996 |
| Financial costs | -859,334 | -1,463,938 | Financial costs | -3,176 | -5,410 |
| Subsidies and affiliate company results | 0 | 0 | Subsidies and affiliate company results | 0 | 0 |
| Non-operating costs / income | -906,109 | -579,007 | Non-operating costs / income | -3,348 | -2,140 |
| Profit before Tax | 6,527,596 | 7,427,198 | Profit before tax | 24,122 | 27,446 |
| Corporate income tax | 2,145,834 | 2,228,159 | Corporate income tax | 7,930 | 8,234 |
| Net Profit | 4,381,762 | 5,199,039 | Net result from ordinary activities | | |
| Extraordinary results | 0 | 0 | Extraordinary results | 0 | 0 |
| Corporate income tax | 0 | 0 | Corporate income tax | 0 | 0 |
| Net Profit of the Year | 4,381,762 | 5,199,039 | Net profit of the year | 16,192 | 19,212 |

Table 10-2 Balance Sheet (B/S)

| | 2016 | unit: 1000 AOA 2015 | | 2016 | (unit: 1000 USD) 2015 |
|--|--------------------|------------------------|--|----------------|--------------------------|
| ASSETS | | | ASSETS | | |
| Non Current Asset | 134,179,383 | 125,647,314 | Non current asset | 495,844 | 464,315 |
| Tangible fixed assets | 134,178,838 | 125,646,596 | Tangible fixed assets | 495,842 | 464,312 |
| Intangible fixed assets | 545 | 718 | Intangible fixed assets | 2 | 3 |
| Investments in subsidiaries and associates | 0 | 0 | Investments in subsidiaries and associates | 0 | 0 |
| Other financial assets | 0 | 0 | Other financial assets | 0 | 0 |
| Other non-current Assets | 0 | 0 | Other non-current Assets | 0 | 0 |
| Current Asset | 113,274,311 | 62,235,637 | Current Asset | 418,592 | 229,985 |
| cash | 68,243 | 203,990 | cash | 252 | 754 |
| Accounts receivable | 101,955,502 | 53,566,640 | Accounts receivable | 376,765 | 197,949 |
| cash and bank deposits | 7,805,495 | 5,476,676 | cash and bank deposits | 28,844 | 20,238 |
| Other current assets | 3,445,071 | 2,988,381 | Other current assets | 12,731 | 11,043 |
| TOTAL ASSETS | 247,453,694 | 187,883,001 | TOTAL ASSETS | 914,436 | 694,300 |
| EQUITY AND LIABILITY | | | EQUITY AND LIABILITY | | |
| Equity | 101,884,053 | 102,548,357 | Equity | 376,501 | 378,955 |
| Equity | | | Equity | 0 | 0 |
| Capital | 11,579,155 | 11,579,155 | Capital | 42,789 | 42,789 |
| Reserves | 81,182,631 | 86,228,695 | Reserves | 300,001 | 318,648 |
| Retained earnings | 4,740,507 | -458,532 | Retained earnings | 17,518 | -1,694 |
| Net profit for the year | 4,381,760 | 5,199,089 | Net profit for the year | 16,192 | 19,212 |
| Total Equity | 101,884,053 | 102,548,357 | Total Equity | 376,501 | 378,955 |
| Non-current Liability | 14,616,216 | 16,851,862 | Non-current Liability | 54,013 | 62,274 |
| Medium and long-term loan | 0 | 0 | Medium and long-term loan | 0 | 0 |
| Deferred taxes | 0 | 0 | Deferred taxes | 0 | 0 |
| Provisions for pensions | 0 | 0 | Provisions for pensions | 0 | 0 |
| Provisions for other risks | 0 | 0 | Provisions for other risks | 0 | 0 |
| Other Non-liquid liability | 14,616,216 | 16,851,862 | Other Non-liquid liability | 54,013 | 62,274 |
| Current Liability | 130,953,425 | 68,482,782 | Current Liability | 483,923 | 253,070 |
| Accounts payable | 123,646,573 | 66,368,651 | Accounts payable | 456,921 | 245,258 |
| Short-term loan | 4,832,965 | 0 | Short-term loan | 17,860 | 0 |
| Current part of medium and long-term loans | 0 | 0 | Current part of medium and long-term loans | 0 | 0 |
| Other current liability | 2,473,887 | 2,114,131 | Other current liability | 9,142 | 7,813 |
| Total Liabilities | 145,569,641 | 85,334,644 | Total Liabilities | 537,935 | 315,344 |
| TOTAL EQUITY AND LIABILITY | 247,453,694 | 187,883,001 | TOTAL EQUITY AND LIABILITY | 914,436 | 694,300 |

(b) B/S

Tangible assets in 2016 (134,178 million AOA) were the biggest component of non-current assets. Accounts payable in 2016 were the biggest component of current assets (101,955 million AOA), exceeding operating income for the year.

(c) C/F

Cash Flow from Operating Activities in 2016 was 446 million AOA, although RNT paid 18,881 million AOA to extraordinary items. Cash Flow from Investment in 2016 went into the red due to investment in subsidies and payment to tangible fixed assets. Meanwhile, RNT borrowed a loan of 4,649 million AOA, as net cash for the year was 2,328 million AOA. Finally, cash and cash equivalents at the end of that year totaled 7,805 million AOA.

Table 10-3 Cash Flow Statement (C/F)

| | (unit: 1000 AOA) | | | (unit: 1000 USD) | |
|--|--------------------|--------------------|--|------------------|----------------|
| | 2016 | 2015 | | 2016 | 2015 |
| Cash Flow from Operational Activities | | | Cash Flow from Operational Activities | | |
| Receipt from customers | 26,038,515 | 1,709,371 | Receipt from customers | 96,222 | 6,317 |
| Payments to suppliers | 46,224,491 | 1,121,398 | Payments to suppliers | 170,817 | 4,144 |
| Payment to employees | 0 | 1,572,087 | Payment to employees | 0 | 5,809 |
| Cash flow from operation | -20,185,976 | -984,114 | Cash flow from operation | -74,595 | -3,637 |
| Other receipts related to operational activities | | 39,916 | Other receipts related to operational activities | 0 | 148 |
| Interest paid | 1,750,305 | | Interest paid | 6,468 | 0 |
| Cash Flow from Extraordinary items | -18,435,671 | -944,198 | Cash Flow from Extraordinary items | -68,127 | -3,489 |
| Payments with extraordinary items | 18,881,692 | 10,430,988 | Payments with extraordinary items | 69,775 | 38,546 |
| Cash Flow from Operating activities | 446,021 | -11,375,186 | Cash Flow from Operating activities | 1,648 | -42,036 |
| Cash Flow from Investment Activities | | | Cash Flow from Investment Activities | | |
| Receipt from: | | | Receipt from: | | |
| Tangible fixed assets | | | Tangible fixed assets | | |
| Intangible fixed assets | 0 | | Intangible fixed assets | 0 | 0 |
| Financial investment | | | Financial investment | | |
| Investment to subsidy | 2,235,645 | 20,188,370 | Investment to subsidy | 8,262 | 74,604 |
| Interest and similar income | | | Interest and similar income | | |
| Dividends | | | Dividends | | |
| Total receipts | 2,235,645 | 20,188,370 | Total receipts | 8,262 | 74,604 |
| Payment to: | | | Payment to: | | |
| Tangible fixed assets | 4,448,443 | | Tangible fixed assets | 16,439 | |
| Intangible fixed assets | 0 | | Intangible fixed assets | 0 | |
| Financial investment | | | Financial investment | | |
| Subsidy to investment | | 3,336,508 | Subsidy to investment | | 12,330 |
| Total payment | 4,448,443 | 3,336,508 | Total payment | 16,439 | 12,330 |
| Cash Flow before Extraordinary | -2,212,798 | 16,851,862 | Cash Flow before Extraordinary | -8,177 | 62,274 |
| Cash Flow from Financial Activities | | | Cash Flow from Financial Activities | | |
| Receipts from: | | 10,241,186 | Receipts from: | | 37,845 |
| Capital increase, supplementary payments and own share sales | | | Capital increase, supplementary payments and own share sales | | |
| Damage coverage | | | Damage coverage | | |
| Loan obtained | 4,649,741 | | Loan obtained | 17,183 | |
| Subsidy and donations | | | Subsidy and donations | | |
| Total receipts | 4,649,741 | 0 | Total receipts | 17,183 | 0 |
| Payment to: | | 0 | Payment to: | | 0 |
| Capital decrease, supplementary provisions | | | Capital decrease, supplementary provisions | | |
| Purchase of shares | | | Purchase of shares | | |
| Loan obtained | | | Loan obtained | | |
| Depreciation of leasing contracts | | | Depreciation of leasing contracts | | |
| Interest and similar interest | 554,144 | | Interest and similar interest | 2,048 | |
| Total payment | 554,144 | | Total payment | 2,048 | |
| Cash Flow from Financial Activities | 4,095,597 | 0 | Cash Flow from Financial Activities | 15,135 | 0 |
| Net Cash Increase and its | 2,328,819 | 5,476,676 | Net Cash Increase and its Equivalents | 8,606 | 20,238 |
| Cash and its Equivalents at the Beginning of the Year | 5,476,676 | 0 | Cash and its Equivalents at the Beginning of the Year | 20,238 | 0 |
| Cash and its Equivalents at the End of the Year | 7,805,495 | 5,476,676 | Cash and its Equivalents at the End of the Year | 28,844 | 20,238 |

(d) Conclusion

The major financial ratios were as follows.

The net profit margin in 2016 was 5.0 %, which was quite good. Return on Assets (ROA) in 2016 was quite small, falling to 1.8%, because accounts receivables were quite big compared to operating income. The current ratio, an indicator of financial stability, was 0.82, which was less than 1.0. The average collection (days) in 2016 was 426 days because the outstanding accounts receivables were bigger than operating income.

Table 10-4 Major financial ratios

| | 2016 | 2015 |
|---------------------------|------|------|
| net profit margin | 5.0% | 9.5% |
| return on assets (ROA) | 1.8% | 2.8% |
| current ratio | 0.86 | 0.91 |
| asset turnover | 0.35 | 0.29 |
| average collection (days) | 426 | 357 |

10.1.2 PRODEL

The financial statements of PRODEL report figures in units of 1000 AOA.

(a) P/L

The major component of operating income in 2016 was sales (42,255 million AOA). Other operating income consisted of subsidies (178,182 million AOA). More than 70% of the operating costs were costs of goods (164,235 million AOA). Gross profit was positive, though subsidies and affiliates and corporate income tax followed. Net profit for the Year in 2016 was 1,862 million AOA.

One guest attending the workshop held in January 2018 pointed out that PRODEL did not debit the fuel cost on its financial statement. The JICA Study Team found that PRODEL's Financial Statement in 2016 debited 25,152,000 AOA of fuel cost as 'Other Costs.' This guest must have meant that PRODEL consumed the fuel for administrative purposes in offices or buildings.

Table 10-5 Profit and Loss Statement (P/L)

| | unit: 1000 AOA | | | (unit: 1000 USD) | |
|---|--------------------|--------------------|---|------------------|-------------------|
| | 2016 | 2015 | | 2016 | 2015 |
| Operating Incomes | 220,420,796 | 116,631,357 | Operating Incomes | 814,539 | 430,997 |
| Sales | 42,238,471 | 25,655,726 | Sales | 156,087 | 94,808 |
| Services rendered | 0 | 0 | Provision of service | 0 | 0 |
| Other operating profits | 178,182,325 | 90,975,631 | Other operating profits | 658,452 | 336,190 |
| Operating Costs | 215,757,239 | 126,819,841 | Operating Costs | 645,351 | 389,741 |
| Changes in inventories of finished goods and work in progress | 0 | 0 | Variation in the finished product and in the process of manufacturing | | |
| Works capitalized | 0 | 0 | Work for the company itself | 0 | 0 |
| Cost of goods sold and the materials consumed | 164,235,499 | 98,320,782 | Cost of goods sold and the raw materials and supplies consumed | 606,913 | 363,333 |
| Personnel costs | 10,401,554 | 7,146,216 | Personnel costs | 38,438 | 26,408 |
| Amortizations | 15,055,711 | 11,246,853 | Amortizations | | |
| Other costs and operating Loss | 26,064,475 | 10,105,990 | Other costs and Operating Loss | | |
| Gross Profit | 4,663,557 | -10,188,484 | Gross Profit | 17,233.63 | -37,650.34 |
| Financial results | 1,297,742 | -431,536 | Financial results | 4,796 | -1,595 |
| Subsidies and affiliate company results | -192,245 | 0 | Results from Subsidiaries and associated companies | | |
| Non-operating costs / income | 66,470 | -83,047 | Non-operating results | | |
| Profit before tax | 5,835,524 | -10,703,067 | Profit before tax | 21,564 | -39,552 |
| Corporate income tax | 0 | 0 | Taxes on income | | |
| Net result from ordinary activities | 5,835,524 | -10,703,067 | Net result from ordinary activities | | |
| Extraordinary results | 0 | 11,033,610 | Extraordinary results | | |
| Corporate income tax | -3,972,868 | -99,357 | Taxes on income | | |
| Net profit of the year | 1,862,656 | 231,186 | Net profit of the year | 6,883.23 | 854.32 |

Table 10-6 Balance Sheet (B/S)

| | unit: 1000 AOA | |
|--|--------------------|--------------------|
| | 2016 | 2015 |
| ASSETS | | |
| Non current assets | 417,084,219 | 415,089,591 |
| Tangible fixed assets | 416,818,944 | 414,632,071 |
| Intangible fixed assets | 0 | 0 |
| Investments in subsidiaries and associates | 265,275 | 457,520 |
| Other Financial Assets | 0 | 0 |
| Other non-liquid Assets | 0 | 0 |
| Current Asset | 193,269,597 | 61,714,599 |
| Cash | 253,823 | 108,125 |
| Accounts receivable | 55,128,687 | 30,760,705 |
| cash and bank deposits | 17,870,497 | 26,635,522 |
| Other current assets | 120,016,590 | 4,210,247 |
| TOTAL ASSET | 610,353,816 | 476,804,190 |
| EQUITY AND LIABILITY | | |
| Equity | 286,949,652 | 309,013,298 |
| Share capital | 233,910,935 | 233,910,935 |
| Reserves | 45,095,506 | 75,761,981 |
| Retained earnings | 6,080,555 | -890,804 |
| Result o travel | 1,862,656 | 231,186 |
| Results for the year | 286,949,652 | 309,013,298 |
| Total Equity | 286,949,652 | 309,013,298 |
| Non-current liabilities | 3,000,000 | 3,000,000 |
| Medium and long-term loan | 3,000,000 | 3,000,000 |
| Deferred taxes | | |
| Provisions for pensions | | |
| Provisions for other risks | | |
| Other non-liquid liability | | |
| Current liabilities | 320,404,164 | 164,790,893 |
| Accounts payables | 311,917,639 | 149,893,665 |
| Short-term loan | 5,046,446 | 7,241,186 |
| Current part of medium and long-term loans | 3,000,000 | 0 |
| Other current liability | 440,079 | 7,656,042 |
| Total Liability | 323,404,164 | 167,790,893 |
| Total EQUITY AND LIABILITY | 610,353,816 | 476,804,191 |

| | (unit: 1000 USD) | |
|--|------------------|------------------|
| | 2016 | 2015 |
| ASSETS | | |
| Non current assets | 1,541,286 | 1,533,915 |
| Tangible fixed assets | 1,540,305 | 1,532,224 |
| Intangible fixed assets | 0 | 0 |
| Investments in subsidiaries and associates | 980 | 1,691 |
| Other Financial Assets | 0 | 0 |
| Other non-liquid Assets | 0 | 0 |
| Current Asset | 714,205 | 228,059 |
| Cash | 938 | 400 |
| Accounts receivable | 203,722 | 113,673 |
| cash and bank deposits | 66,038 | 98,428 |
| Other current assets | 443,507 | 15,558 |
| TOTAL ASSET | 2,255,491 | 1,761,974 |
| EQUITY AND LIABILITY | | |
| Equity | 1,060,389 | 1,141,922 |
| Share capital | 864,390 | 864,390 |
| Reserves | 166,645 | 279,969 |
| Retained earnings | 22,470 | -3,292 |
| Result o travel | 6,883 | 854 |
| Results for the year | 1,060,389 | 1,141,922 |
| Total Equity | 1,060,389 | 1,141,922 |
| Non-current liabilities | 11,086 | 11,086 |
| Medium and long-term loan | 11,086 | 11,086 |
| Deferred taxes | | |
| Provisions for pensions | | |
| Provisions for other risks | | |
| Other non-liquid liability | | |
| Current liabilities | 1,184,016 | 608,965 |
| Accounts payables | 1,152,655 | 553,914 |
| Short-term loan | 18,649 | 26,759 |
| Current part of medium and long-term loans | 11,086 | 0 |
| Other current liability | 1,626 | 28,292 |
| Total Liability | 1,195,102 | 620,051 |
| Total EQUITY AND LIABILITY | 2,255,491 | 1,761,974 |

(b) B/S

Almost all of the non-current assets in 2016 were tangible assets (416,818 million AOA). Accounts payable in 2016 were 311,917 million AOA, exceeding accounts receivables. There was also a middle-term borrowing in 2016 (3,000 million AOA).

(c) C/F

Cash Flow from Operating Activities in 2106 went into the red (-69,075 million AOA) because payments to suppliers were much bigger than receipts and other incomes. Cash Flow from Investment Activities in 2016 was 49,988 million AOA because receipts from subsidy exceeded those to subsidy. Cash Flow from Financial Activities in 2016 mainly consisted of loans. (11,046 million AOA). Moreover, PRODEL received 151 million AOA as income from exchange rates.

As a result, net cash decreased -8,916 million AOA for the year and cash and cash equivalents at the end of the year totaled 17,870 million AOA.

Table 10-7 Cash Flow Statement (C/F)

| | unit: 1000 AOA | | | (unit: 1000 USD) | |
|--|---------------------|---------------------|--|------------------|-----------------|
| | 2016 | 2015 | | 2016 | 2015 |
| Cash Flow from Operational Activities | | | Cash Flow from Operational Activities | | |
| Receipt from customers | 12,516,975 | 2,052,676 | Receipt from customers | 46,255 | 7,585 |
| Payments to suppliers | -127,095,520 | -142,521,055 | Payments to suppliers | -469,667 | -526,670 |
| Payment to employees | -12,539,480 | -5,495,466 | Payment to employees | -46,338 | -20,308 |
| Cash flow from operation | -127,118,025 | -145,963,845 | Cash flow from operation | -469,750 | -539,392 |
| Other receipts related to operational activities | 58,042,079 | 104,933,775 | Other receipts related to operational activities | 214,488 | 387,770 |
| Cash Flow from Operating activities | -69,075,946 | -41,030,070 | Cash Flow from Operating activities | -255,262 | -151,622 |
| Payments with extraordinary items | 0 | 0 | Payments with extraordinary items | 0 | 0 |
| Total cash flow from operating | -69,075,946 | -41,030,070 | Total cash flow from operating | -255,262 | -151,622 |
| Cash Flow from Investment Activities | | | Cash Flow from Investment Activities | | |
| Receipts from subsidy | 75,736,210 | 62,150,986 | Receipts from subsidy | 279,874 | 229,672 |
| Investment to subsidy | -25,747,442 | -11,033,610 | Investment to subsidy | -95,147 | -40,773 |
| Cash Flow from Investing Activities | 49,988,768 | 51,117,376 | Cash Flow from Investing Activities | 184,728 | 188,898 |
| Cash Flow from Financial Activities | | | Cash Flow from Financial Activities | | |
| Receipts from loans | 11,046,446 | 10,241,186 | Receipts from loans | 40,821 | 37,845 |
| Payment to loans | -876,230 | 0 | Payment to loans | -3,238 | 0 |
| Cash Flow from Financial Activities | 10,170,216 | 10,241,186 | Cash Flow from Financial Activities | 37,583 | 37,845 |
| Net Cash Increase and its | -8,916,962 | 20,328,492 | Net Cash Increase and its Equivalents | -32,952 | 75,122 |
| Income / loss from exchange rates | 151,938.00 | 6,307,029.00 | Income / loss from exchange rates | 561 | 23,307 |
| Cash and its Equivalents at the Beginning of the Year | 26,635,522 | 0 | Cash and its Equivalents at the Beginning of the Year | 98,428 | 0 |
| Cash and its Equivalents at the End of the Year | 17,870,498 | 26,635,521 | Cash and its Equivalents at the End of the Year | 66,038 | 98,428 |

(d) Conclusion

The major financial ratios were as follows.

The net profit margin in 2016 was positive, albeit small (0.8%). Given the low net profit margin, Return on Assets (ROA) in 2016 was also small (0.6%). The current ratio, an indicator of financial stability, was 0.6, which was less than 1.0. The average collection (days) in 2016 was 91 days, which was quite good compared to the other two corporations.

Table 10-8 Major financial ratios

| | 2016 | 2015 |
|---------------------------|------|------|
| net profit margin | 0.8% | 0.2% |
| return on assets (ROA) | 0.6% | 0.1% |
| current ratio | 0.6 | 0.4 |
| asset turnover | 0.68 | 0.70 |
| average collection (days) | 91 | 96 |

10.1.3 ENDE

The financial statements of ENDE originally reported figures in units of AOA. To keep consistency with the statements of the other corporations (PRODEL and RNT), the financial statements are analyzed on a 1000 AOA basis.

(a) P/L

Major operating income in 2016 consisted of subsidies in process (68,414 million AOA), as well as electricity power sales (48,336 million AOA) and other. The biggest portion of operating costs was subsidized and consumed raw materials (82,436 million AOA), followed by personnel expenses (17,209 million AOA). Gross profit was positive, though ENDE incurred both financial loss (-7,024 million AOA) and non-operating loss (-12,193 million AOA). Finally, the net profit for the Year in 2016 was -16,318 million AOA.

Table 10-9 Profit and Loss Statement (P/L)

| | (unit: 1000 AoA) | | | (unit: 1000 USD) | |
|--------------------------------------|--------------------|--------------------|--------------------------------------|-------------------|-------------------|
| | 2016 | 2015 | | 2016 | 2015 |
| Operating Incomes | 127,058,787 | 71,032,092 | Operating Incomes | 469,530.79 | 262,490.73 |
| Electricity Power sales | 48,336,107 | 18,818,779 | Electricity Power sales | 178,620 | 69,543 |
| Subsidy on Prices | 68,414,297 | 49,009,948 | Subsidy on Prices | 252,817 | 181,110 |
| Provision of services | 8,782,110 | 2,097,476 | Provision of services | 32,453 | 7,751 |
| Other operating income | 1,526,272 | 1,105,888 | Other operating income | 5,640 | 4,087 |
| Operating Costs | 124,164,811 | 78,075,986 | Operating Costs | 458,836 | 288,521 |
| Costs of goods sold and materials | | | Costs of goods sold and materials | | |
| Susidized and consumed raw materials | 82,436,761 | 49,187,316 | Susidized and consumed raw materials | 304,635 | 181,766 |
| Personnel expences | 17,209,246 | 13,953,362 | Personnel expences | 63,595 | 51,563 |
| Amortizations | 8,769,867 | 6,115,252 | Amortizations | 32,408 | 22,598 |
| Other costs operating losses | 15,748,938 | 8,820,057 | Other costs operating losses | 58,198 | 32,593 |
| Gross Profit | 2,893,976 | -7,043,894 | Gross Profit | 10,694 | -26,029.88 |
| Financial income/ loss | -7,024,058 | -1,496,678 | Financial income/ loss | -25,957 | -5,531 |
| Non-operating income / loss | -12,193,406 | -14,234,891 | Non-operating income / loss | -45,059 | -52,603 |
| Profit before Tax | -16,323,488 | -22,775,464 | Profit before Tax | -60,322 | -84,164.04 |
| Income tax | 0 | 0 | Income tax | 0 | 0 |
| Profit after Tax | -16,323,488 | -22,775,464 | Profit after Tax | -60,322 | -84,164 |
| Extraordinary income/ loss | 4,536 | -27,877 | Extraordinary income/ loss | 17 | -103 |
| Net Profit | -16,318,952 | -22,803,341 | Net Profit | -60,304.77 | -84,267.06 |

Table 10-10 Balance Sheet (B/S)

| | (unit: 1000 AoA) | | | (unit: 1000 USD) | |
|---|--------------------|--------------------|---|------------------|------------------|
| | 2016 | 2015 | | 2016 | 2015 |
| ASSETS | | | ASSETS | | |
| Current Assets | 288,265,058 | 244,428,283 | Current Assets | 1,065,250 | 903,256 |
| Inventory | 6,016,839 | 5,191,603 | Inventory | 22,235 | 19,185 |
| Accounts receivables | 267,923,682 | 233,226,179 | Accounts receivables | 990,080 | 861,860 |
| Cash and equivalents | 12,112,350 | 4,760,025 | Cash and equivalents | 44,760 | 17,590 |
| Other current assets | 2,212,187 | 1,250,476 | Other current assets | 8,175 | 4,621 |
| Non-Current Assets | 183,090,288 | 191,098,017 | Non-Current Assets | 676,589 | 706,180 |
| Fixed tangible assets | 149,990,427 | 152,888,383 | Fixed tangible assets | 554,272 | 564,981 |
| Fixed intangible assets | 11,287,254 | 11,503,474 | Fixed intangible assets | 41,711 | 42,510 |
| Other financial assets | 17,699,466 | 17,986,697 | Other financial assets | 65,406 | 66,468 |
| Other non-current assets | 4,113,142 | 8,719,462 | Other non-current assets | 15,200 | 32,222 |
| Total Assets | 471,355,346 | 435,526,300 | Total Assets | 1,741,838 | 1,609,436 |
| LIABILITIES AND NET ASSETS | | | LIABILITIES AND NET ASSETS | | |
| Current Liabilities | 216,587,284 | 164,213,403 | Current Liabilities | 800,373 | 606,831 |
| Accounts payables | 167,799,183 | 116,401,463 | Accounts payables | 620,082 | 430,148 |
| Short term loans | 5,102,112 | 1,102,112 | Short term loans | 18,854 | 4,073 |
| Other current liabilities | 43,685,989 | 46,709,828 | Other current liabilities | 161,436 | 172,611 |
| Non-Current Liabilities | 9,700,757 | 9,926,640 | Non-Current Liabilities | 35,848 | 36,683 |
| Mid and long-term loans | 169,412 | 395,294 | Mid and long-term loans | 626 | 1,461 |
| Provisions for pension funds | 9,416,453 | 9,416,453 | Provisions for pension funds | 34,797 | 34,797 |
| Provisions for other risks and charges | 114,892 | 114,892 | Provisions for other risks and charges | 425 | 425 |
| Total Liabilities | 226,288,041 | 174,140,043 | Total Liabilities | 836,221 | 643,514 |
| EQUITY & CAPITAL | | | EQUITY & CAPITAL | | |
| Equity & Capital | 245,067,305 | 261,386,257 | Equity & Capital | 905,617 | 965,922 |
| Capital | 284,194,598 | 284,194,598 | Capital | 1,050,208 | 1,050,208 |
| Retained earnings | -22,808,341 | 0 | Retained earnings | -84,286 | 0 |
| Incomes from the related period | -16,318,952 | -22,808,341 | Incomes from the related period | -60,305 | -84,286 |
| Equity & Capitals | 245,067,305 | 261,386,257 | Equity & Capitals | 905,617 | 965,922 |
| Total Liabilities and Net Assets | 471,355,346 | 435,526,300 | Total Liabilities and Net Assets | 1,741,838 | 1,609,436 |

(b) B/S

Accounts receivables were prominent in current assets, and accounts payables were prominent in current liabilities. Outstanding accounts receivables and payables in 2016 were 267,923 million and 167,799 million AOA, respectively. Accounts receivables far exceeded the operating income for the year, so the collection (days) was 770 days. The total billed amounts during the year 2015 to June 2017 are: 52,621,339,094.34 AOA for Law Voltage and 35,046,795,121.71 AOA for Medium Voltage. Meanwhile ENDE collected during the same period 38,292,121.097 AOA for Law Voltage and 20,138,340,323 AOA for Medium Voltage. It means that collection rate for Law Voltage is 72.7% but that for Medium Voltage is 57.4%. It seems that the bill collection of Medium Voltage is harder than that of Law Voltage. As a result, some accounts receivables of Medium Voltage have gone bad. One possible reason for

the gap was the practice of crediting bills to clients without necessarily collecting in some cases. Uncollected receivables accumulated, as some receivables were no longer collected. The same thing happened with accounts payables.

(c) C/F

Cash Flow from Operating Activities in 2016 was negative because payments to suppliers and payments to employees were bigger than receipts from clients. Cash flow from Investment Activities was negative (-1,936 million AOA). Cash Flow from Financial Activities included 26,708 million AOA of allocations to Exploration and Contributions. Moreover, ENDE borrowed 5,000 million AOA. Cash Flow from Financial Activities made up the losses for Cash Flow from Operating Activities and Cash Flow from Investment Activities.

Table 10-11 Cash Flow Statement (CF)

| | (unit: 1000 AOA) | | | (unit: 1000 USD) | |
|---|--------------------|-------------------|---|------------------|---------------|
| | 2016 | 2015 | | 2016 | 2015 |
| Cash Flow from Operational | -19,750,661 | -1,703,503 | Cash Flow from Operational Activities | -72,986 | -6,295 |
| Cash flow from operation | -11,557,392 | 1,866,526 | Cash flow from operation | -42,709 | 6,898 |
| Cash receipts from clients | 36,938,612 | 16,532,900 | Cash receipts from clients | 136,502 | 61,095 |
| Cash payments to suppliers | -32,928,684 | -4,507,034 | Cash payments to suppliers | -121,684 | -16,655 |
| Payment to employees | -15,567,320 | -10,159,340 | Payment to employees | -57,527 | -37,543 |
| Profits tax | -272,885 | -137,051 | Profits tax | -1,008 | -506 |
| Cash flow before other operational activi | -7,791,191 | -3,331,305 | Cash flow before other operational activities | -28,791 | -12,310 |
| Other receipts from operational activities | 609,652 | 0 | Other receipts from operational activities | 2,253 | 0 |
| Other paymentes from operational activities | -8,400,844 | -3,331,305 | Other paymentes from operational activities | -31,044 | -12,310 |
| Cash flow before nonstandard items | -129,193 | -101,672 | Cash flow before nonstandard items | -477 | -376 |
| Receipts from nonstandard items | 27,094 | 50,420 | Receipts from nonstandard items | 100 | 186 |
| Payments from nonstandard items | -156,287 | -152,093 | Payments from nonstandard items | -578 | -562 |
| | 0 | 0 | | | |
| Cash Flow from Investment Activiti | -1,936,745 | -2,039,147 | Cash Flow from Investment Activities | -7,167 | -7,535 |
| Receipts from: | 880,317 | 241,319 | Receipts from: | 3,253 | 892 |
| Tangible fixed assets | 3,753 | 2,081 | Tangible fixed assets | 14 | 8 |
| Financial investments | 0 | 0 | Financial investments | 0 | 0 |
| Interests | 876,563 | 239,237 | Interests | 3,239 | 884 |
| Payments to | -2,817,062 | -2,280,466 | Payments to | -10,410 | -8,427 |
| Fixed tangible assets | -2,817,062 | -2,280,466 | Fixed tangible assets | -10,410 | -8,427 |
| Fixed intangible assets | 0 | 0 | Fixed intangible assets | 0 | 0 |
| | | | | | |
| Cash flow from Financial Activities | 29,039,731 | 4,334,991 | Cash flow from Financial Activities | 107,313 | 16,019 |
| Receipts from | 31,708,536 | 4,645,763 | Receipts from | 117,175 | 17,168 |
| Loans | 5,000,000 | 0 | Loans | 18,477 | 0 |
| Allocations to Exploration and Contributions | 26,708,536 | 4,645,763 | Allocations to Exploration and Contributions | 98,698 | 17,168 |
| Payments to | -2,668,804 | -310,772 | Payments to | -9,862 | -1,148 |
| Loans | -1,225,882 | -169,412 | Loans | -4,530 | -626 |
| Interests | -1,442,922 | -141,360 | Interests | -5,332 | -522 |
| | 0 | 0 | | 0 | 0 |
| Net Cash Increase or Decrease of the Year | 7,352,325 | 592,341 | Net Cash Increase or Decrease of the Year | 27,170 | 2,189 |
| Cash and Equivalent at the Beginning of the Year | 4,760,025 | 0 | Cash and Equivalent at the Beginning of the Year | 17,590 | 0 |
| Impact of the Addition of Cash Balances and its Equivalent from Winded -up ENE and EDEL | 0 | 4,167,684 | Impact of the Addition of Cash Balances and its Equivalent from Winded -up ENE and EDEL | 0 | 15,401 |
| Cash and its Equivalent at the End of the Year | 12,112,350 | 4,760,025 | Cash and its Equivalent at the End of the Year | 44,760 | 17,590 |

(d) Conclusion

The major financial ratios were as follows.

The net profit margin in 2016 was negative (-12.8%). Return on Assets (ROA) in 2016 was small, falling to -3.5%, because accounts receivables were big due to the far bigger total assets versus operating income. The current ratio, an indicator of financial stability, was 1.33 because current assets were bigger than current liabilities. The average collection (days) in 2016 was 770 days, which was bigger than 1 year (365 days).

Table 10-12 Major financial ratios

| | 2016 | 2015 |
|---------------------------|--------|--------|
| net profit margin | -12.8% | -32.1% |
| return on assets (ROA) | -3.5% | -5.2% |
| current ratio | 1.33 | 1.49 |
| asset turnover | 0.27 | 0.16 |
| average collection (days) | 770 | 1,198 |

10.2 Analysis of Financial Soundness and Sustainability

10.2.1 Analysis of a unit revenue price per kWh

The JICA Study Team calculated a unit revenue price and unit cost price. Appropriate actual data for generation, transmission, and distribution were unavailable, which compelled the Survey Team to use the generation data shown in the 'Activity Report' issued by ENDE. As the revenue of ENDE consists of subsidies on prices as well as ordinary power sales, the Survey Team calculated two types of unit revenue prices: one without a subsidy on price and one with a subsidy on price.

The unit revenue price of PRODEL in 2016 was 4.43 AOA, which was far less than the unit cost price. For the other two companies, the unit revenue price and unit cost price were almost the same or the unit cost price was bigger than the unit revenue price. These figures suggest that none of the three companies have been maintaining appropriate profitability. The unit revenue price without a subsidy of ENDE in 2016 was 5.23 AOA, which was less than half of the unit cost price.

Finally the JICA Survey Team calculated the unit cost necessary to deliver electricity to the final users in Angola. The calculation assumes that the power purchased by Angolan nationals is generated by PRODEL, transmitted through the trunk-lines and sub-stations of RNT, and distributed by ENDE. Then the calculation divides the sum of all of the operational costs of PRODEL, RNT and ENDE by sales (kWh). The result is 44.81 AOA (=0.166 USD).

Table 10-13 Unit Revenue Prices and Unit Cost Prices

| | | (AOA, AOA/kWh) | |
|--|--|-------------------|------------------|
| | | 2016 | 2015 |
| <u>PRODEL</u> | | | |
| | sales (kWh) | 10,929,810,809.00 | 6,308,876,489.00 |
| | @revenue unit price /kWh | 20.17 | 18.49 |
| | @cost unit price /kWh | 19.74 | 20.10 |
| <u>R N T</u> | | | |
| | sales (kWh) | 9,348,186,285.76 | 6,136,127,637.00 |
| | @revenue unit price /kWh | 9.34 | 8.93 |
| | @cost unit price /kWh | 8.45 | 7.39 |
| <u>ENDE</u> | | | |
| | sales (kWh) | 9,348,186,285.76 | 5,829,423,620.07 |
| | @revenue unit price /kWh | 13.59 | 12.19 |
| | @revenue unit price (without subsidy) /kWh | 6.27 | 3.78 |
| | @cost unit price /kWh | 13.28 | 13.39 |
| <u>Total cost of PRODEL, RNT and ENDE</u> | | | |
| | sales (kWh) | 9,348,186,285.76 | 5,829,423,620.07 |
| | @total cost unit price /kWh in AOA | 44.81 | 42.93 |
| | @total cost unit price /kWh in USD | 0.208 | 0.200 |

※ USD1= 215.064 AOA based on the official announcement of Banco Nacional de Angola, as of March 12, 2018

10.2.2 Bill Collection

Next, the JICA Survey Team calculated how many days each company needs to collect receivables, from a viewpoint of profitability. In 2014 and 2015, RNT and ENDE took more than 1 year (365 days) to collect receivables, while PRODEL collected receivables in around 90 days. ENDE took an especially long time, more than 1,000 days, to collect receivable in 2015.

ENDE offers an explanation for this issue in its Activity Report: “ENDE sets the goal of collecting from 70% to up to 85% of billed amounts.” If a collection-day extends beyond 365 days, some of the accounts receivables go bad, making further collection almost impossible. This, in turn, makes it necessary to increase the collection rate further. At the same time, ENDE must review whether or not outstanding accounts receivables go bad.

Table 10-14 Collection (days) for Bills (days)

| | days | 2016 | 2015 |
|--------|------|------|-------|
| PRODEL | | 91 | 96 |
| RNT | | 426 | 357 |
| ENDE | | 770 | 1,198 |

10.2.3 Financial Soundness

(1) Current ratio

The current ratio is a financial indicator used to assess insolvency, especially short-term debt against current assets, including cash and high liquidity, to current liabilities. The current ratio should generally be higher than 2.0.

The low current ratios of the three companies, all below 2.0, reveal their poor solvency and financial soundness. The current ratio of ENDE in 2016 was 1.33, the highest among the three. This ratio, however, was calculated with very high accounts receivables. ENDE therefore needs to review accounts receivable more fully to see whether or not these assets are to become uncollectable.

Table 10-15 Current Ratio

| | 2016 | 2015 |
|--------|------|------|
| PRODEL | 0.60 | 0.37 |
| RNT | 0.82 | 0.81 |
| ENDE | 1.33 | 1.49 |

(2) Debt Equity Ratio

The debt equity ratio is a financial indicator used to assess soundness against liabilities. The current debt equity ratios for all three companies exceeded 0.4.

The liabilities for the three companies are limited to short-term borrowings or middle-term borrowings at present, and there are no long-term borrowings. If these companies start borrowing to meet the long-term power development plan, the debt equity ratio will clearly decrease in the long run. These companies will have to either keep certain amounts of profit every year to transfer to retained earnings or periodically increase their capital to maintain their debt equity ratios at a certain level.

Table 10-16 Debt Equity Ratio

| | 2016 | 2015 |
|--------|------|------|
| PRODEL | 0.47 | 0.65 |
| RNT | 0.41 | 0.55 |
| ENDE | 0.52 | 0.60 |

10.3 Review of the Financial Condition of PRODEL, RNT and ENDE

10.3.1 Tariff

As stated in the section 9.3.2, the unit prices of PRODEL and RNT are not big enough to cover the incremental cost derived from the future investment. Both companies need to raise the power tariff or inject a subsidy to cover the incremental cost.

Table 10-17 The Unit Incremental Cost Derived from the Long-term Investment

| | PRODEL | RNT |
|--|------------------------------------|-------------------------------------|
| 1. unit revenue price in 2016 | @0.09 \$ /kWh (=@20.17 AOA/kWh) | @0.043 \$ /kWh (=@9.34 AOA/kWh) |
| 2. unit cost price in 2016 | @0.09\$ /kWh (=@19.74 AOA/kWh) | @0.039 \$ / kWh (=@8.45 AOA/kWh) |
| 3. incremental cost based on the long-term investment | @0.085\$/ kWh (=@18.3 AOA/kWh) | @0.02\$/ kWh (=@4.3 AOA/kWh) |
| 4.. Total cost (2+3) | @0.175 \$/kWh (=@38.04AOA/kWh) | @ 0.059 \$/kWh (=@12.75 AOA/kWh) |
| 5. increase of tariff (unit cost of investment / current unit cost) | 17.9 AOA (1.92) | 3.41 AOA (1.51) |

10.3.2 Cost Structure

The JICA Study Team's review of the financial statements of PRODEL, RNT and ENDE failed to turn up any financial trends, as the statements were available for only two years. Some studies by JICA in other countries, however, were able to find the proper profit margins. In its '*Project Master Plan Study on the Electricity Sector in the Democratic Socialist Republic of Sri Lanka*,' for example, JICA calculated the Return on Asset (ROA) necessary for investment and profit margin that covered the decreasing generation of hydropower plants in the dry season. ※

※ A review of a series of past financial statements of the Ceylon Electricity Board (CEB) in the '*Project Master Plan Study on the Electricity Sector in the Democratic Socialist Republic of Sri Lanka*' (2018) determined that CEB needed an ROA of 5% to generate retained earnings and a profit margin of 3-7.5% to curb the impact of decreasing generation of hydropower plants in the dry season.

10.3.3 Borrowing

The liabilities of PRODEL, RNT and ENDE RNT are currently limited to short-term or middle-term liabilities. There are no long-term liabilities. If the three companies depend solely on borrowing, the credibility of each company will decline commensurately with the decreases in its equity ratio. In order to maintain a proper equity ratio, funds should be raised from a mixture of borrowings and equity, or from a forgivable loan, the approach followed India.

10.3.4 Regulation on the fiscal budget and the tariff

- All of the accounting data must be kept for use for the calculation of their tariffs.
- The net profit of ENDE went into the red in 2016 and a subsidy was received to compensate for the loss. Meanwhile, PRODEL and RNT went into the black.
- While amount of subsidy ENDE receives is important, the calculation of the unit cost for the generation, transmission and sub-station will be unaffected.

10.3.5 Some Financial Issues to be considered

It seems that no rating firms have ever rated PRODEL, RNT, and ENDE so far. From here we summarize several important considerations.

(1) Improvement of profitability

No financial institution would extend a loan to an implementing agency with low profitability. Hence, the implementing agency needs to improve its profitability. While it may not be possible to raise tariffs to cover all costs, it will be important to encourage efforts to improve profitability.

(2) Financial Soundness

(a) Current Ratio

All three corporations have big receivables stemming from their apparently big current ratios. Yet some portion of the receivables went bad. The implementing agencies need to review the receivables and try to collect them faster.

(b) Return on Equity (ROE)

If an investment is extended solely by borrowing, it will push Return on Equity (ROE) down. As continuous borrowing may lead to an ultimate default, overdependence on borrowing is discouraged. A proper capital injection would therefore be necessary from a financial viewpoint.

10.3.6 Other issues

(1) Accounting and disclosure

- The time will come to compare the fuel costs of different thermal power plants, which includes the ones developed by the private investor. This will require disclosure of information on how much fuel cost the implementing agency consumes (though this may not be disclosed in the financial statement of PRODEL).
- In order to access the financial condition of PRODEL, RNT and ENDE, a review must be conducted to determine how the three newly established corporations (PRODEL, RNT and ENDE) took over or did not take over the assets when they were first established. Alternatively, the report from the Audit Firm could be reviewed, if necessary.

(2) Analysis on the fiscal condition of the Government of Angola

The JICA Study Team reviewed the financial conditions of the three corporations in the power Sector. If Angola plans to develop power projects through borrowing, it needs to consider the fiscal condition of the Government of Angola as well as the three corporations of Angola.

As stated in the Chapter 9, borrowings from JICA, JBIC, and AfDB need government guarantees. Borrowings guaranteed by the government surely increase the General Government Gross Debt. As the rate of the Gross Debt in Angola has already reached a high level, failure to undertake a new guarantee may seriously impede long-term power development. (※)

※The power sector in Vietnam faces the same problem. The ratio of General Government Gross Debt already reached the upper ceiling of 65% in 2017. Consequently the Government of Vietnam is reluctant to undertake a new guarantee. Meanwhile, the Government of Vietnam is said not to provide government guarantees to new power project exceptionally. Rather the Government encourages the Electricity of Vietnam (EVN), the biggest utility power company in Vietnam, to raise funds by itself and raise the power tariff.

According to recent macro indices of Angola, the GDP in 2017 was 124.21 billion USD and the Rate of General Government Debt has reached 65.35% (=81.066 billion USD), starting from 44.3% in 2010. The total investment amount up to 2040 will reach 31,548 million USD, the equivalent of 25% of the 2017

GDP. If the Government of Angola goes on undertaking government guarantees, the total debt will almost reach Angola's 2017 GDP. This would not be favorable for the long-term sustainability of the country.

Table 10-18 GDP and General Government Gross Debt of Angola


| | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 |
|--------------------------------------|--------|--------|--------|--------|--------|--------|--------|--------|
| GDP (billion USD) | 82.53 | 104.12 | 113.92 | 124.91 | 126.73 | 102.62 | 96.34 | 124.21 |
| General Government Gross Debt (%) | (44.3) | (33.8) | (29.9) | (32.9) | (40.7) | (64.6) | (79.8) | (65.3) |

(Source: IMF World Economic Outlook 2018)

Chapter 11 Environmental and Social Considerations

11.1 Outline of the Strategic Environmental Assessment (SEA) Approach for the Power Development Master Plan

An SEA focused on environmental and social aspects is to be conducted on the development of various power sources projected in the development scenarios from the "Power development plan / transmission system expansion plan." The assessment will be performed using the method shown in Figure 11-1. That is, we will quantitatively assess the environmental load from the development of each type of generation, prioritize the alternative development scenarios, and propose the most desirable scenario from the viewpoints of environmental and social conservation.



(Source: JICA Survey Team)

Figure 11-1 Workflow for the SEA

(a) Selection of scoping items and indicators

In order to analyze and evaluate each power development plan from environmental and social viewpoints, the plans are to be scoped based on evaluation items focused on the natural, social, and global environments.

(b) Evaluation of scoping items

Quantitative evaluations are to be carried out based on a four-point score (from 0 to -3) quantifying the degree of impact on the above scoping items by project.

(c) Matrix Evaluation of each power generation development plan

A matrix evaluation of each alternative development scenario is to be carried out to quantitatively assess each scenario's impact on the environment.

11.2 Overview of the present state of the proposed project area

Angola consists of a land area of 1,246,700 km² situated on the Atlantic Coast of the western region of southern Africa. The country is bordered in the north by the Republic of Congo (201 km) and the Democratic Republic of Congo (2,511 km), in the east by Zambia (1,110 km), and in the south by Namibia (1,376 km). The physical characteristics of the 1,600 km Angolan coastline are extremely variable.


Angola can be divided into six geomorphological areas: coastal, marginal mountain chain (cadeia marginal de montanhas), the old tableland (planalto central), the Zaire Basin, and the Basins of the Zambezi and the Cubango.

The highest point is Moco Hill (2,620 m) in the central part of the country, where the major Angolan rivers have their origins.

Temperatures range from between 25 and 33 °C in the rainy season (September to April) and between 18 and 22 °C in the dry season (May to August). The climate in the north is tropical and humid, with an annual average rainfall of 1,200-2,000 mm. The coastal region has an average annual rainfall of less than 600 mm, decreasing from north to south. The inland climate ranges from high temperatures and high rainfall to semi-desert conditions.

The country can be divided into five ecozones (SARDC, SADC & IUCN 1994):

1. Lowland Tropical Forest (rainforest) in the northeast characterized by high rainfall all year round, high evaporation, and low soil fertility
2. Moist Savanna occupying around 70% of the country area, characterized by rainfall between 500 and 1,400 mm a year and broad-ranging soil types that are generally poor in nutrients
3. Dry Savanna in southern Angola characterized by unpredictable summer rainfall of 250-500 mm a year, with generally fertile soils but sparse vegetation
4. Nama-Karoo in the southwest characterized by an average rainfall of 100-400 mm a year
5. Desert along the narrow coastal strip in southwest Angola characterized by very low average rainfall of 10-85 mm a year.



(Source: Website Angola vegetation Map 1970)

Figure 11-2 Status of Vegetation

(1) Natural Environment

(a) Current status of biodiversity

The palanca preta gigante (giant sable antelope) and the *Welwitschia mirabilis* ((Source: ERM)

Figure 11-3) have been world-renowned emblems of the Angolan identity for a long time. They are just two of many examples of the rich biological diversity of the Republic of Angola and how living beings can be emblematic of a nation.

Angola has a wealth of unique biological diversity. Scientists believe that Angolan biodiversity is one of the most important in the African continent. Over 5,000 plant species are inferred to exist in Angola (after excluding the vast flora wealth of Cabinda Province), and 1,260 of the species are endemic (Angola is the second richest country in Africa in endemic plants).

In total, 275 species of mammals have been recorded, many more than in most other countries on the continent. Meanwhile, the 872 species of bird recorded in Angola make up 92% of the avifauna in southern Africa.

The exceptional biodiversity in Angola can be attributed to a number of factors in combination: the vast size of the country, its inter-tropical geography, the altitude variation, and the biome types. The climate diversity, coupled with equal geographical and soil variability, contributes to the formation of bioclimatic zones that vary from dense tropical forest to poor vegetation in the desert. These different habitats are favorable for a high level biological diversity.

Chimpanzees, gorillas, and a diversity of other mammals also live in the forests. There is a consensus that special protection measures should be taken to protect the region and its biodiversity. Uncontrolled bush-burning, poaching, and anarchical logging have adversely affected the conservation of this and other important ecosystems in Angola.

Preliminary studies indicate that about 120 species of plant are listed as endangered plants. Many of them can be found protected areas. Trees such as the *Avicenia* and *Combretum* are important for the vegetation that protects the Angolan coast and are also listed as highly endangered species.

Animal species such as the cheetah, brown hyena, African wild dog, black rhinoceros, mountain and plain zebras, giraffe, and oryx are assigned extinct and/or very vulnerable status in some areas of the Angolan territory where they were hitherto abundant. Various other species also face extinction due to pressure from anthropogenic activities. To give a faint idea of the precarious conditions the mammals face, 50 out of the 275 species that inhabit Angola are listed as extinct and threatened species according to the IUCN.

Another threat to biological diversity is illegal trade of animals smuggled outside the country. There are unconfirmed signs that some of the bird species are smuggled in quantities large enough to endanger their survival. Approximately 34 Angolan birds are listed as endangered species.

According to the National Biodiversity Strategy and Action Plan (2007-2012), Angola has over 8,000 species of plant, out of which 1,260 are endemic. Concerning the fauna, 275 mammal species and 872 bird species are confirmed so far, of which 13 mammal, 11 bird, 22 reptile, 23 amphibian, and 72 fresh water fish species are reported to be endemic.



(Source: ERM)

Figure 11-3 *Welwitschia mirabilis*

Table 11-1 Number of Endangered Species in Angola

| Category | | Critical (CR) | Endanger (EN) | Vulnerable (VU) |
|----------|---------|---------------|---------------|-----------------|
| Number | | | | |
| Fauna | 108 Sp. | 10 | 32 | 66 |
| Flora | 34 Sp. | - | 3 | 31 |

(Source: Angola Government)

(b) Designation and management status of protected areas

Angola also has a number of protected areas established during the colonial period of the 1930s mainly for tourism, controlled hunting, protection, and scientific research. These areas were primarily considered to have low agricultural and economic potential but high value for hunters.

The protected areas in Angola include national parks, strict reserves, partial reserves, regional nature parks, and special reserves. As of 2011, Angola had 13 conservation areas, each governed by its own system of legislation. In total, they covered around 12.98% of the country's surface (82,832 km²).

There were nine national parks (6.3%), four strict reserves (4%), two natural reserves, and one regional natural park (0.4%). Five public hunting reserves and a private hunting reserve were also established.

The current protected areas in Angola are listed in Table 11-2 below.

Table 11-2 List of Protected Area

| No. | Name | Area (km ²) | Year |
|------------------------|--|-------------------------|------|
| National Parks | | | |
| 1 | Quiçama National Park | 9,960 | 1957 |
| 2 | Mupa National Park | 6,600 | 1964 |
| 3 | Bicuar National Park | 7,900 | 1964 |
| 4 | Cangandala National Park | 630 | 1970 |
| 5 | Cameia National Park | 14,450 | 1957 |
| 6 | Iona National Park | 15,150 | 1957 |
| 7 | Mayombe National Park | 1,930 | 2011 |
| 8 | Luengue-Luiana National Park | 45,818 | 2011 |
| 9 | Mavinga National Park | 46,072 | 2011 |
| Total | | 148,510 | |
| Regional Park | | | |
| 1 | Chimalavera Nature Park | 150 | 1974 |
| Total | | 150 | |
| Nature Reserves | | | |
| 1 | Ilhéu dos Pássaros Integral Nature Reserve | 2 | 1973 |
| 2 | Luando Integral Nature Reserve | 8,280 | 1957 |
| Total | | 8,282 | |
| Strict Reserves | | | |
| 1 | Buffalo Partial Reserve | 400 | 1974 |
| 2 | Mavinga Partial Reserve | 5,950 | 1973 |
| 3 | Luando Integral Nature Reserve | 8,280 | 1957 |
| 4 | Namibe Partial Reserve | 4,450 | 1973 |
| Total | | 19,080 | |

(Source: Angola Government)




Figure 11-4 Distribution of Protected Areas

(Source: ERM)

(2) Social Environment

The total area of Angola is 1,246,700 km². Angola's 2014 national census reports a national population of 25.8 million and population density of 21.8 head/km². (INE, 2014).

Infrastructures such as transport, electricity, water supply, waste disposal, healthcare and telecommunication have all deteriorated due to the civil war (much infrastructure has been destroyed; much has become untenable). Unexplored ordinance (UXO) still exists in vast areas of the country, which renders much of Angola unusable by inhabitants.

(a) Language and ethnic groups

The official and predominant language of use in Angola is Portuguese. Approximately 40% of the population speaks a Bantu dialect as their mother tongue.

Roughly 37% of Angolans are Ovimbundu, 25% are Ambundu, 13% are Bakongo, 2% are Mestizo, 1-2% are white Africans, and 22% are people from other African ethnicities.

(b) Type of Land Use

By land use, 47% of the country consists of non-agricultural land. Of the remainder, approximately 4% consists of cultivated agricultural land, approximately 46% consists of forests, and the remaining 3% consists of wheat/barley fields, pastures, and urban areas. Details of the land use are as shown in the table below.

Table 11-3 General Land Balance Sheet

| Type of land use | Area (ha, %) |
|---|----------------------|
| Arable land, permanent crop land, permanent pasture land | 59,190,000 (47.47) |
| Forest | 57,856,000 (46.41) |
| Other (wheat/barley/urban land) | 7,624,000 (6.12) |
| Total | 124,670,000 (100.00) |

(Source: Trading Economics World Bank 2015)

11.3 Structure and regime for environmental and social considerations in Angola

11.3.1 Legal and regulatory frameworks for environmental and social considerations

(1) Regulatory framework for strategic environmental assessment

Strategic Environmental Assessment (SEA) is not a mandatory requirement under the Environmental Framework Law (EFL) enacted in 1998.

(2) Related laws and regulations on strategic environmental assessment (SEA)

The table below lists the key laws and regulations to be considered for SEA implementation.

Table 11-4 Legal and Regulatory Frameworks for Environmental and Social Considerations

| Policy, Law, Regulation | Main Contents |
|--|--|
| Environmental Framework Law (Law No. 5/98, 19 June 1998) | The Environmental Framework Law (LBA – Lei de Base do Ambiente) defines the basic concepts and principles for the protection, preservation, and conservation of the environment, promotion of quality of life, and the rational use of natural resources. Article 16 of this law stipulates that an Environmental Impact Study should be mandatory for every undertaking that has an impact on the environmental balance and the population's quality of life. |
| Environmental Impact Assessment (Decree 51/04, July 2004) | The EIA Decree specifies the activities required during the EIA process (Articles 6 and 7), as well as the contents of the EIA report (Article 9). |
| Land Law (Law No. 9/04, 09/11/2004) | The Land Law declares land to be the property of the State and proposes the following multiple uses: ① To provide shelter and homes for inhabitants of Angola; ② A source of natural resources that can be used for mining, agriculture, forestry, and land planning; and ③ A support for economic, agricultural and industrial activities. |
| Cultural Heritage Law (Law No. 14/05, 07 October 2005) | This Law defines cultural heritages as material and immaterial assets that, in light of their value, must be protected. |
| Environmental Licensing (Decree 59/07, 13 July 2007) | This Decree lays down the rules that regulate the environmental licensing of activities that are judged to be potential sources of significant environmental impacts in light of their nature, location, or scale. |
| Environmental Auditing Decree (Decree 1/10, January 2010) | This Decree is a tool to be used after the environmental impact assessment process to make it possible to check whether the planned minimization measures and Monitoring Plan have been implemented once a project is installed. It also requires other checks, such as whether the minimization measures have had a positive performance, whether and how the anticipated impacts have occurred, and whether there have been other unanticipated impacts. |
| Water Quality (Decree 261/11, 06 October 2011) | This Decree specifies the National Environmental Standard on Water Quality. |
| Terms of Reference for Environmental Impact Studies (Decree 92/12, 01 March 2012) | This Decree establishes the guidelines and procedures to be followed during the development of Environmental Impact Studies. |

| | |
|---|---|
| Public Consultation for Projects Subject to Environmental Impact Assessment (Decree 87/12, 24 February 2012) | This Decree describes the opinions of residents concerning environmental impact assessment and the method used to reflect those opinions in the reports. |
| Regulation on Resettlement (Decree 117/16, 30 May 2016) | This Regulation aims to define the rules and procedures to govern the actions of the organs of the central administration and autonomous state in the resettlement and rehousing process for groups of people living in given territories and for households and residents affected by redevelopment and urban areas conversion, in accordance with the principles governing public administration. The Regulation cautions against the pursuit of the public interest and protects the rights and interests of citizens. |

(Source: JICA Survey Team organized based on Angola Government materials)

(3) International treaties/conventions concerning SEA

The following table summarizes international treaties ratified by Angola with regard to environmental conservation.

Table 11-5 International Treaties/Conventions Concerning SEA

| Name of convention | Date of Ratify |
|---|----------------|
| Convention concerning the Protection of the World Cultural and Natural Heritage (1972) | 1992 |
| Convention of Migratory Species of Wild Animals or Bonn Convention (1979) | 2006 |
| Convention on Biological Diversity (1992) | 1997 |
| Convention on International Trade in Endangered Species of Wild Fauna and Flora (CITES, 1973) | 2007 |
| Convention on Wetlands of International Importance especially Waterfowl Habitat (Ramsar Convention, 1971) | 2016 |
| Convention to Combat Desertification (1994) | 2000 |

(Source: JICA Survey Team organized based on Angola Government materials)

(4) INDC (Intended Nationally Determined Contribution) and Contribution of Master Plan 2040

At the United Nations Climate Change Conference, COP21, in Paris, France, the Paris agreement was adopted as a climate agreement by all the nations of the world. While the Paris agreement includes no obligations for CO₂ reduction, all countries are to submit national goals, updates, reports, and reviews every five years. In consideration of the worldwide movements regarding global warming and the environment, the introduction of renewable energy has been discussed positively in Angola.

In 2016 Angola submitted an Intended Nationally Determined Contribution (INDC) that encompasses, for Mitigation purposes, both unconditional and conditional measures for the reduction of GHG, to the United Nations Framework Convention on Climate Change (UNFCC).

In achieving unconditional and conditional goals, Angola promised to reduce GHG emissions by approximately 20% below its 2005 emissions (66.8 million tons) in the BAU (Business As Usual) scenario by 2030. GHG emissions in 2005 were 66.8 million tons, of which more than 95% was attributable to fossil fuel consumption.

In response to this situation, Angola takes the promotion of renewable energy projects as a top priority issue of national strategy.

1. Repowering of the Cambambe Central I Hydropower Plant:

It will increase the installation capacity from 180 MW to 260 MW and aim to reduce emissions by 1,529,311 tCO₂e per year.

2. Cambambe II Hydropower Plant:

It will secure 700 MW capacity and aim to reduce emissions by 3,282,000 tCO₂e per year.

3. Tombwa Wind Farm Plant

It will secure a capacity of 100 MW and reduce emissions by 157,258 tCO₂e per year.

4. The promotion of the biomass business

Along with the promotion of the biomass business, it plans to reduce emissions by 750,000 tCO₂e per year.

Based on the CO₂ emissions per 1 MW for each power development developed by the Angola government, the CO₂ reduction volumes by the renewable energy project proposed in the Master Plan are estimated as follows. The total reduction volume will be 5.64 million CO₂-tons.

Table 11-6 Reduction of CO₂ emissions by project proposed by M/P

| | Hydro PP | Wind PP | Solar PP | Bio. PP | Total |
|-----------------------------------|-----------|---------|----------|---------|-----------|
| Install Capacity* (MW) | 1,000 | 488 | 100 | 3 | 1,591 |
| CO ₂ Reduction (ton/y) | 4,700,000 | 767,000 | 157,000 | 14,000 | 5,638,000 |

(Source: JICA Survey Team organized based on INDC of Angola)

11.3.2 Differences between the JICA guidelines and Angolan regulations

Regarding the environmental and social considerations, the following table show key differences between the main items under the domestic law of Angola (Regulation on Environmental Impact Assessment) and the JICA Environmental and Social Considerations Guideline (2010).

Note, however, that the environmental and social considerations for Donor-supported projects in Angola are to be handled according to the requirements of the Donors.

Table 11-7 Differences between JICA Guidelines and Angolan regulations on SEA

| Items | JICA Guidelines | Angola Regulations | Key differences |
|-------------------------|---|--|---|
| Implementation of SEA | JICA applies an SEA when conducting a Master Plan or Feasibility Study. | SEA is still not a mandatory requirement in Environmental Impact Assessment Regulation (EIAR). | A gap exists. No articles on SEA implementation in the Environmental Framework Law, and no Guideline for SEA implementation |
| EIA Report | EIA reports are requested for projects expected to have serious adverse environmental impact. | Based on Environmental Impact Assessment Regulation, projects requiring EIA/IEE reports are specified. | No gaps. |
| Alternative examination | Examination of available alternatives is mandated. | Examination of available alternatives is mandated by | No gaps. |
| Environmental checklist | An environmental checklist specific to an EIA is provided. | No. | A gap exists. No Article on formulating a Checklist is |

| Items | JICA Guidelines | Angola Regulations | Key differences |
|--------------------------------|--|---|--|
| | | | provided in the Environmental Impact Assessment Regulation |
| Resettlement Action Plan (RAP) | The project proponent is obligated to prepare a RAP. If the number of resettled households is small (e.g., one household), the RAP can be simplified. The RAP is initially prepared as a part of the EIA Report. | No Article on formulating a RAP is provided in the Environmental Impact Assessment Regulation. | A gap exists. While no Article on formulating a RAP is provided in the Environmental Impact Assessment Regulation, a RAP is to be formulated based on the WB Guideline if donors ask for its implementation. |
| Land compensation | Land is compensated by replacement cost as much as possible. | While no descriptions on how to estimate or pay compensation are provided, the compensation cost is likely to be estimated based on the market price. | A gap exists. The full replacement cost is unlikely to be considered. |
| Monitoring/Mitigation measures | Implementation of monitoring and mitigation is required. | Implementation of monitoring and mitigation is required by EIAR. | No gaps. |
| Disclosure information | The EIA report is to be disclosed 120 days before the agreement documents are to be concluded. | Based on EIAR, the EIA is to be disclosed to the public. | No gaps. |

(Source: JICA Survey Team)

11.3.3 Organizations and their roles for Environmental and Social considerations

(1) Organizations for Environmental and Social Considerations (Role of central government and its executing agency)

The administrative organization on environmental and social considerations in Angola is under the control of the National Environmental Impact Prevention and Evaluation Bureau under the Ministry of the Environment. The main tasks of the Ministry of Environment in the field are as follows:

- Coordinate sustainable management strategies and policies for natural resources, such as the assurance of environmental sustainability;
- Coordinate national response actions to address global environmental problems, notably through the implementation of international conventions and agreements;
- Require environmental licensing for activities likely to cause significant environmental and social impacts;
- Develop and coordinate national programs focused on the conservation of natural ecosystems;
- Promote programs run by and for nature conservation areas, natural parks, areas of the biosphere, and landscape protection and preservation;
- Promote necessary measures to ensure biosafety and biodiversity in order to better ensure protection of the environment and quality of life;

The National Directorate for Prevention and Environmental Impact Assessment (DNPAIA) is accountable for evaluating environmental impact studies, while the National Directorate of

Environment (DNA) is accountable for the conception and implementation of urban management policies and urban strategies.

(2) Key items implemented through environmental and social considerations

(a) Implementation of Environmental Impact Assessment

The EIA procedures are set out in the Decree on Environmental Impact Assessment.

The activities listed in the Annex to the EIA Decree are categorized in the following sectors:


- Agriculture, fisheries and forestry;
- Extractive industries, such as petroleum, mining and dredging;
- Energy industry;
- Glass industry;
- Chemical industry;
- Infrastructure projects; and
- Other projects.

The energy industry projects that EIA implementation will be required for the following activities:

- a) Industrial installations for carrying gas, steam, and hot water, and transmission of electrical energy by overhead cables;
- b) Surface storage of natural gas;
- c) Underground storage of combustible gases;
- d) Surface storage of fossil fuels;
- e) Industrial briquetting of coal and lignite;
- f) Installations for the production and enrichment of nuclear fuels;
- g) Installations for the reprocessing of irradiated nuclear fuels;
- h) Installations for the collection and processing of radioactive waste;
- i) Installations for hydroelectric energy plants with capacities of greater than 1,000 kW;
- j) Power transmission lines with capacities above 230 kV;
- k) Hydraulic works for the exploitation of water resources, such as dams for hydroelectric purposes, sanitation or irrigation, the creation of navigable canals, irrigation, the straightening of watercourses, the opening of bars and river mouths, bay crossings, and dykes;
- l) Nuclear power stations with capacities of greater than 500 kW; and
- m) Nuclear power stations generating electricity through fission of isotopes;

(b) EIA Implementation Process

Figure 11-5 shows the screening and appraisal process for environmental permit issuance. At first, the developer carries out a screening to determine whether EIA is necessary according to the EIA Decree. When EIA is judged to be necessary, the process for environmental permit issuance is implemented.



(Source: JICA Survey Team)

Figure 11-5 Screening and Appraisal for Environmental Permit Issuance**(c) Environmental monitoring**

According to Article 22 of the EIA Decree, the competent environmental authority (in this case the Ministry of Environment) is responsible for monitoring the implementation of the EIA in specific projects. In practice, however, the Ministry or its Directorate often neglects to follow up the monitoring due to a lack of available resources and professional capacity.

(d) Public consultation

All projects listed in the Annex to the EIA Decree (see above (2) a) must be a subject to a public consultation programme organized by the Ministry of Environment, as prescribed in Article 10 of the EIA Decree.

The public consultation process, to be undertaken by the responsible ministry, comprises the following steps:

- Release of the non-technical summary of the EIA report to the interested and affected parties (as defined in Article 3 of the Decree);
- Consideration and appraisal of all presentations and comments related to the proposed project;

Compilation of a brief report within eight days of the completion of the consultation period, specifying the measures taken, the level of public participation, and the conclusions that may be drawn;

The consultation process must take place over a period from five to ten days, and the costs must be borne by the developer.

(e) Land acquisition and resettlement

There are two type of regulation for land acquisition and resettlement in Angola: the “Land Law, No.9/04, 09/11/2004” and the “Regulation on Resettlement, No.117/16, 30/05/2016.”

Article 12 of the Land Law stipulates that in cases of land acquisition for public works, the Nation or state governor shall pay appropriate compensation to landowners who have land use rights. Landowners receive compensation under this law.

Moreover, based on the Regulation on Resettlement enforced in 2016, compensation related to relocation is to be negotiated among the state, the affected people, and the business operator.

Compensation is provided in cash or as real estate equivalent to the land and house(s) lost.

11.4 Comparison of Alternatives (including Zero Options)

The zero option in this master plan is to be left out from this study, since it would be unrealistic to prepare measures and plans that enable a power development master plan to meet the power demand up to 2040 without implementing various power developments.

The draft scenario for power development is shown in chapter "11.8 Scenario analysis from ."

11.5 Scoping

In accordance with the following procedure, the SEA is to be conducted on power source development plans in the several alternative development scenarios from environmental and social viewpoints.

(1) Selection of scoping items and indicators

In order to analyze and evaluate each alternative development scenario (power development) from environmental and social viewpoints, evaluation items related to various power development projects are selected with reference to the JICA guidelines (checklist).

Table 11-8 Scoping Item Selection for SEA

| Sort | Impact Items | | Conventional | | | Renewable Energy | | |
|---------------------|--------------|--|--------------|------|----------|------------------|-------|---------|
| | | | Hydro | Coal | LNG, Oil | Wind | Solar | Biomass |
| Pollution Control | 1 | Air Quality | C | A | B | D | D | C |
| | 2 | Water Quality | B | B | B | C | B | B |
| | 3 | Soil Quality | D | B | C | D | D | B |
| | 4 | Sediment | D | D | D | D | C | D |
| | 5 | Noise and Vibration | B | B | B | A | B | B |
| | 6 | Odor | D | C | C | D | D | C |
| | 7 | Waste | C | A | C | D | A | A |
| | 8 | Subsidence | B | B | B | D | D | B |
| Natural Environment | 9 | Protected areas | A | D | D | A | A | A |
| | 10 | Ecosystem | A | D | D | A | A | A |
| | 11 | Topography and Geology | A | C | C | B | B | C |
| | 12 | Hydrology | C | D | D | D | D | D |
| Social Environment | 13 | Land acquisition | A | A | B | D | D | C |
| | 14 | Disturbance of Poor People | C | D | D | D | D | D |
| | 15 | Disturbance of Ethnic Minority Groups and Indigenous People | A | C | D | D | D | D |
| | 16 | Deterioration of Local Economy such as Loss of Employment and Livelihood Means | C | C | C | C | C | C |
| | 17 | Land Use and Utilization of Local Resources | A | B | B | B | B | B |
| | 18 | Disturbance of Water Usage, Water Rights, etc. | A | A | A | D | D | D |
| | 19 | Disturbance of Existing Social Infrastructure and Services | C | C | C | C | C | C |
| | 20 | Social Institutions such as Social Infrastructure and Local Decision-making Institutions | C | C | C | C | C | C |
| | 21 | Misdistribution of Benefits and Compensation | C | C | C | C | C | C |
| | 22 | Local Conflicts of Interest | C | C | C | C | C | C |
| | 23 | Cultural Heritage | B | D | D | D | D | D |
| | 24 | Landscape | B | C | C | A | B | D |
| | 25 | Gender | D | D | D | D | D | D |
| | 26 | Children's Rights | D | D | D | D | D | D |
| | 27 | Infectious Diseases such as HIV/AIDS | C | C | C | C | C | C |
| | 28 | Work Environment (including Work Safety) | C | C | C | C | C | C |
| Other | 29 | Accidents | C | C | C | C | C | C |
| | 30 | Cross-boundary Impact and Climate Change | C | A | B | D | D | D |

- Note;** A: Significant negative impact is expected
B: Negative impact is expected to some extent
C: Negative impact is unknown (further examination is needed and the impact may be clarified as the study progresses), and no evaluation is to be done in the SEA
D: No impact is expected, and no evaluation is to be done in the SEA

Based on the aforementioned screening, the scoping objects to be implemented in the SEA were narrowed down to the 17 items shown in Table 11-9 (natural environment, 10 items; social environment, 6 items; global environment, 1 item) for evaluation according to the evaluation criteria mentioned below.

Table 11-9 Selected scoping items and impact evaluation indicators

| Category | Items | Indicators |
|-----------------|---------------------------------------|---|
| Natural (10) | Topography & Geology | Destruction of ground |
| | Soil | Erosion, disposal, leakage of toxic substances; peeling off of top soil |
| | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances |
| | Quality of Air | Emission of pollutants from facilities |
| | Noise/Vibration | Noise/vibration from facilities or operation activities |
| | Waste | Domestic or industrial waste from facilities |
| | Subsidence | Use of underground water by facilities |
| | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem |
| | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse impact on migratory fish or birds |
| | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks |
| Social (6) | Resettlement / Land acquisition | Involuntary resettlement / Land requirement |
| | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people |
| | Land Use | Land use conflict |
| | Water Use | Water use conflict |
| | Landscape | Destruction of landscape |
| | Historical Heritage | Loss of local heritage |
| Global (1) | CO ₂ Emission | Adverse impacts on global warming |

(Source: JICA Survey Team)

(2) Method for evaluating the scoping items

Each project listed in the alternative development scenario is to be quantitatively evaluated based on impact evaluation criteria scored on a four-point scale (from 0 to -3), as shown in Table 11-10.

The scores (degrees of impact) for each alternative development scenario are totaled, and each scenario is prioritized based on the total score from environmental and social viewpoints.

Table 11-10 Impact Evaluation Criteria

| Score (E.C.I)* | Evaluation Criteria |
|-------------------|--|
| - 3 | Significant direct-negative impact is expected, and mitigation cannot be expected. |
| -2 | Significant direct-negative impact is expected, and mitigation is expected. |
| -1 | Minor direct-negative impact is expected, and mitigation is expected. |
| 0 | Minor indirect-negative impact is expected, and mitigation is not needed. |

*: Environmental Contribution Indicator

(Source: JICA Survey Team)

11.6 Results of SEA

(1) Power development candidate sites selected for evaluation of environmental impacts through SEA

Studies on environmental and social considerations were carried out in consultation with MINEA

using the above scoping and evaluation method for a total of 22 potential development candidates, as shown in the table below.


As no candidate sites for hydropower projects were nominated by MINEA, the environmental evaluation (scoring) for hydropower was done by evaluating the impacts of existing hydropower plants on nature, society, and the global environment, in lieu of conducting SEA evaluations on candidate sites. The environmental impacts when implementing hydropower development projects in Angola were assumed accordingly.

Table 11-11 Power Development Candidate Sites for SEA

| Type of Generation | Name of Project | Location | Capacity (MW) |
|---------------------------------|---|--------------|---------------|
| Hydropower | CAMBAMBE | Kwanza Norte | 960 |
| | MATALA | Huila | 40.8 |
| Sub total | 2 | | 1000.8 |
| Thermal Power (LNG / Heavy-Oil) | CIMANGOLA | Luanda | 212 |
| Sub total | 1 | | 212 |
| Wind Power | BENJAMIN | Benguela | 52 |
| | CACULA | Huila | 88 |
| | CALENGA | Huambo | 84 |
| | GASTAO | Kwanza Norte | 30 |
| | KIWABANZOJI I | Malanje | 62 |
| | MUSSENDE I | Kwanza Sul | 36 |
| | NHAREA | Bie | 36 |
| | TOMBWA | Namibe | 100 |
| Sub total | 8 | | 488 |
| Solar Power | BENGUELA | Benguela | 10 |
| | CARACULO | Namibe | 10 |
| | CAMBONGUE | Namibe | 10 |
| | GANDA/ALTOCATUMBELA | Benguela | 10 |
| | LOBITO/CATUMBELA | Benguela | 10 |
| | LUBANGO | Huila | 10 |
| | MATALA | Huila | 10 |
| | QUIPUNGO | Huila | 10 |
| | NAMACUNDE | Cunene | 10 |
| | TECHAMUTETE | Huila | 10 |
| Sub total | 9 | | 90 |
| Biomass | 1 Biomass Project, (No Project Name as of 2018) | Huila | 3 |
| Sub total | 1 | | 3 |
| Total | 22 | | |

(2) Locations of the candidate power development sites

The map below shows the locations of the candidate sites.



(Source: ERM Report)

Figure 11-6 Locations of the Generation Power Site

(3) Evaluation of each project from social and environmental viewpoints

(a) Hydropower Plant

(a)-1. CAMBAMBE Hydropower Plant

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment
 - There are 4 types of vegetation zone in the site area: (1) Dry savannah with more or less scattered shrubs and trees; (2) Forests of tall, semi-deciduous trees with many climbing plants; (3) Communities of aquatic plants, and (4) plant communities from the cliff margins. Some of the floral species in these zones have low abundance, so any small change could potentially lead to species extinct around the site area.
 - The vegetation is expected to change near the river banks due to the change of the river flow downstream of the dam.

- A change in the migratory patterns of the mammals is expected due to the scarcity of existing habitats.
- There is some concern that excavation and construction for access roads and transmission lines will lead to soil erosion.
- Social Environment
 - There are only a few number of resettlements of rural people.
 - The area is characterized by the presence of well-developed industrial facilities and residential areas.
 - No heritage resources are expected to be affected by the project.



Figure 11-7 Site for CAMBAMBE Hydropower Plant

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-12 Evaluation Results on the CAMBAMBE HPP

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|--|
| Natural | 1 | Topography & Geology | Destruction of ground | -1.0 | Drilling and construction of access roads may cause erosion, but mitigation measures are possible. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | -1.0 | Soil erosion is assumed, but mitigation measures (embankment, planting on the cut surface) are possible. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | -1.0 | There is concern about the influence on wetlands etc in the downstream area, but mitigation measures are possible. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Dust flight is assumed, but it is temporary, there is no emission of pollutants at the time of operation phase. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Waste | Domestic or industrial waste from facilities | 0.0 | Waste is properly processed through 3R (Reduce, Reuse, Recycle) rule. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | -2.0 | Lost of some species of plant is assumed. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | -1.0 | There is concern about the influence on wetlands etc in the downstream area, but mitigation measures are possible. The flight route of birds has not been confirmed. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.60 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | -1.0 | Resettlement of some houses is assumed. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Water Use | Water use conflict | -1.0 | Competition of water use due to intake from rivers in the downstream area is assumed, but mitigation measures (maintenance release) are possible. |
| | 5 | Landscape | Destruction of landscape | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.33 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | CO ₂ will be produced from construction work although the emission is limited and negligible on climate change. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.31 | |

(Source: JICA Survey Team)

(a)-2. MATALA Hydropower Plant

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment
 - The site is located in the proximity of an urban area with lots of human activities. Aquatic plants, scattered shrubs and trees, and tall and dense trees close to river banks are expected to be found in certain areas where no human activities take place (e.g.: crops).
 - No substantial change is expected in the migratory patterns of the mammals due to small effects on the existing habitats.
 - Hydropower activity could potentially affect species vulnerability by changing the ecosystem.
 - No significant noise impacts on the social environment are expected.
- Social Environment
 - There are some rural resettlements in the area.

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-13 Evaluation Results on the MATA LA HPP

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|--|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | -1.0 | There is concern about the influence on aquatic plants etc in the downstream area, but mitigation measures are possible. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Dust might be assumed, but it is temporary, there is no emission of pollutants at the time of operation. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Waste | Domestic or industrial waste from facilities | 0.0 | Waste is properly processed through 3R (Reduce, Reuse, Recycle) rule. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | -1.0 | Lost of some species of plant is assumed. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | 0.0 | There is concern about the influence on wetlands etc in the downstream area, but mitigation measures are possible. The flight route of birds has not been confirmed. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.20 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | -1.0 | Resettlement of some houses is assumed. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Water Use | Water use conflict | -1.0 | Competition of water use due to intake from rivers in the downstream area is assumed, but mitigation measures (maintenance release) are possible. |
| | 5 | Landscape | Destruction of landscape | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.33 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | CO ₂ will be produced from construction work although the emission is limited and negligible on climate change. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.17 | |

(Source: JICA Survey Team)

(b) Thermal Power

(b)-1. CIMANGOLA Thermal Power Plant

CIMANGOLA thermal power plant was only selected as a thermal power plant candidate site for SEA from MINEA.

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment
 - The project site is located in a highly populated area with intense traffic from a combination of industrial-use and specified-use vehicles of nearby roads. Accordingly, there are no significant natural resources to be protected.
 - The predominant soil type in the area is silt soil (0-10% clay), so dry cracks form during dry season. The soil contains a brown expansive clay of silky sand, so soil erosion is a concern during wet season.
 - There is a risk of contamination of air quality by emissions of SO₂, NO₂ and PM₁₀.
 - Negative impact from the generation of noise above the recommended standards is expected around the border between the living quarter and proposed site area.
- Social Environment
 - There is concern that water resources may be contaminated if groundwater is pumped up and used as cooling water.
 - There are some rural resettlements.
- Global Environment
 - Carbon dioxide emissions are expected even after introduction of mitigation measures.



Figure 11-8 Site for CIMANGOLA Thermal Power Plant

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-14 Evaluation Results on the CIMANGOLA Thermal Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|---|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | -2.0 | Soil contamination due to the loss of oil from treatment facilities and pipeline installation is expected, but mitigation measures are possible. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | -2.0 | Rising in the water temperature is expected due to a large amount of thermal effluent to the ocean or river, and in the case of large capacity, mitigation measures are impossible. |
| | 4 | Quality of Air | Emission of pollutants from facilities | -2.0 | Pollution of air quality (NO ₂ , SO ₂ , PM 10, etc.) due to smoke is expected; mitigation measures (introduction of high combustion efficiency boiler, installation of denitration/desulfur, dustproof devices) are possible. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | -1.0 | Noise is assumed, but mitigation measures (construction in remote areas) are possible. |
| | 6 | Waste | Domestic or industrial waste from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | -2.0 | Rising in the water temperature is expected due to a large amount of thermal effluent to the ocean or river, and the influence on plants (mangrove, marine plants) is assumed. In the case of large capacity, mitigation measures are impossible. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | -2.0 | Rising in the water temperature is expected due to a large amount of thermal effluent to the ocean or river, and in the case of large capacity, mitigation measures are impossible. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -1.10 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | -1.0 | Resettlement of some houses is assumed. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Water Use | Water use conflict | -1.0 | Competition for water use due to intake from peripheral rivers as cooling water is assumed, but mitigation measures (introduction of air cooling system) are possible. |
| | 5 | Landscape | Destruction of landscape | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.33 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | -2.0 | CO ₂ emissions is expected. |
| Impact Indicator to Global Environment | | | | -2.00 | |
| Comprehensive Impact Indicator | | | | -1.14 | |

(Source: JICA Survey Team)

(c) Wind Power

(c)-1. BENJAMIN Wind Power

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment
 - The area is characterized mainly by Savannah and bare land.
 - There is concern about a cliff area with a probable concentration of migratory birds.
 - Operational noise may negatively impact agricultural houses nearby.
- Social Environment
 - A farm is located within the buffer area at a distance of around 1 km. Compensation might be required, considering the current land use.



Figure 11-9 Site for BENJAMIN Wind Power Plant

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-15 Evaluation Results on the BENJAMIN Wind Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|---|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | -1.0 | Noise is assumed, but mitigation measures (construction in remote areas) are possible. |
| | 6 | Waste | Domestic or industrial waste from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | -3.0 | The occurrence of bird strike accident is assumed. Even adopting mitigation measures to avoid migratory birds' flight routes, it is difficult to eradicate such an accident. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.40 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | -1.0 | Land competition is assumed, but mitigation (securing of substitute) is possible. |
| | 4 | Water Use | Water use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Landscape | Destruction of landscape | -3.0 | Huge artificial structures appear in the wilderness, etc., so there is concern about serious influence on the surrounding environment, and mitigation measures are difficult. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.66 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.35 | |

(Source: JICA Survey Team)

(c)-2. CACULA Wind Power

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment
 - The area is characterized mainly by forests and agricultural patches. Construction yards and access roads will alter the landscape settings.
 - There is concern about a cliff area with a probable concentration of migratory birds.
 - Reptiles, rodents and other species may be found in the area and could be affected during the installation of the turbines and associated infrastructure.
 - Operational noise may negatively impact agricultural houses nearby.
- Social Environment
 - A farm is located within the buffer area within a range of about 1 km. Compensation might be required, considering the current land use.

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-16 Evaluation Results on the CACULA Wind Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|---|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | -1.0 | Noise is assumed, but mitigation measures (construction in remote areas) are possible. |
| | 6 | Waste | Domestic or industrial waste from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | -3.0 | The occurrence of bird strike accident is assumed. Even adopting mitigation measures to avoid migratory birds' flight routes, it is difficult to eradicate such an accident. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.40 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | -1.0 | resettlement might be required within 1Km. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | -1.0 | Land competition is assumed, but mitigation (securing of substitute) is possible. |
| | 4 | Water Use | Water use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Landscape | Destruction of landscape | -3.0 | Huge artificial structures appear in the wilderness, etc., so there is concern about serious influence on the surrounding environment, and mitigation measures are difficult. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.83 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.41 | |

(Source: JICA Survey Team)

(c)-3. CALENGA Wind Power

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

● Natural Environment

- The area is characterized by savannah and agricultural patches in the north, while the south is mostly covered by forest.
- The site area is situated in Serra do Uendelongo. There is concern about a cliff area with a probable concentration of migratory birds.
- There are expected to be corridors for birds of prey in the site area.

● Social Environment

- There is no agricultural land to be compensated in the buffer area within an approximately 1 km range.




Figure 11-10 Site for CALENGA Wind Power Plant

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-17 Evaluation Results on the CALENGA Wind Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|---|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Waste | Domestic or industrial waste from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | -3.0 | The occurrence of bird strike accident is assumed. Even adopting mitigation measures to avoid migratory birds' flight routes, it is difficult to eradicate such an accident. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.30 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | -1.0 | Land competition is assumed, but mitigation (securing of substitute) is possible. |
| | 4 | Water Use | Water use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Landscape | Destruction of landscape | -3.0 | Huge artificial structures appear in the wilderness, etc., so there is concern about serious influence on the surrounding environment, and mitigation measures are difficult. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.66 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.32 | |

(Source: JICA Survey Team)

(c)-4. GASTAO Wind Power

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment

- The area is characterized by savannah and agricultural patches in the north, while the south is mostly covered by forest.
- There is concern about a site area with a probable concentration of migratory birds.

- Social Environment

- There are no agricultural lands or houses to be compensated in the buffer area within an approximately 1 km range.




Figure 11-11 Site for GASTAO Wind Power Plant

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-18 Evaluation Results on the GASTAO Wind Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|---|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Waste | Domestic or industrial waste from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | -3.0 | The occurrence of bird strike accident is assumed. Even adopting mitigation measures to avoid migratory birds' flight routes, it is difficult to eradicate such an accident. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.30 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Water Use | Water use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Landscape | Destruction of landscape | -3.0 | Huge artificial structures appear in the wilderness, etc., so there is concern about serious influence on the surrounding environment, and mitigation measures are difficult. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.50 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.26 | |

(Source: JICA Survey Team)

(c)-5. KIWABANZOJI I Wind Power

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment
 - The area is characterized mainly by savannah, with some part covered by forests.
 - The nearest protected area is located 40 km east of the site (Milando Special Reserve). No project impacts on the reserve are expected.
- Social Environment
 - There are 118 dwellings in the area.
 - Agricultural lands are located in the buffer area within a range of around 1 km. Compensation might be required, considering the current land use. Influences of the project on the agricultural lands can be avoided by modifying certain design aspects (place of installation, etc.)



Figure 11-12 Site for KIWABANZOJI I Wind Power Plant

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-19 Evaluation Results on the KIWABANZOJI I Wind Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|---|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | -2.0 | Windmill noise is assumed, but mitigation measures (construction in remote areas) are possible. |
| | 6 | Waste | Domestic or industrial waste from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | -3.0 | The occurrence of bird strike accident is assumed. Even adopting mitigation measures to avoid migratory birds' flight routes, it is difficult to eradicate such an accident. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.50 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | -2.0 | A serious negative direct impact due to resettlement of residents is assumed, but mitigation measures (recovery of living base after relocation, securing alternative place etc.) are possible. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Water Use | Water use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Landscape | Destruction of landscape | -3.0 | Huge artificial structures appear in the wilderness, etc., so there is concern about serious influence on the surrounding environment, and mitigation measures are difficult. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.83 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.44 | |

(Source: JICA Survey Team)

(c)-6. MUSSENDE I Wind Power

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment
 - There are mosaic agriculture lands located within 500 m from the site.
 - The nearest protected area (Luanda Integral Nature Reserve) is located 40 km east from the site. No project impacts on the reserve are expected.
- Social Environment
 - There are villages in the south part of the site area. Negative impact from noise is expected.
 - Agricultural lands are located within the 500 m buffer zone of the site area. Resettlement and compensation may be required.



Figure 11-13 Site for MUSSENDE I Wind Power Plant

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-20 Evaluation Results on the MUSSENDE I Wind Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|---|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | -2.0 | Windmill noise is assumed, but mitigation measures (construction in remote areas) are possible. |
| | 6 | Waste | Domestic or industrial waste from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | -3.0 | The occurrence of bird strike accident is assumed. Even adopting mitigation measures to avoid migratory birds' flight routes, it is difficult to eradicate such an accident. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.50 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | -2.0 | A serious negative direct impact due to resettlement of residents is assumed, but mitigation measures (recovery of living base after relocation, securing alternative place etc.) are possible. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Water Use | Water use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Landscape | Destruction of landscape | -3.0 | Huge artificial structures appear in the wilderness, etc., so there is concern about serious influence on the surrounding environment, and mitigation measures are difficult. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.83 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.44 | |

(Source: JICA Survey Team)

(c)-7. NHAREA Wind Power

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment
 - The site area is covered by dense forest with a high potential for rich biodiversity.
 - The nearest protected area (Luanda Integral Nature Reserve) is located 40 km east of the site. No project impacts on the reserve are expected.
- Social Environment
 - There are no houses near the project site.
 - Agricultural lands are located within the 500 m buffer zone of the site area. Resettlement and compensation may be required.




Figure 11-14 Site for NHAREA Wind Power Plant

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-21 Evaluation Results on the NHAREA Wind Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|---|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Waste | Domestic or industrial waste from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | -1.0 | Impacts to the forest near project site is assumed, but mitigation measures will be possible. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | -3.0 | The occurrence of bird strike accident is assumed. Even adopting mitigation measures to avoid migratory birds' flight routes, it is difficult to eradicate such an accident. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.40 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | -1.0 | Competition for land use of agriculture is assumed, but mitigation measures (securing alternative site) are possible. |
| | 4 | Water Use | Water use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Landscape | Destruction of landscape | -3.0 | Huge artificial structures appear in the wilderness, etc., so there is concern about serious influence on the surrounding environment, and mitigation measures are difficult. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.66 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.35 | |

(Source: JICA Survey Team)

(c)-8. TOMBWA Wind Power

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment
 - The project area is located in the Namibe Desert near the coast. Migratory birds and some birds of prey (e.g.: *Circaetus pectoral*) live there.
 - Typical flora species in the site area include *Stoebe cinerea* and several sparse grasses common among the dry areas of the desert.
 - The project is located inside the Iona National Park.
- Social Environment
 - There are no houses or land for agriculture near the project site.



Figure 11-15 Site for TOMBWA Wind Power Plant

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-22 Evaluation Results on the TOMBWA Wind Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|---|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Waste | Domestic or industrial waste from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | -1.0 | Impacts to the forest near project site is assumed, but mitigation measures will be possible. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | -3.0 | The occurrence of bird strike accident is assumed. Even adopting mitigation measures to avoid migratory birds' flight routes, it is difficult to eradicate such an accident. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | -3.0 | Influence on the flight and ecology of bird species' habitats in protected areas is assumed. |
| Impact Indicator to Natural Resources | | | | -0.70 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Water Use | Water use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Landscape | Destruction of landscape | -3.0 | Huge artificial structures appear in the wilderness, etc., so there is concern about serious influence on the surrounding environment, and mitigation measures are difficult. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.50 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.40 | |

(Source: JICA Survey Team)

(d) Solar Power Plant

(d)-1. BENGUELA Solar Power Plant

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment
 - The site area is covered with grass, small shrubs, and meadows.
 - There is low possibility of soil erosion, since the terrain of the site is flat.
 - Batteries will also be installed for use during operations, so industrial waste is expected.
- Social Environment
 - There are several houses around the site.



Figure 11-16 Site for BENGUELA Solar Power Plant

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-23 Evaluation Results on the BENGUELA Solar Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|--|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Waste | Domestic or industrial waste from facilities | -2.0 | A large amount of waste (solar cell modules, storage batteries, power conditioners, etc.) is assumed after reaching the end of its life, but mitigation measures (promotion of 3R) are possible. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | -2.0 | There is a concern about serious impacts on vegetation due to the bare ground under the panels, but mitigation measures (planting of shade-tolerant plants under the panels) are possible. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | -1.0 | There is a concern about the influence of large-scale facilities on the movement route of animals, but mitigation measures are possible. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.50 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | -1.0 | A negative direct impact due to resettlement of residents is assumed, but mitigation measures (securing alternative place etc.) are possible. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Water Use | Water use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Landscape | Destruction of landscape | -3.0 | Huge artificial structures appear at the foot of mountains, in the wilderness, etc., and there is concern about serious impact on the surrounding environment, but mitigation measures (tree planting around the facility) are possible. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.66 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.38 | |

(Source: JICA Survey Team)

(d)-2. CARACULO Solar Power Plant

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment
 - The site area is a suitable habitat for important reptiles and small rodents.
 - There is a possibility of soil erosion due to excavation and construction for access roads and transmission lines.
 - Batteries will also be installed for use during operations, so industrial waste is expected.
- Social Environment
 - There are no houses around the site.



Figure 11-17 Site for CARACULO Solar Power Plant

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-24 Evaluation Results on the CARACULO Solar Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|--|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | -1.0 | Soil collapse, top soil release, and soil erosion is assumed, but mitigation measures (paving, stabilization of foundation soil by gravel bed) are possible. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Waste | Domestic or industrial waste from facilities | -2.0 | A large amount of waste (solar cell modules, storage batteries, power conditioners, etc.) is assumed after reaching the end of its life, but mitigation measures (promotion of 3R) are possible. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | -2.0 | There is a concern about serious impacts on vegetation due to the bare ground under the panels, but mitigation measures (planting of shade-tolerant plants under the panels) are possible. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | -1.0 | There is a concern about the influence of large-scale facilities on the movement route of animals, but mitigation measures are possible. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.60 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Water Use | Water use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Landscape | Destruction of landscape | -3.0 | Huge artificial structures appear at the foot of mountains, in the wilderness, etc., and there is concern about serious impact on the surrounding environment, but mitigation measures (tree planting around the facility) are possible. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.50 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.36 | |

(Source: JICA Survey Team)

(d)-3. CAMBOUNGUE Solar Power Plant

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment
 - The site is located in a desert area devoid of natural vegetation.
 - There is a possibility of soil erosion due to excavation and construction for access roads and transmission lines.
 - Batteries will also be installed for use during operations, so industrial waste is expected.
- Social Environment
 - A port city (Sacomar) is located about 3 km west of the site, but no project impacts are expected.



Figure 11-18 Site for CAMBOUNGUE Solar Power Plant

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-25 Evaluation Results on the CAMBOUNGUE Solar Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|--|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | -1.0 | Soil collapse, top soil release, and soil erosion is assumed, but mitigation measures (paving, stabilization of foundation soil by gravel bed) are possible. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Waste | Domestic or industrial waste from facilities | -2.0 | A large amount of waste (solar cell modules, storage batteries, power conditioners, etc.) is assumed after reaching the end of its life, but mitigation measures (promotion of 3R) are possible. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | -2.0 | There is a concern about serious impacts on vegetation due to the bare ground under the panels, but mitigation measures (planting of shade-tolerant plants under the panels) are possible. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | -2.0 | There is a concern about the influence of large-scale facilities on the flying route of migratory birds. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.70 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Water Use | Water use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Landscape | Destruction of landscape | -3.0 | Huge artificial structures appear at the foot of mountains, in the wilderness, etc., and there is concern about serious impact on the surrounding environment, but mitigation measures (tree planting around the facility) are possible. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.50 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.40 | |

(Source: JICA Survey Team)

(d)-4. GANDA/ALTOCATUMBELA Solar Power Plant

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment
 - The site area is suitable for habitats of important reptiles and small rodents.
 - The site is a savanna zone with agricultural land patches mixed in.
 - There is a possibility of soil erosion due to excavation and construction for access roads and transmission lines.
 - Batteries will also be installed for use during operations, so industrial waste is expected.
- Social Environment
 - Some of the agricultural lands may be affected. The land use may change and compensation may be required. Some of the possible influences during project implementation can be avoided by modifying design aspects (place of installation, etc.)




Figure 11-19 Site for GANDA/ALTOCATUMBELA Solar Power Plant

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-26 Evaluation Results on the GANDA/ALTOCATUMBELA Solar Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|--|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | -1.0 | Soil collapse, top soil release, and soil erosion is assumed, but mitigation measures (paving, stabilization of foundation soil by gravel bed) are possible. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Waste | Domestic or industrial waste from facilities | -2.0 | A large amount of waste (solar cell modules, storage batteries, power conditioners, etc.) is assumed after reaching the end of its life, but mitigation measures (promotion of 3R) are possible. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | -2.0 | There is a concern about serious impacts on vegetation due to the bare ground under the panels, but mitigation measures (planting of shade-tolerant plants under the panels) are possible. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | -1.0 | There is a concern about the influence of large-scale facilities on the movement route of animals, but mitigation measures are possible. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.60 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Water Use | Water use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Landscape | Destruction of landscape | -3.0 | Huge artificial structures appear at the foot of mountains, in the wilderness, etc., and there is concern about serious impact on the surrounding environment, but mitigation measures (tree planting around the facility) are possible. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.50 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.36 | |

(Source: JICA Survey Team)

(d)-5. LOBITO/CATUMBELA Solar Power Plant

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment
 - The site is located in a desert area, but there are residential areas around the site.
 - There is a possibility of soil erosion due to excavation and construction for access roads and transmission lines.
 - Batteries will also be installed for use during operations, so industrial waste is expected.
- Social Environment
 - Some of the grass fields may be affected, possibly necessitating a change in land use and compensation. Some of the influences during project implementation can be avoided by modifying design aspects (place of installation, etc.)



Figure 11-20 Site for Solar LOBITO/CATUMBELA Power Plant

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-27 Evaluation Results on the LOBITO/CATUMBELA Solar Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|--|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | -1.0 | Soil collapse, top soil release, and soil erosion is assumed, but mitigation measures (paving, stabilization of foundation soil by gravel bed) are possible. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Waste | Domestic or industrial waste from facilities | -2.0 | A large amount of waste (solar cell modules, storage batteries, power conditioners, etc.) is assumed after reaching the end of its life, but mitigation measures (promotion of 3R) are possible. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.30 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Water Use | Water use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Landscape | Destruction of landscape | -3.0 | Huge artificial structures appear at the foot of mountains, in the wilderness, etc., and there is concern about serious impact on the surrounding environment, but mitigation measures (tree planting around the facility) are possible. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.50 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.26 | |

(Source: JICA Survey Team)

(d)-6. LUBANGO Solar Power Plant

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment
 - The site area is suitable for habitats of important reptiles and small rodents.
 - The site is located in a desert area, with no residential areas situated nearby.
 - There is a possibility of soil erosion due to excavation and construction for access roads and transmission lines.
 - Batteries will also be installed for use during operations, so industrial waste is expected.
- Social Environment
 - Some of agricultural lands may be affected, possibly necessitating a change in the land use and compensation. Some of the influences during project implementation can be avoided by modifying design aspects (place of installation, etc.)




Figure 11-21 Site for LUBANGO Solar Power Plant

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-28 Evaluation Results on the LUBANGO Solar Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|--|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | -1.0 | Soil collapse, top soil release, and soil erosion is assumed, but mitigation measures (paving, stabilization of foundation soil by gravel bed) are possible. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Waste | Domestic or industrial waste from facilities | -2.0 | A large amount of waste (solar cell modules, storage batteries, power conditioners, etc.) is assumed after reaching the end of its life, but mitigation measures (promotion of 3R) are possible. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | -1.0 | There is a concern about the influence of large-scale facilities on the movement route of animals, but mitigation measures are possible. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.40 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | 0.0 | Impacts that require mitigation measures are assumed, but mitigation measures are possible. |
| | 4 | Water Use | Water use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Landscape | Destruction of landscape | -3.0 | Huge artificial structures appear at the foot of mountains, in the wilderness, etc., and there is concern about serious impact on the surrounding environment, but mitigation measures (tree planting around the facility) are possible. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.50 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.30 | |

(Source: JICA Survey Team)

(d)-7. MATALA Solar Power Plant

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment
 - The site area is suitable for habitats of important reptiles and small rodents.
 - There is a possibility of soil erosion due to excavation and construction for access roads and transmission lines.
 - Batteries will also be installed for use during operations, so industrial waste is expected.
- Social Environment
 - Some of the agricultural lands may be affected, possibly necessitating a change in the land use and compensation. Some of the influences during project implementation can be avoided by modifying design aspects (place of installation, etc.).



Figure 11-22 Site for MATALA Solar Power Plant

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-29 Evaluation Results on the MATALA Solar Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|--|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | -1.0 | Soil collapse, top soil release, and soil erosion is assumed, but mitigation measures (paving, stabilization of foundation soil by gravel bed) are possible. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Waste | Domestic or industrial waste from facilities | -2.0 | A large amount of waste (solar cell modules, storage batteries, power conditioners, etc.) is assumed after reaching the end of its life, but mitigation measures (promotion of 3R) are possible. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | -1.0 | There is a concern about the influence of large-scale facilities on the movement route of animals, but mitigation measures are possible. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.40 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Water Use | Water use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Landscape | Destruction of landscape | -3.0 | Huge artificial structures appear at the foot of mountains, in the wilderness, etc., and there is concern about serious impact on the surrounding environment, but mitigation measures (tree planting around the facility) are possible. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.50 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.30 | |

(Source: JICA Survey Team)

(d)-8. QUIPUNGO Solar Power Plant

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment
 - The area is an agricultural land cultivated in a mosaic pattern, with 84 residences situated in the 1 km buffer area around the site.
 - A water resource (Cuanhama pond) is located nearby.
 - Batteries will also be installed for use during operations, so industrial waste is expected.
- Social Environment
 - The 84 houses in the surrounding area may be affected by the installation of panels.
 - Some of agricultural lands may be affected, possibly necessitating a change in the land use and compensation.




Figure 11-23 Site for QUIPUNGO Solar Power Plant

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-30 Evaluation Results on the QUIPUNGO Solar Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|--|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | 0.0 | Soil collapse, top soil release, and soil erosion is assumed, but mitigation measures (paving, stabilization of foundation soil by gravel bed) are possible. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | -1.0 | Occurrence of muddy flow due to soil erosion is assumed, but mitigation measures (construction of adjustment reservoirs and installation of drainage channels) are possible. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Waste | Domestic or industrial waste from facilities | -2.0 | A large amount of waste (solar cell modules, storage batteries, power conditioners, etc.) is assumed after reaching the end of its life, but mitigation measures (promotion of 3R) are possible. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | 0.0 | There is a concern about the influence of large-scale facilities on the movement route of animals, but mitigation measures are possible. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.30 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | -1.0 | The use of agricultural land may be restricted. |
| | 4 | Water Use | Water use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Landscape | Destruction of landscape | -3.0 | Huge artificial structures appear at the foot of mountains, in the wilderness, etc., and there is concern about serious impact on the surrounding environment, but mitigation measures (tree planting around the facility) are possible. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.66 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.32 | |

(d)-9. NAMACUNDE Solar Power Plant

(Source: JICA Survey Team)

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment
 - The area is primarily forested and some parts are covered with savanna.
 - A water source (Cuanhama pond) is located nearby.
 - The site area is suitable for habitats of important reptiles and small rodents.
 - Storage batteries will be installed for use during operations, so industrial waste is expected.
- Social Environment
 - Agricultural lands are located in the surrounding area, and impacts are assumed. Some of the influences during project implementation can be avoided by modifying design aspects (place of installation, etc.).




Figure 11-24 Site for NAMACUNDE Solar Power Plant

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-31 Evaluation Results on the NAMACUNDE Solar Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|--|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | 0.0 | Soil collapse, top soil release, and soil erosion is assumed, but mitigation measures (paving, stabilization of foundation soil by gravel bed) are possible. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | -1.0 | Occurrence of muddy flow due to soil erosion is assumed, but mitigation measures (construction of adjustment reservoirs and installation of drainage channels) are possible. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Waste | Domestic or industrial waste from facilities | -2.0 | A large amount of waste (solar cell modules, storage batteries, power conditioners, etc.) is assumed after reaching the end of its life, but mitigation measures (promotion of 3R) are possible. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | 0.0 | There is a concern about the influence of large-scale facilities on the movement route of animals, but mitigation measures are possible. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.30 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Water Use | Water use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Landscape | Destruction of landscape | -3.0 | Huge artificial structures appear at the foot of mountains, in the wilderness, etc., and there is concern about serious impact on the surrounding environment, but mitigation measures (tree planting around the facility) are possible. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.50 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.26 | |

(Source: JICA Survey Team)

(d)-10. TECHAMUTETE Solar Power Plant

i) Following is a summary of the main features of the natural and social environments identified through the SEA survey.

- Natural Environment
 - The area is mainly characterized by savanna and bare land, with a national park located nearby.
 - The site is surrounded by an area of bare fields, with an iron man located nearby.
 - A water source (Cuanhama pond) is located nearby.
 - Batteries will also be installed for use during operations, so industrial waste is expected.
- Social Environment
 - There are no residences or agricultural lands in the surrounding area.




Figure 11-25 Site for TECHAMUTETE Solar Power Plant

ii) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

Table 11-32 Evaluation Results on the TECHAMUTETE Solar Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|--|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | 0.0 | Soil collapse, top soil release, and soil erosion is assumed, but mitigation measures (paving, stabilization of foundation soil by gravel bed) are possible. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | -1.0 | Occurrence of muddy flow due to soil erosion is assumed, but mitigation measures (construction of adjustment reservoirs and installation of drainage channels) are possible. |
| | 4 | Quality of Air | Emission of pollutants from facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Waste | Domestic or industrial waste from facilities | -2.0 | A large amount of waste (solar cell modules, storage batteries, power conditioners, etc.) is assumed after reaching the end of its life, but mitigation measures (promotion of 3R) are possible. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | 0.0 | There is a concern about the influence of large-scale facilities on the movement route of animals, but mitigation measures are possible. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.30 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Water Use | Water use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 5 | Landscape | Destruction of landscape | -3.0 | Huge artificial structures appear at the foot of mountains, in the wilderness, etc., and there is concern about serious impact on the surrounding environment, but mitigation measures (tree planting around the facility) are possible. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.50 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.26 | |

(Source: JICA Survey Team)

(e) Biomass Power Plant

(e)-1. Huila Biomass Power Plant

MINEA nominated only one biomass power plant, with a 3 MW capacity plant. The plant is to be located somewhere within the Huila District, but the exact location is uncertain.

Referring examples from other countries, the JICA Study Team evaluated an assumed case where the plant is to be constructed in “Some Area” of Huila District, from environmental and social viewpoints.

i) Evaluation from environmental and social viewpoints

Following is a summary of the evaluation results on the expected influences of this project on the natural, social, and global environments.

ii) Evaluation from environmental and social viewpoints

Table 11-33 Evaluation Results on the Huila Biomass Power Plant Power Plant

| Group | No. | Item | Indicator | Score | Basis of Score |
|---|-----|---------------------------------------|---|--------------|--|
| Natural | 1 | Topography & Geology | Destruction of ground | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Soil | Erosion, Disposal, Leakage of toxic substances, Peeling off of top soil | 0.0 | Soil collapse, top soil release, and soil erosion is assumed, but mitigation measures (paving, stabilization of foundation soil by gravel bed) are possible. |
| | 3 | Quality of Water | Pollution due to water-diversion / sedimentation of toxic substances | -1.0 | Leakage of polluted water from the collection materials is expected, but mitigation measures (drainage canals, construction of purification ponds) are possible. |
| | 4 | Quality of Air | Emission of pollutants from facilities | -1.0 | Contamination of air quality (NO ₂ , SO ₂ , PM 10, etc.) is assumed, but mitigation measures (introduction of high efficiency boilers, installation of denitrification/sulfur, dustproof device) are possible. |
| | 5 | Noise/Vibration | Noise/vibration from facilities or operation activities | -1.0 | Noise due to vehicles and heavy machinery used for loading materials, discharging waste, etc. are assumed, but mitigation measures (low noise vehicles, maintenance of vehicles at regular intervals, etc.) are possible. |
| | 6 | Waste | Domestic or industrial waste from facilities | -2.0 | A serious negative direct impact is assumed when securing the disposal site for waste (combustion residues, etc.), but mitigation measures (promotion of 3R etc.) are possible. |
| | 7 | Subsidence | Use of underground water by facilities | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 8 | Flora | Deforestation (including mangroves), peeling of vegetation, changing of the flora ecosystem | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 9 | Fauna/Fish/Coral | Destruction of animal habitats/ecosystems, adverse on migratory fish or birds | 0.0 | There is a concern about the influence of large-scale facilities on the movement route of animals, but mitigation measures are possible. |
| | 10 | Natural Protected Areas | Impacts on strict natural protected areas such as National Parks | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Natural Resources | | | | -0.50 | |
| Social | 1 | Resettlement | Involuntary resettlement / loss of means of livelihood | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 2 | Ethnic minorities / Indigenous people | Adverse impacts on vulnerable people | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 3 | Land Use | Land use conflict | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 4 | Water Use | Water use conflict | -1.0 | Competition for water use due to intake from peripheral rivers as cooling water is assumed, but mitigation measures (introduction of air cooling system) are possible. |
| | 5 | Landscape | Destruction of landscape | 0.0 | Impacts that require mitigation measures are not assumed. |
| | 6 | Historical Heritage | Loss of local heritage | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Social Resources | | | | -0.15 | |
| Global | 1 | Green House Gas | Emission of CO ₂ | 0.0 | Impacts that require mitigation measures are not assumed. |
| Impact Indicator to Global Environment | | | | 0.00 | |
| Comprehensive Impact Indicator | | | | -0.21 | |

(Source: JICA Survey Team)

11.7 Environmental Evaluation

The table below presents the results of the SEA evaluation on power development from environmental and social viewpoints by indicator (degree of environmental impact).

The power source ranking by negative impact on the natural and social environments, in ascending order (from lowest to highest), was as follows: (i). Biomass, (ii). Hydropower, (iii). Solar, (iv). Wind, (v). Thermal (LNG/Heavy Oil).


The relatively high total environmental impact of wind power and solar power generation stems from the large negative impact on the local landscape caused by the appearance of huge artificial structures in the vast plains of the continent of Africa (mainly savanna, shrub vegetation).

Table 11-34 Environmental indicator on each power generation plant

| | Type | HYPP | | THPP | Wind PP | | | | | | | | | | Solar PP | | | | | | | | | | Bio. PP |
|---|------|-------|-------|-------|---------|-------|-------|-------|-------|--------|-------|-------|--------|--------|----------|--------|--------|--------|--------|--------|--------|--------|--------|--|---------|
| | Name | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | | |
| | MW | 960 | 40.8 | 212 | 52 | 88 | 84 | 30 | 62 | 36 | 36 | 100 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 3 | | |
| Topography & Geology | | -1.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| Soil | | -1.0 | 0.0 | -2.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | -1.0 | -1.0 | -1.0 | -1.0 | -1.0 | -1.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| Quality of Water | | -1.0 | -1.0 | -2.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | -1.0 | -1.0 | -1.0 | -1.0 | | |
| Quality of Air | | 0.0 | 0.0 | -2.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | -1.0 | | |
| Noise/Vibration | | 0.0 | 0.0 | -1.0 | -1.0 | -1.0 | 0.0 | 0.0 | -2.0 | -2.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | -1.0 | | |
| Waste | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | -2.0 | -2.0 | -2.0 | -2.0 | -2.0 | -2.0 | -2.0 | -2.0 | -2.0 | -2.0 | -2.0 | | |
| Subsidence | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| Flora | | -2.0 | -1.0 | -2.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | -1.0 | -1.0 | -2.0 | -2.0 | -2.0 | -2.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| Fauna/Fish/Coral | | -1.0 | 0.0 | -2.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | -1.0 | -1.0 | -2.0 | -1.0 | 0.0 | -1.0 | -1.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| Nature Protected Areas | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | -3.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| (Natural Environment) | | -0.60 | -0.20 | -1.10 | -0.40 | -0.40 | -0.30 | -0.30 | -0.50 | -0.50 | -0.40 | -0.70 | 0.50 | -0.60 | -0.70 | -0.60 | -0.30 | -0.40 | -0.40 | -0.30 | -0.30 | -0.30 | -0.50 | | |
| (Average) | | -0.40 | | -1.10 | | | | -0.43 | | | | | | | | | -0.44 | | | | | | -0.50 | | |
| Resettlement | | -1.0 | -1.0 | -1.0 | 0.0 | -1.0 | -1.0 | 0.0 | -2.0 | -2.0 | 0.0 | 0.0 | -1.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| Ethnic/Indigenous pec | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| Land use | | 0.0 | 0.0 | 0.0 | -1.0 | -1.0 | -1.0 | 0.0 | 0.0 | 0.0 | -1.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | -1.0 | 0.0 | 0.0 | 0.0 | | |
| Water Use | | -1.0 | -1.0 | -1.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | -1.0 | | |
| Landscape | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | -3.0 | 0.0 | | |
| Historical Heritage | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| (Social Environment) | | -0.33 | -0.33 | -0.33 | -0.66 | -0.83 | -0.66 | -0.50 | -0.83 | -0.83 | -0.66 | -0.50 | -0.66 | -0.50 | -0.50 | -0.50 | -0.50 | -0.50 | -0.50 | -0.66 | -0.50 | -0.50 | -0.15 | | |
| (Average) | | -0.33 | | -0.33 | | | | -0.68 | | | | | | | | | -0.53 | | | | | | -0.15 | | |
| Ren House Gas | | 0.0 | 0.0 | -2.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | |
| (Global Environment) | | 0.00 | 0.00 | -2.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | | |
| (Average) | | 0.00 | | -2.00 | | | | 0.00 | | | | | | | | | 0.00 | | | | | | 0.00 | | |
| Comprehensive Environmental Indexes | | -0.31 | -0.17 | -1.14 | -0.35 | -0.41 | -0.32 | -0.26 | -0.44 | -0.44 | -0.35 | -0.40 | -0.38 | -0.36 | -0.40 | -0.36 | -0.26 | -0.30 | -0.30 | -0.32 | -0.26 | -0.26 | -0.21 | | |
| Comprehensive Environmental Indexes (Average) | | -0.24 | | -1.14 | | | | -0.31 | | | | | | | | | -0.32 | | | | | | -0.21 | | |
| Comprehensive Environmental Indexes/per MW (each Plant) * | | -0.32 | -4.16 | -5.37 | -6.73 | -4.65 | -3.80 | -8.66 | -7.08 | -12.22 | -9.72 | -4.00 | -38.00 | -36.00 | -40.00 | -36.00 | -26.00 | -36.00 | -30.00 | -32.00 | -26.00 | -26.00 | -70.00 | | |
| Comprehensive Environmental Indexes/per MW (Type of Generation) | | -2.24 | | -5.37 | | | | -7.11 | | | | | | | | | -32.00 | | | | | | -70.00 | | |

*: For convenience sake, it is 1,000 times for comparison.

(Source: JICA Survey)



(Source: JICA Survey Team)

Figure 11-26 Environmental Impact Analysis Diagram of Power Generation Type (Overall)

11.8 Scenario analysis from environmental and social viewpoints

The following (A) scenario plan is analyzed as a draft scenario

Meanwhile, the JICA Survey Team formulated a draft scenario (B) to develop more renewable energy, as a reference plan with lower burdens on the global environment and regional environment.

● Scenario (A)

Only hydropower plants and thermal power plants (LNG / heavy oil fired) will be developed in this scenario. Hence, hydropower will be the only renewable energy developed.

[Reference plan]

● Scenario (B)

In this scenario, all types of renewable energy will be developed except hydropower.

Both scenarios were evaluated through the following steps.

From environmental and social viewpoints, the global environment was assessed based on the CO₂ emissions volume and the regional environment was evaluated by the negative impact (environmental index) on the surrounding environment (see 11.5(2)).

(a) Evaluation from the viewpoint of the global environment (CO₂ emissions)

Section 11.7 summarizes the evaluation of global environmental aspects in the project area of each power source.

The numerical values are re-listed in the table below.

Table 11-35 Evaluation Points on the Global Environment for Each Power Source

| Type of Generation | Hydro | Thermal (LNG/Oil) | Wind | Solar | Biomass |
|-------------------------|-------|-------------------|------|-------|---------|
| Environmental Indicator | 0.00 | -2.00 | 0.00 | 0.00 | 0.00 |

(Source: JICA Survey Team)

(b) Evaluation from the viewpoint of the regional environment

Section 11.7 summarizes the evaluation of regional environmental aspects in the project area of each power source.

The numerical values are re-listed in the table below.

Table 11-36 Evaluation Points on the Regional Environment for Each Power Source

| Type of Generation | Hydro | Thermal (LNG/Oil) | Wind | Solar | Biomass |
|-------------------------|--------|-------------------|-------|-------|---------|
| Environmental Indicator | -0.36 | -0.71 | -0.55 | -0.48 | -0.32 |
| Average | -0.535 | | -0.45 | | |

(Source: JICA Survey Team)

【Analysis result on Scenario (A)】

(c) Global environment

A thermal power generation project with a capacity of 212 MW (CIMANGOLA) using LNG / heavy oil as fuel was indicated by MINEA.

Carbon dioxide of 0.392 kg-CO₂/kWh (EIA statistic data 2011) will be emitted with the implementation of this project.

However, if hydropower projects such as CAMBAMBE, MATALA (total capacity of about 1,000 MW) are operated, CO₂ emission of 4.7 million tons-CO₂ will be reduced annually in comparison with fossil fuel power generation (see Section 11.3.1(4)).

(d) Regional environment

The average value of the natural and social environmental load index (environmental indicator) of hydropower plants and thermal power plants (LNG / heavy oil) is -0.535.

This figure is about 20% higher than the average value of the natural and social environmental load index of renewable energy (wind power, sunlight, biomass), namely, -0.45 (see Table 11-36).

Accordingly, from environmental and social viewpoints, replacing some hydropower and thermal power projects with renewable energy power plants will help improve the local environment.

The analysis of reference Scenario (B), where renewable energy power plants are incorporated into the power development master plan, showed the following results.

【Analysis result on Scenario (B)】

(e) Global environment

By implementing the renewable energy plans indicated by MINEA, wind power plants (total: 488 MW), solar power plants (total: 100 MW), and biomass power plant (total: 3 MW) will reduce 938 thousand tons of CO₂ emission annually in comparison with fossil-fuel-fired thermal power plants (see Section 11.3.1(4)). This contribution to global environment improvement exceeds the contribution by the diesel-dependent power supply development configuration (2005) by more than 95%.

(f) Regional environment

The average value of the natural and social environmental load index (environmental indicator) of Renewable Energy projects (wind power, solar power, biomass) is about 20% lower than that of hydraulic power generation and thermal power generation (LNG / heavy oil).

The replacement with renewable energy power plants helps to improve the regional environment in the project area.

The following issues are to be taken into account, however, in the case of development of renewable energy power plants instead of hydropower/thermal power plants.

Power system operators have great difficulty in controlling power system stability, as the output of wind power and/or solar power depends on climate conditions. And as the configuration rate of wind power and solar increases, it becomes harder to keep power system stable without sufficient ancillary service such as frequency control.

Therefore, the stability aspect must be considered along with the environmental aspect when introducing renewable energy.

Meanwhile, since biomass power plants can supply stable power less subject to the influences of climate, positive efforts to introduce them would be advantageous.

11.9 Expected mitigation measures

This survey excludes any coverage of the detailed development plans (scale, design etc.) of the respective projects embodied in the various power developments.

Accordingly, since concrete mitigation measures against the environmental impacts caused by the respective power development projects are impossible to quantify at this survey stage (SEA level), the table below describes only the general mitigation measures to be considered for each power development project.

Table 11-37 Expected Mitigation Measures for Each Power Source

| | Expected mitigation measures (avoidance, reduction, compensation) |
|--------------------|--|
| Hydropower | <ul style="list-style-type: none"> • Prioritize the adoption of “Run-of River Type” and reduce the impact on the natural and social environments (resettlement of residents). • Preferentially select an alternative that can avoid resettling residents. • Release river maintenance flow to avoid influences on the natural and social environments (drinking water supply, irrigation, tourism use) downstream due to water reduction. • Install fish passes to avoid influences on migratory fish due to the installation of dams / intake weirs. • Use nets, barriers or screens to prevent fish from passing into the turbines. • Discharge at various elevations of the dam to avoid outflow of anoxic or cold water. • In principle, adopt an “embedded type” for a penstock. If inevitable, adopt an “open type.” • In the case of the “ground surface type” or “semi-underground type” power house, design the building harmoniously with the surrounding landscape. |
| Thermal (LNG, Oil) | <ul style="list-style-type: none"> • Avoid new land alterations by locating the plant where existing infrastructure can be used. • Adopt the cooling tower system to avoid influence from heated effluent. • Set any equipment that generates noise/vibration as far as possible apart from the residences. • Offset CO₂ emission from the power plant by energy-saving measures throughout the whole factory or by introducing renewable energy power plants. |
| Wind | <ul style="list-style-type: none"> • Use blades to suppress the generation of noise and very-low-frequency sound. • Avoid flight routes of migratory birds and avoid bird strikes. • Avoid shadow flicker by locating the plant as far as possible apart from residential areas. • Avoid the influence of electromagnetic waves on fish, in the case of offshore wind power generation. • Design the facilities in harmony with the surrounding landscape |
| Solar | <ul style="list-style-type: none"> • Develop a battery that can be disposed of simply, as waste. • Design the facilities harmoniously with the surrounding landscape by planting around the site. |
| Biomass | <ul style="list-style-type: none"> • Avoid new land alterations by locating the plant where existing infrastructure can be used. • Adopt a cooling tower system to avoid the influence of heated effluent. • Set any equipment that generates noise/vibration as far apart as possible from residences. • Promote the effective use of combustion residue. |

(Source: JICA Survey Team)

11.10 Implementation of the monitoring plan

For the same reason described in Section 11.9 Mitigation Measures, the preparation and implementation of the monitoring plan is to be considered in the EIA at the project implementation stage.

The table below describes the general monitoring items to be considered when monitoring in time-series the appropriate implementation of mitigation measures proposed in the power development project.

Table 11-38 Common Monitoring Items for Power Development Project

| | Main Monitoring Items | | |
|---------------------------|-------------------------|----------------------------------|---|
| Power Development Project | Anti-Pollution measures | Air Quality | SO ₂ , NO ₂ , CO, O ₃ , Soot, Dust, Suspended Particulate Matter (PM10, PM2.5), Coarse Particulate |
| | | Water Quality (Surface) (Ground) | pH, Suspended Solids (SS), Biochemical Oxygen Demand (BOD), Chemical Oxygen Demand (COD), Dissolved Oxygen (DO), Total Nitrogen, Total Phosphorus, Heavy Metals, etc. |
| | | Waste (Industrial) (Domestic) | Types, Volume, Implementation of 3R |
| | | Noise Vibration | Level of noise (dB) and vibration |
| | | Odors | Specific bad smell material |
| | | Soil | Presence of heavy metals |
| | | Sedimentation | Sedimentation volume |
| | Natural Environment | Ecosystem | Threatened species, Endemic species |
| | | Topography Geology | Erosion, landslide or collapse |
| | Social Environment | Resettlement | Impacts due to resettlement Adequate payment of compensation cost |
| | | Living Livelihood | Adverse impacts on the livelihood of inhabitants |
| | Global Environment | Air Quality | GHG (CO ₂) emission |

(Source: JICA Survey Team)

11.11 Stakeholder Meeting

Two stakeholder meetings (SHMs) were scheduled to be held at MINEA in Luanda. The first SHM was held at the scoping implementation stage and the second will be held at the draft final stage of the SEA.

Relevant government agencies, environment-related NGOs, international development support organizations, etc. are invited to participate.

(1) The first stakeholder meeting

MINEA held the first SHM in Luanda with the support of the JICA Survey Team on October 17, 2017.

There were 40 participants, including the JICA Survey Team.



The SHM was held to explain the following matters to MINEA's counterparts and related organizations and exchange opinions on the SEA to be implemented in the master plan.

- What SEA is conducted in the Master Plan?
- How is the SEA for the power generation projects to be implemented?
- What is the “Best Scenario from an environmental viewpoint” for power development?
- How is the SEA for transmission lines to be implemented?
- What points should be considered regarding the “best route from an environmental viewpoint”?

In addition, a local consultant entrusted by JICA explained how to collect and analyze information on environmental and social considerations necessary for the SEA.

The main opinions or questions are as follows.

- The potential candidate sites for hydroelectric power have already been submitted to RNT (GAMEK).
- For hydroelectric power candidate sites, adjust to RNT and compile as soon as possible (MINEA).
- The international connecting line (Route No.4, Xangongo - Baynes) passes through a national park, which creates a problem when applying the JICA guidelines (INRH).

| | |
|---|--|
|  |  |
| Discussion by SHM participants | Explanations by the JICA study Team |




LISTA DE PRESENCAS DO PRIMEIRO ENCONTRO SOBRE A AVALIAÇÃO AMBIENTAL
ESTRATÉGICA (AAE) DO PLANO DE DESENVOLVIMENTO ELÉCTRICO DE ANGOLA
LUANDA, AOS 17 DE OUTUBRO DE 2017.



| NOME | INSTITUIÇÃO | FUNÇÃO | CONTACTOS (TELEMÓVEL OU EMAIL) |
|-------------------|-------------|----------------|--------------------------------|
| Eduardo Ferdinand | Holisticos | Engº Ambiental | |
| Adrius Namico | IRSEA | Chfº de Opº | |
| Marion Balanera | ENDE | Director | |
| Eudes Paulo | RNT | Chfº de Opº | |
| Manuel Domingos | RNT | Engº Domingos | |
| Paulino Dineito | JICA | Tradutor | |
| VICTOR UINDANDA | FREE-LANCER | TRANSLUTOR | |
| Masayuki ITO | JICA Team | | |
| Akumano Vidal | ENDE | DIRECTOR | |
| Kimiori Nakamura | JICA | | |
| Hitoshi FURUKOSHI | JICA Team | | |



* Encontro realizado nas instalações do Ministério da Energia e Águas.

Participants List of 1st Stake Holder Meeting (1/4)



LISTA DE PRESENCAS DO PRIMEIRO ENCONTRO SOBRE A AVALIAÇÃO AMBIENTAL
ESTRATÉGICA (AAE) DO PLANO DE DESENVOLVIMENTO ELÉCTRICO DE ANGOLA

LUANDA, AOS 17 DE OUTUBRO DE 2017.

| NOME | INSTITUIÇÃO | FUNÇÃO | CONTACTOS (TELEMÓVEL OU EMAIL) |
|------------------|-------------|---------------|--------------------------------|
| ABONGALA VUANGA | MINEA | CHEFE DE DPTO | |
| LEONAR LUCAS | MINGA | CHEFE DE DPTO | |
| António Furtado | MINEA | CHEFE DPTO | |
| Carlos Fergentus | ENDE | Director | |
| Manuel Fozzo | PRODEL | Director | |
| Manuel Quintino | INRH | Director | |
| Armando Carlos | GAMER | Técnico | |
| Shigehi MADA | JICA | Expert | |
| Paula Francisco | GAMER | Técnico | |
| NEGÍDIO BUAKELA | GAMCK | TECNICO | |
| João Luís | GAMER | TECNICO | |

* Encontro realizado nas instalações do Ministério da Energia e Águas.

Participants List of 1st Stake Holder Meeting (2/4)




LISTA DE PRESENCAS DO PRIMEIRO ENCONTRO SOBRE A AVALIAÇÃO AMBIENTAL
ESTRATÉGICA (AAE) DO PLANO DE DESENVOLVIMENTO ELÉCTRICO DE ANGOLA

LUANDA, AOS 17 DE OUTUBRO DE 2017.





| NOME | INSTITUIÇÃO | FUNÇÃO | CONTACTOS (TELEMÓVEL OU EMAIL) |
|--------------------------|-------------|-------------------|--------------------------------|
| ALBANO GASPAR | GATER | Técnico | |
| Morris Jimbo | " | " | |
| Adolfo de Santo | " | " | |
| Nuno Lopes | " | " | |
| Tomásico | GATER | Técnico | |
| ALBERTO FERNANDES | IRSEA | Técnico | |
| Alfredo J. J. J. J. | PRODEL | " | |
| EDUARDO M. F. dos Santos | PRODEL | Defensoramento | |
| Isabel Ferreira | PRODEL | Defensoramento | |
| Sandra Custódio | DNER | Director | |
| LARDA JOÃO | DNER | C. Defensoramento | |

*Encontro realizado nas instalações do Ministério da Energia e Águas.



LISTA DE PRESENCAS DO PRIMEIRO ENCONTRO SOBRE A AVALIAÇÃO AMBIENTAL
ESTRATÉGICA (AAE) DO PLANO DE DESENVOLVIMENTO ELÉCTRICO DE ANGOLA

LUANDA, AOS 17 DE OUTUBRO DE 2017.

| NOME | INSTITUIÇÃO | FUNÇÃO | CONTACTOS (TELEMÓVEL OU EMAIL) |
|--------------------------------|-------------|----------------------|--------------------------------|
| Erédia Maria | MINA / DNER | Técnica | [Redacted Contact Information] |
| Jonil Mithunga | MINA / DNER | TÉCNICO | |
| Vladimir Noso | HOLISTICS | DIRETOR TÉCNICO | |
| Esabelos de Porto | CANVET | Diretor Geral | |
| António Beisa Costa | MINA | SEE | |
| Osvaldo Manuel Tullio Loureiro | MINA | TÉCNICO | |
| Rafael Miguel Henri | GAUEK | Chefe de Equipamento | |
| | | | |
| | | | |
| | | | |

* Encontro realizado nas instalações do Ministério da Energia e Águas.

Página 2 | 2

Participants List of 1st Stake Holder Meeting (4/4)

(2) The second stakeholder meeting

MINEA held the second SHM in Luanda with the support of the JICA Survey Team on June 12, 2018.

There were 61 participants, participating from RNT (22 persons), PRODEL (9), MINEA (7), ENDE (4), GAMEK (3) and others (16).





The SHM was held, following the opening remarks of Mr. João Baptista Borges, Minister of Energy and Water, to explain the main contents of Draft Final Report to MINEA's counterparts and related organizations and exchange opinions on the SEA results which are the main them of the DFR and to be implemented in the master plan.

After both presentations, participants were required to provide comments and questions:

The main question is as follows;

(Q): Mr. Euclides de Brito, Deputy Director of GAMEK, indicated that Strategic Environmental Assessment is an important step towards clarifying the country's strategic options. He asked for additional information on the Cimangola Thermal Project particularly with regards to the required mitigation measures due to the existence of communities and sensitive receptors in the vicinity of the project. Mr. Brito asked if the project investment amount would increase if strict mitigation measures would be proposed;

(A): all sites were assessed at SEA level and no specific details were provided for each project to allow for Environmental Impact Assessment. However, in case strict mitigation measures are imposed to meet international guidelines it is likely that the project investment amount would be increased.

| | |
|---|--|
|  |  |
| Photo 1: Opening ceremony of the Stakeholder Meeting. | Photo 2: Opening speech by Honourable Minister of Water and Energy, Eng.º João Baptista Borges |
|  |  |
| Photo 3: Participants of the stakeholder meeting. | Photo 4: Presentation by JICA Team |



REPÚBLICA DE ANGOLA

MINISTÉRIO DA ENERGIA E ÁGUAS

DIRECÇÃO NACIONAL DE ENERGIA ELÉCTRICA

LISTA DE PRESENÇA

DATA: 12 DE JUNHO 2018

HORA: 08:30 – 13:00

LOCAL: ANFITEATRO DA ENDE NO EDIFÍCIO SEDE

ASSUNTO: PROJECTO DE ELABORAÇÃO DO PLANO DIRECTOR DE DESENVOLVIMENTO DO SISTEMA ELÉCTRICO

| Nº | NOME | ORGANISMO | TELEMOVEL | E-MAIL |
|----|----------------------------------|-----------|-----------|--------|
| 01 | Osvaldo Marques Julião Gonçalves | MINEA | | |
| 02 | Rosa Maria Afonso Miguel | PRODEL | | |
| 03 | Manuel de Sousa Gomes | PRODEL | | |
| 04 | Fernando Alberto Pinto Pereira | GAMER | | |
| 05 | Gaspar Emmanuel Nogueira | PRODEL | | |
| 06 | Lourenço Jacob de Bragança | RNT | | |

Avenida Cónego Manuel das Neves 234, 1º andar, CP 2229, Luanda

Participants List of 2nd Stake Holder Meeting (1/4)

| | | |
|----|--------------------------------|------------|
| 07 | Paulo Bernardo | RNT |
| 08 | Nelson Quicalongo | RNT-EP |
| 09 | Rui Oliveira | RNT-EP |
| 10 | Abelito Mambico | TRSEA |
| 11 | CRISTÓVÃO MAGALHÃES | MINEA |
| 12 | Rafael Oliveira | RNT-EP |
| 13 | Pedro Neto | RNT-EP |
| 14 | Albino Julio Domingos | RNDE-EP |
| 15 | Alexandre Demary Vaz | PRODEL-EP |
| 16 | Alfonsinho dos Santos Jompep | PRODEL-EP |
| 17 | Eucles Lanza | RNT-EP |
| 18 | Nelson Neto | RNT-EP |
| 19 | Delcio Delfino Cruz da Fonseca | RNT-EP |
| 20 | José Rafaela Vitorina | PRODEL-EP |
| 21 | VLADIMIR DUSO | Huisticas |
| 22 | Hiroyuki SHIMOMURA | JICA TEAM |
| 23 | Hitoshi FURUKOSHI | JICA TEAM |
| 24 | Hitoshi NAKAUCHI | JICA TEAM |
| 25 | Masayuki TADA | JICA TEAM |
| | 62: Zecedito Almeida Gypm | MAEST-DNEG |

Participants List of 2nd Stake Holder Meeting (2/4)

| | | |
|----|-------------------------------|------------|
| 26 | Masahito Sado | TZCA |
| 27 | Shigeki WADA | 4 |
| 28 | João Gonçalves da Gama | ENDE-EP |
| 29 | Miguel José Victoria | ENDE-EP |
| 30 | Raul Noñez | ENDE-EP |
| 31 | João Henrique Afonso | ENDE-EP |
| 32 | Manuel Ericson Dominges | RNT-EP |
| 33 | William Gomes | RNT-EP |
| 34 | João Maria Garcia Pulido | RNT-EP |
| 35 | Yuzo KITAHARA | JICA |
| 36 | António Edgar F. FURTADO | MINEA |
| 37 | LEONEL LUCAS | MINEA |
| 38 | Guaruna Paula Vidal Gonçalves | ENDE |
| 39 | Helena Maria Gonçalves | ENDE |
| 40 | Aldina G.A. Joo | PRODEL |
| 41 | Enrêdia Maima | MINEA/DNER |
| 42 | Pierre Muhongo | MINEA/DNER |
| | Dr. Xavier Afonso Januário | PRODEL/DPH |

37

Participants List of 2nd Stake Holder Meeting (3/4)

| | | |
|----|---------------------------------|-----------|
| 43 | Eusebio de Brito | GAMIEL |
| 44 | NEGÍDIO BUAKELA | GAMEK |
| 45 | ANTÓNIO MONTE | RNT-EP |
| 46 | Domingos Lúcia Adriano | PRODEL |
| 47 | Derivaldo F. Manuel | RNT |
| 48 | Domingo Brito de Sá | RNT |
| 49 | Elis Laimonba | RNT |
| 50 | João Baptista Pereira | RNT |
| 51 | FRANCISCO MEIRELES | PRODEL |
| 52 | Luís Mourão Silva | IRSEA |
| 53 | Vicente Vinça | GCIT |
| 54 | Zeugza Zol | RNT |
| 55 | Meluzes CHAMALIS | EASABE |
| 56 | António Inglês Pinto | RNT-EP |
| 57 | João Aires Amador de M. Paredes | RNT |
| 58 | Paulino Ernesto | JICA TEAM |
| 59 | Hisanobu Kuroki | JICA TEAM |
| 60 | Helena Múcio Cassiano Ntambi | JICA TEAM |

Participants List of 2nd Stake Holder Meeting (4/4)

11.12 SEA concerning transmission expansion plans

(1) Outlines of Projects

An SEA has been conducted on the following transmission lines shown in the "Angola Energy Long-term Vision (Angola Energia 2025)" aiming at appropriate power development up to 2025.

Table 11-39 List of T/Ls to be evaluated by SEA

| | | Interval | Length (km) | | Route |
|------|---|------------------------------------|-------------|-------|----------------------|
| | | | Section | Total | |
| Dom. | 1 | Capanda PS – Saurimo | 550 | 2,290 | See the Below Figure |
| | 2 | Cambambe PS – Lubango | 600 | | |
| | 3 | Belem do Dango – Lubango SS | 330 | | |
| | 4 | Lubango SS – Cahama SS – Baynes SS | 330 | | |
| | 5 | Belem do Dango – Ondjiva | 480 | | |
| Int. | 1 | Cahama SS – Ruacana PS | 120 | 280 | |

(Source: JICA Survey Team)



(Source: JICA Survey Team)

Figure 11-27 Transmission Lines to be evaluated by SEA (5+1 Routes)

(2) Comparative analysis of alternatives (including Zero Option)

The transmission lines listed in Table 11-39 are bulk transmission lines proposed in Angola Energia 2025 to interconnect among the northern, central, and southern regions and neighboring countries.

An SEA is therefore to be implemented for the above T/L expansion plan. Noteworthy environmental and social issues when implementing the T/L expansion projects are indicated based on the results of this SEA.

In concrete terms, scoping will be carried out on each planned transmission line route to determine which of the environmental items to be evaluated quantitatively (from 0 to -3) have negative impacts on the surrounding environment. Environmental items evaluated with low numerical values (high negative impact) will be identified as items to address when planning alternative routes.

However, since the methods for quantitatively evaluating environmental impacts have not yet been scientifically proven, each evaluation item is to be scored on a four-point scale (from 0 to -3) focused on the qualitative differences of each route.

- 0: No impact
- 1: Small but not serious impact
- 2: Serious but not irreversible impact
- 3: Huge, serious, irreversible impact

The table below shows the results of a quantitative comparison of the impact of each transmission line on the environment, from environmental and social viewpoints.

The examination of the zero option is not considered at the SEA stage, since no practical or concrete project plan to transmit electricity other than the construction of transmission lines can be seen.

The zero option would be considered at the F/S stage or EIA, where various investigations on the natural and social environments will be conducted.

Table 11-40 Items to watch when implementing or selecting the T/L routes and weighing the impacts of each route

| Name | ① | ② | ③ | ④ | ⑤ | ① |
|-----------------------------|--------------------|-----------------------|-----------------------------|------------------------------------|-----------------------------|------------------------|
| Items | Capanda PS - Saurm | Cambambe PS - Lubango | Belem do Dango - Lubango SS | Lubango SS - Cahama SS - Baynes SS | Belem do Dango - Ondjiva SS | Cahama SS - Ruacana PS |
| Protected Area ⁱ | -2 | -3 | -3 | -2 | 0 | 0 |
| Topography ⁱⁱ | 0 | -1 | -1 | -1 | -1 | -1 |
| Resettlement ⁱⁱⁱ | -1 | -2 | -2 | -2 | -2 | -1 |

(Source: JICA Survey Team)

- Note)
- i: National Parks and Bird Sanctuary (for migratory birds) evaluated as (-3)
 - ii: Average slope of the whole route evaluated as 0%~5% (0), 5%~10% (-1), 10%~20% (-2), >20% (-3)
 - iii: No house (0), 100~400 houses (-1), 401~1,000 houses (-2), >1,000 houses (-3)

(3) Scoping on every transmission line route

The scoping on every Transmission Line is shown in the following tables.

(3)-1. CapanSaurimoda PS – Saurimo Route

Table 11-41 Scoping for Capanda PS – Saurimo Transmission Line

| Item | Impact | Rating | Results |
|---------------------|---|--------|---|
| Pollution Control | 1 Air Quality | D | No specific negative impact is expected. |
| | 2 Water Quality | D | No specific negative impact is expected. |
| | 3 Soil Quality | D | No specific negative impact is expected. |
| | 4 Sediment (bottom of dam) | D | No specific negative impact is expected. |
| | 5 Noise and Vibration | D | No specific negative impact is expected. |
| | 6 Odor | D | No specific negative impact is expected. |
| | 7 Waste | D | No specific negative impact is expected. |
| | 8 Subsidence | D | No specific negative impact is expected. |
| Natural Environment | 9 Protected Areas | B | Specific negative impact on protected area(s) is expected. |
| | 10 Ecosystem | C | The extent of the influence associated with the construction of the transmission line is unknown at present. |
| | 11 Topography and Geology | C | Depending on the geology, there is a possibility of soil erosion around the towers. |
| Social Environment | 12 Land acquisition and Resettlement | B | Confirm the existence of private land on the transmission line land (ROW) and the usage situation. The actual condition of the settlements and other residences on the route is also unconfirmed, but no need for involuntary resettlement relating to the construction of transmission lines is assumed. |
| | 13 Poor People | C | The extent of the influence associated with the construction of the transmission line is unknown at present. |
| | 14 Ethnic Minority Groups and Indigenous People | D | No specific negative impact is expected. |
| | 15 Local Economy such as Loss of Employment and Livelihood Means | C | The extent of the influence associated with the construction of the transmission line is unknown at present. |
| | 16 Land Use and Utilization of Local Resources | C | The impact is unknown from the existing documents. This item will be evaluated after collecting and analyzing information through social surveys in the field. |
| | 17 Water Usage, Water Rights, etc. | C | The extent of the influence associated with the construction of the transmission line is unknown at present. |
| | 18 Existing Social Infrastructure and Services | D | No specific negative impact is expected. |
| | 19 Social Institutions such as Social Infrastructure and Local Decision-making Institutions | D | No specific negative impact is expected. |
| | 20 Misdistribution of Benefits and Loss | D | No specific negative impact is expected. |
| | 21 Local Conflicts of Interest | D | No specific negative impact is expected. |

| Item | Impact | Rating | Results |
|-------|---|--------|--|
| | 22 Cultural Heritage | D | No specific negative impact is expected. |
| | 23 Landscape | D | There are no scenic spots in or around the site. |
| | 24 Gender | D | No specific negative impact is expected. |
| | 25 Children's Rights | D | No specific negative impact is expected. |
| | 26 Infectious Diseases such as HIV/AIDS | C- | The extent of the influence associated with the construction of the transmission line is unknown at present. |
| | 27 Work Environment (including Work Safety) | B- | Accidents may occur at the construction site. Accidents involving workers may occur during maintenance work |
| Other | 28 Accidents | B- | Accidents may occur at the construction site. Increased traffic volume may cause traffic accidents. |
| | 29 Cross-boundary Impact and Climate Change | D | No specific negative impact is expected. |

Note: A+/-: Significant positive/negative impact is expected

B+/-: Positive/negative impact is expected to some extent

C+/-: Extent of positive/negative impact is unknown (further examination is needed; the impact may be clarified as the study progresses)

D: No impact is expected

(Source: JICA Survey Team)

(3)-2. Cambambe PS – Lubango Route

Table 11-42 Scoping for Cambambe PS – Lubango Transmission Line

| Item | Impact | Rating | Results |
|---------------------|---|--------|---|
| Pollution Control | 1 Air Quality | D | No specific negative impact is expected. |
| | 2 Water Quality | D | No specific negative impact is expected. |
| | 3 Soil Quality | D | No specific negative impact is expected. |
| | 4 Sediment (bottom of dam) | D | No specific negative impact is expected. |
| | 5 Noise and Vibration | D | No specific negative impact is expected. |
| | 6 Odor | D | No specific negative impact is expected. |
| | 7 Waste | D | No specific negative impact is expected. |
| | 8 Subsidence | D | No specific negative impact is expected. |
| Natural Environment | 9 Protected Areas | A- | Specific negative impact on protected area(s) is expected. |
| | 10 Ecosystem | A- | Bird strikes on power transmission lines are assumed. |
| | 11 Topography and Geology | C | Depending on the geology, there is a possibility of soil erosion around the towers. |
| Social Environment | 12 Land acquisition and Resettlement | B | Confirm the existence of private land on the transmission line land (ROW) and the usage situation. The actual condition of the settlements and other residences on the route is also unconfirmed, but no need for involuntary resettlement relating to the construction of transmission lines is assumed. |
| | 13 Poor People | C | The extent of the influence associated with the construction of the transmission line is unknown at present. |
| | 14 Ethnic Minority Groups and Indigenous People | D | No specific negative impact is expected. |
| | 15 Local Economy such as Loss of Employment and | C | The extent of the influence associated with the construction of the transmission line is unknown at present. |

| Item | Impact | Rating | Results |
|-------|---|--------|--|
| | Livelihood Means | | |
| | 16 Land Use and Utilization of Local Resources | C | The impact is unknown from the existing documents. This item will be evaluated after collecting and analyzing information through social surveys in the field. |
| | 17 Water Usage, Water Rights, etc. | C | The extent of the influence associated with the construction of the transmission line is unknown at present. |
| | 18 Existing Social Infrastructure and Services | D | No specific negative impact is expected. |
| | 19 Social Institutions such as Social Infrastructure and Local Decision-making Institutions | D | No specific negative impact is expected. |
| | 20 Misdistribution of Benefits and Loss | D | No specific negative impact is expected. |
| | 21 Local Conflicts of Interest | D | No specific negative impact is expected. |
| | 22 Cultural Heritage | D | No specific negative impact is expected. |
| | 23 Landscape | D | There are no scenic spots in or around the site. |
| | 24 Gender | D | No specific negative impact is expected. |
| | 25 Children's Rights | D | No specific negative impact is expected. |
| | 26 Infectious Diseases such as HIV/AIDS | C- | The extent of the influence associated with the construction of the transmission line is unknown at present. |
| | 27 Work Environment (including Work Safety) | B- | Accidents may occur at the construction site. Accidents involving workers may occur during maintenance work |
| Other | 28 Accidents | B- | Accidents may occur at the construction site. Increased traffic volume may cause traffic accidents. |
| | 29 Cross-boundary Impact and Climate Change | D | No specific negative impact is expected. |

(Source: JICA Survey Team)

(3)-3. Belem do Dango – Lubango SS Route

Table 11-43 Scoping for Belem do Dango – Lubango SS Transmission Line

| Item | Impact | Rating | Results |
|---------------------|----------------------------|--------|---|
| Pollution Control | 1 Air Quality | D | No specific negative impact is expected. |
| | 2 Water Quality | D | No specific negative impact is expected. |
| | 3 Soil Quality | D | No specific negative impact is expected. |
| | 4 Sediment (bottom of dam) | D | No specific negative impact is expected. |
| | 5 Noise and Vibration | D | No specific negative impact is expected. |
| | 6 Odor | D | No specific negative impact is expected. |
| | 7 Waste | D | No specific negative impact is expected. |
| | 8 Subsidence | D | No specific negative impact is expected. |
| Natural Environment | 9 Protected Areas | A- | Specific negative impact on protected area(s) is expected. |
| | 10 Ecosystem | A- | Bird strikes on power transmission lines are assumed. |
| | 11 Topography and Geology | C | Depending on the geology, there is a possibility of soil erosion around the towers. |
| 12 | Land acquisition and | B- | Confirm the existence of private land on the transmission line |

| Item | Impact | Rating | Results |
|-------|---|--------|--|
| | Resettlement | | land (ROW) and the usage situation. The actual condition of the settlements and other residences on the route is also unconfirmed, but no need for involuntary resettlement relating to the construction of transmission lines is assumed. |
| | 13 Poor People | C | The extent of the influence associated with the construction of the transmission line is unknown at present. |
| | 14 Ethnic Minority Groups and Indigenous People | D | No specific negative impact is expected. |
| | 15 Local Economy such as Loss of Employment and Livelihood Means | C | The extent of the influence associated with the construction of the transmission line is unknown at present. |
| | 16 Land Use and Utilization of Local Resources | C | The impact is unknown from the existing documents. This item will be evaluated after collecting and analyzing information through social surveys in the field. |
| | 17 Water Usage, Water Rights, etc. | C | The extent of the influence associated with the construction of the transmission line is unknown at present. |
| | 18 Existing Social Infrastructure and Services | D | No specific negative impact is expected. |
| | 19 Social Institutions such as Social Infrastructure and Local Decision-making Institutions | D | No specific negative impact is expected. |
| | 20 Misdistribution of Benefits and Loss | D | No specific negative impact is expected. |
| | 21 Local Conflicts of Interest | D | No specific negative impact is expected. |
| | 22 Cultural Heritage | D | No specific negative impact is expected. |
| | 23 Landscape | D | There are no scenic spots in or around the site. |
| | 24 Gender | D | No specific negative impact is expected. |
| | 25 Children's Rights | D | No specific negative impact is expected. |
| | 26 Infectious Diseases such as HIV/AIDS | C- | The extent of the influence associated with the construction of the transmission line is unknown at present. |
| Other | 27 Work Environment (including Work Safety) | B- | Accidents may occur at the construction site. Accidents involving workers may occur during maintenance work |
| | 28 Accidents | B- | Accidents may occur at the construction site. Increased traffic volume may cause traffic accidents. |
| | 29 Cross-boundary Impact and Climate Change | D | No specific negative impact is expected. |

(Source: JICA Survey Team)

(3)-4. Lubango SS – Cahama SS – Baynes SS Route

Table 11-44 Scoping for Lubango SS – Cahama SS – Baynes SS Transmission Line

| Item | Impact | | Rating | Results |
|---------------------|--------|--|--------|---|
| Pollution Control | 1 | Air Quality | D | No specific negative impact is expected. |
| | 2 | Water Quality | D | No specific negative impact is expected. |
| | 3 | Soil Quality | D | No specific negative impact is expected. |
| | 4 | Sediment (bottom of dam) | D | No specific negative impact is expected. |
| | 5 | Noise and Vibration | D | No specific negative impact is expected. |
| | 6 | Odor | D | No specific negative impact is expected. |
| | 7 | Waste | D | No specific negative impact is expected. |
| | 8 | Subsidence | D | No specific negative impact is expected. |
| Natural Environment | 9 | Protected Areas | A- | Specific negative impact on protected area(s) is expected. |
| | 10 | Ecosystem | A- | Bird strikes on power transmission lines are assumed. |
| | 11 | Topography and Geology | C | Depending on the geology, there is a possibility of soil erosion around the towers. |
| Social Environment | 12 | Land acquisition and Resettlement | B- | Confirm the existence of private land on the transmission line land (ROW) and the usage situation. The actual condition of the settlements and other residences on the route is also unconfirmed, but no need for involuntary resettlement relating to the construction of transmission lines is assumed. |
| | 13 | Poor People | C | The extent of the influence associated with the construction of the transmission line is unknown at present. |
| | 14 | Ethnic Minority Groups and Indigenous People | D | No specific negative impact is expected. |
| | 15 | Local Economy such as Loss of Employment and Livelihood Means | C | The extent of the influence associated with the construction of the transmission line is unknown at present |
| | 16 | Land Use and Utilization of Local Resources | C | The impact is unknown from the existing documents. This item will be evaluated after collecting and analyzing information through social surveys in the field. |
| | 17 | Water Usage, Water Rights, etc. | C | The extent of the influence associated with the construction of the transmission line is unknown at present |
| | 18 | Existing Social Infrastructure and Services | D | No specific negative impact is expected. |
| | 19 | Social Institutions such as Social Infrastructure and Local Decision-making Institutions | D | No specific negative impact is expected. |
| | 20 | Misdistribution of Benefits and Loss | D | No specific negative impact is expected. |
| | 21 | Local Conflicts of Interest | D | No specific negative impact is expected. |
| | 22 | Cultural Heritage | D | No specific negative impact is expected. |
| | 23 | Landscape | D | There are no scenic spots in or around the site. |
| | 24 | Gender | D | No specific negative impact is expected. |
| | 25 | Children's Rights | D | No specific negative impact is expected. |
| | 26 | Infectious Diseases such as HIV/AIDS | C- | The extent of the influence associated with the construction of the transmission line is unknown at present |

| Item | Impact | Rating | Results |
|-------|---|--------|--|
| | 27 Work Environment (including Work Safety) | B- | Accidents may occur at the construction site. Accidents involving workers may occur during maintenance work. |
| Other | 28 Accidents | B- | Accidents may occur at the construction site. Increased traffic volume may cause traffic accidents. |
| | 29 Cross-boundary Impact and Climate Change | D | No specific negative impact is expected. |

(Source: JICA Survey Team)

(3)-5 Belem do Dango – Ondjiva SS Route

Table 11-45 Scoping for Belem do Dango – Ondjiva SS Transmission Line

| Item | Impact | Rating | Results |
|---------------------|--|--------|---|
| Pollution Control | 1 Air Quality | D | No specific negative impact is expected. |
| | 2 Water Quality | D | No specific negative impact is expected. |
| | 3 Soil Quality | D | No specific negative impact is expected. |
| | 4 Sediment (bottom of dam) | D | No specific negative impact is expected. |
| | 5 Noise and Vibration | D | No specific negative impact is expected. |
| | 6 Odor | D | No specific negative impact is expected. |
| | 7 Waste | D | No specific negative impact is expected. |
| | 8 Subsidence | D | No specific negative impact is expected. |
| Natural Environment | 9 Protected Areas | D | No specific negative impact is expected. |
| | 10 Ecosystem | D | No specific negative impact is anticipated. |
| | 11 Topography and Geology | C | Depending on the geology, there is a possibility of soil erosion around the towers. |
| Social Environment | 12 Land acquisition and Resettlement | B- | Confirm the existence of private land on the transmission line land (ROW) and the usage situation. The actual condition of the settlements and other residences on the route is also unconfirmed, but no need for involuntary resettlement relating to the construction of transmission lines is assumed. |
| | 13 Poor People | C | The extent of the influence associated with the construction of the transmission line is unknown at present. |
| | 14 Ethnic Minority Groups and Indigenous People | D | No specific negative impact is expected. |
| | 15 Local Economy such as Loss of Employment and Livelihood Means | C | The extent of the influence associated with the construction of the transmission line is unknown at present. |
| | 16 Land Use and Utilization of Local Resources | C | The impact is unknown from the existing documents. This item will be evaluated after collecting and analyzing information through social surveys in the field. |
| | 17 Water Usage, Water Rights, etc. | C | The extent of the influence associated with the construction of the transmission line is unknown at present. |
| | 18 Existing Social Infrastructure and Services | D | No specific negative impact is expected. |
| | 19 Social Institutions such as Social Infrastructure and | D | No specific negative impact is expected. |

| Item | Impact | Rating | Results |
|-------|---|--------|--|
| | Local Decision-making Institutions | | |
| | 20 Misdistribution of Benefits and Loss | D | No specific negative impact is expected. |
| | 21 Local Conflicts of Interest | D | No specific negative impact is expected. |
| | 22 Cultural Heritage | D | No specific negative impact is expected. |
| | 23 Landscape | D | There are no scenic spots in or around the site. |
| | 24 Gender | D | No specific negative impact is expected. |
| | 25 Children's Rights | D | No specific negative impact is expected. |
| | 26 Infectious Diseases such as HIV/AIDS | C- | The extent of the influence associated with the construction of the transmission line is unknown at present |
| | 27 Work Environment (including Work Safety) | B- | Accidents may occur at the construction site. Accidents involving workers may occur during maintenance work |
| Other | 28 Accidents | B- | Accidents may occur at the construction site. Increased traffic volume may cause traffic accidents. |
| | 29 Cross-boundary Impact and Climate Change | D | No specific negative impact is expected. |

(Source: JICA Survey Team)

(3)-6 Cahama SS – Ruacana PS Route

Table 11-46 Scoping for Cahama SS – Ruacana PS Transmission Line

| Item | Impact | Rating | Results |
|---------------------|---|--------|---|
| Pollution Control | 1 Air Quality | D | No specific negative impact is expected. |
| | 2 Water Quality | D | No specific negative impact is expected. |
| | 3 Soil Quality | D | No specific negative impact is expected. |
| | 4 Sediment (bottom of dam) | D | No specific negative impact is expected. |
| | 5 Noise and Vibration | D | No specific negative impact is expected. |
| | 6 Odor | D | No specific negative impact is expected. |
| | 7 Waste | D | No specific negative impact is expected. |
| | 8 Subsidence | D | No specific negative impact is expected. |
| Natural Environment | 9 Protected Areas | D | No specific negative impact is expected. |
| | 10 Ecosystem | D | No specific negative impact is expected. |
| | 11 Topography and Geology | C | Depending on the geology, there is a possibility of soil erosion around the towers. |
| Social Environment | 12 Land acquisition and Resettlement | B- | Confirm the existence of private land on the transmission line land (ROW) and the usage situation. The actual condition of the settlements and other residences on the route is also unconfirmed, but no need for involuntary resettlement relating to the construction of transmission lines is assumed. |
| | 13 Poor People | C | The extent of the influence associated with the construction of the transmission line is unknown at present. |
| | 14 Ethnic Minority Groups and Indigenous People | D | No specific negative impact is expected. |
| | 15 Local Economy such | C | The extent of the influence associated with the construction of |

| Item | Impact | Rating | Results |
|-------|--|--------|--|
| | as Loss of Employment and Livelihood Means | | the transmission line is unknown at present |
| 16 | Land Use and Utilization of Local Resources | C | The impact is unknown from the existing documents. This item will be evaluated after collecting and analyzing information through social surveys in the field. |
| 17 | Water Usage, Water Rights, etc. | C | The extent of the influence associated with the construction of the transmission line is unknown at present |
| 18 | Existing Social Infrastructure and Services | D | No specific negative impact is expected. |
| 19 | Social Institutions such as Social Infrastructure and Local Decision-making Institutions | D | No specific negative impact is expected. |
| 20 | Misdistribution of Benefits and Loss | D | No specific negative impact is expected. |
| 21 | Local Conflicts of Interest | D | No specific negative impact is expected. |
| 22 | Cultural Heritage | D | No specific negative impact is expected. |
| 23 | Landscape | D | There are no scenic spots in or around the site. |
| 24 | Gender | D | No specific negative impact is expected. |
| 25 | Children's Rights | D | No specific negative impact is expected. |
| 26 | Infectious Diseases such as HIV/AIDS | C- | The extent of the influence associated with the construction of the transmission line is unknown at present |
| 27 | Work Environment (including Work Safety) | B- | Accidents may occur at the construction site. Accidents involving workers may occur during maintenance work |
| Other | 28 | B- | Accidents may occur at the construction site. Increase of traffic volume may cause traffic accidents |
| | 29 | D | No specific negative impact is expected. |

(Source: JICA Survey Team)

(4) Proposed TOR on survey to collect data

The table below summarizes the surveys on major environmental and social aspects to be carried out at the implementation stage of the project, based on the above evaluations.

Table 11-47 Survey Items and Methods

| Environmental Items | Survey Items | Survey Method |
|---------------------|--|--|
| Air Quality | <ul style="list-style-type: none"> - Relevant environmental standards - Meteorological information - Current status of ambient atmosphere | <ul style="list-style-type: none"> - Obtain ambient air quality standards, - Measure the air pollutants (TSP), SO₂, NO₂, CO, O₃, PM₁₀, PM_{2.5}. |
| Water Quality | <ul style="list-style-type: none"> - Relevant environmental standards - Current status of water quality | <ul style="list-style-type: none"> - Obtain water quality standards and effluent standards. - Measure the existing reservoir and river water quality (temperatures, salinity, COD, nutrients, etc.) |
| Soil Quality | <ul style="list-style-type: none"> - Relevant environmental | <ul style="list-style-type: none"> - Measure the soil quality and screen |

| Environmental Items | Survey Items | Survey Method |
|--|---|---|
| | standards | for any contamination. |
| Noise and Vibration | <ul style="list-style-type: none"> - Relevant environmental standards - Current status of noise and vibration | <ul style="list-style-type: none"> - Obtain noise level standards - Measure the noise levels (background) |
| Waste | <ul style="list-style-type: none"> - Relevant environmental standards | <ul style="list-style-type: none"> - Obtain waste handling standards / manuals / guidelines. |
| Subsidence | <ul style="list-style-type: none"> - Current status of soil conditions | <ul style="list-style-type: none"> - Geological survey |
| Protected Areas | <ul style="list-style-type: none"> - Current status of Protected Areas | <ul style="list-style-type: none"> - Collect relevant laws and regulations, information on Protected Areas |
| Ecosystem | <ul style="list-style-type: none"> - Current habitat status of flora, mammal, birds, reptiles, amphibians, fish, precious species (migrant birds) | <ul style="list-style-type: none"> - Survey the distribution of flora and fauna. |
| Topography and Geology | <ul style="list-style-type: none"> - Geological conditions | <ul style="list-style-type: none"> - Obtain geological information |
| Land acquisition / Resettlement | <ul style="list-style-type: none"> - Confirm who the affected people are and the negative impacts caused by the project. - Confirm the assets of the affected people - Identify the livelihoods of the affected people | <ul style="list-style-type: none"> - Collect relevant laws and regulations, information on relevant cases - Conduct a population census - Conduct an asset inventory survey - Conduct a household socioeconomic survey |
| Disturbances to Ethnic Minority Groups and Indigenous People | <ul style="list-style-type: none"> - Identify ethnic minority groups and indigenous people among the affected people | <ul style="list-style-type: none"> - Collect information on relevant laws and regulations, information on relevant cases - Conduct a population census - Conduct an asset inventory survey - Conduct a household socioeconomic survey |
| Land Use and Utilization of Local Resources | <ul style="list-style-type: none"> - Identify the present land use - Identify the jobs and livelihoods of the affected people | <ul style="list-style-type: none"> - Collect information on the employment and income in the affected area - Interviews with the households |
| Disturbance of Water Usage, Water Rights, etc. | <ul style="list-style-type: none"> - Identify the present water use for day-to-day life and agricultural activities. | <ul style="list-style-type: none"> - Household socioeconomic survey - Interviews with the households |
| Cultural Heritage | <ul style="list-style-type: none"> - Current status of Cultural Heritage Areas | <ul style="list-style-type: none"> - Collect information on relevant laws and regulations and information on Heritage Areas |
| Landscape | <ul style="list-style-type: none"> - Current status of outstanding scenery | <ul style="list-style-type: none"> - Collect information on relevant laws and regulations and information on outstanding scenery |
| Cross-boundary Impact and Climate Change | <ul style="list-style-type: none"> - Identify the present air quality | <ul style="list-style-type: none"> - Measure CO₂ emitted from construction vehicles and heavy machines |

(Source: JICA Survey Team)

(5) Environment Impact Assessment

The following table summarizes environmental items that should be considered from environmental and social viewpoints when preparing concrete plans for each transmission line route (5 +1 routes), based on the evaluation results from the scoping on the planned routes.

Table 11-48 Environmental Items to be considered for Determination of the T/L Route

| No. | Name of Route | ➤ Environmental Items |
|-----|------------------------------------|---|
| ① | Capanda PS – Saurimo | <ul style="list-style-type: none"> ➤ An Important Bird Area (CUANGO) is located nearby, so considerations for ecological conservation will be necessary. ➤ There are three villages, each with about 50 households, nearby. These villages should preferably be avoided when deciding the routes. ➤ The terrain is generally flat, but about 20% of the total area is sloped at gradients of 5 to 10%, entailing a risk of soil erosion. |
| ② | Cambambe PS - Lubango | <ul style="list-style-type: none"> ➤ A protected area (BUFFALO) and Important Bird Area (GABELA) are located in and around the planned area, so considerations for ecological conservation will be necessary. ➤ There are 13 villages, each with about 50 households. It will be preferable to avoid these villages when deciding the routes. ➤ The terrain is generally flat, but about 25% of the total area is sloped at gradients of 5 to 10%, entailing a risk of soil erosion. |
| ③ | Belem do Dango – Lubango SS | <ul style="list-style-type: none"> ➤ A protected area (BUFFALO) and Important Bird Area (CACONDA) are located in and around the planned area, so considerations for ecological conservation will be necessary. ➤ There are 11 villages, each with about 50 households. These villages should preferably be avoided when deciding the routes. ➤ The terrain is generally flat, but about 30% of the total area is sloped at gradients of 5 to 10%, entailing a risk of soil erosion. |
| ④ | Lubango SS – Cahama SS – Baynes SS | <ul style="list-style-type: none"> ➤ A National Park (IONA) is located in the planned area, so considerations for ecological conservation will be necessary. ➤ There are 4 villages, each with about 50 households. These villages should preferably be avoided when deciding the routes. ➤ The terrain is generally flat, but about 10% of the total area is sloped at gradients of 5 to 10%, entailing a risk of soil erosion. |
| ⑤ | Belem do Dango – Ondjiva SS | <ul style="list-style-type: none"> ➤ There are 14 villages, each with about 50 households. These villages should preferably be avoided when deciding the routes. |

| | | |
|---|-----------------------|--|
| ⑥ | Cahama SS –Ruacana PS | ➤ There are 2 villages, each with about 50 households. These villages should preferably be avoided when deciding the routes. |
|---|-----------------------|--|

(Source: JICA Survey Team)

(6) Expected Mitigation Measures

No detailed determination of transmission line routes is covered in this survey.

As concrete mitigation measures against the environmental impacts caused by each transmission line expansion project are impossible to quantify at this survey stage (SEA level), the table below presents only general mitigation measures to be considered.

Table 11-49 Expected Mitigation Measures for Transmission Lines

| | Expected mitigation measures (avoidance, reduction, compensation) |
|-------------------|--|
| Transmission line | <p>(Countermeasure on Environment)</p> <ul style="list-style-type: none"> • Optimization of transmission line route with respect to avian migration corridors. • Installation of anti-perching devices or platforms specially designed to encourage birds to perch or nest in safer places. • Placement of fluttering banners and brightly-colored (orange, yellow, white) spirals on transmission lines. • Use of plant screens or other types of screens close to the transmission lines to force birds to fly at a higher altitude. • Avoidance of conservation units in habitats that have good wildlife potential. <p>(Work Environment and Accidents)</p> <ul style="list-style-type: none"> • Confirmation of landmine laying areas and a thorough ban on entry into dangerous areas. • Establishment of safety management plans and enforcement of compliance. • Thorough use of basic safety equipment such as safety shoes, gloves, and helmets. • Thorough use of safety belts when working high above the ground. |

(Source: JICA Survey Team)

(7) Implementation of Monitoring Plan

For the same background reasons described in the above section on Mitigation Measures, the preparation and implementation of the monitoring plan is to be considered in the EIA at the project implementation stage.

The table below describes the general monitoring items to be considered when monitoring in time-series the appropriate implementation of mitigation measures proposed in a transmission expansion project.

Table 11-50 Common Monitoring Items for Transmission Line Expansion Projects

| | Main Monitoring Items | | |
|-------------------|-------------------------|-----------------------------------|---|
| Transmission Line | Anti-Pollution measures | Air Quality | SO ₂ , NO ₂ , CO, O ₃ , Soot, Dust, Suspended particulate Matter (MP ₁₀ , PM _{2.5}), Coarse particulate |
| | | Water Quality Surface (Ground) | pH, Suspended solids (SS), Biochemical Oxygen Demand (BOD), Chemical Oxygen Demand (COD), Dissolved Oxygen (DO), Total Nitrogen, Total Phosphorus, Heavy Metals, etc. |
| | | Waste (Industrial) | Types, Volume, Implementation of 3R |

| | | | |
|--|------------------------|-----------------------|--|
| | | (Domestic) | |
| | | Noise Vibration | Level of noise (dB) and vibration |
| | | Odors | Specific bad smell materials |
| | | Soil | Presence of heavy metals |
| | Natural Environment | Ecosystem | Threatened species, Endemic species Grasping of bird strike accidents |
| | | Topography Geology | Erosion, Landslide |
| | Social Environment | Resettlement | Impacts of Resettlement Adequate explanation on compensation |
| | | Living Livelihood | Adverse impacts on the living conditions of inhabitants |
| | Global Environment | Air Quality | Emission of GHG (CO ₂) |
| | | | |

(Source: JICA Survey Team)

Chapter 12 Drafting the Master Plan

12.1 To Draft Comprehensive Power Master Plans toward the Year 2040

12.1.1 Generation Development Project List Formulation Policy

Based on the results examined in Chapter 6 and the results of the study on environmental and social considerations in Chapter 11, we will formulate a generation development project list according to the following policy

(1) To Reflect the Results of the study on Environmental and Social Considerations, Including SEA

- Since renewable energy has less impact on the natural environment than large hydropower and thermal power generation, we will introduce feasible projects to the maximum extent possible.
- The examinations so far performed indicate that large hydropower and thermal power generation do not have a huge influence on the natural environment and social environment in Angola. We will therefore introduce them appropriately according to their characteristics.
- The CO₂ emissions from the thermal power plants planned under this Master Plan will stand at around 3,000 kton-CO₂ / year in 2030, or about 3% of the INDC estimate (Conditional scenario). The impact, therefore, is not considered significant.

(2) Planned Introduction of Large Hydropower

- Based on the latest project cost, large hydropower is the most advantageous from the viewpoint of economy, as discussed in terms of power generation expenses. For this reason, hydropower development is planned as the first priority.
- Large hydropower is also important for the mitigation of CO₂ emissions, so positive adoption has significance. There will, however, be possible impacts on the social environment (e.g., resident resettlement) and impacts on the natural environment inside dam reservoirs. It will therefore be essential to consider these points when planning the future stages of development.
- As a development pattern, multiple projects should not overlap in the same river in a scheduled manner. If project schedules overlap, a schedule change in one project is very likely to affect the schedules of other projects, impeding the planning overall.

(3) Listing of Renewable Generation Projects as Much as Possible

- From the viewpoint of reducing CO₂ emissions, we will actively introduce renewable power generation.
- Many of the plans, however, remain at the theoretical reserves study level and still appear to have low feasibility. Among the projects listed in the plans, feasibility will only be confirmed for those that have been given project names.

(4) Introduction of CCGT as a Middle Demand Power Supply

- As study on the power generation expenses, CCGT is advantageous in terms of cost as a middle demand power supply and is economical next to hydropower as a base demand power supply.
- The fuel to be used in the CCGT is assumed to be natural gas in the future. Earlier, however, the fuel will be switched from LPG at the initial stage to LNG at the second stage.

(5) Introduction of GT as a Peak Demand Power Supply

- GT has cost advantages as a peak demand power supply, according to our examinations of power generation expenses. Because GT is economical as a reserve power, we also introduce it as capacity for the reserve margin.
- It will be essential, however, to operate the peak demand power supply in response to sudden changes in demand. SCADA and other controllable systems will therefore have to be introduced.
- According to the experiences of the Survey Team, peak demand often shifts to middle demand as the load factor changes. An effective approach to this is to combine single cycle GT with steam turbine to make CCGT. Hence, the new GT plant will be connected to the 400 kV backbone to the maximum extent possible, on the premise of large capacity. To ensure high heat efficiency, GT will be placed where cooling water on rivers or coastlines is easily available. One possibility would be to place a GT plant in Lobito Port.
- Although we assume natural gas in the future, LPG is the assumed fuel in the early stages.

12.1.2 Policy for Formulating the Transmission Development Project List

Based on the results examined in Chapter 7, we formulated the electric power transmission development list in accordance with the following policy.

(1) Expansion of the 400 kV Backbone from the Northern Part to the Central Part, Southern Part, and Western part

- To promote the electrification of the whole country of Angola, we expand the 400 kV main system to realize the supply of grid electricity nationwide by the target year of 2025.
- To prioritize development of the backbone project from the middle part to Lubango in the southern part on the extension line of the 400 kV transmission development already started among Lauca ~ Waco Kungo ~ Belem do Huambo.
- In parallel, we recommend new backbone line projects from Cambutasu ~ Gabela ~ Nova Biopio to Lubango, the development we newly planned in this study.
- To coordinate the timing with the completion of the international interconnection line with Namibia, from Lubango to Cahama, we will extend the 400 kV backbone line toward 2027 of the target year.

(2) Development of 220 kV Lines for Reinforcement of Regional Power System Substations to Respond to Increased Demand

- To enhance the regional supply system in Luanda in the capital and Benguela in the central region, etc.

(3) Construction of Transmission Lines for Newly Developed Power Sources

- We will link the newly developed hydropower supply and gas thermal power plants to be installed in the central and southern parts to the backbone lines.

(4) Adoption of a Two-Circuit-type Main Transmission Line to Satisfy the N-1 Criteria.

- We plan to install one more transmission line circuit for formation of two parallel circuits, in order to avoid overload during accidents of the existing one-circuit main line, eliminate operational restrictions, and improve reliability.

12.1.3 Project Lists

(1) Generation Development Plan

Table 12-1 List of Generation Development Plan Projects

| | Plant name | Province | Installed capacity (MW) | Project costs (MUSD) | Commissioning year | Note |
|---------------|----------------------|--------------|----------------------------|-------------------------|-----------------------|------|
| Hydropower | Lauca | Malanje | 2,070 | 4,300 | 2018 | |
| | Lomaú (extension) | Benguela | 65 | 385 | 2018 | |
| | Luachimo (extension) | Lunda Norte | 34 | N/A | 2020 | |
| | Caculo Cabaça | Kwanza Norte | 2,100 | 4,500 | 2024 | |
| | Baynes | Namibe | 300 | 660 | 2026 | |
| | Quilengue | Kwanza Sul | 210 | N/A | 2028 | |
| | Zenzo | Kwanza Norte | 950 | N/A | 2032 | |
| | Genga | Kwanza Sul | 900 | N/A | 2035 | |
| | Tumulo do Cacador | Kwanza Norte | 453 | 1,041 | 2038 | |
| | Biopio (Repower) | Benguela | 29 | N/A | N/A | |
| | Matala(Repower) | Lubango | 15 | N/A | N/A | |
| Thermal power | Soyo 1 CCGT | Zaire | 750 | 900 | 2017-2018 | |
| | Soyo 2 CCGT | Zaire | Apprx.750 | N/A | 2021-2022 | |
| | Lobito 1 CCGT | Benguela | Apprx.750 | 900 | 2027-2029 | |
| | Lobito 2 CCGT | Benguela | Apprx.750 | 900 | 2031-2034 | |
| | Namibe 1 CCGT | Namibe | Apprx.750 | 900 | 2036-2038 | |
| | Lobito 3 CCGT | Benguela | Apprx.375 | 450 | 2040 | |
| | Cacuaco GT | Luanda | 125 x 6 | 81 x 6 | 2022-2037 | |
| | Sambizanga GT | Luanda | 125 x 3 | 81 x 3 | 2025-2037 | |
| | Quileva GT | Benguela | 125 x 6 | 81 x 6 | 2027-2035 | |
| | Soyo-SS GT | Zaire | 125 x 3 | 81 x 3 | 2030-2037 | |
| Renewable | Beniamin Wind | Benguela | 52 | N/A | 2028 | |
| | Benguela Solar | Benguela | 10 | N/A | 2028 | |
| | Cacula Wind | Huila | 88 | N/A | 2029 | |
| | Cambongue Solar | Namibe | 10 | N/A | 2029 | |
| | Chibia Wind | Huila | 78 | N/A | 2030 | |
| | Caraculo Solar | Namibe | 10 | N/A | 2030 | |
| | Calenga Wind | Huambo | 84 | N/A | 2031 | |
| | Catumbela Solar | Benguela | 10 | N/A | 2031 | |
| | Gasto Wind | Kwanza Norte | 30 | N/A | 2032 | |
| | Lobito Solar | Benguela | 10 | N/A | 2032 | |
| | Kiwaba Nzoji I Wind | Malanje | 62 | N/A | 2033 | |
| | Lubango Solar | Huila | 10 | N/A | 2033 | |
| | Kiwaba Nzoji II Wind | Malanje | 42 | N/A | 2034 | |
| | Matala Solar | Huila | 10 | N/A | 2034 | |
| | Mussede I Wind | Kwanza Sul | 36 | N/A | 2035 | |
| | Quipungo Solar | Huila | 10 | N/A | 2035 | |
| | Mussede II Wind | Kwanza Sul | 44 | N/A | 2036 | |
| | Nharea Wind | Bie | 36 | N/A | 2036 | |
| | Techamutete Solar | Huila | 10 | N/A | 2036 | |
| | Tombwa Wind | Namibe | 100 | N/A | 2037 | |
| | Namacunde Solar | Cunene | 10 | N/A | 2037 | |

(2) Transmission Development Plan

Table 12-2 List of 400 kV Substation Projects

| Project# | Year of operation | Area | Voltage (kV) | Substation Name | Capacity (MVA) | Cost (MUS\$) | Remarks |
|----------|-------------------|-------------|--------------|-----------------|----------------|--------------|-------------------------------------|
| 1 | 2020 | Cuanza Sul | 400 | Waco kungo | 450 | 40.5 | 450 x 1, under construction(China) |
| 2 | 2020 | Huambo | 400 | Belem do Huambo | 900 | 51.3 | 450 x 2, under construction(China) |
| 3 | 2022 | Luanda | 400 | Bitá | 900 | 51.3 | 450 x 2, under construction(Brazil) |
| 4 | 2025 | Cuanza Sul | 400 | Waco kungo | 450 | 40.5 | upgrade 450 x 1 |
| 5 | 2025 | Luanda | 400 | Bitá | 450 | 40.5 | upgrade 450 x 1 |
| 6 | 2025 | Zaire | 400 | N'Zeto | 450 | 40.5 | upgrade 450 x 1 |
| 7 | 2025 | Luanda | 400 | Viana | 2,790 | 96.6 | upgrade 930 x 3 |
| 8 | 2025 | Bengo | 400 | Kapary | 450 | 40.5 | upgrade 450 x 1 |
| 9 | 2025 | Huíla | 400 | Lubango2 | 900 | 51.3 | 450 x 2, Pre-FS implemented* |
| 10 | 2025 | Huíla | 400 | Capelongo | 900 | 51.3 | 450 x 2 |
| 11 | 2025 | Huíla | 400 | Calukembe | 120 | 32.6 | 60 x 2 |
| 12 | 2025 | Benguela | 400 | Nova Biopio | 900 | 51.3 | 450 x 2 |
| 13 | 2025 | Southern | 400 | Cahama | 900 | 51.3 | 450 x 2 |
| 14 | 2025 | Eastern | 400 | Saurimo | 900 | 51.3 | 450 x 2, under Pre-FS |
| 15 | 2025 | Lunda Norte | 400 | Xa-Muteba | 360 | 38.3 | 180 x 2, under Pre-FS |
| 16 | 2025 | Huíla | 400 | Quilengues | 120 | 32.6 | 60 x 2 |
| 17 | 2025 | Cuanza Sul | 400 | Gabela | 900 | 51.3 | 450 x 2 |
| 18 | 2025 | Luanda | 400 | Sambizanga | 2,790 | 96.6 | 930 x 3 |
| 19 | 2025 | Malanje | 400 | Lucala | 900 | 51.3 | 450 x 2 |
| 20 | 2025 | Chipindo | 400 | Chipindo | 360 | 38.3 | 180 x 2 |
| 21 | 2030 | Bengo | 400 | Kapary | 450 | 40.5 | upgrade 450 x 1 |
| 22 | 2030 | Luanda | 400 | Catete | 450 | 40.5 | upgrade 450 x 1 |
| 23 | 2035 | Cunene | 400 | Ondjiva | 900 | 51.3 | 450 x 2, Pre-FS implemented* |
| 24 | 2035 | Luanda | 400 | Bitá | 450 | 40.5 | upgrade 450 x 1 |
| 25 | 2035 | Malanje | 400 | Lucala | 450 | 40.5 | upgrade 450 x 1 |
| Total | | | | | 19,590 | 1,171.4 | |

Pre-FS implemented*:Candidate site were selected by USTDA and DBSA.

Table 12-3 List of 220 kV Substation Projects (1)

| Project# | Year of operation | Area | Voltage (kV) | Substation Name | Capacity (MVA) | Cost (MU\$) | Remarks |
|----------|-------------------|----------------|--------------|-------------------|----------------|-------------|-------------------------------------|
| 1 | 2018 | Benguela | 220 | Benguela Sul | 240 | 24.5 | 120 x 2, under construction(China) |
| 2 | 2020 | Luanda | 220 | Bitá | 240 | 24.5 | 120 x 2, under construction(Brazil) |
| 3 | 2020 | Zaire | 220 | Tomboco | 40 | 13.7 | 20 x 2 |
| 4 | 2020 | Malanje | 220 | Capanda Elevadora | 130 | 18.6 | 65 x 2, upgrade |
| 5 | 2021 | Luanda | 220 | Cacuaco | 480 | 37.5 | 240 x 2, upgrade |
| 6 | 2022 | Luanda | 220 | Zango | 360 | 31.0 | 120 x 3 |
| 7 | 2022 | Malanje | 220 | Malanje 2 | 240 | 24.5 | 120 x 2 |
| 8 | 2022 | Cuanza Sul | 220 | Waco Kungo | 60 | 14.8 | 60 x 1 |
| 9 | 2022 | Cuanza Sul | 220 | Quibala | 120 | 18.1 | 60 x 2 |
| 10 | 2022 | Benguela | 220 | Cubal | 120 | 18.1 | 60 x 2 |
| 11 | 2022 | Huíla | 220 | Lubango | 240 | 24.5 | 120 x 2, Pre-FS implemented* |
| 12 | 2022 | Huíla | 220 | Matala | 120 | 18.1 | 60 x 2, Pre-FS implemented* |
| 13 | 2022 | Huíla | 220 | Capelongo | 60 | 14.8 | 60 x 1 |
| 14 | 2022 | Cuando-Cubango | 220 | Cuchi | 60 | 14.8 | 60 x 1 |
| 15 | 2022 | Cuando-Cubango | 220 | Menangue | 240 | 24.5 | 120 x 2 |
| 16 | 2022 | Namibe | 220 | Namibe | 240 | 24.5 | 120 x 2, Pre-FS implemented* |
| 17 | 2022 | Namibe | 220 | Tombwa | 120 | 18.1 | 60 x 2, Pre-FS implemented* |
| 18 | 2022 | Lunda Norte | 220 | Lucapa | 60 | 14.8 | 60 x 1 |
| 19 | 2022 | Lunda Norte | 220 | Dundo | 120 | 18.1 | 60 x 2, under Pre-FS |
| 20 | 2022 | Lunda Sur | 220 | Saurimo | 120 | 18.1 | 60 x 2, under Pre-FS |
| 21 | 2022 | Uíge | 220 | Uíge | 240 | 24.5 | 120 x 2, upgrade |
| 22 | 2025 | Luanda | 220 | Golfe | 360 | 31.0 | 120 x 3 |
| 23 | 2025 | Luanda | 220 | Chicara | 480 | 37.5 | 240 x 2 |
| 24 | 2025 | Bengo | 220 | Caxito | 60 | 14.8 | 60 x 1 |
| 25 | 2025 | Bengo | 220 | Maria Teresa | 60 | 14.8 | 60 x 1 |
| 26 | 2025 | Cuanza Sul | 220 | Porto Amboim | 120 | 18.1 | 60 x 2 |
| 27 | 2025 | Cuanza Sul | 220 | Cuacra | 60 | 14.8 | 60 x 1 |
| 28 | 2025 | Benguela | 220 | Catumbela | 120 | 18.1 | 60 x 2 |
| 29 | 2025 | Benguela | 220 | Bocoio | 120 | 18.1 | 60 x 2 |
| 30 | 2025 | Huambo | 220 | Ukuma | 60 | 14.8 | 60x 1, Pre-FS implemented* |
| 31 | 2025 | Huambo | 220 | Catchiungo | 120 | 18.1 | 60 x 2, Pre-FS implemented* |
| 32 | 2025 | Bié | 220 | Andulo | 60 | 14.8 | 60 x 1 |
| 33 | 2025 | Huíla | 220 | Nova Lubango | 120 | 18.1 | 60 x 2 |
| 34 | 2025 | Huíla | 220 | Caluquembe | 60 | 14.8 | 60 x 1 |
| 35 | 2025 | Huíla | 220 | Quilengues | 60 | 14.8 | 60 x 1 |
| 36 | 2025 | Huíla | 220 | Tchamutete | 120 | 18.1 | 60 x 2, Pre-FS implemented* |
| 37 | 2025 | Cunene | 220 | Ondjiva | 120 | 18.1 | 60 x 2, Pre-FS implemented* |
| 38 | 2025 | Cunene | 220 | Cahama | 60 | 14.8 | 60 x 1, Pre-FS implemented* |
| 39 | 2025 | Cunene | 220 | Xangongo | 60 | 14.8 | 60 x 1, Pre-FS implemented* |
| 40 | 2025 | Moxico | 220 | Luna | 240 | 24.5 | 120 x 2, under Pre-FS |
| 41 | 2025 | Lunda Norte | 220 | Xa-Muteba | 120 | 18.1 | 60 x 2 |
| 42 | 2025 | Luanda | 220 | Viana | 600 | 44.0 | 300 x 2, upgrade |
| 43 | 2025 | Luanda | 220 | Camama | 120 | 18.1 | 120 x 1, upgrade |
| 44 | 2025 | Luanda | 220 | Sambizanga | 240 | 24.5 | 240 x 1, upgrade |
| 45 | 2025 | Kuanza Norte | 220 | N' Dalatando | 80 | 15.9 | 40 x 2, upgrade |
| 46 | 2027 | Moxico | 220 | Cazombo | 60 | 14.8 | 60 x 1 |
| 47 | 2027 | Moxico | 220 | Luau | 60 | 14.8 | 60 x 1 |
| 48 | 2027 | Lunda Sur | 220 | Muconda | 60 | 14.8 | 60 x 1 |
| 49 | 2027 | Bié | 220 | Kuito | 120 | 18.1 | 120 x 1, upgrade |
| 50 | 2030 | Luanda | 220 | Futungo de Belas | 120 | 18.1 | 120 x 1, upgrade |

Pre-FS implemented*:Candidate site were selected by USTDA and DBSA.

Table 12-4 List of 220 kV Substation Projects (2)

| Project# | Year of operation | Area | Voltage (kV) | Substation Name | Capacity (MVA) | Cost (MUSS) | Remarks |
|----------|-------------------|----------------|--------------|------------------|----------------|-------------|------------------|
| 51 | 2030 | Uíge | 220 | Negage | 180 | 21.3 | 60 x 3 |
| 52 | 2030 | Cabinda | 220 | Cabinda | 240 | 24.5 | 120x 2 |
| 53 | 2030 | Cabinda | 220 | Cacongo | 120 | 18.1 | 60 x 2 |
| 54 | 2030 | Benguela | 220 | Alto Catumbela | 120 | 18.1 | 60 x 2 |
| 55 | 2030 | Benguela | 220 | Baria Farta | 120 | 18.1 | 60 x 2 |
| 56 | 2030 | Huambo | 220 | Bailundo | 120 | 18.1 | 60 x 2 |
| 57 | 2030 | Huíla | 220 | Chipindo | 60 | 14.8 | 60 x 1 |
| 58 | 2031 | Zaire | 220 | M'Banza Congo | 180 | 21.3 | 60 x 3, upgrade |
| 59 | 2032 | Cunene | 220 | Ondjiva | 120 | 18.1 | 120 x 1, upgrade |
| 60 | 2032 | Lunda Sur | 220 | Saurimo | 120 | 18.1 | 120 x 1, upgrade |
| 61 | 2034 | Luanda | 220 | Cacuaco | 240 | 24.5 | 240 x 1, upgrade |
| 62 | 2035 | Luanda | 220 | PIV | 480 | 37.5 | 240 x 2 |
| 63 | 2035 | Kuanza Norte | 220 | Lucala | 120 | 18.1 | 60 x 2 |
| 64 | 2035 | Uíge | 220 | Sanza Pombo | 120 | 18.1 | 60 x 2 |
| 65 | 2035 | Bié | 220 | Camacupa | 60 | 14.8 | 60 x 1 |
| 66 | 2035 | Cuando-Cubango | 220 | Cuito Cuanavale | 60 | 14.8 | 60 x 1 |
| 67 | 2035 | Luanda | 220 | Cazenga | 120 | 18.1 | 120 x 1, upgrade |
| 68 | 2035 | Bengo | 220 | Kapary | 120 | 18.1 | 120 x 1, upgrade |
| 69 | 2035 | Benguela | 220 | Catumbela | 240 | 24.5 | 120 x 2, upgrade |
| 70 | 2036 | Luanda | 220 | Sambizanga | 240 | 24.5 | 240 x 1, upgrade |
| 71 | 2036 | Uíge | 220 | Maquela do Zombo | 40 | 13.7 | 40 x 1, upgrade |
| 72 | 2036 | Huambo | 220 | Belém do Dango | 240 | 24.5 | 240 x 1, upgrade |
| 73 | 2036 | Lunda Norte | 220 | Dundo | 120 | 18.1 | 120 x1, upgrade |
| 74 | 2037 | Cuanza Sul | 220 | Gabela | 60 | 14.8 | 60 x 1, upgrade |
| 75 | 2038 | Benguela | 220 | Cubal | 240 | 24.5 | 120 x 2, upgrade |
| 76 | 2040 | Cuando-Cubango | 220 | Mavinga | 60 | 14.8 | 60 x 1 |
| 77 | 2040 | Malanje | 220 | Malanje 2 | 120 | 18.1 | 120 x 1, upgrade |
| 78 | 2040 | Huíla | 220 | Caluquembe | 60 | 14.8 | 60 x 1, upgrade |
| Total | | | | | 11,810 | 772.4 | |

Table 12-5 List of 400 kV Transmission Line Projects

| Project# | Year of operation | Area | Voltage (kV) | Starting point | End point | number of circuit | Power Flow (MVA) | Line Length (km) | Cost (MU\$) | Remarks |
|----------|-------------------|----------|--------------|-----------------|-----------------|-------------------|------------------|------------------|-------------|-------------------------------|
| 1 | 2020 | Central | 400 | Lauca | Waco kungo | 1 | 307 | 177 | 138.1 | under construction(China) |
| 2 | 2020 | Central | 400 | Waco kungo | Belem do Huambo | 1 | 242 | 174 | 135.7 | under construction(China) |
| 3 | 2020 | Northern | 400 | Cambutas | Bitá | 1 | 580 | 172 | 134.2 | under construction(Brazil) |
| 4 | 2022 | Northern | 400 | Catete | Bitá | 2 | 504 | 54 | 52.9 | under construction(Brazil) |
| 5 | 2025 | Northern | 400 | Cambutas | Catete | 1 | 791 | 123 | 95.9 | Dualization |
| 6 | 2025 | Northern | 400 | Catete | Viana | 1 | 579 | 36 | 28.1 | Dualization |
| 7 | 2025 | Northern | 400 | Lauca | Capanda elev. | 1 | 518 | 41 | 32.0 | Dualization |
| 8 | 2025 | Northern | 400 | Kapary | Sambizanga | 2 | 1130 | 45 | 44.1 | For New Substation |
| 9 | 2025 | Northern | 400 | Lauca | Catete | 2 | 868 | 190 | 186.2 | Changing Connection Plan |
| 10 | 2025 | Central | 400 | Lauca | Waco kungo | 1 | 307 | 177 | 138.1 | Dualization |
| 11 | 2025 | Central | 400 | Waco kungo | Belem do Huambo | 1 | 242 | 174 | 135.7 | Dualization |
| 12 | 2025 | Central | 400 | Cambutas | Gabela | 2 | 484 | 131 | 128.4 | Pre-FS implemented* |
| 13 | 2025 | Central | 400 | Gabela | Benga | 2 | 848 | 25 | 24.5 | Pre-FS implemented* |
| 14 | 2025 | Central | 400 | Benga | Nova Biopio | 2 | 550 | 200 | 196.0 | Pre-FS implemented* |
| 15 | 2025 | Southern | 400 | Belem do Huambo | Caluquembe | 2 | 606 | 175 | 171.5 | Pre-FS implemented* |
| 16 | 2025 | Southern | 400 | Caluquembe | Lubango2 | 2 | 666 | 168 | 164.6 | Pre-FS implemented* |
| 17 | 2025 | Southern | 400 | Belem do Huambo | Chipindo | 2 | 264 | 114 | 111.7 | |
| 18 | 2025 | Southern | 400 | Chipindo | Capelongo | 2 | 190 | 109 | 106.8 | |
| 19 | 2025 | Southern | 400 | Nova Biopio | Quilengues | 2 | 840 | 117 | 114.7 | Pre-FS implemented* |
| 20 | 2025 | Southern | 400 | Quilengues | Lubango2 | 2 | 772 | 143 | 140.1 | Pre-FS implemented* |
| 21 | 2025 | Southern | 400 | Lubango2 | Cahama | 2 | 450 | 190 | 186.2 | Pre-FS implemented* |
| 22 | 2025 | Eastern | 400 | Capanda elev | Xa-Muteba | 2 | 590 | 266 | 260.7 | |
| 23 | 2025 | Eastern | 400 | Xa-Muteba | Saurimo | 2 | 510 | 335 | 328.3 | under Pre-FS |
| 24 | 2027 | Southern | 400 | Capelongo | Ondjiva | 2 | 292 | 312 | 305.8 | |
| 25 | 2027 | Southern | 400 | Cahama | Ondjiva | 2 | 442 | 175 | 171.5 | |
| 26 | 2027 | Southern | 400 | Cahama | Ruacana | 2 | 409 | 125 | 122.5 | International Interconnection |
| Total | | | | | | | | 3,948 | 3,654.2 | |

Pre-FS implemented*:Candidate route were selected by USTDA and DBSA.

Table 12-6 List of 220 kV Transmission Line Projects


| Project# | Year of operation | Area | Voltage (kV) | Starting point | End point | number of circuit | Required Capacity (MVA) | Line Length (km) | Cost (MUSS) | Remarks |
|----------|-------------------|----------|--------------|-----------------|-----------------|-------------------|-------------------------|------------------|-------------|-------------------------|
| 1 | 2020 | Southern | 220 | Lubango2 | Lubango | 2 | 360 | 30 | 13.5 | Pre-FS implemented* |
| 2 | 2020 | Southern | 220 | Lubango2 | Namibe | 2 | 360 | 162 | 72.9 | Pre-FS implemented* |
| 3 | 2020 | Southern | 220 | Namibe | Tombwa | 2 | 120 | 97 | 43.7 | Pre-FS implemented* |
| 4 | 2020 | Eastern | 220 | Saurimo | Lucapa | 2 | 300 | 157 | 70.7 | Pre-FS implemented* |
| 5 | 2020 | Eastern | 220 | Lucapa | Dundo | 2 | 240 | 135 | 60.8 | Pre-FS implemented* |
| 6 | 2022 | Northern | 220 | Bitá | Camama | 2 | 840 | 21 | 9.5 | |
| 7 | 2022 | Northern | 220 | Catete | Zango | 2 | 360 | 40 | 18.0 | |
| 8 | 2022 | Northern | 220 | Capanda elev. | Maranje | 2 | 360 | 110 | 49.5 | |
| 9 | 2022 | Central | 220 | Gabela | Alto Chingo | 1 | 300 | 81 | 29.2 | Dualization |
| 10 | 2022 | Central | 220 | Quibala | Waco Kungo | 2 | 120 | 92 | 41.4 | |
| 11 | 2022 | Central | 220 | Lomaum | Cubal | 2 | 360 | 2 | 0.9 | |
| 12 | 2022 | Southern | 220 | Lubango | Matala | 2 | 120 | 168 | 75.6 | Pre-FS implemented* |
| 13 | 2022 | Southern | 220 | Matala HPS | Matala | 1 | 41 | 5 | 1.8 | upgarade |
| 14 | 2022 | Southern | 220 | Capelongo | Cuchi | 2 | 420 | 91 | 41.0 | |
| 15 | 2022 | Southern | 220 | Cuchi | Menongue | 2 | 360 | 94 | 42.3 | |
| 16 | 2025 | Northern | 220 | Sambizanga | Golle | 2 | 360 | 7 | 3.2 | |
| 17 | 2025 | Northern | 220 | Kapary | Caxito | 2 | 60 | 26 | 11.7 | |
| 18 | 2025 | Northern | 220 | N'Zeto | Tomboco | 2 | 220 | 5 | 2.3 | For Substation inserted |
| 19 | 2025 | Northern | 220 | M'banza Congo | Tomboco | 2 | 220 | 5 | 2.3 | For Substation inserted |
| 20 | 2025 | Northern | 220 | Sambizanga | Chicala | 2 | 480 | 7 | 3.2 | |
| 21 | 2025 | Northern | 220 | Catete | Maria Teresa | 2 | 60 | 51 | 23.0 | |
| 22 | 2025 | Central | 220 | Alto Chingo | Cuacra | 2 | 60 | 25 | 11.3 | |
| 23 | 2025 | Central | 220 | Alto Chingo | Port Amboim | 2 | 120 | 60 | 27.0 | |
| 24 | 2025 | Central | 220 | Quileva | Nova Biopio | 1 | 550 | 18 | 6.5 | Dualization |
| 25 | 2025 | Central | 220 | Quileva | Catumbela | 2 | 240 | 8 | 3.6 | |
| 26 | 2025 | Central | 220 | Nova Biopio | Bocoio | 2 | 120 | 5 | 2.3 | For Substation inserted |
| 27 | 2025 | Central | 220 | Lomaum | Bocoio | 2 | 120 | 5 | 2.3 | For Substation inserted |
| 28 | 2025 | Central | 220 | Belem do Huambo | Ukuma | 2 | 60 | 66 | 29.7 | |
| 29 | 2025 | Central | 220 | Belem do Huambo | Catchiungo | 2 | 720 | 76 | 34.2 | Strengthen |
| 30 | 2025 | Central | 220 | Catchiungo | Kuito | 2 | 480 | 85 | 38.3 | Strengthen |
| 31 | 2025 | Central | 220 | Kuito | Andulo | 2 | 60 | 110 | 49.5 | |
| 32 | 2025 | Southern | 220 | Cahama | Xangongo | 2 | 180 | 97 | 43.7 | Pre-FS implemented* |
| 33 | 2025 | Southern | 220 | Ondjiva | Xangongo | 1 | 120 | 97 | 34.9 | Pre-FS implemented* |
| 34 | 2025 | Southern | 220 | Capelongo | Tchamutete | 2 | 120 | 98 | 44.1 | |
| 35 | 2025 | Eastern | 220 | Saurimo | Luená | 2 | 240 | 265 | 119.3 | Pre-FS implemented* |
| 36 | 2027 | Eastern | 220 | Saurimo | Muconda | 2 | 180 | 187 | 84.2 | |
| 37 | 2027 | Eastern | 220 | Muconda | Luau | 2 | 120 | 115 | 51.8 | |
| 38 | 2027 | Eastern | 220 | Luau | Cazombo | 2 | 60 | 264 | 118.8 | |
| 39 | 2030 | Central | 220 | Cubal | Alto Catumbela | 2 | 120 | 47 | 21.2 | |
| 40 | 2030 | Central | 220 | Catchiungo | Bailundo | 2 | 120 | 66 | 29.7 | |
| 41 | 2030 | Central | 220 | Benguela Sul | Baia Farta | 2 | 120 | 30 | 13.5 | |
| 42 | 2030 | Northern | 220 | Uige | Negage | 2 | 620 | 5 | 2.3 | For Substation inserted |
| 43 | 2030 | Northern | 220 | Pambos de Sonhe | Negage | 2 | 620 | 5 | 2.3 | For Substation inserted |
| 44 | 2035 | Northern | 220 | Viana | PIV | 2 | 480 | 7 | 3.2 | |
| 45 | 2035 | Northern | 220 | Negage | Sanza Pombo | 2 | 120 | 109 | 49.1 | |
| 46 | 2035 | Central | 220 | Kuito | Camacupa | 2 | 60 | 145 | 65.3 | |
| 47 | 2035 | Southern | 220 | Menongue | Cuito Cuanavale | 2 | 120 | 189 | 85.1 | |
| 48 | 2035 | Southern | 220 | Cuito Cuanavale | mavinga | 2 | 60 | 176 | 79.2 | |
| Total | | | | | | | | 3,746 | 1,667.6 | |

Pre-FS implemented*:Candidate route were selected by USTDA and DBSA.

Table 12-7 List of Transmission Line Projects for Newly Developed Power Sources

| Project# | Year of operation | Area | Voltage (kV) | Starting point | End point | number of circuit | Generation Capacity (MVA) | Line Length (km) | Cost (MUS\$) | Remarks |
|----------|-------------------|----------|--------------|--------------------|-------------------|-------------------|---------------------------|------------------|--------------|---------------------------|
| 1 | 2025 | Northern | 400 | HPP Caculo Cabaça | Cambutas | 2 | 496 | 54 | 52.9 | under construction(China) |
| 2 | 2025 | Northern | 400 | HPP Caculo Cabaça | Lauca | 2 | 1326 | 25 | 24.5 | |
| 3 | 2025 | Northern | 400 | TPP Soyo 2 | Soyo | 2 | 750 | 5 | 4.9 | |
| 4 | 2025 | Central | 400 | TPP Lobito CCGT #1 | Nova Biopio | 2 | 750 | 23 | 22.5 | |
| 5 | 2025 | Northern | 220 | TPP Cacuo GT #1 | Cacuaco | 2 | 375 | 5 | 2.3 | |
| 6 | 2025 | Northern | 220 | TPP Cacuo GT #2 | Cacuaco | 2 | 375 | 5 | 2.3 | |
| 7 | 2025 | Northern | 220 | TPP Boavista GT #3 | Sambizanga | 2 | 375 | 5 | 2.3 | |
| 8 | 2030 | Northern | 220 | HPP Quilengue ⑤ | Gabera | 2 | 210 | 37 | 16.7 | |
| 9 | 2030 | Southern | 400 | HPP Baynes | Cahama | 2 | 300 | 195 | 191.1 | |
| 10 | 2030 | Central | 220 | TPP Quileva GT #4 | Quileva | 2 | 250 | 1 | 0.5 | |
| 11 | 2030 | Central | 220 | TPP Quileva GT #5 | Quileva | 2 | 250 | 1 | 0.5 | |
| 12 | 2030 | Central | 220 | TPP Quileva GT #6 | Quileva | 2 | 250 | 1 | 0.5 | |
| 13 | 2030 | Northern | 400 | TPP Soyo GT #7 | Soyo | 2 | 375 | 5 | 4.9 | |
| 14 | 2035 | Northern | 400 | HPP Zenzo | Cambutas | 2 | 950 | 41 | 40.2 | |
| 15 | 2035 | Northern | 400 | HPP Genga | Benga Switch-yard | 2 | 900 | 30 | 29.4 | |
| 16 | 2035 | Central | 400 | TPP Lobito CCGT #2 | Nova Biopio | 2 | 720 | 23 | 22.5 | |
| 17 | 2035 | Southern | 220 | HPP Jamba Ya Mina | Matala | 1 | 205 | 86 | 31.0 | |
| 18 | 2035 | Southern | 220 | HPP Jamba Ya Oma | HPP Jamba Ya Mina | 1 | 79 | 37 | 13.3 | |
| 19 | 2040 | Northern | 220 | HPP Tímulo Caçador | Cambutas | 2 | 453 | 16 | 7.2 | |
| 20 | 2040 | Southern | 220 | TPP Namibe CCGT #3 | Namibe | 2 | 750 | 17 | 7.7 | |
| 21 | 2040 | Central | 400 | TPP Lobito CCGT #4 | Nova Biopio | 2 | 375 | 23 | 22.5 | |
| Total | | | | | | | | 635 | 499.4 | |

The generation development plan and transmission development plan are summarized in the table below.



| Transmission Dev. Plan | Year 2018-20 | Year 2021-25 | Year 2026-30 | Year 2031-35 | Year 2036-40 |
|---|--|--|--------------|--------------|--------------|
| Trans. For Power Plant | Implementation of projects to connect the new hydropower plants and the new gas-fired thermal power plants in the central and south to the main & regional system. | | | | |
| Construction of 400 kV Main System | <div>Lauca – Waco Kungo – Belem do Huambo</div> <div>Cambutasu – Gabela – Nova Biopio – Lubango</div> | <div>– Lubango</div> <div>Lubango – Cahama</div> | | | |
| Enhancement of 220 kV System | to enhance the 220 kV regional system, mainly in Luanda, Benguela region | | | | |
| Two circuit of the backbone line to secure N-1 criteria | To avoid overload during accidents of an existing circuit of the transmission line, eliminate operational restrictions, and improve the reliability, one circuit has to be added in parallel to make the backbone line a two-circuit type. | | | | |

Figure 12-1 Summary of Generation Development Plan & Transmission Development Plan




Figure 12-2 Project Map toward 2040




Figure 12-3 Project Map toward 2040 (nearby Luanda)



Figure 12-4 Project Map toward 2040 (Northern Region from Luanda)




Figure 12-5 Project Map toward 2040 (Western Region from Luanda)



Figure 12-6 Project Map toward 2040 (Central Region)




Figure 12-7 Project Map toward 2040 (South Region)




Figure 12-8 Current Project under Construction

12.2 Projects to which Japan can contribute from a technical standpoint

12.2.1 South Transmission System Enhancement Project

Because the power transmission system enhancement project in the northern system is already underway with China and Brazilian funds, Japan can cooperate more meaningfully by assisting other power transmission enhancement projects in the central and southern regions. In this region, JICA currently supports renovation of the port of Namibe by grant aid. Therefore, JICA can contribute to the economic growth of this region by improving power access along with logistics. When Japan provides financial cooperation, however, the participation of Japanese companies should be considered, which in turn raises the issue of safety.

Figure 12-8 shows the transmission system enhancement plan superimposed on an Angolan risk map obtained from the Ministry of Foreign Affairs Overseas Safety Website.

Two possibilities can be found from this figure. The first is the development of the CCGT power near Lobito Port in Benguela Province and the development of a 400 kV power line spanning a short 23 km distance to the 400 kV Nova BioPio substation.

We had already confirmed, however, during our second regional survey of Benguela and Huambo, that the Chinese side was beginning to work on power transmission system enhancements in that area.

The second possibility is the development of a 220 kV transmission line connecting a CCGT plant near Namibe Port to the 220 kV Namibe substation and the 400 kV Lubango 2 substation. We investigated the route of the transmission lines along the national roads in this area in our 3rd regional survey and confirmed that there were no big problems in terms of safety. We therefore think this second possibility would be preferable for scale, and would like to recommend it. We also considered an optional inclusion of a 220 kV Tombwa substation.




Figure 12-9 South Transmission System Enhancement Project Map

Table 12-8 List of South Transmission System Enhancement Projects

| Item | Voltage | Name of Facilities | Overview | Cost (MUS\$) |
|----------------------|---------|--------------------|---------------|--------------|
| Substation | 400kV | Lubango2 | 900MVA | 51.3 |
| | 220kV | Namibe | 240MVA | 24.5 |
| | 220kV | Tombwa | 120MVA | 18.1 |
| Transmission Line | 220kV | Lubango2-Namibe | 2cct,154km | 68.0 |
| | 220kV | Namibe-Tombwa | 2cct,110km | 49.5 |
| | | | Project Total | 211.4 |

12.2.2 New CCGT Project

As mentioned in Chapter 6, it will be necessary to introduce CCGT as a middle demand power supply in Angola in order to realize the optimal generation mix. Japanese manufacturers have the world's top-class technology in CCGT and are ideally positioned to contribute through technical cooperation. A typical CCGT project is shown in Table 12-9.

Table 12-9 CCGT Project (example)

| Item | Contents |
|--------------------|--|
| Project | New CCGT Construction |
| Installed Capacity | Approx. 750 MW/plant |
| Project Costs* | Approx. 900 millUSD |
| Project Boundary | CCGT main machine, auxiliaries (chiller, condenser, fuel receiving tank, etc.), civil work, architectural work, etc. |
| Project Type | EPC, BOT, IPP |


* The above construction cost is CCGT project only. Considering fuel consumption, it is necessary to construct the following fuel supply facilities.

| | |
|---|---|
| Note (Costs based on investigation in Japan) | Construction Costs for LNG Tank: 100-150 millUSD/unit Construction Costs for Gas Pipeline: 4-13 millUSD/km FSRU (Floating Storage Regasification Unit): 250 - 330 millUSD (Capacity 140,000 m3) Construction Costs for LPG Tank: 10-30 millUSD/unit (Capacity 20,000 m3) |
|---|---|

<Tank matter>

An approximately 750-MW-class CCGT requires about 50,000 m3 of LNG per month. One 125,000 m3 LNG tank can therefore store more than two months of fuel. For backup purposes, a system should ideally have 2 tanks. With 2 tanks, fuel can be supplied to up to about 4 CCGT power plants.

When LPG is used as a fuel, about 30,000 tons of LPG is required per month. Unlike LNG, LPG is procured through diversified routes and accordingly can be stored in smaller quantities. The maintenance of total tank capacities of 20,000 tons is thought to be sufficient, with backups included.



12.2.3 New GT Construction as a Peak Demand Power Supply & Introduction of SCADA for GT Control


An examination of the optimal generation mix clearly showed that it will be necessary to introduce GT to some extent as a peak demand power supply. Japanese manufacturers are ideally suited to introduce the technology, as they are the world's most technologically advanced entities in this field.

Peak demand power supply must incur a low power generation cost at times of low utilization and requires a function to allow rapid load fluctuation when peak demand occurs. This latter function can be realized by introducing a control system such as SCADA for dispatching the power supply. As a system enabling the easy collection of data on power generation and demand, SCADA also leads to more efficient system operation and ensures system stability.

Japan's example experience in this field makes Japan an ideal source of technical cooperation.

Table 12-10 Construction of Peak Demand Power Supply & Introduction of SCADA

| New GT Construction Project | | SCADA Introduction Project | |
|-----------------------------|-----------------------------|----------------------------|----------------------------------|
| Project | New GT Construction | Project | SCADA development & introduction |
| Installed Capacity | Approx. 100 MW/plant | Project Costs | Depends on the project scale |
| Project Costs | Approx. 60-80 millUSD/plant | | |
| Project Type | EPC, BOT | Project Type | Technical Assistance Project |



12.2.4 Project to Repower Old Hydropower Plants

The Biópio hydropower plant and Matala hydropower plant in Angola are medium-sized plants that supply the core power for each region. Both, however, were developed as far back as the 1950s and suffer from problems such as equipment damage and efficiency reductions due to aging and other causes. Given these background conditions, we believe that the regional power supply could be strengthened by diagnosing the equipment at these hydropower plants and rehabilitating them based on the results.

Japan's ample experience in repowering aged hydropower plants makes Japan as an ideal source of technical cooperation.

Table 12-11 Current Status of the HPP

| Name | Province | Municipality | Installed capacity (MW) | Available capacity (MW) | Commissioning Year | Status |
|---------------|----------|--------------|-------------------------|-------------------------|--------------------|--|
| Biópio | Benguela | Lobito | 14.58 (4x 3.645) | 12.0 | 1955 | The penstock is damaged and no water can be supplied to the turbine. Operations at the power plant are therefore completely stopped. |
| Matala | Huíla | Matala | 40.8 (3x 13.6) | 27.2 | 1959 | There were plans to install three generators, but one of the three has not been installed. The efficiency of the remaining two units is thought to be declining as a result. |




Figure 12-10 Biópio HPP's Current Status

12.3 Advice to MINEA, RNT, PRODEL, ENDE and IRSEA's Action Plan on the Power Development Master Plan

12.3.1 Action Plan for the Power Development Master Plan

The Angolan action Plans on the Power Development Master Plan are summarized in the following table.

Table 12-12 Action Plans for the Power Development Master Plan

| Target | Item | Action Plan in Detail |
|--|--|--|
| Action plans related to maintenance of the Power Master Plan | Establishment of an organization to formulate PDMP | ➤ Establishment of the Institute of Power Development Planning (IPDP) <tentative name> |
| | Continuing to revise PDMP | Ongoing revisions to the Power Demand Forecast ➤ To collect necessary data such as economic indicators ➤ To collect demand data and improve accumulation method ➤ Hearing customers |
| | | Ongoing revisions to the Generation Development Plan ➤ Review of fuel procurement plans ➤ Collection of the latest technical information on hydropower & thermal power ➤ Ongoing study on the occupancy hydropower potential ➤ Maintaining the Best Generation Mix |
| | | Ongoing revisions of the Transmission Development Plan ➤ Ongoing analysis of the supply-demand imbalance by region ➤ Review of transmission facility specifications ➤ Review of power flow analysis |
| Action plans related to execution of development projects | Company Operation & Project management | ➤ PDMP deployment and reflection of PDMP in the medium-term plans of the respective entities |
| | Management and reform of fund procurement | ➤ Improvement of the tariff system ➤ Study on utilizing the foreign loan ➤ Study on introducing private sector funds |
| Others | Reform of dispatching organizations | ➤ Introduction of SCADA ➤ Reform of central and regional dispatching organizations |

The action plans will be described in detail from the next section.

12.3.2 Establishment of an Organization to Formulate and Continuously Revise the PDMP

The preconditions for the formulation of Power Development Master Plan such as the power demand, power generation situation, project schedule, and electric power technology in general all evolve and change every day. Given the ever-changing nature of these preconditions, the master plan must be reviewed at least every three to five years. A dedicated department will be required to accomplish this.

At present, Angola has individually arranged an electricity planning department in each public corporation, and MINEA consolidates the examination results within the departments. This regime is not necessarily efficient or effective. In the near future we should establish a department with motivated staff within MINEA to oversee the power planning function (demand forecast, power development plan, transmission and distribution development plan), revise the master plan consistently, and develop human resources. We need to proceed with the preparations for the establishment such a department immediately.




Figure 12-11 Example of Organization to Formulate PDPM

12.3.3 Improvement Activities to Establish a Method for Accurate Power Demand Forecasts

Angola currently lacks the accumulated data needed to formulate power demand forecasts. To improve the Power Development Master Plan in the future, it will be necessary to prepare a system for collecting these data and forecasting power demand more accurately. And to predict and grasp special demand for industrial/commercial use, ENDE will have to grasp customer contract requests, information on factory construction, information on commercial facility development, etc. on the basis of the supply areas of distribution S/S. A hearing system will have to be developed for this purpose.

The following shows an example of a power demand forecasting system.




Figure 12-12 Action Plan and Structure for Power Demand Forecast

12.3.4 Ongoing study on the occupancy hydropower potential

The hydropower development plan is an important item to consider when formulating generation development plans, especially in a country with a high ratio of hydropower power supply, like Angola. The most basic data to review when considering a hydropower development plan is focused on the occupancy hydropower potential. Surveys on hydropower potential must be periodically reviewed to keep track of how it has been affected by changes in the natural environment (e.g., weather), social environment, economic conditions, etc. While some hydropower potential has been described in Enagia, we have no clear information on if and how often the surveys have been periodically revised. The Survey Team therefore recommends periodic revisions.

12.3.5 Management and Improvement of Fund Procurement

As mentioned in Chapter 9, the total investment in the power sector amounts to 31,548 MUSD. It would be impossible to cover the entire investment in the power sector with national funds. The following are therefore considered as the most feasible options for enabling fund procurement.

- Introduction of private funds
- Utilization of diverse ODA
- Improvement of electricity tariff structures

(1) Establishment of Framework for Introducing Private Funds

One way to reduce the national fiscal burden is to introduce private funds such as IPP. Angola has also enforced a PPP Law from April 2011 with a view of introducing IPP from 2021, but the method for awarding entrance licenses (bidding method), the method for selling contracts, the tariff structure etc. have not yet been made clear. It will therefore be necessary to advance a concrete system design.

(2) Establishing a Method and Scheme to Borrow from Foreign Funds

While Angola has borrowed from European countries and China, support from other aid organizations should henceforth be considered with a view to diversifying fund procurement.

Note, however, that loans provided by OECD member countries and loans provided by aid organizations will entail ideas and financing conditions divergent from those associated with financial assistance from China.

- The projects developed with foreign funds in Angola are initially constructed by GAMEK. Later, after the operation is started, the equipment is handed over to PRODEL, RNT, and ENDE. Borrowed funds are repaid by the Angolan government, and the implementing agency, the borrower of the funds, and the repayer of the funds all seem to be separate in that sense. Considering the financial burden accompanying borrowing and the availability of government guarantees, etc., it will be necessary to reconsider whether the implementing agency, the borrower of the funds, and the repayer of the funds can be separated in this way.
- The entities will have to familiarize themselves with the project formation cycle of each donor organization, to know what will be required for the loan reviews, and to have an accurate idea of how long the project will take to implement. With this information, we can decide which projects to request and which ones to develop by ourselves.
- Government guarantees are necessary for loans from JICA and AfDB. Note, also, that JICA will only implement ODA loans that the partner country officially requests. Therefore, the government of Angola and the agency implementing the project must both establish procedures for approval by the competent authorities and the formal request for the ODA loan.
- The Angolan government, meanwhile, should pay attention to external debt and additionally consider the risk that it will be unable to issue government guarantees. If no government guarantees can be issued, there is a risk that an unavailability of borrowing from outside will bring the development to halt. In such an event, the implementing agency would have to raise the tariff rate and endeavor to enrich its financial content.
- A donor agency wishing to review the case requires an Implementation Report (I/P) report examining the content of the project over a reasonable amount of time and the expense required. JICA, for example, has a system (*) to promote necessary surveys in the project cycle. In order to make use of these, we should be familiar with the project formation cycle of donor agencies.

* Specifically, a Special Assistance Facility Survey (SAF) in line with JICA's project cycle. Three types are available: Special Assistance for Project Formation (SAPROF), Special Assistance for Project Implementation (SAPI), and Special Assistance for Project Sustainability (SAPS).

Table 12-13 shows an example of a project schedule for arranging a JICA ODA loan for a thermal power plant.

Table 12-13 Flow of Implementation of ODA Loan

| Timetable | Item | Duration |
|---|--|-----------|
| 1. Project Preparation | Fact-finding mission, F/S etc. | 1-2 years |
| 2. Official Loan Request | Follow the official procedures of the financial institutions | |
| 3. Project formation | Follow the project cycle and make use of an official project formation support system such as SAPROF (※) . | 1-2 years |
| 4. Appraisal of the project | If necessary, exchange an E/S loan agreement | |
| 5. Exchange of Notes and Loan Agreement | Sometimes including E/S loans | |
| 6. Project Implementation | | 4-7 years |

(3) Improvement of Tariff Structure

In order to achieve stable power supply and systematic reinforcement of equipment, it is essential that the equipment at each facility be financed with the public power company's own funds. A tariff rate enabling capital recovery must be established to enable this. It will be important, in this regard, to consider action plans by which to realize the tariff rate level examined in Chapter 9.

- The income and expenses related to the project must be considered when examining the tariff rate. The analysis of LRMC in Section 9.3 and the costs per kWh (including financial costs) are examples. The examination of the tariff rate will require ready access to the accounting data at all times.
- On the political level, the actual costs to be incurred tend to be forgotten when a deficit is supplemented with a subsidy to curb the electricity tariff rate of distribution. The extent to which subsidies are to be introduced should be decided after calculating the original income and expenses involved in the project.
- We recommend that the IRSEA evaluate the power generation, power transmission, and distribution costs with reference to the results of this survey and revise the electricity tariff in the future.

12.3.6 Deploying the PDMP and reflecting it in the medium-term plan of each entity

The Power Development Master Plan is a super-long-term plan with a target period of longer than 20 years. As such, the assumptions on which it is based may sharply diverge from the realities over time. Power companies usually deploy and reflect a super-long-term plan into their mid-term plans and prepare annual management plans and implementation plans for individual projects. These plans typically include the following components.


- Power demand forecast
- Generation development plan
- Transmission development plan
- Capital investment plan (based on the generation & transmission development plan)
- Fuel Procurement Plan
- Toll collection plan
- Fund procurement plan
- O&M plan
- Toll collection plan

- Organization & Human Resources Development Plan
- Other

An annual budget is formulated based on these plans.

Even in Angola, RNT, PRODEL and ENDE each formulate a mid-term plan to realize the aforesaid based on the Power Development Master Plan revised by MINEA. These mid-term plans are often revised every year through a Plan-Do-Check-Action (PDCA) cycle.

Table 12-14 Medium-Term Planning Cycle



12.3.7 Improvement of Power Operation System / Introduction of SCADA

As mentioned earlier, Angola is currently unable to accumulate or consolidate various types of operational data. One of the reasons for this is thought to be the practice of entering most of the data into handwritten datasheets and then digitizing later at the head office.

In several S/Ss and power plants we visited during the survey, the operational data was written out by hand and transferred to the headquarters in hard copy form. Computerized operating systems were introduced but unused for the data-keeping purpose.

The use of the computer systems is likely to be discouraged by the poor uniformity of operating systems from project to project and development to development. Smooth data transmission from system to system appears not to have been adequately considered during system installation.

In order to make effective use of these existing systems, it will be necessary to develop middleware and integrate each system to enable data browsing and transmission.

If this approach is applied, remote control of the machines will become possible, enabling use of the machines for SCADA system construction.




Figure 12-13 Example of SCADA

12.3.8 Improvement of Operation System to Make Use of Power Generation Characteristics

The optimal generation mix is obtained by considering and combining power generation methods with the lowest power generation cost at utilization rates set according to the facility utilization ratios. The cost is cheapest if the GT corresponds to the peak demand area, that is, the low utilization rate area. Meanwhile, it is advantageous to respond to base demand, that is, the large utilization rate area, by hydropower. Conversely, if GT is to be used as a power source capable of responding to peak demand, it will be necessary cease generating electricity by GT over many hours and dispatch a base demand power supply such as hydropower to operate as long as possible. Given that the peak demand is also rapidly changing, the stable supply of electric power will hinge on close and effective control of the time zones in operation. The establishment of the control system will be an extremely important step in making this possible.

Figure 12-13 and Figure 12-14 show TEPCO's load dispatching system. The organization of the whole load dispatching system consists of local load dispatching offices established under a central load dispatching office. Orders to adjust operations, power generation commands, and operation record management procedures are all under the control of the central and local load dispatching offices. Only after establishing such an organization will it be possible to operate a power system according to the characteristics of the power plants. Hence, such an organization will have to be prepared even in Angola.




Figure 12-14 TEPCO's Load Dispatching Offices




Figure 12-15 Staffing of Load Dispatching Office

12.3.9 Establishment of standards for transmission and substation facilities

Since we have not clearly set up facility planning criteria in Angola at this time, we have set standards for transmission line type / size, transformer capacity, number of units. However in the future, the standard for transmission facilities taking account of regional environmental characteristics is necessary to be established.

The provisional transmission and substation planning standards for this time are shown in Table 12 15 and Table 12 16.

(Each conductor thermal capacity was calculated by Cigre formula according to allowable current calculation condition of conductors in Angola.)

Table 12-15 The standard for Substation facilities

| Voltage (Primary/Secondary) | Maximum Number per Substation | Transformer Capacity (MVA) | Remarks |
|--------------------------------|----------------------------------|-------------------------------|------------|
| 400/220 | 3 | 450 | usual |
| | | 930 | heavy load |
| 220/60 | 3 | 60 | rural |
| | | 120 | usual |
| | | 240 | heavy load |

(Source: JICA Survey Team)

Table 12-16 The standard for Transmission line facilities

| Voltage (kV) | Conductor Type | Number of Conductor per Phase | Transmission Line Thermal Capacity per Circuit (MVA) | Remarks |
|-----------------|-----------------------------------|----------------------------------|--|------------|
| 400 | AAAC Sorbus (659mm ²) | 2 | 1519 | usual |
| | 〃 | 3 | 2278 | heavy load |
| 220 | ACSR Crow (409mm ²) | 1 | 305 | rural |
| | AAAC Yew (479mm ²) | 1 | 343 | rural |
| | 〃 | 2 | 686 | usual |
| | AAAC Sorbus (659mm ²) | 2 | 835 | heavy load |

(Source: JICA Survey Team)



Particularly in the above table, since AAAC (all aluminum alloy stranded wire) is weak against breeze vibration fatigue and has a weak point that the creep amount is large, and its application to a place where the load becomes large (strong wind, icing, large difference in height, etc.), you should be aware of its application.. In addition, fretting corrosion phenomenon (friction corrosion due to vibration) is known to occur, and attention must also be paid to use in coastal areas and desert areas.

Also, since AAAC is made of aluminum alloy, the power transmission loss is larger than that of pure aluminum type electric conductors. Compared to AAAC Yew which is approximately the same size as LL-ACSR 500 mm which is a low-loss conductor (Low-Loss ACSR: abbreviated as LL-ACSR) developed in Japan, the resistance of LL-ACSR is about 16.7% smaller as Table 12 17 , The initial investment amount due to the high electric conductor price of LL-ACSR can be collected in

10 to 20 years at the place where tidal current is large, and it becomes economical in consideration of the life of electric conductor 40 years.

In the future, planning of transmission lines with large currents should be done, planning criteria should be determined considering power transmission loss well enough.

Table 12-17 Compare of AAAC and LL-ACSR

| | | Conventional | Recent |
|----------------------------|--------|---|--|
| Description | Unit | AAAC Yew | LL-ACSR 500mm ² |
| Cross sectional view | — |  |  |
| Nominal diameter | mm | 28.4 | 27.00 |
| Cross sectional area | AL | 479 | 500.2 |
| | Core | | 21.99 |
| | Total | 479 | 522.2 |
| Nominal weight | kg/km | 1,319 | 1,546 |
| DC resistance at 20 deg. C | ohm/km | 0,069 | 0.05750 |
| Unit price | USD/km | 5,000* | 7,420 |

(Source: JICA Survey Team)

Table 12-18 Schedule for Action Plan on PDMP

| | | 2018-'20 | 2021-'25 | 2026-'30 | 2031-'35 | 2036-'40 |
|--|--------------------------------|---|---|--|----------|----------|
| Establishment of Organization to Formulate PDPM | MINEA RNT PRODEL ENDE | <div>Establishment of IPDP</div> | | | | |
| Revision of PDPM | MINEA/IPDP | | ▼ | ▼ | ▼ | ▼ |
| <div>➤ Actions to improve the accuracy of the Power Demand Forecasting</div> <div>✧ Organizing and accumulating information</div> <div>✧ Hearings with customers</div> | RNT ENDE | <div>Design & introduction of SCADA</div> | | <div>Efficient accumulation and analysis of data</div> | | |
| | | <div>Enhancement of customer hearing system; Continuation of hearings</div> | | | | |
| | | | | | | |
| <div>➤ Revision of study on occupancy hydropower potential</div> | | | ▼ | ▼ | ▼ | ▼ |
| Formulation of mid-term plan | RNT PRODEL ENDE | <div>Review of the mid-term plan year by year</div> | | | | |
| Design of electricity tariff structure | IRSEA | <div>Tariff structure design</div> | until the start of liberalization at the latest | | | |
| Institution design for IPP entry <div>➤ Concession system, PPA system, etc.</div> | IRSEA | <div>Institution design for IPP entry</div> | until the start of liberalization at the latest | | | |
| Renovation of load dispatching organization <div>➤ Reform of load dispatching offices</div> <div>➤ Introduction of SCADA</div> | RNT PRODEL | <div>Reform of load dispatching offices</div> | | | | |
| | | <div>Introduction of</div> | | | | |

Chapter 13 Technology Transfer & Capacity Building

The survey covers technology transfer activities related to the formulation of the Power Development Master Plan. The plans formed during the work implementation planning called for technology transfer through workshops and OJT. Later, for the following reasons, we narrowed down the approach to workshops alone. Approval from the Angola side has been obtained for this approach.

- The personnel involved in the planning of the power sector are widely distributed within MINEA, RNT, PRODEL, ENDE, and IRSEA, making it difficult to grasp the target counterparts to whom the technology should be transferred. It will therefore be more efficient to invite the target counterparts to workshops than to visit and cooperate with them through OJT.
- The Survey Team works out of an office located at some distance from the office of the counterpart, making OJT physically impossible.
- MINEA wants as many personnel as possible to master the skills.

13.1 Workshop

The workshops shown in the table below were held over the course of four missions. PDPAT, a demand and supply operation simulation software package, was introduced on the Angola Side.


Table 13-1 Workshop Curriculum

| Mission | Date | Curriculum |
|-------------------------------|---------|--|
| 1st Mission | 18-Jul | TEPCO's Power Development History |
| | 25-Jul | Power Demand Forecasts +Methodology of Power Demand Forecasts Generation Development Plan +Supply reliability criteria |
| 2nd Mission | 28-Sep | Generation Development Plan +Screening Method |
| | 29-Sep | Transmission Development Plan +Fundamental Concepts of power system planning in TEPCO |
| | 4-Oct | Generation Development Plan +Annual Expenditure Transmission Development Plan +Power Flow Analysis |
| | 5-Oct | Generation Development Plan +Dispatching game |
| | 6-Oct | Transmission Development Plan +Outline of Transmission Line Design & Cost Estimation |
| | | |
| 3rd Mission | 12-Jan | Financial & Economical Analysis +Basic item of Financial & Economical Analysis Generation Development Plan +How to operate PDPAT |
| | 18-Jan, | Generation Development Plan +Configuration of data for GDP (1) |
| | 25-Jan, | Power Demand Forecast +Confirming accomplishment Transmission Development Plan +Proceeding with formulation work +Clarifying matters entailed in the formulation of the TDP Generation Development Plan |

| | |
|----------------------|---|
| | +Configuring data for GDP (2) |
| 31-Jan | Environmental & Social Considerations +SEA General +Perspective of the Final Power Development Master Plan |
| Final Mission | Procedure to formulate the Power Development Master Plan |



18-July Workshop



25-July Workshop



25-July Workshop



28-Sept. Workshop



28-Sept. Workshop



29-Sept. Workshop

13.2 Training in Japan

Angola side counterparts were invited to Japan for training to deepen their understanding of the status of Japan's power system operations (including operation at the central dispatching office) for stable power supply, the influence of renewable energy power supplies on the power system, and advanced technologies possessed by Japanese companies (high-efficiency thermal power generation, etc.).

13.2.1 Participants

Ten counterparts were invited to the training in Japan. The participants were affiliated with MINEA (including GAMEK), PRODEL, RNT, ENDE, and IRSEA.

Table 13-2 Participants List

| | Name | Entity | Department | Position |
|-----|---|--------|--|-----------------------------|
| Mr. | Osvaldo Marcos Julião Gonçalves | MINEA | National Directorate of Electrical Energy | Engineer |
| Mr. | Ernesto Milton Pereira da Costa | PRODEL | Hydraulic Production Directorate | Director |
| Mr. | Cláudio Morais Marques | PRODEL | Statistic and Planning | Senior Engineer |
| Mr. | Eudes Panzo | RNT | Power System Planning | Head of Department |
| Mr. | Leonardo Tshama | RNT | Power System Planning | Engineer |
| Mr. | Délcio Fonseca | RNT | Power System Planning | Engineer |
| Mr. | Caterça Calumbo da Costa | ENDE | Maintenance Protection | Engineer |
| Mr. | Kuatel Xeku Conceição | ENDE | Operation Division | Chief of Division Operation |
| Mr. | Negidio Francisco Neto da Silva Buakela | GAMEK | Technical Department | Engineer |
| Mr. | Adérito Pedro Manico | IRSEA | Technical Supervision and Quality of Electricity Service | Head of Department |

13.2.2 Activity Records

The inspection site was chosen mainly from the following viewpoints.

- To understand the system operation status of the Japanese power utilities and the training policies of the operators
- To visit two plants: first, the mega solar power plant, to grasp the influence of renewable energy on the grid; second, the pumped storage power plant in charge of regulating the stability of the power system
- To grasp the state-of-the-art coal-fired thermal power generation technology and CCGT technology in Japan
- To understand the interconnection of power system technologies between companies

The details of the training program are summarized in the table below.


Table 13-3 Activity Record of Training in Japan

| Date | Time | | | Program | Site |
|-----------|-------|---|-------|---|--|
| 27-Nov-17 | | ~ | 22:45 | Arrival in Japan | |
| 28-Nov-17 | 13:00 | ~ | 14:30 | Courtesy call to JICA | JICA Ichigaya office |
| | 14:30 | ~ | 15:30 | Kick off | |
| 29-Nov-17 | 9:00 | ~ | 10:00 | Role of electric power company's central load dispatching office | TEPCO PG Central Load Dispatching Office |
| | 12:30 | ~ | 14:00 | Inspection of load dispatching operator training | TEPCO PG Training Center |
| | 15:00 | ~ | 16:00 | Inspection of Tokyo Electric's mega solar | TEPCO Renewable Power Company Ukishima Solar Power Plant |
| 30-Nov-17 | 11:00 | ~ | 12:00 | Confirmation of state-of-the-art coal fired power, IGCC construction status | TEPCO FP Hirono Thermal Power Plant |
| | 14:00 | ~ | 15:00 | Inspection of 500 kV switchgear | TEPCO PG Shin-Iwaki S/S |
| 1-Dec-17 | 9:00 | ~ | | Inspection of small and medium type CCGT plant | Mitsubishi Hitachi Power Systems Hitachi Works |
| | | ~ | 12:00 | Inspection of Hitachi Mitsubishi Hydropower related technology | Hitachi MitsubishiHydro Corporation Hitachi Works |
| 2-Dec-17 | | | | Experience of Japanese culture | |
| 3-Dec-17 | | | | ditto | |
| 4-Dec-17 | 10:00 | ~ | 11:30 | Inspection of More Advanced CCGT | TEPCO FP Kawasaki Thermal Power Plant |
| | 13:00 | ~ | 15:00 | Inspection of Toshiba's latest power related technology | Toshiba Energy Systems & Solutions Corporation Keihin Product Operations |
| 5-Dec-17 | 13:30 | ~ | 16:30 | Inspection of the state-of-the-art Large Gas Combined Cycle Manufacturing Factory | Mitsubishi Hitachi Power Systems Takasago Works |
| 6-Dec-17 | | | | Experience of Japanese culture | |
| 7-Dec-17 | 10:30 | ~ | 12:30 | Inspection of pumped storage power plant with high head | TEPCO RPC Kannagawa Pumped Storage Power Plant |
| | 15:30 | ~ | 16:30 | Inspection of frequency converter substation | TEPCO PG Shin-Shinano Frequency Converter Station |
| 8-Dec-17 | 15:00 | ~ | 16:30 | Ministry of Economy, Trade and Industry | METI; Agency for Natural Resources and Energy |
| | 17:00 | ~ | 18:30 | Wrap-up | JICA Ichigaya office |
| 9-Dec-17 | 22:00 | ~ | | Departure to Angola | |

Date: 2017 Nov. 28 / Kick-off meeting (in JICA Ichigaya office)



Date: 2017 Nov. 29 / TEPCO PG Central Load Dispatching



Date: 2017 Nov. 29 / TEPCO PG Training Center



Date: 2017 Nov. 29 / TEPCO/Renewable Power Company Ukishima Solar Power Plant



Date: 2017 Nov. 30 / TEPCO FP Hirono Thermal Power Plant



Date: 2017 Nov. 30 / TEPCO PG Shin-Iwaki S/S





**Date: 2017 Dec. 1 / Mitsubishi Hitachi Power Systems, Hitachi Mitsubishi Hydro Corporation
Hitachi Works**



Date: 2017 Dec. 4 / TEPCO FP Kawasaki Thermal Power Plant



Date: 2017 Dec. 4 / Toshiba Energy Systems & Solutions Corporation Keihin Product Operations



Date: 2017 Dec. 5 / Mitsubishi Hitachi Power Systems Takasago Works



Date: 2017 Dec. 7 / TEPCO RPC Kannagawa Pumped Storage Power Plant





Date: 2017 Dec. 7 / TEPCO PG Shin-Shinano Frequency Converter Station



Date: 2017 Dec. 8 / Ministry of Economy, Trade and Industry; Agency for Natural Resources and Energy



Date: 2017 Dec. 8 / Wrap-up meeting (in JICA Ichigaya office)



13.3 Additional Training in Japan

There was a plan to invite relevant parties of Angolan power industry to Japan for training so that they would have deeper understanding of Japan's power system operations for stable power supply (including operations at a Central Load Dispatching Center), impacts of renewable energy power supplies on electric power systems, and Japanese companies' advanced technologies for high-efficiency thermal power generation, etc. As Angola's power development master plan was formulated and it was expected that additional training of higher-level officials in Japan would deepen the counterparts' understanding and the knowledge would be reflected in Angolan policies, we invited the Minister of Energy and Aqua (MINEA) and other top officials of electric power companies and other controlling government offices for training in Japan. During the training, we also held a seminar about the Angolan Power Sector to present Angola's power development master plan to Japanese companies and attract interest in investment in Angola from Japanese companies through the presence of Angolan officials.

13.3.1 Participants

There were 8 participants – 4 members from MINEA including the MINEA Minister Borges, directors and chairpersons of the power companies and organizations of ENDE, PRODEL, RNT and IRSEA.

Table 13-1 Angolan Participants

| | Name | Entity | Ministry or Company | Position |
|---------|---------------------------------|--------|---|---|
| M r. | João Baptista <u>Borges</u> | MINEA | Ministry of Energy and Water Affairs | Minister |
| M r. | Carlos Gil Ferreira De Sousa | MINEA | Minister's Office of Energy and Water Affairs | Director |
| M r. | Osvaldo Marcos Julião Gonçalves | MINEA | Ministry of Energy and Water Affairs, National Directorate of Electric Energy | Director |
| M r. | Ruth Cardoso De Almeida Safeca | ENDE | National Electricity Distribution Company | Chairman of Board of Directors |
| M r. | José Antônio Neto | PRODEL | Public Electricity Production Company | Chairman of Board of Directors |
| M r. | Rui Pereira Do Amaral Gourgel | RNT | National Electricity Transportation Company | Chairman of Board of Directors |
| M r. | Luís Mourão Da Silva | IRESA | Regulatory Institute of Electricity and Water Services | Chairman of Board of Directors |
| M r. | Benevides Cabral Marcelino | MINEA | Minister's Office of Energy and Water Affairs | Head of Public Relations and Protocol Section |

13.3.2 Activity Results

The participants learned Japan's state-of-the-art technologies mainly through the attendance at the Angolan Power Sector Seminar, which was the major purpose of the training, and the activity contributed to the future technical cooperation for Angola.

The sites for visits were selected mainly from the following viewpoints.

- Understanding of the power system operations of the Japanese power companies and understanding of the operator training policies
- Understanding of Japan's technologies for state-of-the-art coal-fired power generation and gas-combined cycle power generation
- Understanding of Japan's latest technologies used for gas insulated transformers/switchgears installed at unmanned underground substations

The training program and contents are as shown in Table 13-5.

Table 13-2 Additional Training Activities in Japan

| Date | Time | Program Contents | Destination |
|---------------------|---------------|---|---|
| 2018/12/8 (Sat.) | ~ 22:45 | Arrive in Japan | Haneda Airport |
| 2018/12/9 (Sun) | All day | Briefings by the Embassy of Angola in Japan | Embassy of Angola in Japan |
| 2018/12/10 (Mon) | 10:00 ~ 11:30 | Explanation of the itinerary, explanation of MP and potential Japanese collaborators | JICA Headquarters |
| | 11:30 ~ 12:30 | Courtesy visit to JICA executives | JICA Headquarters |
| | 14:00 ~ 14:15 | Courtesy visit to President of TEPCO Power Grid | Headquarters of Tokyo Electric Power Company Holdings |
| | 14:15 ~ 14:30 | Overview of major electric power companies in Japan | Central Load Dispatching Center of TEPCO Power Grid |
| | 14:30 ~ 15:15 | Explanation of roles of load dispatching centers of Japanese electric power companies | Central Load Dispatching Center of TEPCO Power Grid |
| | 15:30 ~ 17:00 | Visit to a state-of-the-art underground substation in Japan | Higashi Uchisaiwai-cho Substation of TEPCO Power Grid |
| 2018/12/11 (Tue) | 10:00 ~ 12:00 | Seminar for Japanese companies & FR Transfer Ceremony | JICA Ichigaya Building |
| | 14:00 ~ 16:00 | Visit to a combined cycle gas turbine (CCGT) power station | Kawasaki Thermal Power Plant of TEPCO Fuel & Power |
| 2018/12/12 (Wed) | 9:45 ~ | Leave Japan (Minister and others for London) | Haneda Airport |
| | 22:00 ~ | Leave Japan (Director and others for Angola) | Narita Airport |

Report on the training results and materials used have already been submitted to JICA.

Date: 2018 Dec. 10 / Kick-off meeting (in JICA Head Quarter)



Date: 2018 Dec. 10 / TEPCO PG Central Load Dispatching Center



Date: 2018 Dec. 10 /TEPCO PG Higashi-uchisaiwai-cho Underground Substation



Date: 2018 Dec. 11 /Angolan Power sector Seminar in JICA Ichigaya Office





Date: 2018 Dec. 11 /TEPCO FP Kawasaki Thermal Power Plant

