
ETHIOPIAN ELECTRIC POWER



ETHIOPIA



Country in the horn of Africa

- Total area 1.13 million square km
- 90 million inhabitants
 - Population growth rate – 2.3% per year
 - Average annual GDP growth rate ~ 10.7 % for the last 10 yrs



Indigenous Energy Resources


Resource	Unit	Exploitable Reserve	Exploited Percent
Hydropower	MW	45,000	<5%
Solar/day	kWh/m ²	Avg. 5.5	<1%
Wind: Power Speed	GW m/s	1,350 > 6.5	<1%
Geothermal	MW	7000	<1%
Wood	Million tons	1120	50%
Agricultural waste	Million tons	15-20	30%
Natural gas	Billion m ³	113	0%
Coal	Million tons	300	0%
Oil shale	Million tons	253	0%



Power Generation & Environment Low Level of Emission











Exixting System Generation

- Hydro Power 1978 MW
- Diesel Power 112 MW
- Gothermal Power 7 MW
- Wind Power 171 MW
- Total 2268 MW

Transmission Capacity

- 400 kV 686.7
- 230 kV
- 132 kV
- 66 kV
- 45 kV
- Total 12652.65 km







Existing & Future Domestic Consumption by Regional Administration

New EEF Zone 🗾	Sum of 2012	Sum of 2015	Sum of 2017	Sum of 2020	Sum of 2025	Sum of 2030	Sum of 2037
EASTERN A.A.	172	341	550	797	1038	1399	2066
NORTHERN A.A.	178	212	279	327	475	730	1207
SOUTHERN A.A.	320	513	744	846	973	1323	1956
WESTERN A.A.	81	146	189	252	365	545	880
SOUTH EASTERN	96	165	221	260	444	757	1350
SOUTHERN	95	246	374	615	1055	1654	2647
EASTERN	47	271	427	735	1245	1846	2815
JIJIGA	11	30	60	64	82	113	164
SEMERA	14	62	132	310	677	1063	1638
NORTH EASTERN	39	205	401	645	764	959	1281
NORTHERN	87	129	265	461	700	849	1128
NORTH WESTERN	66	122	178	391	907	1262	1889
WESTERN	51	58	80	159	381	504	728
ASOSA	8	14	25	33	60	88	140
GAMBELA	7	8	10	25	66	115	188
Grand Total	1272	2524	3935	5918	9232	13210	20077



- **×** Power plants completed in 2013
 - + Ashegoda wind power 120 MW
- + Power plants under construction
 - + Grand Ethiopian Renaissance Dam 6,000MW
 - + Gibe III 1,870 MW
 - + Genale Dawa III 254 MW
 - + Adama II 153 MW
 - + Solar power 300MW (US based company)
 - + Aluto Langano geothermal expansion 70 MW

+ GoE, GoJ, WB, SREP

+ Repi Waste-to-Energy power – 50 MW



Demand Forecast



A number of new type of consumers recently commenced or are under development identified:

- 1. Transport Sector developments
- 2. Agricultural Sector developments
- 3. Industrial Sector Developments
- 4. Large scale Dwelling house expansion Programs
- 5. Universal Electricity Access expansion Program
- 6. Electricity export consumers



Ethiopia Electricity Demand Forecast

1. Transport Sector Demand Forecast- Sources

	Freight Rail Traffic (Kton)		Passenger Rail Numbers			
	Export	Import	Total	Domestic	Internationa	Total
2015	799	6 421	7 220	214 128	32 119	246 247
2020	1 538	11 316	12 855	344 745	57 712	396 457
2025	2 711	18 225	20 936	555 040	83 256	638 296
2030	4 778	29 352	34 130	893 615	134 042	1 027 657
2035	7 695	47 271	54 966	1 438 721	215 808	1 654 529

- –Passenger (per day) andfreight numbers (per year)forAddis Dewele route
- Passenger and freight numbers other planned routes

	Rail freight	Passenger
	(kton)	numbers
2017	1 500	42 826
2022	3 150	103 424
2027	6 615	222 016
2032	13 892	446 808
2037	29 172	863 233

Ethiopia Electricity Demand Forecast Railway Demand Forecast- Assumptions

- Average number of trains per day are calculated
- Average 8 hours operation per day per freight train
- Average of 3 hours operation per day per passenger train (shorter distances and more stops than freight trains)
- Number locomotives per freight (2 x 4.5MW) passenger (1 x 4.5MW) train energy requirements calculated for the railway development
- Freight and rail passengers adjusted upwards (37%) and downwards (32%) for high and low cases
- Light rail system developed from 2015 to 2030, from 5 to 42 trains in operation, 16 hours per day, two locomotives 3MW





Ethiopia Electricity Demand Forecast


Transport Sector Demand Forecast Reference Scenario-

Results

year	Sales (GWh)	Gen. (GWh)	Peak (MW)
2015	404	513	97
2020	1477	1711	319
2025	2583	2976	553
2030	4123	4739	879
2035	6398	7354	1365
2037	7331	8427	1564



Total Transport Sales Ethiopia Electricity Demand Forecast



Ethiopia Electricity Demand Forecast

• Main source of data were regional Offices - Agriculture and Rural Development Bureau

	Hectar Value		
Region	GTP1	After GTP1	
SNNP	120,500	60,000	
BENShangul	64,000	64,000	
Gambela	1,510	107,304	
Oromia	7,240	821,750	
Somalia	60,000	918,250	
Afar	40000	540,000	
Tigray	16,000	18,000	
Amhara	74,000	91,000	
	383,250.0	2,620,304	



Ethiopia Electricity Demand Forecast

2. Agricultural Sector

Power consumption rates derived from 0.34 – 5.4 kW/ha across locations in different regions

- Demand requirements distributed first 5 years (85% probability) thereafter up to the study period end (70% probability)
- Energy requirements calculated assuming average 5 hours operation per day 9 months of year
- For High and Low cases irrigable assumed higher (100% and 85%) and lower (70% and 50% probabilities)




Total Agriculture Sales Ethiopia Electricity Demand Forecast-Results

year	Sales (GWh)	Gen. (GWh)	Peak (MW)
2015	490	623	197
2020	2967	3438	1123
2025	6231	7178	2342
2030	9494	10913	3556
2035	12684	14580	4756
2037	13917	15996	5219



Total Agricultural Sales Ethiopia Electricity Demand Forecast





Ethiopia Electricity Demand Forecast 3. New Industrial Development in Ethiopia- Sources

•Programme driven by government establish industrial zones-

- Industrial parks during Growth and Transformation Plan period planned at 1,125MW
- After the GTP period Industrial park development planned at 1,200MW

GIP-1			
		Expected Demand	
No.	Industry Zone	(MW)	
1	Kilento	73	
2	Bole	103	
3	Melka Jebedu	315	
4	Kombolcha	334	
5	Awassa	300	
Total		1125	

CTD 1

GTP-2

No.	Industry Zone	Expected Demand (MW)
1	Bahar Dar	300
2	Gondar	300
3	Mekele	300
4	Jimma	300
	Total	1200



Ethiopia Electricity Demand Forecast 3. New Industrial Development in Ethiopia- Sources

•Applications for new industrial developments received- EEP:

Cement Factories	700 MW
Steel & Metals	800 MW
 General industry 	600 MW
 Mining 	100MW
Total	2100MW



Industrial Consumers New Industrial Demand Forecast- Assumptions

Expected new industrial demand:

- Scheduled to develop across 10 year period from 2012 to 2022
- Load factor of 75% assumed to determine energy
- Uncertainty associated probabilities of 85% (for GTP-1 projects) and 70% (for GTP2 projects) assumed for base case
- Average annual electricity sales growth of 30% from 2012 to 2022
- Uncertainty associated probabilities of 70% and 50% assumed for low case
- Uncertainty associated probabilities of 100% and 85% assumed for High case



Industrial Consumers New Industrial Demand - Results

year	Sales (GWh)	Gen. (GWh)	Peak (MW)
2015	4303	5474	753
2020	16461	19074	2614
2022	20324	23496	3219



Industrial Consumers Industrial Demand Forecast- Assumptions

 Growth beyond 2022 econometric model used derived from historical industrial sales and sectoral GDP data correlation

ltem	High Voltage	Low Voltage
Equation	Sales Growth=(1+Industrial GDP Growth) ^b	Sales Growth=(1+Industrial GDP Growth) ^b
Elasticity (b)	0.928	0.881

Industrial GDP Growth Rate Assumptions

Sector	2012-2015	2016-2020	2021-2025	2026-2030
Industrial	20%	ے 15.60%	۶ 13.90%	10.70%






Total Industrial Sales Total Industrial Demand Forecast- Results

year	Sales (GWh)	Gen. (GWh)	Peak (MW)
2013	2491	3244	447
2015	5758	7326	1007
2020	17916	20761	2845
2025	25319	29169	3994
2030	31695	36431	4986
2037	44505	51155	7002



Total Industrial Sales Industrial Demand Forecast- Results





Commercial Consumers Commercial Demand Forecast- Assumptions

- Econometric analysis conducted on commercial demand and indicative independent Variables
- Number of connections in Commercial sector found to have correlation with GDP/capita
- -Specific consumption correlates with number of households growth

ltem	Commercial Number of Customers	Commercial Specific Consumption
Equation	Number of Customers=(1+ GDP/capita Growth) ^b	Specific Consumption=(1+Number of HH Growth) ^b
Elacticity (b)	1.403	0.448

Number of HH and GDP/Capita Growth Assumptions

Sector	2012-2015	2016-2020	2021-2025	2026-2030	2031-2035
GDP/Capita	8.50%	6.80%	6.20%	5.50%	4.70%
Number of HH	2.6%	2.60%	2.60%	2.60%	2.60%




Servise Sector Sales Service Sector Demand Forecast-Result

year	Sales (GWh)	Gen. (GWh)	Peak (MW)
2013	1350	1758	304
2015	1736	2209	381
2020	2937	3403	582
2025	4833	5568	950
2030	7642	8784	1498
2037	13391	15392	2624



Service Sector Sales Ethiopia Electricity Demand Forecast






Domestic Consumers Ethiopia Electricity Demand Forecast

- -Domestic forecast done in two categories
- Forecast based on Number of Connections and specific consumption
- –Number of consumers forecasted to achieve 95% electrification ratio by 2037

Connection Rate	%	Year
Current Total Household Connection Rate	23%	2012
Target Household Connection Rate 1	45%	2018
Target Household Connection Rate 2	65%	2024
Target Household Connection Rate 3	80%	2030
Target Household Connection Rate	95%	2037



Domestic Consumers Domestic Demand Forecast (New Customers) - assumptions




 Considers increased electric usage (more utensils) within a household. Considers Expansion of the Grid to rural areas (UEAP) and also the housing projects within the big towns.



Domestic Consumers Domestic Demand Forecast (New Customers) - assumptions


Avoiding Initial connection
 Barriers could increase the customer number significantly





Domestic Consumers Domestic Demand Forecast (Existing Customers) - assumptions

• EEU has an Existing Domestic customers base of 2.1 Million






Domestic Consumers

Domestic Demand Forecast - Results

	Sales (GWh)			Gen.	Peak
Year	Existing	UEAP	Total	(GWh)	(MW)
2013	2192	206	2398	3122	753
2015	2512	605	3118	3966	975
2020	2982	1845	4827	5593	1410
2025	3114	4039	7153	8241	2150
2030	3144	8029	11173	12842	3453
2035	3150	12772	15922	18302	5006
2037	3151	14485	17636	20271	5566



Domestic Sales Domestic Demand Forecast composition






Total Electricity Sales Ethiopia Electricity Demand Forecast


- -Total energy sales forecasted grow 4,925GWh in 2012 to 97,326GWh by 2037 in Base case
- –Presents an average annual compound growth rate of 12.7%
- Biggest growth occurs in industrial, in 2012 it 34% of totals sales and grows to 46% by 2037
- -Total energy sales forecasted grow 5,204GWh in 2012 to 142,884GWh by 2037 in High case
- –Presents an average annual compound growth rate of 14.2%
- -Total energy sales forecasted grow 4,633GWh in 2012 to 54,019GWh by 2037 in Low case
- –Presents an average annual compound growth rate of 10.1%




Total Base Case Electricity Sales Ethiopia Electricity Demand Forecast



Total Base Case Electricity Sales **Ethiopia Electricity Demand Forecast**






2037 Internal Demand Composition



Total Electricity Sales Ethiopia Electricity Demand Forecast





Total Energy Generation sent out Ethiopia Electricity Demand Forecast

- -Energy losses forecasted to reduce to 14%
- -Total energy sent out forecasted grow 6,443GWh in 2012 to 111,388GWh by 2037 in Base case
- –Presents an average annual compound growth rate of 12%
- –Energy sent-out is forecast grow from 6,443GWh in 2012 to 179,064GWh by 2037 in High case
- –Presents an average annual compound growth rate of 14%
- Energy sent-out is forecast grow from 6,443GWh in 2012 to69,867GWh by 2037 in Low case
- –Presents an average annual compound growth rate of 10%




Total Peak Demand Ethiopia Electricity Demand Forecast

- Peak demand forecast grow 1,237MW in 2012 to 21,731MW by 2037 in base case
- Represents average annual compound growth rate of 12.3%.
- Peak demand forecast grow 1,237MW in 2012 to 32,486MW by 2037 in high case
- Represents average annual compound growth rate of 13.5%.
- Peak demand forecast grow 1,237MW in 2012 to 14,356MW by 2037
- Represents average annual compound growth rate of 10.3%



Total Peak Demand Ethiopia Electricity Demand Forecast





Ethiopia Electricity Demand Forecast

4. Electricity export consumers

Assumptions/strategy estimating exports for study:

- Current export agreements Sudan (100MW)
 Djibouti (100MW) retained throughout study period;
- Exports Egypt via Sudan, exports Sudan and Egypt grouped;
- 1200 MW (Sudan) and 2000 MW (Egypt) scheme, 3,200MW assumed exports, Eastern Nile trade program study;
- Exports Kenya and Tanzania extracted draft Kenyan Updated Least Cost Development Plan February 2013.



Total Export Demand Ethiopia Electricity Demand Forecast

	N	on-Coin	cident Ma	x Dema	nd (MW)				Energy	(GWh)			Coincident Max Demand (MW)					
			Sudan or						Sudan or						Sudan			
	Djibouti	Sudan	Egypt	Kenya	Tanzania	Total	Djibouti	Sudan	Egypt	Kenya	Tanzania	Total	Djibouti	Sudan	or Egypt	Kenya	Tanzania	Total
2012	100	100	0	0	0	200	569	876	0	0	0	1445	65	100	0	0	0	165
2013	100	100	0	0	0	200	569	876	0	0	0	1445	65	100	0	0	0	165
2014	100	100	0	0	0	200	569	876	0	0	0	1445	65	100	0	0	0	165
2015	100	100	200	0	0	400	569	876	1314	0	0	2759	65	100	150	0	0	315
2016	100	100	200	0	0	400	569	876	1314	0	0	2759	65	100	150	0	0	315
2017	100	100	600	400	0	1200	569	876	3942	2978	0	8366	65	100	450	340	0	955
2018	100	100	600	400	0	1200	569	876	3942	2978	0	8366	65	100	450	340	0	955
2019	100	100	800	400	0	1400	569	876	5256	2978	0	9680	65	100	600	340	0	1105
2020	100	100	800	400	200	1600	569	876	5256	2978	1314	10994	65	100	600	340	150	1255
2021	100	100	1200	600	200	2200	569	876	7884	4292	1314	14936	65	100	900	490	150	1705
2022	100	100	1200	600	200	2200	569	876	7884	4292	1314	14936	65	100	900	490	150	1705
2023	100	100	1600	600	400	2800	569	876	10512	4292	2628	18878	65	100	1200	490	300	2155
2024	100	100	1600	800	400	3000	569	876	10512	5606	2628	20192	65	100	1200	640	300	2305
2025	100	100	2000	1000	400	3600	569	876	13140	6920	2628	24134	65	100	1500	790	300	2755
2026	100	100	2000	1000	400	3600	569	876	13140	6920	2628	24134	65	100	1500	790	300	2755
2027	100	100	2200	1200	400	4000	569	876	14454	8234	2628	26762	65	100	1650	940	300	3055
2028	100	100	2200	1400	400	4200	569	876	14454	9548	2628	28076	65	100	1650	1090	300	3205
2029	100	100	2200	1600	400	4400	569	876	14454	10862	2628	29390	65	100	1650	1240	300	3355
2030	100	100	2600	1600	400	4800	569	876	17082	10862	2628	32018	65	100	1950	1240	300	3655
2031	100	100	2600	1600	400	4800	569	876	17082	10862	2628	32018	65	100	1950	1240	300	3655
2032	100	100	2900	1600	400	5100	569	876	19053	10862	2628	33989	65	100	2175	1240	300	3880
2033	100	100	3000	1600	400	5200	569	876	19710	10862	2628	34646	65	100	2250	1240	300	3955
2034	100	100	3000	1600	400	5200	569	876	19710	10862	2628	34646	65	100	2250	1240	300	3955
2035	100	100	3100	1600	400	5300	569	876	20367	10862	2628	35303	65	100	2325	1240	300	4030
2036	100	100	3100	1600	400	5300	569	876	20367	10862	2628	35303	65	100	2325	1240	300	4030
2037	100	100	3100	1600	400	5300	569	876	20367	10862	2628	35303	65	100	2325	1240	300	4030




Total Export Demand- adjusted

Ethiopia Electricity Demand Forecast-Increased export Scenario

	Non-Coincident Max Demand (MW) Energy (GWh)								Vh)		Coincident Max Demand (MW)										
	Djibout i	Sudan	Sudan or Egypt	Keny a	Tanzani a	Other exports	Total	Djibouti	Sudan	Sudan or Egypt	Kenya	Tanzan ia	Other exports	Total	Djibouti	Sudan	Sudan or Egypt	Kenya	Tanzani a	Other exports	Total
2012	100	100	0	0	0		200	569	876	0	0	0		1445	65	100	0	0	0		165
2013	100	100	0	0	0		200	569	876	0	0	0		1445	65	100	0	0	0		165
2014	100	100	0	0	0		200	569	876	0	0	0		1445	65	100	0	0	0		165
2015	100	100	200	0	0		400	569	876	1314	0	0		2759	65	100	150	0	0		315
2016	100	100	200	0	0		400	569	876	1314	0	0		2759	65	100	150	0	0		315
2017	100	100	600	400	0		1200	569	876	3942	2978	0		8366	65	100	450	340	0		955
2018	100	100	600	400	0		1200	569	876	3942	2978	0		8366	65	100	450	340	0		955
2019	100	100	800	400	0		1400	569	876	5256	2978	0		9680	65	100	600	340	0		1105
2020	100	100	800	400	200	165	1765	569	876	5256	2978	1314	1081	12075	65	100	600	340	150	123	1378
2021	100	100	1200	600	200	165	2365	569	876	7884	4292	1314	1081	16017	65	100	900	490	150	123	1828
2022	100	100	1200	600	200	982	3182	569	876	7884	4292	1314	6451	21387	65	100	900	490	150	736	2441
2023	100	100	1600	600	400	982	3782	569	876	10512	4292	2628	6451	25329	65	100	1200	490	300	736	2891
2024	100	100	1600	800	400	982	3982	569	876	10512	5606	2628	6451	26643	65	100	1200	640	300	736	3041
2025	100	100	2000	1000	400	982	4582	569	876	13140	6920	2628	6451	30585	65	100	1500	790	300	736	3491
2026	100	100	2000	1000	400	982	4582	569	876	13140	6920	2628	6451	30585	65	100	1500	790	300	736	3491
2027	100	100	2200	1200	400	982	4982	569	876	14454	8234	2628	6451	33213	65	100	1650	940	300	736	3791
2028	100	100	2200	1400	400	982	5182	569	876	14454	9548	2628	6451	34527	65	100	1650	1090	300	736	3941
2029	100	100	2200	1600	400	982	5382	569	876	14454	10862	2628	6451	35841	65	100	1650	1240	300	736	4091
2030	100	100	2600	1600	400	982	5782	569	876	17082	10862	2628	6451	38469	65	100	1950	1240	300	736	4391
2031	100	100	2600	1600	400	982	5782	569	876	17082	10862	2628	6451	38469	65	100	1950	1240	300	736	4391
2032	100	100	2900	1600	400	982	6082	569	876	19053	10862	2628	6451	40440	65	100	2175	1240	300	736	4616
2033	100	100	3000	1600	400	982	6182	569	876	19710	10862	2628		41097	65	100	2250	1240	300	736	4691
2034	100	100	3000	1600	400	982	6182	569	876	19710	10862	2628		41097	65	100	2250	1240	300	736	4691
2035	100	100	3100	1600	400	982	6282	569	876	20367	10862	2628		41754	65	100	2325	1240	300	736	4766
2036		100	3100	1600	400	982	6282	569	876	20367	10862	2628		41754	65	100	2325	1240	300	736	4766
2037	100	100	3100	1600	400	982	6282	569	876	20367	10862	2628	6451	41754	65	100	2325	1240	300	736	4766




Ethiopia ICS and Exports – Maximum Demand – Base Case Load Forecast





Ethiopia ICS and Exports - Energy – Base Case








Methodology Stage 1


Generation Planning






Methodology Stage 2

Generation Planning



Model dimensions Generation Planning -Hydro System Modelling






Model dimensions Generation Planning -Hydro System Modelling

•For the Master Plan Study, AQUARIUS models have been constructed of :

- The potential system, made up of
 - 41 Reservoirs
 - 45 Hydro plants
 - 26 Flow Points
 - 117 River Reaches
 - 12 Water Demand areas
 - 6 Electricity Demand areas i.e. domestic and export markets
 - 42 Inflow series
- The seven major Ethiopian river basins
- Individual projects viz. Grand Renaissance





Objective : To estimate existing and candidate hydro plant capabilities for input to the expansion planning process, taking adequate account of:

- Project interdependencies
- Cumulative regulation effects from reservoirs in cascade
- Benefits from coordinated operation
- Reductions in generation capacity during critical droughts
- Evaporation losses
- Water demands and compensation releases



Results obtained :

- Extension of (monthly) inflow series from 1961 to 2005
- Determination of system 'Firm' energies for Potential and River Basin systems
- Identification of multi-year 'critical' period from 1984 to 1987
- Hydro plant capacity and energy capabilities for up to five hydrological conditions, input to WASP



Wien Automatic System Planning (WASP) program:

- Developed from Tennessee Valley Authority model for thermal systems dynamic programming and probabilistic dispatch
- Adopted by International Atomic Energy Agency (IAEA) to *Generation Planning to promote nuclear power*
- Further developed by Hydro Quebec for application to hydrothermal systems (cumulate methodology - WASP III and IV)
- Favored by World Bank, ADB and other international lending agencies
- Widely used by power utilities in over 60 countries



For each year (up to 30) WASP calculates cost of each plant configuration meeting one or more of following annual planning constraints:

- Reserve Margin (upper and lower limits)
- Loss of Load Probability (LOLP)
- Cost of Unserved Energy (COUE)
- No of new units permitted ('tunnel width')





Costs include:

- Capital
- Salvage
- Fuel
- Operations and Maintenance (O&M)
- Energy not Served



In optimized planning, up to 5000 different sequences of annual generation planting can be examined

- For each sequence (plan) WASP calculates the OBJECTIVE FUNCTION
- The OBJECTIVE FUNCTION is the Present Value (PV) of all the discounted year-by year costs
- The plan with the minimum PV should be the optimum plan
- Sensitivity Analysis needed to confirm



Committed Plants

Generation Planning

Existing and committed plant MW	Inst	Site	Dry Year	Comm	2012	2013	2014	2015	2016	2017	2018	2019
Hydro - Under Construction - MW							427	1730	1730	6274	6274	6274
Gilgel Gibe III (enters 2014)	748	74	3 427	2014			427	427	427	42	427	427
Gilgel Gibe III (enters 2015)	1122	112	2 640	2015				640	640	640	640	640
Genale Dawa III	254	254	4 250	2015				250	250	250	250	250
Grand Renaissance (enters 2015)	500	50	413	2015				413	413	413	3 413	413
Grand Renaissance (enters 2017)	5500	550	4544	2017						4544	4544	4544
Existing and committed plant MW	I	nst	Comm	2012	2013	2014	201	5 20	16 2	017	2018	2019
Wind - Existing				81	81	171	1 17	71 [·]	171	171	171	171
Adama		51	2012	51	51	51	1	51	51	51	51	51
Ashegoda (enters 2012)		30	2012	30	30	30) (30	30	30	30	30
Ashegoda (enters 2014)		90	2014			90) (90	90	90	90	90
Wind - Committed							1	53 ⁻	153	153	153	153
Adama II		153	2015				1;	53	153	153	153	153



Committed Plants

Generation Planning

Existing and committed plant MW	Inst	Comm	2012	2013	2014	2015	2016	2017	2018	2019
Geothermal - Existing			5	5	5	5	5	5	5	5
Aluto Langano	7	2007	5	5	5	5	5	5	5	5
Geothermal - Committed									75	75
Aluto Langano II	75	2018							75	75

Energy From Waste - Committed				25	25	25	25	25
Addis Ababa EFW	25	2015		25	25	25	25	




Committed Plants

Generation Planning


Existing and committed plant MW	Inst	Comm	2012	2013	2014	2015	2016	2017	2018	2019
Sugar Factories - Exist., U/C & Co	Inst			26	26	254	354	434	434	474
Tendaue / Ende	120	2015				70	70	70	70	70
Wenji	30	2013		16	16	16	16	16	16	16
Finchaa	31	2013		10	10	10	10	10	10	10
Beles 1	30	2015				20	20	20	20	20
Beles 2	30	2015				20	20	20	20	20
Beles 3	30	2016					20	20	20	20
Wolkayit	133	2015				82	82	82	82	82
Omo Kuraz 1	60	2015				20	20	20	20	20
Omo Kuraz 2	60	2016					40	40	40	40
Omo Kuraz 3	60	2016					40	40	40	40
Omo Kuraz 4	60	2017						40	40	40
Omo Kuraz 5	60	2017						40	40	40
Omo Kuraz 6	60	2019								40
Kessem	26	2015				16	16	16	16	16
Biomass - Committed						120	120	120	120	120
Bio - committed - "120MW"		2015				60	60	60	60	60
Bio - committed - "137.5MW"		2015				60	60	60	60	60



Existing and Committed Plants- Power Balance Generation Planning



Existing and Committed Plants- Energy Balance (Average Hydrologic Year) Generation Planning




Total available generation from exist and committed plant Energy demand including exports

Surplus (deficit -ve)


Exports



Existing and Committed Plants- Energy Balance (Dry Hydrologic Year) Generation Planning



Total available generation from exist and committed plant Energy demand including exports



Exports



Candidate Hydro Plants Generation Planning- Pricing and other Information Source

Scheme	Pricing Year	Pricing Source
Beko-Abo	2010	Pre-feasibility Nov 2012 - Vol 3 Annex 3J Table 2-2 and Alternatives to Mandaya Cascade Options
		Memo July 2011 Table 3.1
Karadobi	2005	Pre-feasibility September 2006 Table 11-12 and Alternatives to Mandaya Cascade Options Memo
		July 2011 Table 3.1
Lower Didessa	2001	Reconnaissance study August 2001 Volume 2 Appendix 5
Lower Dabus	2002	Reconnaissance study June 2002 - Table 5.6
Lower Dabus Weir 1	2002	Reconnaissance study June 2002 - Table 5.7
Genale GD-6	2009	Feasibility study May 2009 - Annex 3G
Gibe V	2008	Reconnaissance study June 2008 - Gibe V Economic analysis CH 2.1
Gibe IV	2008	Reconnaissance study June 2008 - Gibe IV Economic analysis CH 2.1
Mandaya	2007	Inception report, 5 th November 2010, Table 3.11 and Alternatives to Mandaya Cascade Options
		Memo July 2011 Table 3.1
Chemoga-Yeda Stg 1	2006	Feasibility study May 2006 - Table 13.2
Chemoga-Yeda Stg 2	2006	Feasibility study May 2006 - Table 11.2
Gojeb	1996	Design report May 1998 - Volume 3, Table 31A
Halele-Werabesa Stg II	2005	Feasibility study July 2005 Table 13.2
Geba 1	2005	Feasibility study February 2005 Volume 2 Table 15-11
Geba 2	2005	Feasibility study February 2005 Volume 2 Table 15-12
Aleltu West	1992	Aleltu Pre-feasibility Study Jan 1994 - Table 8.1
Aleltu East Stage 1	1993	Aleltu East Stage 1 feasibility study Feb 1995 - Table 10.1
Aba Samuel	2012	Preliminary design report August 2012
Halele-Werabesa Stg I	2000	Feasibility report Aug 2000. Table 15.1
Birbir R	2001	Reconnaissance study August 2001. Appendix 5
Wabi Shebele WS18	2004	Wabi Shebele Basin Development Masterplan Study. May 2004. Table 14
Sor Phase II	~1990	II Phase Sor hydroelectric feasibility study Table 7.5.I
Genale Dawa 5 (GD-5)	2004	Genale Dawa river basin integrated master plan study July 2007. Section 6.15.2.7
Tams	1996	Baro-Akobo river basin integrated development master plan study annex 1 pt 4 table 1J-9.2. May 1997



Candidate Hydro Plants – Price Adjustment Generation Planning

Information from EEPCO and MWE for 28 schemes

- Inception, Reconnaissance, Pre-Feasibility Feasibility studies
- Varying Dates
- Costs broken down into Civil, Electromechanical and
- Environmental
- Further broken down and the updated to 2012 prices using inflation indices
- Then add to get an EPC (engineer, procure, construct) price:
- 8% Engineering and construction
- 3% Owner's costs
- 20% Contractor's overheads and margins
- 0.90 Standard Conversion Factor (SCF) for local costs




Candidate Hydro Plants – Price Adjustment Generation Planning

Category		Index	Factor
		Expat Labour	24%
		Steel	19%
	Foreign Portion	Equipment	15%
		Marine Transport	8%
		Misc. Imp. Material	14%
Civil works		Non-Adjusted Portion	20%
		Local Labour	23%
		Cement	25%
	Local Portion	Diesel	23%
		Local Transport	9%
		Non-Adjusted Portion	20%
		Expat Labour	28%
	Familia Dartian	Steel	42%
	Foreign Portion	Marine Transport	10%
Electromechanical works		Non-Adjusted Portion	20%
		Local Labour	50%
	Local Portion	Local Transport	30%
		Non-Adjusted Portion	20%
Environmental works	Foreign Portion	Expat Labour	100%
	Local Portion	Local Labour	100%



Candidate Hydro Plants – Price Adjustment Generation Planning





Candidate Hydro Plants – Costs Generation Planning

	Installed Capacity	Average Energy	Average Plant Factor	Construction Cost	IDC Cost	Total Cost	Average Levelised Cost	First available year
	(MW)	(GWh/year)		(million \$)	(million \$)	(million \$)	(\$/kWh)	year
Beko Abo	935	6632	0.81	1260.8	441.3	1702.1	0.026	2022
Genji	214	910	0.49	197.6	69.1	266.7	0.029	2020
Upper Mendaya	1700	8582	0.58	2436.4	852.7	3289.1	0.038	2023
Karadobi	1600	7857	0.56	2576.0	901.6	3477.5	0.0443	2021
Geba 1 + Geba 2	372	1709	0.53	572.0	200.2	772.1	0.0452	2020
Genale 6	246	1532	0.71	587.9	205.8	793.7	0.052	2020
Gibe IV	1472	6146	0.48	2588.3	776.5	3364.8	0.055	2020
Sor 2	5	39	0.88	18.6	3.7	22.3	0.058	2017
Upper Dabus	326	1460	0.51	628.2	219.9	848.1	0.058	2020
Birbir R	467	2724	0.67	1231.1	369.3	1600.4	0.059	2020
Werabesa + Halele	436	1973	0.52	886.0	310.1	1196.1	0.061	2020
Yeda 1 + Yeda 2	280	1089	0.44	540.2	189.1	729.2	0.067	2020
Genale 5	100	575	0.66	297.7	89.3	387.1	0.067	2020
Gibe V	660	1905	0.33	1036.9	311.1	1348.0	0.071	2020
Lower Didessa	550	976	0.20	619.2	185.8	804.9	0.083	2020
Baro 1 + Baro 2	645	2614	0.46	1595.9	558.6	2154.4	0.082	2020
Tekeze II	450	2721	0.69	1690.4	591.6	2282.0	0.084	2020
Gojeb	150	562	0.43	526.8	184.4	711.2	0.127	2020
Aleltu East	189	804	0.49	760.6	266.2	1026.9	0.128	2020
Tams	1000	6057	0.69	5814.9	2035.2	7850.1	0.130	2020
Abu Samuel	6	16	0.30	18.5	2.8	21.2	0.135	2020
Aleltu West	265	1067	0.46	1180.5	413.2	1593.6	0.149	2020
Wabi Shebele	88	691	0.90	887.8	221.9	1109.7	0.161	2020
Lower Dabus	250	637	0.29	866.3	259.9	1126.2	0.177	2020



Candidate Non-Hydro Plants


Generation Planning

Type and generic size

- Geothermal 100 MW
- Wind 300 MW
- Solar 300 MW
- Gas turbines on light fuel oil (LFO) 140 MW
- Diesels on heavy fuel oil (HFO) converted to gas when available 70 MW
- Gas turbines on gas 140 MW
- Combined cycle gas turbines on gas 420 MW
- Nuclear 300 MW/ 1200 MW



Candidate Non-Hydro Plants- Geothermal Generation Planning



Typical Time line

Years	1	2	3	4	5	6
Exploration and field appraisal						
Drilling (production & reinjection)						
Financial closure - start of EPC				<u>,</u>		
Steamfield						
Power Plant						
COD (Commercial Operation date)						ζ
Commercial Operation - Generation						
Costs spread % of investment	2	5	15	42	36	

Cost

Plant capacity MW Net	100
Well productivity	5 MW/well
Exploration and field appraisal	30
Drilling (production & reinjection)	210
Steamfield	40
Power Plant US\$ million	150
Power Plant US\$ / kW net	1,500
sub-total Capex US\$ million	430
Owner's costs 10%	43
Total Capex US\$ million	473
Total Capex US\$/kW Net	4,730
Total Capex (local: 35%) US\$/kW Net	1,656
Total Capex (foreign: 65%) US\$/kW Net	3,075



 Masterplan Report of Wind and Solar Energy – July 2012 – HYDROCHINA Corporation

•Considered 51 wind power sites using ave annual wind-speed data

•Recommended solar power at Debre Birhan, Metehara, Awash, and Dera with demonstration base in Addis Ababa


 Solar and Wind Energy Utilization and project Development Scenarios – SWERA 2007




Candidate Non-Hydro Plants- Wind Potential Generation Planning

Good sites with av. speed >7m/s

- >15 m/s is too windy
- Central N-S axis, East central region
- Ogaden remote from transmission & security issues






Lower altitude sites with greater air density hence greater power extracted from the air – i.e. Aysha area

• Complex topography causes turbulent flows and makes it difficult to use approximations for wind speed data



Generation Planning

- Detailed wind data from 4 data loggers at Ashegoda, Adama x2 and Mosobo No data for the Aysha region
- High wind speeds Nov to Feb, lower wind speeds May to Sept.
- Complimentary to hydro wet season June – Sept.
- Monthly Modelling in Aquarius, WASP and EPSIM





Generation Planning


Wind capacity limited to max of 20% of demand (agreed with EEPCO)

- Grid stability
- Ease of operation
- Minimize additional transmission costs associated with variable nature of wind generation
- Energy contribution would be 10% of total annual generation

Costs

Technology	Capital	Oper	ating
		Fixed	Variable
Wind Farm	\$1,900/kW	\$25/kW/year	\$0.01/kWh

Location






Candidate Non-Hydro Plants- Solar Potential Generation Planning

In Ethiopia the solar radiation resource is highest in the north highland, the


mid south, and the east Somali regions



		Long			Yield	Energy		Solar Plant
	Lat Degrees	Degrees	GHI	Panel Tilt	kWh/kWp	Output	CF	Size
Station	(North)	(East)	kWh/m ²	Degrees	/year	MWh/year	%	MW
1) Mekele	13.5	39.5	2391.2	20	20,542	205,420	23.40%	100
2) Jijiga	9.3	42.8	2379.7	15	20,184	201,840	23.00%	100
3) Addis Ababa	9	38.7	1934.5	20	16,639	166,390	19.00%	100
4) Border Ethiopia-Kenya	4.1	40.2	1903.6	10	15,561	155,610	17.80%	100
5) Border Ethiopia- Somalia	7.2	45.7	2086	15	16,697	166,697	19.10%	100



Candidate Non-Hydro Plants- Solar Potential Generation Planning






Generation Planning

Limits on capacity Reasonable limit - Installed solar to be 10% of demand

- Grid stability
- Ease of operation
- Extra transmission costs
- Overall contribution 6% of total energy generation

Price of modules fallen 75% since 2008. Grid parity may soon reached METEC PV assembly line in Addis Used in planning: Capex: 1800 \$/kW Opex: 25\$/kWyear



Chinese c-Si PV module prices (US\$/W)





Candidate Non-Hydro Plants- Gas Potential Generation Planning

Sources:

Ethiopia e.g. Calub and Hilala fields (4TCF = 113 billion cu m – BCM)


Import LNG at Djibouti, re-gassify and pipe to Dire Dawa /Awash

- Assumed available from 2025
- Sensitivity in Reference and High Case for gas in 2020
- Gas price of 11.5\$/GJ assumed , based on import




• Candidate Non-Hydro Plants- Screening \$/kWh

Generation Planning





Candidate Non-Hydro Plants- Screening \$/kW Generation Planning





Candidate Non-Hydro Plants- Limits on candidates

Generation Planning

													Maxim	num nu	mber t	hat car	be in	stalled										
	Capacity MW	First year	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037
Geothermal (1)	100	2018	-	-	-	-	-	-	2	3	5	7	9	11	13	15	17	19	21	23	25	28	31	34	38	42	46	50
Wind	300	2016	-	-	-	-	1	2	3	3	4	5	5	6	7	7	8	9	10	11	12	13	13	14	15	16	17	17
Solar	300	2016	-	-	-	-	1	2	2	2	3	3	3	4	4	4	5	5	5	6	6	6	7	7	8	8	8	9
GT on diesel	140	2016	-	-	-	-	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV						
GT on gas	140	2025	-	-	-	-	-	-	-	-	-	-	-	-	-	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV
CCGT on gas	420	2025	-	-	-	-	-	-	-	-	-	-	-	-	-	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV
Nuclear	300	2021	-	-	-	-	-	-	-	-	-	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV
Diesels	70	2016	-	-	-	-	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV	AV						
Wind and solar l	imits	Limit																										
Ref. Forecast	MW		1378	1681	2157	2956	3650	5062	5750	6601	7474	8667	9553	10659	11481	12636	13399	14510	15540	16611	17868	18870	20134	21277	22365	23556	24699	25761
Max wind	MW	20%					730	1012	1150	1320	1495	1733	1911	2132	2296	2527	2680	2902	3108	3322	3574	3774	4027	4255	4473	4711	4940	5152
Existing	MW		81	81	171	171	171	171	171	171	171	171	171	171	171	171	171	90	90									
Committed	MW		0	0	0	153	153	153	153	153	153	153	153	153	153	153	153	153	153	153								
Max load supplied by candidates	MW						406	688	826	996	1171	1409	1587	1808	1972	2203	2356	2659	2865	3169	3574	3774	4027	4255	4473	4711	4940	5152
Max wind	Units						1	2	3	3	4	5	5	6	7	7	8	9	10	11	12	13	13	14	15	16	17	17
Max load supplied by solar	MW	0.1					365	506	575	660	747	867	955	1066	1148	1264	1340	1451	1554	1661	1787	1887	2013	2128	2237	2356	2470	2576
Max Solar	Units						1	2	2	2	3	3	3	4	4	4	5	5	5	6	6	6	7	7	8	8	8	9
AV	Available		(1) Ma	ximum	n 5000N	/W																						



Generation Planning

	Costs in US\$	million	discounted	d to 2012 (all	costs in mo	ney of 2012)							Cu	ımulativ	e Additi	onal Pla	ant (from	n Candidate	s)			
Year	Construction Cost	Salvage Cost	Operating Cost	Energy Not Served Cost	Total Discounted Cost	Cost	Annual LOLP %	Geothermal 100 MW	Wind 300 MW	Solar PV 300 MW	GT (diesel) 140 MW	GT (gas) 140 MW	CCGT (gas) 420 MW	Nuclear 300 MW	Low Speed Diesel 70 MW	Hydro Group 1	Hydro Group 2		I	Hydro Planting		
2012			36		36	36																
2013			36	1,886.1	1,922	1,958	75.2%															
2014			130	940.0	1,070	3,028	43.7%															
2015			135		384	3,412	14.4%															
2016	891		145		1,048	4,460	1.1%		1+	1+												
2017	449	-2	222	27.2	696	5,155	2.5%		2+	1						1		Sor 2				
2018	940	-34	226	1.1	1,133	6,288		2+	3+	1						1						
2019	778	-29	467	44.5	1,261	7,549	4.0%	3+	3+	-1					6	1						
2020	3,146	-527	310	2.7	2,932	10,481	0.2%	5+	3	1					-6	1	4	Geba 1 and 2	Genale 6	Gibe 4	Upper Dabus	
2020	1,884	-338	254	2.1	1,800	12,281	0.2 /0	7+	3	1					-0	2	4	Karadobi			Dabus	
2021	842	-168	234	0.5		13,238	0.1%	8	3	-1					-6	3	4	Beko Abo				
2022	2,133		202	0.3	1,838	,		8	3	1					6	4	6	Upper Mendaya	Birbir R	Werabesa and Halele		
2020	2,100	000	2	0.1	1,000	10,010	0.170	<u> </u>	0								0	Genale 5	Yeda 1 and	Gibe V	Baro 1 and	Genji
2024	1,557	-409	194		1,342	16,418		8	3	1					6	4	11		Yeda 2		Baro2	· · ·
2025	581	-125	243	3.3	702	17,120		12	3	-1		1			-6	4	11					
2026	508	-127	241	5.6	628	17,749		16	3	1		1			6	4	11					
2027			214	1.8		17,964		16	3	1		1			-6	4	11					
2028	542	-174	235	2.6	605	18,569	0.2%	21+	3	-1		2			6	4	11					
2029	427	-156	281	0.1	552	19,121	0.0%	23+	3	1		2	2		-6	4	11					
2030	421	-159	328	2.3	592	19,713	0.4%	25+	4	1		3	3		6	4	11					
2031	334	-155	340	0.2	520	20,233	0.0%	28+	4	-1		3	4		6	4	11					
2032	408	-203	366	1.7	573	20,806	0.2%	31+	5	1		3	5		-6	4	11					
2033	287	-167	383	0.6	504	21,310	0.1%	34+	5	1		4	6		6	4	11					
2024	557	-375	329		512	21,821		37	F	1		4	6		6	4	10	Tekeze 2	Lower Didessa			
2034 2035	278	-375	329	3.1	408	21,821	0.6%	37 42+	5 5	-1 1		4 5	6 6		-6	4	13 13		Didessa			
2035	278	-202	329	0.6		22,229	0.6%	42+ 46+	5 5	1		5 5	0 7		- 0 6	4	13					
2036	237	-208	328	0.6	378			40+ 50+	5 5	1		5 5	8		<u>ь</u> 6	4	13					
Totals		-	6,593		22,957	22,957	0.170	007	5	1		5	0		0	4	13					
Totals	57.49		28.7%	13.9%	100.0%																	

Case IHpL76FO



Results for Reference Case Generation Planning

Comparison of NPVs for Stage 1 optimisation cases

Case	Description	NPV - \$million
IHL_1DBWD	No diesels – Potential System hydro characteristics	29,780
IHL_1DBD	With diesels - Potential System hydro characteristics	26,046

Comparison of NPVs for Stage 3 and 4 optimisation cases

Case	Description	NPV - \$million
IHL_800Aq	No diesels – Refined hydro characteristics	28,191
IHpL76FO	With diesels – Refined hydro characteristics	22,957
IHL_76F3	With diesels – Refined hydro characteristics -Upper	23,005
	Dabus moved back two years	
IHL_78F5	With diesels – Refined hydro characteristics - Werabesa	22,961
	and Halele and Genji each moved back one year	
IHL_84F4	With diesels – Refined hydro characteristics –	22,932
	Werabesa and Halele, Genale 5 and Gibe 5 each	
	moved back one year	
IHL_84F3	With diesels – Refined hydro characteristics – Werabesa	22,950
	and Halele, Genale 5, Gibe 5 and Genji each moved back	
	one year	



Generation Planning

[Costs in US\$	million	discountee	d to 2012 (all	costs in mo	ney of 2012)							Cumula	ative Ad	ditional	Plant (fr	rom Car	didates)			
Year	Construction Cost	Salvage Cost	Cost	Served Cost	Total Discounted Cost	Cumulative Discounted Cost	Annual LOLP %	Geothermal 100 MW	Wind 300 MW	Solar PV 300 MW	GT (diesel) 140 MW	GT (gas) 140 MW	CCGT (gas) 420 MW	Nuclear 300 MW	Low Speed Diesel 70 MW	Hydro Group 1	Hydro Group 2		Hydro	Planting	
2012			36		36	36															
2013			36	1,886.1	1,922																
2014			130	940.0	1,070		43.7%														
2015			135	248.7	384	3,412	14.4%														
2016	891		145	11.1	1,048	4,460	1.1%		1+	1+											
2017	449	-2	222	27.2	696	5,155	2.5%		2+	1						1		Sor 2			
2018	940	-34	226	1.1	1,133	6,288	0.1%	2+	3+	1						1					
2019	778	-29	467	44.5	1,261	7,549	4.0%	3+	3+	-1					6	1					
																		Geba 1 and	Genale 6	Gibe 4	Upper
2020	3,146	-527	310	2.7		10,481	0.2%	5+	3	1					6	1	4	2			Dabus
2021	1,884	-338			1,800	12,281		7+	3	1					6	2	4	Karadobi			
2022	1,028	-194	254		1,088	13,369		9+	3	-1					6	3	4	Beko Abo			
2023	1,714	-409	230	6.9	1,541	14,911	0.5%	9	3	1					6	4	5	Upper Mendaya	Birbir R		
	,				,	, ,												Werabesa	Yeda 1 and	Baro 1 and	Genji
2024	1,386	-364	213	0.0	1,235	16,146	0.0%	9	3	1					6	4	9	and Halele	Yeda 2	Baro2	
2025	944	-240	243	3.3	950	17,096	0.3%	12	3	-1		1			6	4	11	Genale 5	Gibe V		
2026	508	-127	241	5.6	628	17,724	0.4%	16	3	1		1			6	4	11				
2027			214	1.8	216	17,940	0.2%	16	3	1		1			6	4	11				
2028	542	-174	235	2.6	605	18,544	0.2%	21+	3	-1		2			6	4	11				
2029	427	-156	281	0.1	552	19,096	0.0%	23+	3	1		2	2		6	4	11				
2030	421	-159	328	2.3	592	19,688	0.4%	25+	4	1		3	3		6	4	11				
2031	334	-155			520	20,208	0.0%	28+	4	-1		3	4		6	4	11				
2032	408	-203	366	1.7	573	20,781	0.2%	31+	5	1		3	5		-6	4	11				
2033	287	-167	383	0.6	504	21,285	0.1%	34	5	1		4	6		6	4	11				
																		Tekeze 2	Lower		
2034	557	-375			512	21,797		37	5	-1		4	6		6	4	13		Didessa		
2035	278	-202	329	-	408	22,205	0.6%	42+	5	1		5	6		6	4	13				
2036	257	-208	328	0.6		22,583	0.1%	46	5	1		5	7		6	4	13				
2037	233	-210		0.3		22,932	0.1%	50+	5	1		5	8		6	4	13				
Totals	17,411	-4,270	6,601	3,190	,																
	57.3%	6	28.8%	13.9%	100.0%																

Case IHL_84F4



Results for Reference Case-with no gas and Geothermal limit is increased

Generation Planning

	Costs in US\$	million	discounted	d to 2012 (all	costs in mo	ney of 2012)							Cumula	tive Ad	ditional	Plant (fr	rom Car	didates)			
Year	Construction Cost	Salvage Cost	Cost	Energy Not Served Cost	Cost	Cost	Annual LOLP %	Geothermal 100 MW	Wind 300 MW	Solar PV 300 MW	GT (diesel) 140 MW	GT (gas) 140 MW	CCGT (gas) 420 MW	Nuclear 300 MW	Low Speed Diesel 70 MW	Hydro Group 1	Hydro Group 2		Hydro	Planting	
2012			36		36																
2013			36	1,886.1	1,922	1,958															
2014			130	940.0	1,070	3,028	43.7%														
2015			135	248.7	384	3,412	14.4%														
2016	891		145	11.1	1,048	4,460	1.1%		1+	1+											
2017	449	-2	222	27.2	696	5,155	2.5%		2+	1						1		Sor 2			
2018	940	-34	226	1.1	1,133	6,288	0.1%	2+	3+	1						1					
2019	731	-28	467	44.5	1,215	7,504	4.0%	3+	3+	-1					6	1					
																		Geba 1 and	Genale 6	Gibe 4	Upper
2020	3,146	-	310	2.7	,	10,436	0.2%	5+	3	1					6	1	4	2			Dabus
2021	1,884	-338	254		1,800	12,235		7	3	-1					6	2	4	Karadobi			
2022	1,028	-194	254		1,088	13,324		9	3	-1					6	3	4	Beko Abo			
																		Upper	Birbir R		
2023	1,714	-409	230	6.9	1,541	14,865	0.5%	9	-3	1					6	4	5	Mendaya			
																		Werabesa		Baro 1 and	Genji
2024	1,386	-364	213	0.0		16,100		9	3	-1					6	4	9	and Halele	Yeda 2	Baro2	
2025	1,341	-328	230	0.8		17,344	0.1%	15	-3	1					-6	4	11	Genale 5	Gibe V		
2026	508	-127	230	2.9		17,959	0.3%	19	3	-1					6	4	11				
2027			197	0.6	-	18,156	0.1%	19	-3	1					6	4	11				
2028	630	-204	206	2.2	634	18,790	0.2%	25	3	-1					-6	4	11				
2029	764	-279	203	2.6		19,481	0.2%	33	-3	1					6	4	11				
2030	781	-322	207	4.0		20,151	0.3%	42	3	-1					6	4	11				
2031	473	-219	203	5.5		20,613	0.4%	48	-3	1					-6	4	11				
2032	645	-336	202	7.0		21,132	0.5%	57	3	1					6	4	11				
2033	456	-266	200	9.1	400	21,532	0.6%	64	3	-1					6	4	11				
																		Tekeze 2	Lower		
2034	438		182	12.5		21,867	0.8%	65	-3	1					-6	4	13		Didessa		
2035	377	-274	180	13.9		22,165	0.8%	72	3	-1					6	4	13				
2036	343	-277	175	14.1	255	22,419	0.8%	79	-3	1					6	4	13				
2037	356	-	168	13.7	218	22,637	0.8%	87	3	1					6	4	13				
Totals		-5,145	5,242	3,257	22,637																
	62.5%	%	23.2%	14.4%	100.0%																

Case IL84Fgen



Results for Reference Case-with no diesel considered Generation Planning

	Costs in US\$	million	discounted	to 2012 (all o	costs in mo	ney of 2012)											Cumulative A	dditional Pla	nt (from Can	didates)						
Year	Construction Cost	Salvage Cost	Cost	Served Cost	Cost	Cost	LOLP %	Geothermal 100 MW	Wind 300 MW	Solar PV 300 MW	GT (diesel) 140 MW	GT (gas) 140 MW	CCGT (gas) 420 MW	Hydro Group 1	Hydro Group 2			-		ŀ	lydro Planting	1				
2012			36		36																					
2013			36	1,886.4	1,922		75.2%																			
2014			130	940.7	1,070		44.8%																			
2015			140	226.5	366																					
2016	891		146	8.6	1,046				1+	1+																
2017	824		211	0.3	1,034				2+	2+				1		Sor 2										
2018	940		297	274.8	1,478			2+	3+	2+				1												
2019	248	-19	298	2,102.9	2,629	9,581	61.5%	3+	3+	2+				1												
2020	6,281		205		5,360	14,941		3	3	2				1	11	Geba 1 and 2	Genale 6	Gibe 4	Upper Dabus		Werabesa and Halele	Genale 5	Yeda 1 and Yeda	Gibe V	Baro 1 and Baro2	Genji
2021	1,475		210	18.0	1,412	16,354		3	3	2				2	11	Karadobi										
2022	656	-142	186		700	17,054		3	3	2				3	11	Beko Abo										
2023	1,998	-412	204	14.4	1,804	18,858	1.9%	8	3	2				4	11	Upper Mendaya										
2024	769		207	44.9	876			13+	3	2				4	11											
2025	390		298	0.1	606			13	3	2		2	2	4	11											
2026	528		296		693			17+	3	2		3	2	4	11											
2027	392		374	1.5				19+	3	2		4	3	4	11											
2028	357		429		672			21+	3	2		5	4	4	11											
2029	324		483	2.1	692		0.2%	23+	3	2		6	5	4	11											
2030	389		535	0.7	764		0.1%	25+	3	2		6	7	4	11											
2031	334		531	0.1	711	24,528		28+	3	2		6	8	4	11											
2032	315		552	0.4	705		0.1%	31+	3	2		7	9	4	11											
2033	276		552	1.2			0.1%	34+	3	2		7	10	4	11											
2034	311		534	0.0	642			38+	3	2		7	11	4	11											
2035	462	-329	501		634	27,177		42+	5	2		7	11	4	12	Tekeze 2										
2036	435	-356	463	0.1	542	27,719	0.0%	46+	5	2		8	11	4	13	Lower Didessa										
2030	233		403		472			50+	5	2		8	12	4	13	Diacosa										
Totals	18,830		8,302	5,524	28,191		0.076	507	5	2		0	12	+	13											
	51.09	%	29.4%	19.6%	100.0%																					

Case IL_800Aq




Generation Planning

Alternatives considered for replacing the imported fuel based diesel plants:

		Diesel (HFO) LS	Diesel (HFO) MS	Diesel (gas) LS	Diesel (gas) MS	GT gas	CCGT gas	Biomass - wood/bagasse	Yayu FBC Coal
Capital Cost	US\$/kW	2060	1600	2060	1600	500	1250	1356	2440
Construction period	years	2	2	2	2	2	3	3	4
Discount Rate (real)	% p.a.	10.0%	10.0%	10.0%	10.0%	10.0%	10.0%	10.0%	10.0%
IDC (1)	%	10.00%	10.00%	10.00%	10.00%	10.00%	15.00%	15.00%	20.00%
IDC	US\$/kW	206	160	206	160	50	187.5	203.4	488
IDC % Cap + IDC	%	9.09%	9.09%	9.09%	9.09%	9.09%	13.04%	13.04%	16.67%
Capital + IDC	US\$/kW	2266	1760	2266	1760	550	1438	1559	2928
% Foreign		90.0%	90.0%	90.0%	90.0%	90.0%	90.0%	90.0%	81.0%
Foreign	US\$/kW	2039.4	1584.0	2039.4	1584.0	495.0	1293.8	1403.5	2372
Local	US\$/kW	226.6	176.0	226.6	176.0	55.0	143.8	155.9	556.3
Standard Conversion factor		0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90
Local with SCF	US\$/kW	203.9	158.4	203.9	158.4	49.5	129.4	140.3	500.7
Capital +IDC with SCF	US\$/kW	2243.3	1742.4	2243.3	1742.4	544.5	1423.1	1543.8	2872.4
Life	Years	20	20	20	20	20	25	25	25
Annual capital cost	US\$/kW/year	263.5	204.7	263.5	204.7	64.0	156.8	170.1	316.4
Fixed O and M cost	US\$/kW/month	5.00	5.00	4.00	4.00	1.50	2.00	6.278	4.4
Fixed O and M cost	US\$/kW/year	60.0	60.0	48.0	48.0	18.0	24.0	75.3	53.2
Total Annual LRMC cost	US\$/kW/year	323.5	264.7	311.5	252.7	82.0	180.8	245.4	369.6
Fuel		HFO	LFO	gas	gas	gas	gas	Wood/bagasse	Lignite
Fuel cost	US\$/GJ	22.0	22.0	11.5	11.5	11.5	11.5	4.52	1.240
Fuel cost	US\$/kWhth	0.079	0.079	0.041	0.041	0.041	0.041	0.0163	0.0045
"Efficiency"		46.4%	38.6%	46.4%	38.6%	33.0%	47.0%	22.5%	33.5%
Fuel cost per kWh	US\$/kWh	0.171	0.205	0.089	0.107	0.125	0.088	0.072	0.0133
Variable O and M	US\$/kWh	0.0090	0.0090	0.0060	0.0060	0.0018	0.0025	0.0070	0.0119
Fuel + Var Oand M	US\$/kWh	0.180	0.214	0.095	0.113	0.127	0.091	0.079	0.0252



Generation Planning



- Comparison:
 - Above the 40% P.F CCGT and the Woody Biomass plants are comparable
 - Below 25% P.F the Gas Turbine plant is preferable.
 - Since during the early years the plant can be utilized at higher plant factors the woody Biomass and CCGT plants are preferable
 - Because of lack of definitive resource assessment on the woody biomass the Natural gas based CCGT is preferred



Results for Reference Case-with diesels replaced with Natural Gas based plants Generation Planning

- Preliminary discussions made with the Ministry of Mines personnel indicate that the Calub and Hilala sites are under the concession agreement with a company named Poly GCL
- The company intends to export the gas after transporting it to the Djibouti port with a gas pipe and liquefying it.
- The amount of gas required for the 420 MW is much less than the potential in the region and the company could agree to sell the gas to EEP with a price less than the international price.
- It is good that the generating station be located at Calub with minor additional transmission line works.
- EEP needs to get a Government agreement to use the gas for power generation.
- If EEP gets the government agreement, discussions with ministry of Mines and with the company (Poly GCL) needs to be started.



- Review of the new Tams prefeasibility study: Installed Capacity = 1700 MW Average Energy = 5760 GWh/year Cost = 3,241.6 MUSD
- The Unit generation Cost is 7.3 USD cents/kWh with the following assumptions:
 Discount rate = 10%
 - Construction Period = 6 year
 - Life time = 70 years



	Installed Capacity	Average Energy	Project Cost	IDC Cost	Total Cost	Cost /kW inst	Annualised Cost	Average Levelised Cost	
Plant	(MW)	(GWh/year)	(million \$)	(million\$)	(million \$)	(\$/kW)	(million\$)	(\$/kWh)	Rank
Beko Abo	935	6632.2	1260.8	441.3	1,702	1,820.5	170.348	0.0257	1
Genji	214	910.2	197.6	69.1	267	1,246.3	26.692	0.0293	2
Upper Mendaya	1700	8582.3	2436.4	852.7	3,289	1,934.8	329.173	0.0384	3
Karadobi	1600	7857.2	2576.0	901.6	3,478	2,173.5	348.027	0.0443	4
Geba 1 + Geba 2	372	1709.4	572.0	200.2	772	2,078.4	77.275	0.0452	5
Genale 6	246	1532.4	587.9	205.8	794	3,226.3	79.428	0.0518	6
Sor 2	5	38.5	18.6	3.7	22	4,461.6	2.233	0.0580	7
Upper Dabus	326	1460.3	628.2	219.9	848	2,601.6	84.880	0.0581	8
Gibe IV + V	2132	8051.3	3625.2	1087.6	4,713	2,210.5	471.651	0.0586	9
Birbir R	467	2724.1	1231.1	369.3	1,600	3,427.1	160.170	0.0588	10
Werabesa + Halele	436	1972.8	886.0	310.1	1,196	2,743.4	119.708	0.0607	11
Yeda 1 + Yeda 2	280	1089.4	540.2	189.1	729	2,604.5	72.982	0.0670	12
Genale 5	100	574.6	297.7	89.3	387	3,870.6	38.737	0.0674	13
Tams 💦 👘	1700	5760.0	3241.5	972.3	4,214	2,478.7	421.715	0.0732	<mark>15</mark>
Baro 1 + Baro 2	645	2614.3	1595.9	558.6	2,154	3,340.2	215.614	0.0825	16
Lower Didessa	550	975.6	619.2	185.8	805	1,463.5	80.557	0.0826	17
Tekeze II	450	2720.7	1690.4	591.6	2,282	5,071.2	228.382	0.0839	18
Gojeb	150	561.7	526.8	184.4	711	4,741.4	71.177	0.1267	19
Aleltu East	189	804.1	760.6	266.2	1,027	5,433.2	102.768	0.1278	20
Abu Samuel	6	15.7	18.5	2.8	21	3,536.8	2.124	0.1351	21
Aleltu West	265	1067.3	1180.5	413.2	1,594	6,022.7	159.487	0.1494	22
Wabi Shebele	88	691.0	887.8	221.9	1,110	12,637.6	111.058	0.1607	23
Lower Dabus	250	637.0	866.3	259.9	1,126	4,504.7	112.707	0.1769	24



- According to the ranking TAMS stand as the 15th plant and is to be considered after the Baro 1, 2 and Genji project which has a unit cost of 6.9 US cents per kWh.
 - The prefeasibility study document indicates that the project is a multi-purpose project having additional benefits such as:
 - downstream Irrigation projects
 - Flood control
 - Drinking water supply
 - And others
 - But in the prefeasibility study no portion of the dam cost is ascribed for the irrigation and the other side benefits.



- Finchaa Amerti Neshe project study documents were also Investigated in order to identify possible cost allocation of the dam structure among the multiporpose applications.
 - Presented Project irrigation costs were rather downstream costs such as: irrigation diversion weirs, intakes, pumping stations, canals, irrigation tertiary network and systems.
 - No irrigation cost is associated with the dam
- Even though the studies indicate the benefits of the upstream dams to the downstream irrigation activities, it was not possible to identify costs that can be deducted from the project cost in order to bring the project forward in the project ranking.



Results for Reference Case- Hydro Sequencing Generation Planning

• The consultant in prioritizing projects used a cost minimization objectives. Based on this criteria the following hydro plants were prioritized.

Year		Hydro	Planting	
2017	Sor 2			
2018				
2019				
2020	Geba 1 and 2	Genale 6	Gibe 4	Upper Dabus
2021	Karadobi			
2022	Beko Abo			
2023	Upper Mendaya	Birbir R		
2024	Warebesa and Halele	Yeda 1 and 2	Baro 1 and Baro2	Genji
2025	Genale 5	Gibe V		
	Tekeze 2	Lower		
2034		Didessa		



Results for Reference Case- additional prioritizing criterions Generation Planning

- Other prioritization criterions include:
 - Multipurpose use
 - Basin Distribution
 - Project readiness
 - On the basis of availing additional power for export ,Multipurpose use and basin distribution TAMS and Wabishebeli projects are advanced forward to be implemented by year 2021
 - On the basis of project readiness and also availing additional power Chemoga Yeda is advanced forward to year 2020.
- This will allow to increase export generation capability by around 1000 MW and 6500 GWh possibly to Yemen corridor and South Sudan starting from year 2021.
- The advancement of the plants will result into increased costs to the system and this shall be compensated with the revenue to be generated from the export. This will be further investigated with WASP analysis .





Other Sensitivity Studies Generation Planning

- Reference Forecast COUE 0.50\$/kWh Un-served energy doubles – slight decrease in non-hydro plant
- Reference Forecast Discount Rate 8%
 A few hydro plants brought forward
- Reference Forecast Discount Rate 12% Tekeze 2 delayed, Lower Didessa not built
- High Forecast Gas in 2025
 - Hydros brought forward, large number of diesels, 6% increase in NPV



Main Findings Generation Planning

- Ethiopian system will move from a hydro system to a mixed hydro- renewable thermal system
- Renewables will comprise geothermal plus some wind & solar
- Mixed system with dispatchable plant (thermal and geothermal) will need sophisticated modelling to optimise operation
- If load growth is lower than reference case or exports reduced,
- diesels may not be required in short-term
- Monitor rate of load growth to decide on planting in short-term
- Some hydros can be late without big penalty in cost insurance
- Gas needed from 2025
- Geothermal potential shall be investigated immediately and if it is proofed to be greater than 8500 MW Gas utilization can be safely avoided
- More expensive hydros (after Tekeze 2) not selected
- Ability to reduce exports in dry years could delay new plant
- •





Objective Transmission Planning


The transmission expansion plan must identify the required transmission infrastructure at a number of key stages for:

- Interconnection of all generating plant identified in the generation expansion plan.
- Reinforcement and expansion of the grid to meet the forecast demand at all existing and planned transmission substations.
- Compliance with the transmission planning criteria at all stages of development




Distributed Load Forecasting-Regional Distribution of the system Peak

Transmission Planning










 Prior to developing the detailed expansion plan a regional assessment of supply and demand was conducted, based on the location of existing and planned power plants and the disaggregated demand forecast.



Supply/demand balance

Transmission Planning





The short-term plan includes:


- 114 new transmission substations,
- 63 substation reinforcements and
- 13,540 km of new 500 kV to 66 kV transmission lines required at various stages up to 2020.

Year	_	Substation Reinforcemnets	Transmission Lines
2013	11	9	2343
2014	9	3	1167
2015	45	30	4071
2016	27	5	2352
2017	22	16	3627
Total	114	63	13560



Transmission Expansion Plan – Short term – 2013-2015

Transmission Planning



Peak substation demand 2524 MW (excluding exports) – approximately double the 2012 peak.

• Many projects either already under construction or at design/feasibility Stage.


Generation

- GR (2015, 400MW)
- GD III (2015, 250MW)
- Gibe III (2015, 1000MW)
- 65 new transmission
 substations and 42 substation
 reinforcements
- + 7000 km of new transmission lines.




Transmission Expansion Plan – Short term– 2013-2015

Transmission Planning



- 500 kV GERD-Dedessa- Holeta.
- 500 kV GERD-Rabak (Sudan interconnector)
- 400 kV GERD-Beles
- 400 kV developments around Addis (next slide)
- 400 kV developments associated with Gilgel Gibe III and Genale Dawa
- Numerous 230 kV projects including reinforcement of the Djibouti and Sudan export routes.
- Numerous 132 kV projects.






- New 400 kV substations at Holeta, Akaki and Debre Zeit.
- Completion of 230 kV ring around Addis.
- New bulk supply points at Addis West, Bole Lemi and Shegole.



Transmission Expansion Plan – Short term– 2016-2017

Transmission Planning




•Peak substation demand 3935 MW (excluding exports) - 56% increase on 2015 peak.

Generation includes

- GR (2017, 6000MW)
- Aysha (2016, 300MW)
- Assela (2017, 300MW)
- •Required projects (in addition to the 2015 projects) include 27 new transmission substations, 5 substation reinforcements and 2300 km of new transmission lines.
- •HVDC link to Kenya
- •Additional 400 kV circuit from Debre Markos-Suluta.
- •400 kV Bahir Dar-Woldia
- •Numerous 230 kV and 132 kV



Transmission Expansion Plan – Short term– 2016-2017 Addis Ababa Transmission Planning




New 230 kV substations – Cotobie I, Addis East II, H. Tannery



Transmission Expansion Plan – Short term– 2018-2020


Transmission Planning



Peak substation demand 5918 MW (excluding exports) - 50% increase on 2017 peak. Generation:

- •Upper Dabus (2020, 326MW)
- Aluto Lan II (2018, 75MW)
- Corbetti (2018, 200 to 500MW)
- •Dire Dawa die (2018, 70 420MW)
- Genale 6 (2020, 237MW)
- Geba 1 & 2 (2020, 344MW)
- Gibe IV (2020, 1410MW





Required projects (in addition to the 2017 projects) - 22 new transmission substations, 16 substation reinforcements and 3600 km of new transmission lines.
400 kV developments including generation connections;

Debre Zeit- Hurso in Eastern region.

Hurso – Shi Kulun


Woldia-Combolcha.

Debre Zeit-Shashemene-Yirgalem

Gilgel Gibe III-Gilgel Gibe IV.

Numerous 230 kV and 132 kV projects





Completion of a 400 kV ring around Addis Ababa by constructing a 400/230 kV substation at Cotobie II (Legetafo) and interconnecting it with Sululta and Debre Zeit



There is less detail in the long-term plan due to uncertainty in the developments. The plan includes (indicative based on modelling);

- •Approximately 130 new and upgraded substations
- Approximately 9,000 km of new 400 kV to 132 kV transmission lines required at various stages up to 2037

	Substation Reinforcemnets	Transmission Lines
2025	33	2769
2030	38	3098
2037	59	3186
Total	130	9054



FINANCIAL ANALYSIS AND TARIFFS


FINANCE



•Costs

FINANCIAL ANALYSIS AND TARIFFS

•The resultant total cost of the expansion plan over the 25 year period is estimated at US\$177bn, equivalent to US\$56bn in 2012 values)



Cost allocation: MUS\$

